Tab 4

MAY 1, 2017

CELT Report

2017-2026 Forecast Report of Capacity, Energy, Loads, and Transmission

System Planning

ISO-NE PUBLIC

Introduction

2017 ISO New England (ISO-NE) Reliability Coordinator Area Forecast [1]

The "2017-2026 Forecast Report of Capacity, Energy, Loads, and Transmission" (CELT Report) is a source of assumptions for use in electric planning and operations reliability studies. This report provides assumptions for the ISO New England Reliability Coordinator area.

In Section 1, the ISO New England Reliability Coordinator area reference load forecast may be characterized as having a fifty percent chance of being exceeded. The load forecast distributions for the years 2017 through 2026 are included in Section 1.6 of this report. Additional information on the load forecast, including the forecast bandwidths, is available on the ISO New England web site (see links below).

The capacity values in Section 1 are based on the Capacity Supply Obligations (CSO) for the Forward Capacity Market's (FCM) 2016-2017, 2017-2018, 2018-2019, 2019-2020 and 2020-2021 Capacity Commitment Periods as of March 18, 2017. These include new and existing generating resources, demand resources, and imports.

The CSOs for each of the commitment periods are based on the following FCM auction results:

2016-2017	Annual Reconfiguration Auction 3
2017-2018	Annual Reconfiguration Auction 3
2018-2019	Annual Reconfiguration Auction 1
2019-2020	Forward Capacity Auction
2020-2021	Forward Capacity Auction

The generating resource and demand resource CSO totals for the 2020-2021 Capacity Commitment Period are assumed to remain in place for the remainder of the CELT reporting period. Imports beyond the 2020-2021 Capacity Commitment Period reflect only known, long-term contracts.

The annual generating capacity totals based on Seasonal Claimed Capability (SCC)[2] are included as a line item in Sections 1.1 and 1.2. Those values are based on the SCCs of existing assets plus the expected capability of future FCM and non-FCM resources. The non-FCM resources are those that do not have FCM obligations, but are part of the ISO New England Generator Interconnection Queue[3] and are expected to become commercial in 2017 or 2018.

Section 2.1 of the CELT Report lists details for all generating assets in-service as of April 1, 2017. It also includes SCC values for generating assets as of January 1, 2017 and the winter 2016/17 peak, which occurred on December 15, 2016, as well as projected summer SCC values for July 1, 2017.

Section 3.1 consists of total state-by-state solar PV forecasts based on nameplate rating, as well as the estimated summer seasonal peak load reductions and estimated energy production from behind-the-meter (BTM) PV. The forecast methodology and assumptions are available at http://www.iso-ne.com/system-planning/system-forecasting/distributed-generation-forecast.

Introduction

Section 4 summarizes data from the Forward Capacity Market. Section 4.1 summarizes the results of the 2016-2017, 2017-2018, 2018-2019, 2019-2020, and 2020-2021 Forward Capacity Market Capacity Supply Obligations (CSOs) by Load Zone as of March 18, 2017. In the case of 2016-2017, monthly auction results are not taken into consideration; the results shown are for the third Annual Reconfiguration Auction (ARA3). Section 4.2 contains the Renewable Technology Resource (RTR) Allotments. Section 4.3 lists the Qualified and Cleared Capacity for all Resources that qualified to participate in the eleventh Forward Capacity Auction (FCA 11).

The October 31, 2008 Forward Capacity Market (FCM)/Queue Amendments filing (FERC Docket ER09237 http://www.iso-ne.com/static-assets/documents/regulatory/ferc/filings/2008/oct/er09_237_000_10_8_31_fcm_queue.pdf) established the Network Resource Capability (NRC) and Capacity Network Resource Capability (CNRC) values for each generating resource. Section 5.1 lists the NRC & CNRC values calculated consistent with Schedules 22 and 23 of the Open Access Transmission Tariff (the Large and Small Generator Interconnection Procedures).

Section 6.1 lists links associated with transmission related documents available on the ISO New England website at: http://www.iso-ne.com.

The appendices in the report are as follows:

- Appendix A defines the commonly used terms and abbreviations used in this report;
- Appendix B provides a list of the Federal Information Processing Standard (FIPS) Codes and the list of Regional System Plan (RSP) Subareas;
- Appendix C is the most recent update of the New England geographic transmission map.

CELT Reports and related documents are available on the ISO New England website at:

http://www.iso-ne.com/system-planning/system-plans-studies/celt
http://www.iso-ne.com/isoexpress/web/reports/operations/-/tree/seasonal-claimed-capability
http://www.iso-ne.com/system-planning/system-plans-studies/rsp
http://www.iso-ne.com/participate/applications-status-changes/new-modified-interconnections
http://www.iso-ne.com/system-planning/transmission-planning/interconnection-request-queue

Please do not hesitate to contact ISO New England at custserv@iso-ne.com with any questions or comments regarding the information contained herein.

FOOTNOTES:

(1) ISO New England is the Reliability Coordinator (RC), Balancing Authority (BA) and Transmission Operator (TOP) for New England. Throughout this document, the ISO is referred to as the RC since the RC has responsibility for overseeing the other two functions.

(2) For more information on generating assets, refer to the Seasonal Claimed Capability Report at: http://www.iso-ne.com/isoexpress/web/reports/operations/-/tree/seasonal-claimed-capability.

(3) The Generator Interconnection Queue is posted on the ISO New England website at http://www.iso-ne.com/system-planning/transmission-planning/interconnection-request-queue.

Preface

This 2017 edition of the "Forecast Report of Capacity, Energy, Loads, and Transmission" (CELT) reflects a load forecast based upon demographic, economic, and market information available through winter 2016-17 for publication in May 2017. Accordingly, this CELT edition supersedes prior CELT publications.

This report presents the ISO-NE Reliability Coordinator area 2017-2026 forecast of:

- Electric energy demand and peak load;
- Existing ISO-NE Control Area electrical capacity and proposed changes;
- Scheduled and proposed transmission changes; with listings and summaries of existing and proposed generation projects

Generating asset details are represented in Section 2.1 of this report for three different periods: a snapshot of January 1, 2017, a snapshot of the winter peak on December 15, 2016, and a projection for the summer of 2017.

This report represents the efforts of Market Participants' staffs, jointly with ISO-NE, under the review of the Load Forecasting and Reliability Committees.

Additional information regarding the documentation of the electric energy demand and peak load forecasts presented in this report may be found on ISO-NE's web site at:

http://www.iso-ne.com/system-planning/system-plans-studies/celt

Table of Contents

Introduction

Preface

Section 1 - Summaries
- 1.1 Summer Peak Capabilities and Load Forecast
- 1.2 Winter Peak Capabilities and Load Forecast
- 1.3 Summary Summer Capability by Fuel/Unit Type
- 1.4 Summary Winter Capability by Fuel/Unit Type
- 1.5 Load and Energy Forecast
  - 1.5.1 Actual and Forecasted Peak Loads
  - 1.5.2 Actual and Forecasted Energy
- 1.6 Seasonal Peak Load Forecast Distributions

Section 2 - Control Area Capability
- 2.1 Generator List with Existing and Expected Seasonal Claimed Capability (SCC)
- 2.1 Endnotes
- 2.2 Net of Imports and Exports

Section 3 - Solar Forecast
- 3.1 Forecast of Solar Photovoltaic (PV) Resources by State
  - 3.1.1 Nameplate Rating
  - 3.1.2 Estimated Summer Seasonal Peak Load Reductions - BTM PV
  - 3.1.3 Estimated Annual Energy - BTM PV

Section 4 - FCM Summary Tables
- 4.1 Summary of Capacity Supply Obligations (CSO)
- 4.2 FCM Renewable Technogy Resource Allotments
- 4.3 List of FCA 11 Qualified and Cleared Capacity for All Resources

Section 5 - Resource Interconnection Capabilities
- 5.1 Network Resource Capability (NRC) and Capacity Network Resource Capability (CNRC) List
- 5.2 Summary of Demand Resource Capacity (MW) Used in System Planning Studies

Section 6 - Transmission Information
- 6.1 Transmission Project Links

Appendix A
- A.1 Definitions
- A.2 Company Abbreviations
- A.3 Column Abbreviations - Prime Mover (Unit Type)
- A.4 Column Abbreviations Energy Source (Fuel)

Appendix B
- B.1 Federal Information Processing Standard (FIPS) Codes
- B.2 Regional System Plan (RSP) Subarea Descriptions

Appendix C
- New England Geographic Transmission Map

1.1 Summer Peak Capabilities and Load Forecast (MW)

	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
ISO-NE RELIABILITY COORDINATOR AREA											
1. LOAD [1, 2, 3]											
1.1 REFERENCE - Without reductions	28815	29146	29454	29753	30039	30327	30623	30923	31223	31521	31820
1.1.1 Behind-the-Meter (BTM) PV [4]	439	575	690	783	848	891	929	963	992	1014	1035
1.2 REFERENCE - With reduction for BTM PV	28376	28571	28764	28970	29191	29436	29694	29960	30231	30507	30785
1.2.1 Passive DR (PDR) used in System Planning [5]	1839	2089	2306	2561	2893	3223	3527	3805	4055	4278	4475
1.3 REFERENCE - With reduction for BTM PV and PDR	26537	26482	26458	26409	26298	26213	26167	26155	26176	26228	26310
2. CAPACITY BASED ON FCM OBLIGATIONS											
2.1 GENERATING RESOURCES [6]	29888	29627	30607	31326	31359	31359	31359	31359	31359	31359	31359
2.2 DEMAND RESOURCES [6, 7]	2441	2691	2696	2734	3211	3211	3211	3211	3211	3211	3211
2.2.1 ACTIVE DR	556	382	546	367	420	420	420	420	420	420	420
2.2.2 PASSIVE DR	1885	2309	2150	2367	2791	2791	2791	2791	2791	2791	2791
2.3 IMPORTS [8]	1162	1376	1479	1480	1265	89	89	89	89	89	89
2.4 TOTAL [9]	**33492**	**33693**	**34782**	**35540**	**35835**	**34659**	**34659**	**34659**	**34659**	**34659**	**34659**
3. CAPACITY BASED ON SEASONAL CLAIMED CAPABILITY (SCC) [10, 11]											
3.1 GENERATION CLAIMED FOR CAPABILITY	30581	29174	30933	31621	31712	31730	31747	31762	31773	31779	31784
4. RESERVES - Based on Reference Load with reduction for Passive DR											
4.1 INSTALLED RESERVES - Based on CSOs of Generating Resources (line 2.1), Active DR (line 2.2.1), and Imports (line 2.3)											
4.1.1 MW	5070	4903	6175	6763	6746	5656	5702	5713	5692	5640	5559
4.1.2 % OF LOAD	19	19	23	26	26	22	22	22	22	22	21
4.2 INSTALLED RESERVES - Based on Generation SCC (line 3.1), Active DR (line 2.2.1), Imports (line 2.3), and Exports (see footnote 12)											
4.2.1 MW	5663	4350	6400	6959	7099	6027	6090	6116	6106	6060	5984
4.2.2 % OF LOAD	21	16	24	26	27	23	23	23	23	23	23

KEY:

4.1.1 = 2.1 + 2.2.1 + 2.3 – 1.3
4.1.2 = (4.1.1 / 1.3) x 100
4.2.1 = (3.1 + 2.2.1 + 2.3) – 1.3
4.2.2 = (4.2.1 / 1.3) x 100
2.4 = 2.1 + 2.2 + 2.3

FOOTNOTES:

See Section 1.1 Footnotes on following sheet

1.1 Footnotes

(1) Represents MW load level associated with a reference forecast having a 50% chance of being exceeded. More information on the April 2017 CELT forecast, including the high and low bandwidths, is available on the ISO-NE Website located at http://www.iso-ne.com/system-planning/system-plans-studies/celt.

(2) Three versions of the seasonal peak load forecast are shown. The first forecast does not reflect the peak and energy savings of Passive Demand Resources (PDR) or Behind-the-Meter (BTM) PV. The second forecast shown reflects a reduction for BTM PV. The third forecast shown reflects the reductions of BTM PV and PDR. Detailed forecast documentation on the ISO-NE website includes all three versions of the forecast.

(3) The 2016 summer peak load shown reflects weather normalization. Prior to weather normalization, the actual metered 2016 summer peak of 25,596 MW occurred on August 12, 2016 at hour ending 15:00. See Section 1.5 for actual and estimated peaks and energies. The reconstituted peak was 28,504 MW, which includes reconstitution for the load reducing action of FCM Passive Demand Resources and estimated peak load reduction resulting from behind-the-meter PV at the time of the peak.

(4) Line 1.1.1 consists of Behind-the-Meter PV estimated summer peak load reductions as of July 1 of that year, including an 8% transmission and distribution loss gross up. Refer to Section 3.1 for more details on these values.

(5) The passive DR shown on line 1.2.1 consists of the Qualified Capacity (QC) of existing resources and primary auction (FCA) results for new resources. These values are used by ISO-NE System Planning in their long-term Needs Assessments and Solutions Studies (see Sec. 5.2 of this report for a breakdown by Load Zone and DR type), and are different from the Capacity Supply Obligations shown on line 2.2.2. Beginning in 2021-2022, passive DR includes an ISO-NE forecast of incremental EE beyond the FCM.

(6) The 2017 through 2020 capacity for generating and demand resources consists of the current Forward Capacity Market CSOs as of March 18, 2017, and the 2016 CSOs are based on the 2016-2017 ARA 3 results. The 2020 FCM CSO is assumed to remain in place through the end of the CELT reporting period. It is assumed that the 435 MW of Static and Dynamic De-List Bids that were cleared to leave the 2020-2021 Forward Capacity Auction will remain de-listed through the reporting period. The Citizens Block Load CSO is treated as an import rather than a generating resource.

(7) The demand resource values are based on DR with FCM CSOs, including an 8% transmission and distribution loss gross-up. A passive DR forecast is included with the QC-based DR values on line 1.2.1, beginning in 2021.

(8) The 2016 through 2020 imports are based on FCM import CSOs. An Administrative Export De-List of 100 MW is taken into account in the generation capability values from 2016 through 2019. That 100 MW export will remain as an Export De-List Bid in 2020. The imports beyond the 2020-2021 Capacity Commitment Period reflect only known, long-term contracts.

(9) May not equal sum due to rounding.

(10) The generating capability based on SCC values includes all existing ISO New England generating assets as well as projected additions and retirements. Future generating assets consist of non-FCM resources that are expected to go commercial in 2017 or 2018, and all new resources with FCM CSOs. The capabilities of the FCM resources are based on their Qualified Capacity. Also included is a forecast of non-FCM PV capacity, which is based on the nameplate PV forecast shown in Section 3.1.1, together with the assumed percentage of annual growth (37% in service by July 1), and estimated summer seasonal peak load reduction (in % of nameplate) for each year, as shown in Section 3.2.2.

(11) The 2017 SCC value of 29,174 MW is consistent with the total capacity projected for July 1 in the Section 2.1 Generator List.

(12) Exports consist of a 100 MW Export De-List through 2020.

1.2 Winter Peak Capabilities and Load Forecast (MW)

	16/17	17/18	18/19	19/20	20/21	21/22	22/23	23/24	24/25	25/26	26/27
ISO-NE RELIABILITY COORDINATOR AREA											
1. LOAD [1, 2, 3]											
1.1 REFERENCE - Without reductions	22992	23029	23180	23318	23436	23556	23691	23830	23970	24106	24244
1.1.1 Behind-the-Meter (BTM) PV [4]	0	0	0	0	0	0	0	0	0	0	0
1.2 REFERENCE - With reduction for BTM PV	22992	23029	23180	23318	23436	23556	23691	23830	23970	24106	24244
1.2.1 Passive DR (PDR) used in System Planning [5]	1652	1832	2171	2371	2788	3105	3398	3666	3907	4122	4312.056
1.3 REFERENCE - With reduction for BTM PV and PDR	21340	21197	21009	20947	20648	20451	20293	20164	20063	19984	19931.94
2. CAPACITY BASED ON FCM OBLIGATIONS											
2.1 GENERATING RESOURCES [6]	30178	29995	31322	31975	31633	31633	31633	31633	31633	31633	31633
2.2 DEMAND RESOURCES [6, 7]	2427	2703	2699	2738	3198	3198	3198	3198	3198	3198	3198
2.2.1 ACTIVE DR	543	388	549	371	414	414	414	414	414	414	414
2.2.2 PASSIVE DR	1884	2315	2150	2367	2783	2783	2783	2783	2783	2783	2783
2.3 IMPORTS [8]	1137	1332	1017	1069	1265	91	91	91	91	91	91
2.4 TOTAL [9]	**33742**	**34029**	**35038**	**35782**	**36096**	**34921**	**34921**	**34921**	**34921**	**34921**	**34921**
3. CAPACITY BASED ON SEASONAL CLAIMED CAPABILITY (SCC) [10]											
3.1 GENERATION CLAIMED FOR CAPABILITY	33045	32331	33418	34204	34323	34323	34323	34323	34323	34323	34323
4. RESERVES - Based on Reference Load with reduction for Passive DR											
4.1 INSTALLED RESERVES - Based on CSOs of Generating Resources (line 2.1), Active DR (line 2.2.1), and Imports (line 2.3)											
4.1.1 MW	10518	10518	11879	12468	12664	11687	11845	11974	12075	12154	12206
4.1.2 % OF LOAD	49	50	57	60	61	57	58	59	60	61	61
4.2 INSTALLED RESERVES - Based on Generation SCC (line 3.1), Active DR (line 2.2.1), Imports (line 2.3), and Exports (see footnote 11)											
4.2.1 MW	13285	12754	13875	14597	15354	14378	14536	14664	14766	14845	14897
4.2.2 % OF LOAD	62	60	66	70	74	70	72	73	74	74	75

KEY:

4.1.1 = 2.1 + 2.2.1 + 2.3 – 1.3
4.1.2 = (4.1.1 / 1.3) x 100
4.2.1 = (3.1 + 2.2.1 + 2.3) – 1.3
4.2.2 = (4.2.1 / 1.3) x 100
2.4 = 2.1 + 2.2 + 2.3

FOOTNOTES:

See Section 1.2 Footnotes on following sheet

1.2 Footnotes

(1) Represents MW load level associated with a reference forecast having a 50% chance of being exceeded. More information on the April 2017 CELT forecast, including the high and low bandwidths, is available on the ISO-NE Website located at http://www.iso-ne.com/system-planning/system-plans-studies/celt.

(2) Two versions of the seasonal peak load forecast are shown. The first forecast does not reflect the peak and energy savings of the passive demand resources. The second forecast shown reflects a reduction for that passive DR. Detailed forecast documentation on the ISO-NE website includes both the original CELT forecast and the forecast minus passive demand resources.

(3) The 2016/17 winter peak load shown reflects weather normalization. Prior to weather normalization, the actual metered 2016/17 winter peak of 19,581 MW occurred on December 15, 2016 at hour ending 18:00. See Section 1.5 for actual and estimated peaks and energies. The reconstituted (for the load reducing action of FCM Passive Demand Resources) peak of 22,185 MW occurred on December 15, 2016 at hour ending 18:00.

(4) Behind-the-Meter PV is assumed to be zero during the winter peak.

(5) The passive DR shown on line 1.2.1 consists of the Qualified Capacity (QC) of existing resources and primary auction (FCA) results for new resources. These values are used by ISO-NE System Planning in their long-term Needs Assessments and Solutions Studies (see Sec. 5.2 of this report for a breakdown by Load Zone and DR type), and are different from the Capacity Supply Obligations shown on line 2.2.2. Beginning in 2021/22, passive DR includes an ISO-NE forecast of incremental EE beyond the FCM.

(6) The 2017/18 through 2020/21 capacity for generating and demand resources consists of the Forward Capacity Market CSOs current as of March 18, 2017, and the 2016/17 CSOs are based on the ARA 3 results. The 2020/21 FCM CSO is assumed to remain in place through the end of the CELT reporting period. It is assumed that the 435 MW of Static and Dynamic De-List Bids that were cleared to leave the 2020-2021 Forward Capacity Auction will remain de-listed through the reporting period. The Citizens Block Load CSO is treated as an import rather than a generating resource.

(7) The demand resource values are based on DR with FCM CSOs, including an 8% transmission and distribution loss gross-up. A passive DR forecast is included with the QC-based DR values on line 1.2.1, beginning in 2020/21.

(8) The 2016/17 through 2020/21 imports are based on FCM import CSOs. An Administrative Export De-List of 100 MW is taken into account in the generation capability values from 2016/17 through 2019/20. That 100 MW export will remain as an Export De-List Bid in 2020/21. The imports beyond the 2020/21 Capacity Commitment Period reflect only known, long-term contracts.

(9) May not equal sum due to rounding.

(10) The generating capability based on SCC values includes all existing ISO New England generating assets as well as projected additions and retirements. Future generating assets consist of non-FCM resources that are expected to go commercial in 2017 or 2018, and all new resources with FCM CSOs. The capabilities of the FCM resources are based on their Qualified Capacity.

(11) Exports consist of a 100 MW Export De-List through 2020/21.

1.3 - Summary Summer Capability by Fuel/Unit Type (MW) [1]

	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
NUCLEAR STEAM	4010	4008	4024	3347	3344	3344	3344	3344	3344	3344	3344
HYDRO (DAILY CYCLE - PONDAGE)	338	340	339	340	340	340	340	340	340	340	340
HYDRO (DAILY CYCLE - RUN OF RIVER)	261	252	277	239	248	248	248	248	248	248	248
HYDRO (WEEKLY CYCLE)	868	876	875	872	867	867	867	867	867	867	867
HYDRO (PUMPED STORAGE)	1677	1682	1670	1665	1667	1667	1667	1667	1667	1667	1667
GAS COMBINED CYCLE	8283	8806	9554	10092	10202	10202	10202	10202	10202	10202	10202
GAS/OIL COMBINED CYCLE	3957	4333	4306	4275	4416	4416	4416	4416	4416	4416	4416
GAS COMBUSTION (GAS) TURBINE	219	227	517	1335	1335	1335	1335	1335	1335	1335	1335
GAS/OIL COMBUSTION (GAS) TURBINE	542	556	552	549	546	546	546	546	546	546	546
OIL COMBUSTION (GAS) TURBINE	1695	1692	1697	1710	1696	1696	1696	1696	1696	1696	1696
COAL STEAM	1947	927	922	917	917	917	917	917	917	917	917
GAS/OIL STEAM	2831	2485	2497	2490	2490	2490	2490	2490	2490	2490	2490
OIL STEAM	2128	2216	2198	2192	2041	2041	2041	2041	2041	2041	2041
GAS INTERNAL COMBUSTION	5	5	5	5	5	5	5	5	5	5	5
GAS/OIL INTERNAL COMBUSTION	9	9	9	9	9	9	9	9	9	9	9
OIL INTERNAL COMBUSTION	116	116	112	110	105	105	105	105	105	105	105
BIO/REFUSE	897	948	902	962	905	905	905	905	905	905	905
WIND TURBINE	79	122	116	135	137	137	137	137	137	137	137
GAS FUEL CELL	21	20	16	21	23	23	23	23	23	23	23
PHOTOVOLTAIC	5	5	20	62	66	66	66	66	66	66	66
SUBTOTAL ISO-NE RELIABILITY COORDINATOR AREA CAPACITY [2, 4]	**29888**	**29627**	**30607**	**31326**	**31359**	**31359**	**31359**	**31359**	**31359**	**31359**	**31359**
DEMAND RESOURCES [2]	2441	2691	2696	2734	3211	3211	3211	3211	3211	3211	3211
IMPORTS [3]	1162	1376	1479	1480	1265	89	89	89	89	89	89
TOTAL ISO-NE RELIABILITY COORDINATOR AREA CAPACITY [4]	**33492**	**33693**	**34782**	**35540**	**35835**	**34659**	**34659**	**34659**	**34659**	**34659**	**34659**

FOOTNOTES:

(1) Gas/oil units are not necessarily fully operable on both fuels.

(2) The 2016 through 2020 capacity values consist of the Forward Capacity Market CSOs current as of March 18, 2017. The 2020 FCM CSO is assumed to remain in place through the end of the CELT reporting period. It is assumed that the 435 MW of Static and Dynamic De-List Bids that were cleared to leave the 2020/21 Forward Capacity Auction will remain de-listed through the reporting period.

(3) Imports are from entities outside the ISO-NE Reliability Coordinator area boundary. The 2016 through 2020 imports are based on FCM import CSOs. An Export De-List of 100 MW is taken into account in the generation capability values through 2020. The imports beyond the 2019/20 Capacity Commitment Period reflect only known, long-term contracts.

(4) May not equal sum due to rounding.

1.4 - Summary Winter Capability by Fuel/Unit Type (MW) [1]

	16/17	17/18	18/19	19/20	20/21	21/22	22/23	23/24	24/25	25/26	26/27
NUCLEAR STEAM	4010	4008	4024	3347	3344	3344	3344	3344	3344	3344	3344
HYDRO (DAILY CYCLE - PONDAGE)	339	341	340	340	340	340	340	340	340	340	340
HYDRO (DAILY CYCLE - RUN OF RIVER)	384	418	438	411	396	396	396	396	396	396	396
HYDRO (WEEKLY CYCLE)	860	875	873	854	867	867	867	867	867	867	867
HYDRO (PUMPED STORAGE)	1677	1660	1670	1655	1667	1667	1667	1667	1667	1667	1667
GAS COMBINED CYCLE	8285	8873	9971	10369	10220	10220	10220	10220	10220	10220	10220
GAS/OIL COMBINED CYCLE	3983	4335	4313	4360	4416	4416	4416	4416	4416	4416	4416
GAS COMBUSTION (GAS) TURBINE	221	234	523	1335	1335	1335	1335	1335	1335	1335	1335
GAS/OIL COMBUSTION (GAS) TURBINE	542	556	552	549	546	546	546	546	546	546	546
OIL COMBUSTION (GAS) TURBINE	1719	1714	1739	1770	1707	1707	1707	1707	1707	1707	1707
COAL STEAM	1947	927	922	917	917	917	917	917	917	917	917
GAS/OIL STEAM	2831	2485	2481	2479	2479	2479	2479	2479	2479	2479	2479
OIL STEAM	2128	2216	2198	2192	2041	2041	2041	2041	2041	2041	2041
GAS INTERNAL COMBUSTION	5	5	5	5	5	5	5	5	5	5	5
GAS/OIL INTERNAL COMBUSTION	9	9	9	9	9	9	9	9	9	9	9
OIL INTERNAL COMBUSTION	116	116	112	110	105	105	105	105	105	105	105
BIO/REFUSE	902	958	913	973	915	915	915	915	915	915	915
WIND TURBINE	200	246	224	280	301	301	301	301	301	301	301
GAS FUEL CELL	21	20	16	21	23	23	23	23	23	23	23
PHOTOVOLTAIC	0	0	0	0	0	0	0	0	0	0	0
SUBTOTAL ISO-NE RELIABILITY COORDINATOR AREA CAPACITY [2, 4]	**30178**	**29995**	**31322**	**31975**	**31633**	**31633**	**31633**	**31633**	**31633**	**31633**	**31633**
DEMAND RESOURCES [2]	2427	2703	2699	2738	3198	3198	3198	3198	3198	3198	3198
IMPORTS [3]	1137	1332	1017	1069	1265	91	91	91	91	91	91
TOTAL ISO-NE RELIABILITY COORDINATOR AREA CAPACITY [4]	**33742**	**34029**	**35038**	**35782**	**36096**	**34921**	**34921**	**34921**	**34921**	**34921**	**34921**

FOOTNOTES:

(1) Gas/oil units are not necessarily fully operable on both fuels.

(2) The 2016/17 through 2020/21 capacity values consist of the Forward Capacity Market CSOs as of March 18, 2017. The 2020/21 FCM CSO is assumed to remain in place through the end of the CELT reporting period. It is assumed that the 435 MW of Static and Dynamic De-List Bids that were cleared to leave the 2020/21 Forward Capacity Auction will remain de-listed through the reporting period.

(3) Imports are from entities outside the ISO-NE Reliability Coordinator Area boundary. The 2016/17 through 2020/21 imports are based on FCM import CSOs. An Export De-List of 100 MW is taken into account in the generation capability values through 2020/21. The imports beyond the 2020/21 Capacity Commitment Period reflect only known, long-term contracts.

(4) May not equal sum due to rounding.

1.5.1 - Actual and Forecasted Peak Loads [1]

						2016 ACTUAL						
MONTHLY PEAK LOAD - MW	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
Without reductions	21866	21963	19730	19139	21567	22611	27102	28504	25701	18488	19712	22185
Reduced for BTM PV [2]	21866	21955	19730	19133	21253	22133	26596	27787	25320	18488	19712	22185
Reduced for BTM PV and PDR	19451	19561	17341	16963	19029	19966	24416	25596	23142	16298	17517	19581

						2017 FORECAST						
MONTHLY PEAK LOAD - MW	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
Without reductions	22165 A	20753 A	20082 A	17884	20291	25360	29146	29146	23790	18570	20117	23029
Reduced for BTM PV [2]	22165 A	20753 A	20082 A	17884	19734	24795	28571	28559	23192	18570	20117	23029
Reduced for BTM PV and PDR	19570 A	18130 A	17453 A	15795	17645	22706	26482	26470	21103	16481	18028	21197

						2018 FORECAST						
MONTHLY PEAK LOAD - MW	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
Without reductions	23029	22167	21391	17995	20465	25625	29454	29454	24028	18655	20227	23180
Reduced for BTM PV [2]	23029	22167	21391	17995	19790	24943	28764	28754	23319	18655	20227	23180
Reduced for BTM PV and PDR	21197	20335	19559	15689	17484	22637	26458	26448	21013	16349	17921	21009

						ANNUAL						CAGR [3]
SUMMER PEAK - MW	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2017 to 2026
Without reductions	28504 A	29146	29454	29753	30039	30327	30623	30923	31223	31521	31820	0.98
Reduced for BTM PV	27787 A	28571	28764	28970	29191	29436	29694	29960	30231	30507	30785	0.83
Reduced for BTM PV and PDR	25596 A	26482	26458	26409	26298	26213	26167	26155	26176	26228	26310	-0.07
WINTER PEAK - MW [4]												
Without reductions	22185 A	23029	23180	23318	23436	23556	23691	23830	23970	24106	24244	0.93
Reduced for BTM PV	22185 A	23029	23180	23318	23436	23556	23691	23830	23970	24106	24244	0.93
Reduced for BTM PV and PDR	19581 A	21197	21009	20947	20648	20451	20293	20164	20063	19984	19932	0.23

FOOTNOTES:

A = ACTUAL

(1) Recognizing that the seasonal peaks usually occur within a few months of the year, the forecasted monthly peaks of July and August have been replaced by the summer peak, and December and January have been replaced by the winter peak.

(2) Actual BTM PV output is typically zero at the time of the peak during winter months, since these peaks typically occur after sunset. Forecast values for BTM PV are therefore assumed to be zero for all months other than May-September

(3) Compound Annual Growth Rate (%).

(4) Winter beginning in December of the year shown.

1.5.2 - Actual and Forecasted Energy

						2016 ACTUAL						
MONTHLY NET ENERGY - GWH	**JAN**	**FEB**	**MAR**	**APR**	**MAY**	**JUN**	**JUL**	**AUG**	**SEP**	**OCT**	**NOV**	**DEC**
Without reductions	12434	11484	11312	10417	10720	11387	13666	13937	11245	10734	10665	12340
Reduced for BTM PV	12371	11408	11181	10259	10559	11194	13473	13749	11098	10618	10580	12270
Reduced for BTM PV and PDR	11015	10126	9819	9020	9433	10176	12387	12642	10164	9356	9403	10840

						2017 FORECAST						
MONTHLY NET ENERGY - GWH	**JAN**	**FEB**	**MAR**	**APR**	**MAY**	**JUN**	**JUL**	**AUG**	**SEP**	**OCT**	**NOV**	**DEC**
Without reductions	12721 A	10786 A	11878 A	10267	10724	11578	13973	13362	11370	10642	10828	12044
Reduced for BTM PV	12164 A	10786 A	11878 A	10070	10520	11363	13748	13135	11178	10498	10715	11972
Reduced for BTM PV and PDR	10689 A	9404 A	10386 A	9088	9634	10549	12855	12216	10399	9463	9775	10730

						2018 FORECAST						
MONTHLY NET ENERGY - GWH	**JAN**	**FEB**	**MAR**	**APR**	**MAY**	**JUN**	**JUL**	**AUG**	**SEP**	**OCT**	**NOV**	**DEC**
Without reductions	12857	11609	11711	10376	10838	11702	14121	13505	11491	10755	10943	12172
Reduced for BTM PV	12758	11506	11522	10126	10580	11431	13841	13222	11253	10578	10804	12084
Reduced for BTM PV and PDR	11483	10282	10214	9030	9592	10522	12844	12196	10385	9423	9756	10699

						ANNUAL						CAGR [3]
NET ANNUAL ENERGY - GWH [1, 2]	**2016**	**2017**	**2018**	**2019**	**2020**	**2021**	**2022**	**2023**	**2024**	**2025**	**2026**	**2017 to 2026**
Without reductions	140341 A	140583	142078	143447	144611	145799	147127	148507	149884	151233	152593	0.92
Reduced for BTM PV	138761 A	138689	139705	140647	141478	142418	143518	144677	145857	147048	148255	0.74
Reduced for BTM PV and PDR	124382 A	126786	126426	125736	124440	122977	121859	120994	120349	119911	119680	-0.64

FOOTNOTES:

A = ACTUAL

(1) May not equal sum due to rounding.

(2) The Net Annual Energy does not include a reduction for Passive DR. With a reduction for PDR, the CAGR would be -0.2%. Refer to the ISO website for the full forecast details: http://www.iso-ne.com/system-planning/system-plans-studies/celt

(3) Compound Annual Growth Rate (%).

1.6 - Seasonal Peak Load Forecast Distributions (Forecast is Reference with reduction for BTM PV)

		Peak Load Forecast at Milder Than Expected Weather				Reference Forecast at Expected Weather	Peak Load Forecast at More Extreme Than Expected Weather				
Summer (MW)	2017	27148	27409	27748	28146	28571	29037	29511	30177	30954	31641
	2018	27319	27584	27928	28332	28764	29237	29718	30395	31183	31880
	2019	27503	27773	28122	28532	28970	29450	29938	30626	31426	32134
	2020	27702	27976	28330	28746	29191	29678	30174	30871	31683	32401
	2021	27925	28203	28562	28984	29436	29930	30432	31140	31964	32693
	2022	28162	28444	28808	29236	29694	30196	30705	31423	32259	32998
	2023	28406	28692	29062	29496	29960	30469	30986	31714	32562	33311
	2024	28655	28945	29320	29760	30231	30747	31271	32009	32869	33629
	2025	28910	29203	29584	30030	30507	31030	31562	32310	33182	33952
	2026	29166	29463	29849	30301	30785	31315	31854	32612	33496	34277
WTHI (1)		**78.49**	**78.73**	**79.00**	**79.39**	**79.88**	**80.30**	**80.72**	**81.14**	**81.96**	**82.33**
Dry-Bulb Temperature (2)		**88.50**	**88.90**	**89.20**	**89.90**	**90.20**	**91.20**	**92.20**	**92.90**	**94.20**	**95.40**
Probability of Forecast Being Exceeded		**90%**	**80%**	**70%**	**60%**	**50%**	**40%**	**30%**	**20%**	**10%**	**5%**
Winter (MW)	2017/18	22589	22712	22809	22874	23029	23185	23360	23466	23727	24107
	2018/19	22740	22863	22960	23025	23180	23337	23511	23617	23878	24258
	2019/20	22878	23002	23099	23164	23318	23475	23650	23756	24017	24397
	2020/21	22996	23120	23217	23281	23436	23593	23767	23874	24135	24514
	2021/22	23116	23240	23337	23402	23556	23713	23888	23994	24255	24635
	2022/23	23251	23374	23471	23536	23691	23848	24022	24128	24389	24769
	2023/24	23390	23514	23611	23676	23830	23987	24162	24268	24529	24909
	2024/25	23530	23653	23750	23815	23970	24127	24301	24407	24668	25048
	2025/26	23666	23790	23887	23952	24106	24263	24437	24544	24805	25185
	2026/27	23804	23927	24024	24089	24244	24401	24575	24681	24942	25322
Dry-Bulb Temperature (3)		**10.72**	**9.66**	**8.84**	**8.30**	**7.03**	**5.77**	**4.40**	**3.58**	**1.61**	**(1.15)**

FOOTNOTES:

(1) WTHI - a three-day weighted temperature-humidity index for eight New England weather stations. It is the weather variable used in producing the summer peak load forecast. For more information on the weather variables see *http://www.iso-ne.com/system-planning/system-plans-studies/celt* .

(2) Dry-bulb temperature (in degrees Fahrenheit) shown in the summer season is for informational purposes only.

(3) Dry-bulb temperature (in degrees Fahrenheit) shown in the winter season is a weighted value from eight New England weather stations.

2.1 Generator List with Existing and Expected Seasonal Claimed Capability (SCC)

- Generator Information as of January 1, 2017

- Summer and Winter SCC as of January 1, 2017, and as of the 2016/17 Winter and 2017 Summer Peaks

- Generators In-Service as of 4/1/2017

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	As of Jan. 2017 SCC Report SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
253	TURNKEY LANDFILL	253	TURNKEY LANDFILL	IC	LFG		BIO/REFUSE	01-Mar-92	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH	54663	3.000	0.710	0.709	0.710	0.709	0.001
321	MANCHESTER 10/10A CC	321	MANCHESTER 10 10A CC	CC	NG	DFO	GAS/OIL COMBINED CYCLE	15-Nov-95	Dominion Energy Marketing, Inc.	DEM	RI	007	RI	RI	3236	170.200	170.000	157.421	170.000	157.421	0.000
322	MANCHESTER 11/11A CC	322	MANCHESTER 11 11A CC	CC	NG	DFO	GAS/OIL COMBINED CYCLE	01-Oct-95	Dominion Energy Marketing, Inc.	DEM	RI	007	RI	RI	3236	170.200	170.000	158.658	170.000	158.658	0.000
323	MANCHESTER 9/9A CC	323	MANCHESTER 9 9A CC	CC	NG	DFO	GAS/OIL COMBINED CYCLE	14-Nov-95	Dominion Energy Marketing, Inc.	DEM	RI	007	RI	RI	3236	170.200	170.000	155.912	170.000	155.912	0.060
324	CDECCA	324	CDECCA	CC	NG	DFO	GAS/OIL COMBINED CYCLE	01-Nov-88	Pawtucket Power Holding Company LLC	PPH	CT	003	CT	CT	50498	62.624	61.334	51.685	61.334	51.685	1.593
326	ALTRESCO	326	ALTRESCO	CC	NG	DFO	GAS/OIL COMBINED CYCLE	01-Sep-90	Pawtucket Power Holding Company LLC	PPH	MA	003	WMA	WCMA	50002	160.088	182.982	144.599	182.982	144.599	-0.858
327	AMOSKEAG	327	AMOSKEAG	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-22	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH	2354	15.000	17.500	17.041	17.500	17.041	0.000
328	GULF ISLAND COMPOSITE	328	GULF ISLAND COMPOSITE Incremental	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-26	Brookfield White Pine Hydro LLC	FPLEMH	ME	001	ME	ME	1480	39.462	33.440	29.795	33.440	29.795	-3.645
329	ASCUTNEY GT	329	ASCUTNEY GT	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Nov-61	Green Mountain Power Corporation	GMP	VT	027	VT	VT	3708	11.500	12.581	8.646	12.581	8.646	0.387
330	AYERS ISLAND	330	AYERS ISLAND	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-25	Public Service Company of New Hampshire	PSNH	NH	009	NH	NH	2355	7.200	8.943	8.290	8.943	8.290	0.000
331	AZISCOHOS HYDRO	331	AZISCOHOS HYDRO	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jul-88	Brookfield Energy Marketing, LP	BEMLP	ME	019	ME	ME	50999	6.777	6.645	6.645	6.645	6.645	0.000
335	BELLOWS FALLS	335	BELLOWS FALLS	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-28	TransCanada Hydro Northeast Inc	TCHN	VT	025	VT	NH	3745	45.900	47.216	47.216	47.216	47.216	0.000
336	BERLIN 1 GT	336	BERLIN 1 GT	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Jan-72	Green Mountain Power Corporation	GMP	VT	023	VT	VT	3734	41.850	50.409	40.956	50.409	40.956	0.696
337	BETHLEHEM	337	BETHLEHEM	ST	WDS		BIO/REFUSE	01-Dec-86	Engie Energy Marketing NA, Inc	SUEZ	NH	007	NH	NH	50208	14.535	0.000	15.288	0.000	15.288	0.049
340	BRIDGEPORT HARBOR 3	340	BRIDGEPORT HARBOR 3	ST	SUB		COAL STEAM	01-Aug-68	PSEG Energy Resources & Trade LLC	PSEG	CT	001	SWCT	CT	568	399.500	384.984	383.426	384.984	383.426	0.000
341	BRIDGEPORT HARBOR 4	341	BRIDGEPORT HARBOR 4	GT	JF		OIL COMBUSTION (GAS) TURBINE	01-Oct-67	PSEG Energy Resources & Trade LLC	PSEG	CT	001	SWCT	CT	568	18.594	21.816	17.024	21.816	17.024	0.000
345	CATALYST CO-GEN	345	MEAD	ST	BIT	OBS	COAL STEAM	01-Feb-90	American PowerNet Management, LP	APNM	ME	017	ME	ME	10495	102.600	0.000	0.000	0.000	0.000	0.000
346	BOLTON FALLS	346	BOLTON FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-80	Green Mountain Power Corporation	GMP	VT	023	VT	VT	7056	6.400	4.279	0.000	4.279	0.000	-1.507
348	BOOT MILLS	348	BOOT MILLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-85	NSTAR Electric Company	NSTAR	MA	017	CMA/NEMA	WCMA	10556	18.213	11.875	0.990	11.875	0.990	-3.720
349	WHEELABRATOR BRIDGEPORT, L.P.	349	WHEELABRATOR BRIDGEPORT, L.P.	ST	MSW		BIO/REFUSE	01-Apr-88	Wheelabrator Bridgeport, L.P.	WB	CT	001	SWCT	CT	50883	67.150	59.401	58.034	59.401	58.034	-0.617
350	BRAYTON PT 1	350	BRAYTON PT 1	ST	BIT		COAL STEAM	01-Aug-63	Brayton Point Energy, LLC	BPE	MA	005	RI	SEMA	1619	241.020	233.216	225.230	233.216	0.000	0.000
351	BRAYTON PT 2	351	BRAYTON PT 2	ST	BIT		COAL STEAM	01-Jul-64	Brayton Point Energy, LLC	BPE	MA	005	RI	SEMA	1619	241.020	236.938	234.800	236.938	0.000	-3.042
352	BRAYTON PT 3	352	BRAYTON PT 3	ST	BIT		COAL STEAM	01-Jul-69	Brayton Point Energy, LLC	BPE	MA	005	RI	SEMA	1619	642.690	584.895	573.847	584.895	0.000	-1.143
353	BRAYTON PT 4	353	BRAYTON PT 4	ST	RFO	NG	GAS/OIL STEAM	01-Dec-74	Brayton Point Energy, LLC	BPE	MA	005	RI	SEMA	1619	475.560	432.667	430.348	432.667	0.000	-4.652
354	BRAYTON DIESELS 1-4	354	Brayton Diesels 1-4 Incremental	IC	DFO		OIL INTERNAL COMBUSTION	01-Mar-67	Brayton Point Energy, LLC	BPE	MA	005	RI	SEMA	1619	10.552	0.000	0.000	0.000	0.000	0.000
355	BRANFORD 10	355	BRANFORD 10	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Jan-69	NRG Power Marketing LLC	NRGPM	CT	009	SWCT	CT	540	18.594	20.950	15.840	20.950	15.840	0.000
356	BRISTOL REFUSE	356	BRISTOL REFUSE	ST	MSW		BIO/REFUSE	01-May-88	Covanta Energy Marketing, LLC	CEM	CT	003	CT	CT	50648	18.000	13.128	13.385	13.128	13.385	-0.002
357	BRIDGEWATER	357	BRIDGEWATER	ST	WDS		BIO/REFUSE	01-Sep-87	Bridgewater Power Company, L.P.	BPCLP	NH	009	NH	NH	10290	15.088	14.774	14.645	14.774	14.645	0.183
358	BRUNSWICK	358	BRUNSWICK	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-82	Brookfield White Pine Hydro LLC	FPLEMH	ME	005	ME	ME	1483	19.600	13.714	3.520	13.714	3.520	-3.101
359	J. COCKWELL 1	359	J. COCKWELL 1	PS	WAT		HYDRO (PUMPED STORAGE)	01-Sep-74	Bear Swamp Power Company LLC	BSP	MA	003	WMA	WCMA	8005	299.700	292.275	292.275	292.275	292.275	0.000
360	J. COCKWELL 2	360	J. COCKWELL 2	PS	WAT		HYDRO (PUMPED STORAGE)	01-Oct-74	Bear Swamp Power Company LLC	BSP	MA	003	WMA	WCMA	8005	299.700	292.113	293.238	292.113	293.238	0.000
362	BULLS BRIDGE	362	BULLS BRIDGE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-03	FirstLight Power Resource Management, LLC	NEL1	CT	005	SWCT	CT	541	7.200	0.000	0.000	0.000	0.000	-1.370
363	BURLINGTON GT	363	BURLINGTON GT	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Jul-71	Burlington Electric Department	BED	VT	007	VT	VT	3754	27.648	23.354	18.007	23.354	18.007	-0.760
365	CANAL 1	365	CANAL 1	ST	RFO		OIL STEAM	01-Jul-68	Genon Energy Management, LLC	MET	MA	001	SEMA	SEMA	1599	584.600	566.705	567.940	562.305	567.940	5.720
366	CANAL 2	366	CANAL 2	ST	RFO	NG	GAS/OIL STEAM	01-Feb-76	Genon Energy Management, LLC	MET	MA	001	SEMA	SEMA	1599	579.500	558.750	558.750	558.750	558.750	0.250
367	CAPE GT 4	367	CAPE GT 4	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Jan-70	NextEra Energy Power Marketing, LLC	FPLP	ME	005	SME	ME	1484	17.553	20.011	14.807	20.011	14.807	-0.126
368	CAPE GT 5	368	CAPE GT 5	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Jan-70	NextEra Energy Power Marketing, LLC	FPLP	ME	005	SME	ME	1484	18.400	20.272	15.822	20.272	15.822	0.000
369	CATARACT EAST	369	CATARACT EAST	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-37	Brookfield White Pine Hydro LLC	FPLEMH	ME	031	SME	ME	1486	6.650	7.733	7.373	7.733	7.373	0.000
370	COS COB 10	370	COS COB 10	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Sep-69	NRG Power Marketing LLC	NRGPM	CT	001	NOR	CT	542	21.250	23.000	18.932	23.000	18.932	0.000
371	COS COB 11	371	COS COB 11	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Jan-69	NRG Power Marketing LLC	NRGPM	CT	001	NOR	CT	542	21.250	23.000	18.724	23.000	18.724	0.000
372	COS COB 12	372	COS COB 12	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Jan-69	NRG Power Marketing LLC	NRGPM	CT	001	NOR	CT	542	21.250	23.000	19.082	23.000	19.082	0.000
375	CLEARY 9/9A CC	375	CLEARY 9 9A CC	CC	NG	DFO	GAS/OIL COMBINED CYCLE	01-Dec-75	Taunton Municipal Lighting Plant	TMLP	MA	005	SEMA	SEMA	1682	116.620	109.931	104.931	109.931	104.931	0.000
376	CLEARY 8	376	CLEARY 8	ST	RFO		OIL STEAM	01-Jan-66	Taunton Municipal Lighting Plant	TMLP	MA	005	SEMA	SEMA	1682	27.200	22.253	24.825	22.253	24.825	0.000
379	COBBLE MOUNTAIN	379	COBBLE MOUNTAIN	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-23	Holyoke Gas & Electric Department	HGE	MA	013	WMA	WCMA	1630	23.100	27.431	26.966	27.431	26.966	0.466
382	MERRIMACK CT1	382	MERRIMACK CT1	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Jul-69	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH	2364	18.594	21.676	16.826	21.676	16.826	0.000
383	MERRIMACK CT2	383	MERRIMACK CT2	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Aug-68	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH	2364	18.594	21.304	16.804	21.304	16.804	0.000
388	DARTMOUTH POWER	388	DARTMOUTH POWER	CC	NG	DFO	GAS/OIL COMBINED CYCLE	01-May-92	Talen Energy Marketing, LLC	EPLU-I	MA	005	SEMA	SEMA	52026	74.070	67.656	61.720	67.656	61.720	1.009
389	DERBY DAM	389	DERBY DAM	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Mar-89	Connecticut Light and Power Company, The	CLP	CT	001	SWCT	CT	10063	8.320	7.050	6.753	7.050	6.753	0.000
393	DEERFIELD 5	393	DEERFIELD 5	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Oct-74	TransCanada Hydro Northeast Inc	TCHN	MA	011	WMA	WCMA	1620	17.550	13.990	13.965	13.990	13.965	0.000
395	DOREEN	395	DOREEN	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Jan-69	Essential Power Massachusetts, LLC	NAEA-EM	MA	003	WMA	WCMA	1631	18.594	20.385	15.820	20.385	15.820	0.000
396	DEVON 10	396	DEVON 10	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Apr-88	NRG Power Marketing LLC	NRGPM	CT	009	SWCT	CT	544	18.594	18.852	14.407	18.852	14.407	0.000
397	DEVON 11	397	DEVON 11	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	01-Oct-96	NRG Power Marketing LLC	NRGPM	CT	009	SWCT	CT	544	51.000	38.819	29.299	38.819	29.299	0.000
398	DEVON 12	398	DEVON 12	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	01-Oct-96	NRG Power Marketing LLC	NRGPM	CT	009	SWCT	CT	544	51.000	38.437	29.227	38.437	29.227	0.000
399	DEVON 13	399	DEVON 13	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	01-Oct-96	NRG Power Marketing LLC	NRGPM	CT	009	SWCT	CT	544	51.000	38.967	29.967	38.967	29.967	0.000
400	DEVON 14	400	DEVON 14	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	01-Oct-96	NRG Power Marketing LLC	NRGPM	CT	009	SWCT	CT	544	51.000	40.274	29.704	40.274	29.704	0.000
401	EASTMAN FALLS	401	EASTMAN FALLS	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-12	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH	2356	5.889	6.098	5.330	6.098	5.330	0.000
405	ELLSWORTH HYDRO	405	ELLSWORTH HYDRO	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-19	Black Bear Hydro Partners, LLC	BBHP	ME	009	BHE	ME	1469	8.900	9.050	9.044	9.050	9.044	0.000
407	EASTPORT DIESEL #3	407	EASTPORT DIESELS 1-3	IC	DFO		OIL INTERNAL COMBUSTION	01-Jan-48	New Brunswick Energy Marketing Corporation	NBPGC	ME	029	BHE	ME	1468	1.995	2.100	0.000	2.100	0.000	-1.900
410	ESSEX 19 HYDRO	410	ESSEX 19 HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-17	Green Mountain Power Corporation	GMP	VT	007	VT	VT	3737	7.040	5.927	1.500	5.927	1.500	-2.172
411	EXETER	411	EXETER	ST	TDF		BIO/REFUSE	01-Dec-91	EmpireCo Limited Partnership	ECLP	CT	015	CT	CT	50736	36.225	0.000	0.000	0.000		0.000
412	FALLS VILLAGE	412	FALLS VILLAGE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-14	FirstLight Power Resource Management, LLC	NEL1	CT	005	CT	CT	560	9.000	4.301	0.000	4.301	0.000	-1.053
413	FIFE BROOK	413	FIFE BROOK	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Oct-74	Bear Swamp Power Company LLC	BSP	MA	003	WMA	WCMA	8004	11.250	5.586	0.000	5.586	0.000	-0.240
417	FRAMINGHAM JET 1	417	FRAMINGHAM JET 1	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Sep-69	Exelon Generation Company, LLC	EXGC	MA	017	BOSTON	NEMA	1586	14.195	14.175	9.620	14.175	9.620	-0.525

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
418	FRAMINGHAM JET 2	418	FRAMINGHAM JET 2	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Sep-69	Exelon Generation Company, LLC	EXGC	MA	017	BOSTON	NEMA	1586	14.195	15.686	10.129	15.686	10.129	0.080
419	FRAMINGHAM JET 3	419	FRAMINGHAM JET 3	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Sep-69	Exelon Generation Company, LLC	EXGC	MA	017	BOSTON	NEMA	1586	14.195	15.250	10.220	15.250	10.220	-1.030
420	FRANKLIN DRIVE 10	420	FRANKLIN DRIVE 10	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Nov-68	NRG Power Marketing LLC	NRGPM	CT	005	CT	CT	561	18.594	20.527	15.417	20.527	15.417	0.000
421	FRONT STREET DIESELS 1-3	421	FRONT STREET DIESELS 1-3	IC	DFO		OIL INTERNAL COMBUSTION	01-Dec-80	Chicopee Municipal Lighting Plant	CMLP	MA	013	WMA	WCMA	7396	9.653	7.706	7.713	7.706	7.713	-0.002
424	GREAT LAKES - MILLINOCKET	424	GREAT LAKES - MILLINOCKET	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Mar-87	Brookfield Energy Marketing, LP	BEMLP	ME	019	BHE	ME	55830	138.798	92.787	90.836	92.787	90.836	0.000
426	GORGE 1 DIESEL	426	GORGE 1 DIESEL	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Jan-65	Green Mountain Power Corporation	GMP	VT	007	VT	VT	3735	16.941	13.547	7.486	13.547	7.486	0.396
427	GORHAM	427	GORHAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-09	Public Service Company of New Hampshire	PSNH	NH	007	NH	NH	2358	2.150	1.679	0.695	1.679	0.695	-0.238
432	HARRIS 1	432	HARRIS 1	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-54	Brookfield White Pine Hydro LLC	FPLEMH	ME	025	ME	ME	1492	15.000	16.776	16.790	16.776	16.790	0.000
433	HARRIS 2	433	HARRIS 2	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-54	Brookfield White Pine Hydro LLC	FPLEMH	ME	025	ME	ME	1492	31.950	34.500	34.865	34.500	34.865	0.000
434	HARRIS 3	434	HARRIS 3	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-53	Brookfield White Pine Hydro LLC	FPLEMH	ME	025	ME	ME	1492	30.000	33.905	34.210	33.905	34.210	0.000
435	HARRIMAN	435	HARRIMAN	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-24	TransCanada Hydro Northeast Inc	TCHN	VT	025	WMA	WCMA	3746	33.600	38.471	40.605	38.471	40.605	-0.338
436	HEMPHILL 1	436	HEMPHILL 1	ST	WDS		BIO/REFUSE	01-Dec-87	Springfield Power, LLC	SPRING	NH	019	NH	NH	10838	20.900	16.932	16.896	16.932	16.896	0.078
440	HIRAM	440	HIRAM	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-17	Brookfield White Pine Hydro LLC	FPLEMH	ME	005	SME	ME	1493	11.094	11.240	10.067	11.240	10.067	0.000
445	COVANTA WEST ENFIELD	445	COVANTA WEST ENFIELD	ST	WDS		BIO/REFUSE	01-Nov-87	Stored Solar J&WE, LLC	IESI-I	ME	019	BHE	ME	10766	27.500	21.446	0.000	21.446	0.000	-20.461
446	COVANTA JONESBORO	446	COVANTA JONESBORO	ST	WDS		BIO/REFUSE	01-Nov-87	Stored Solar J&WE, LLC	IESI-I	ME	029	BHE	ME	10765	30.735	20.226	0.000	20.226	0.000	-20.226
448	IPSWICH DIESELS	448	IPSWICH DIESELS	IC	DFO	NG	GAS/OIL INTERNAL COMBUSTION	01-Jan-51	Ipswich Municipal Light Department	IMLD	MA	009	BOSTON	NEMA	1670	9.563	9.495	9.457	9.495	9.457	0.358
449	JACKMAN	449	JACKMAN	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Feb-26	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH	2360	3.200	3.541	3.600	3.541	3.600	0.035
452	KENDALL JET 1	452	KENDALL JET 1	GT	DFO		OIL COMBUSTION (GAS) TURBINE	24-Sep-70	Kendall Green Energy, LLC	KENDALL	MA	017	BOSTON	NEMA	1595	21.250	22.400	17.987	22.400	17.987	-0.013
457	LAWRENCE HYDRO	457	LAWRENCE HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-81	CHI Power Marketing, Inc.	CHIPM	MA	009	CMA/NEMA	WCMA	50545	16.720	10.390	1.719	10.390	1.719	-2.567
460	LOCKWOOD	460	LOCKWOOD	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-84	Brookfield Energy Marketing, LP	BEMLP	ME	011	ME	ME	10066	7.933	4.931	2.757	4.931	2.757	-0.487
461	LENERGIA ENERGY CENTER	12521	Lowell Power Reactivation	CC	NG	DFO	GAS/OIL COMBINED CYCLE	11-Mar-93	EDF Trading North America, LLC	EDFT	MA	017	CMA/NEMA	WCMA	54586	85.140	78.446	74.638	78.446	74.638	0.000
462	LISBON RESOURCE RECOVERY	462	LISBON RESOURCE RECOVERY	ST	MSW		BIO/REFUSE	01-Jan-96	Connecticut Light and Power Company, The	CLP	CT	011	CT	CT	54758	15.449	13.365	13.700	13.365	13.700	0.173
463	REENERGY LIVERMORE FALLS	463	AEI LIVERMORE	ST	WDS		BIO/REFUSE	01-Oct-92	ReEnergy Stratton LLC	REESTR	ME	001	ME	ME	10354	39.600	35.630	35.300	35.630	35.300	0.000
464	LOST NATION	464	LOST NATION	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Sep-69	Public Service Company of New Hampshire	PSNH	NH	007	NH	NH	2362	18.000	17.992	13.979	17.992	13.979	0.205
465	DEERFIELD 2/LWR DRFIELD	465	DEERFIELD 2 LWR DRFIELD	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-12	TransCanada Hydro Northeast Inc	TCHN	MA	011	WMA	WCMA	6047, 6083, 6119	9.600	18.667	18.580	18.667	18.580	0.000
466	L STREET JET	466	L STREET JET	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Sep-66	Exelon Generation Company, LLC	EXGC	MA	025	BOSTON	NEMA	1587	19.125	21.770	16.030	21.770	16.030	0.000
467	MARBLEHEAD DIESELS	467	MARBLEHEAD DIESELS	IC	DFO		OIL INTERNAL COMBUSTION	25-Sep-98	Marblehead Municipal Light Department	MMLD	MA	009	BOSTON	NEMA	6586	5.200	5.000	5.000	5.000	5.000	0.000
468	MARSHFIELD 6 HYDRO	468	MARSHFIELD 6 HYDRO	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-27	Green Mountain Power Corporation	GMP	VT	023	NH	VT	3739	5.000	4.650	4.565	4.650	4.565	0.057
472	M STREET JET	472	M STREET JET	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Jan-78	Massachusetts Bay Transportation Authority	MBTA	MA	025	BOSTON	NEMA	10176	61.290	67.200	21.737	67.200	21.737	-25.263
473	MCINDOES	473	MCINDOES	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-31	TransCanada Hydro Northeast Inc	TCHN	NH	009	NH	NH	6483	11.880	10.764	10.170	10.764	10.170	0.000
474	J C MCNEIL	474	J C MCNEIL	ST	WDS		BIO/REFUSE	01-Feb-84	Burlington Electric Department	BED	VT	007	VT	VT	589	53.519	54.000	52.000	54.000	52.000	0.000
478	MIDDLETOWN 10	478	MIDDLETOWN 10	GT	JF		OIL COMBUSTION (GAS) TURBINE	01-Jan-66	NRG Power Marketing LLC	NRGPM	CT	007	CT	CT	562	18.594	20.015	15.515	20.015	15.515	0.000
480	MIDDLETOWN 2	480	MIDDLETOWN 2	ST	RFO	NG	GAS/OIL STEAM	01-Jan-58	NRG Power Marketing LLC	NRGPM	CT	007	CT	CT	562	113.636	120.000	117.000	120.000	117.000	0.000
481	MIDDLETOWN 3	481	MIDDLETOWN 3	ST	RFO	NG	GAS/OIL STEAM	01-Jan-64	NRG Power Marketing LLC	NRGPM	CT	007	CT	CT	562	239.360	244.398	226.481	244.398	226.481	-0.269
482	MIDDLETOWN 4	482	MIDDLETOWN 4	ST	RFO		OIL STEAM	01-Jun-73	NRG Power Marketing LLC	NRGPM	CT	007	CT	CT	562	414.900	402.000	399.923	402.000	399.923	0.000
484	MILLSTONE POINT 2	484	MILLSTONE POINT 2	ST	NUC		NUCLEAR STEAM	01-Dec-75	Dominion Energy Marketing, Inc.	DEM	CT	007	CT	CT	566	909.900	859.038	856.515	859.038	856.515	-11.324
485	MILLSTONE POINT 3	485	MILLSTONE POINT 3	ST	NUC		NUCLEAR STEAM	01-Apr-86	Dominion Energy Marketing, Inc.	DEM	CT	011	CT	CT	566	1,253.098	1,233.633	1,225.000	1,233.633	1,225.000	4.987
486	MILFORD POWER	486	MILFORD POWER	CC	NG		GAS COMBINED CYCLE	01-Jan-94	Dynegy Marketing and Trade, LLC	DMT1	MA	027	RI	SEMA	54805	147.050	170.730	149.000	170.730	149.000	0.000
487	WORUMBO HYDRO	487	MILLER HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-84	Energy New England LLC	ENE	ME	001	ME	ME	50278	18.624	12.782	4.079	12.782	4.079	-2.093
489	MERRIMACK 1	489	MERRIMACK 1	ST	BIT		COAL STEAM	01-Dec-60	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH	2364	113.636	108.050	108.000	108.050	108.000	0.000
490	MERRIMACK 2	490	MERRIMACK 2	ST	BIT		COAL STEAM	30-Apr-68	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH	2364	345.600	330.513	330.000	330.513	330.000	1.863
492	MONTVILLE 10 AND 11	492	MONTVILLE 10 and 11	IC	KER		OIL INTERNAL COMBUSTION	01-Jan-67	NRG Power Marketing LLC	NRGPM	CT	011	CT	CT	546	5.504	5.354	5.296	5.354	5.296	0.000
493	MONTVILLE 5	493	MONTVILLE 5	ST	RFO	NG	GAS/OIL STEAM	01-Jan-54	NRG Power Marketing LLC	NRGPM	CT	011	CT	CT	546	75.000	81.590	81.000	81.590	81.000	0.000
494	MONTVILLE 6	494	MONTVILLE 6	ST	RFO		OIL STEAM	01-Jul-71	NRG Power Marketing LLC	NRGPM	CT	011	CT	CT	546	414.900	406.659	405.050	406.659	405.050	19.002
495	MONTY	495	MONTY	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-80	Brookfield White Pine Hydro LLC	FPLEMH	ME	025	ME	ME	805	28.440	26.960	26.960	26.960	26.960	0.000
497	MASS POWER	497	MASS POWER	CC	NG		GAS COMBINED CYCLE	01-Jul-93	Dynegy Marketing and Trade, LLC	DMT1	MA	013	WMA	WCMA	10726	270.655	279.889	245.259	279.889	245.259	0.000
498	MT TOM	498	MT TOM	ST	BIT		COAL STEAM	01-Jun-60	Engie Energy Marketing NA, Inc	SUEZ	MA	013	WMA	WCMA	1606	132.813	0.000	0.000	0.000	0.000	0.000
502	MYSTIC 7	502	MYSTIC 7	ST	RFO	NG	GAS/OIL STEAM	01-Jun-75	Exelon Generation Company, LLC	EXGC	MA	025	BOSTON	NEMA	1588	617.040	559.775	574.547	559.775	574.547	-0.932
503	MYSTIC JET	503	MYSTIC JET	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Jun-69	Exelon Generation Company, LLC	EXGC	MA	025	BOSTON	NEMA	1588	14.195	13.218	8.953	13.218	8.953	0.678
507	NEA BELLINGHAM	507	NEA BELLINGHAM	CC	NG	DFO	GAS/OIL COMBINED CYCLE	01-Oct-91	NextEra Energy Power Marketing, LLC	FPLP	MA	021	RI	SEMA	10307	387.180	329.957	273.343	329.957	273.343	1.292
508	NEWINGTON 1	508	NEWINGTON 1	ST	RFO	NG	GAS/OIL STEAM	01-Jun-74	Public Service Company of New Hampshire	PSNH	NH	015	NH	NH	8002	368.000	400.200	400.200	400.200	400.200	0.000
513	NEW HAVEN HARBOR	513	NEW HAVEN HARBOR	ST	RFO	NG	GAS/OIL STEAM	01-Aug-75	PSEG Energy Resources & Trade LLC	PSEG	CT	009	CT	CT	6156	460.260	436.610	447.894	436.610	447.894	0.776
515	NORWICH JET	515	NORWICH JET	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Sep-72	Connecticut Municipal Electric Energy Cooperative	CMEEC	CT	011	CT	CT	581	19.125	18.800	15.255	18.800	15.255	0.000
519	NORWALK HARBOR 1	519	NORWALK HARBOR 1	ST	RFO		OIL STEAM	01-Jan-60	NRG Power Marketing LLC	NRGPM	CT	001	NOR	CT	548	163.200	0.000	0.000	0.000		0.000
520	NORWALK HARBOR 2	520	NORWALK HARBOR 2	ST	RFO		OIL STEAM	01-Jan-63	NRG Power Marketing LLC	NRGPM	CT	001	NOR	CT	548	163.200	0.000	0.000	0.000		0.000
521	NORWALK HARBOR 10 (3)	521	NORWALK HARBOR 10 (3)	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Oct-96	NRG Power Marketing LLC	NRGPM	CT	001	NOR	CT	548	16.320	0.000	0.000	0.000		0.000
527	OGDEN-MARTIN 1	527	OGDEN-MARTIN 1	ST	MSW	DFO	BIO/REFUSE	01-Jun-89	Covanta Haverhill Associates	CHA	MA	009	BOSTON	NEMA	50661	50.088	41.712	38.218	41.712	38.218	-1.315
528	OCEAN ST PWR GT1/GT2/ST1	528	OCEAN ST PWR GT1 GT2 ST1	CC	NG	DFO	GAS/OIL COMBINED CYCLE	31-Dec-90	TransCanada Power Marketing, Ltd.	TCPM	RI	007	RI	RI	51030	262.013	316.901	270.901	316.901	270.901	0.000
529	OCEAN ST PWR GT3/GT4/ST2	529	OCEAN ST PWR GT3 GT4 ST2	CC	NG	DFO	GAS/OIL COMBINED CYCLE	01-Oct-91	TransCanada Power Marketing, Ltd.	TCPM	RI	007	RI	RI	54324	262.013	318.180	270.180	318.180	270.180	0.000
531	PAWTUCKET POWER	531	PAWTUCKET POWER	CC	NG	DFO	GAS/OIL COMBINED CYCLE	01-Feb-91	Pawtucket Power Holding Company LLC	PPH	RI	007	RI	RI	54056	70.141	60.478	54.736	60.478	54.736	2.634
532	PEJEPSCOT	532	PEJEPSCOT	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-87	Black Bear Hydro Partners, LLC	BBHP	ME	023	ME	ME	50758	16.506	10.114	3.371	10.114	3.371	-2.100
536	PERC-ORRINGTON 1	536	PERC-ORRINGTON 1	ST	MSW		BIO/REFUSE	01-Jan-88	New Brunswick Energy Marketing Corporation	NBPGC	ME	019	BHE	ME	50051	25.500	20.482	21.600	20.482	21.600	0.041
537	PILGRIM NUCLEAR POWER STATION	537	PILGRIM NUCLEAR POWER STATION	ST	NUC		NUCLEAR STEAM	01-Dec-72	Entergy Nuclear Power Marketing LLC	ENPM	MA	023	SEMA	SEMA	1590	741.000	683.421	670.455	683.421	670.455	-6.829
538	PINETREE POWER	538	PINETREE POWER	ST	WDS		BIO/REFUSE	01-Nov-92	Engie Energy Marketing NA, Inc	SUEZ	MA	027	WMA	WCMA	54620	16.200	17.309	16.919	17.309	16.919	-0.196
539	PONTOOK HYDRO	539	PONTOOK HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-86	Brookfield Energy Marketing, LP	BEMLP	NH	007	NH	NH	50741	10.260	8.389	2.897	8.389	2.897	-1.774
540	POTTER 2 CC	540	POTTER 2 CC	CC	NG		GAS COMBINED CYCLE	01-Mar-77	Braintree Electric Light Department, Town of	BELD	MA	021	SEMA	SEMA	1660	90.900	89.998	71.998	89.998	71.998	0.000
541	PROCTOR	541	PROCTOR	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-80	Green Mountain Power Corporation	GMP	VT	021	VT	VT	6450	7.873	3.684	0.733	3.684	0.733	-0.295
542	ECO MAINE	542	ECO MAINE	ST	MSW		BIO/REFUSE	01-Aug-88	Exelon Generation Company, LLC	EXGC	ME	005	SME	ME	50225	13.286	11.459	11.333	11.459	11.333	-0.190
546	RESCO SAUGUS	546	RESCO SAUGUS	ST	MSW		BIO/REFUSE	01-Nov-85	Wheelabrator North Andover Inc	WNE	MA	009	BOSTON	NEMA	50880	45.032	30.114	30.845	30.114	30.845	0.000
547	WHEELABRATOR NORTH ANDOVER	547	WHEELABRATOR NORTH ANDOVER	ST	MSW		BIO/REFUSE	01-Aug-85	Wheelabrator North Andover Inc	WNE	MA	009	BOSTON	NEMA	50877	42.755	30.605	30.144	30.605	30.144	-0.115

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
549	RUTLAND 5 GT	549	RUTLAND 5 GT	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Jan-62	Green Mountain Power Corporation	GMP	VT	021	VT	VT	3723	11.500	12.203	7.919	12.203	7.919	0.201
555	SEABROOK	555	SEABROOK	ST	NUC		NUCLEAR STEAM	01-Apr-90	NextEra Energy Power Marketing, LLC	FPLP	NH	015	NH	NH	6115	1,309.251	1,249.075	1,249.075	1,249.075	1,249.075	1.175
556	SCHILLER 4	556	SCHILLER 4	ST	BIT	RFO	COAL STEAM	01-Apr-52	Public Service Company of New Hampshire	PSNH	NH	015	NH	NH	2367	39.950	48.000	47.500	48.000	47.500	0.000
557	SCHILLER 5	557	SCHILLER 5	ST	WDS		BIO/REFUSE	01-May-55	Public Service Company of New Hampshire	PSNH	NH	015	NH	NH	2367	39.950	42.594	43.082	42.594	43.082	0.000
558	SCHILLER 6	558	SCHILLER 6	ST	BIT	RFO	COAL STEAM	01-Jul-57	Public Service Company of New Hampshire	PSNH	NH	015	NH	NH	2367	50.050	47.948	47.820	47.948	47.820	0.603
559	SCHILLER CT 1	559	SCHILLER CT 1	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Nov-70	Public Service Company of New Hampshire	PSNH	NH	015	NH	NH	2367	21.250	18.500	17.621	18.500	17.621	0.000
561	SEARSBURG	561	SEARSBURG	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Mar-22	TransCanada Hydro Northeast Inc	TCHN	VT	003	WMA	WCMA	6529	4.500	4.567	4.451	4.567	4.451	0.000
562	SECREC-PRESTON	562	SECREC-PRESTON	ST	MSW		BIO/REFUSE	01-Jan-92	Covanta Energy Marketing, LLC	CEM	CT	011	CT	CT	10646	18.400	16.594	16.355	16.594	16.355	0.381
563	SEMASS 1	563	SEMASS 1	ST	MSW	DFO	BIO/REFUSE	01-Oct-88	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA	50290	58.050	49.986	48.881	49.986	48.881	0.169
564	SEMASS 2	564	SEMASS 2	ST	MSW	DFO	BIO/REFUSE	01-May-93	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA	50290	29.700	24.470	24.566	24.470	24.566	0.531
565	SHELDON SPRINGS	565	SHELDON SPRINGS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-88	Vermont Electric Power Company, Inc.	VELCO	VT	011	VT	VT	10494	21.660	9.605	0.749	9.605	0.749	-4.768
566	SHEPAUG	566	SHEPAUG	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-55	FirstLight Power Resource Management, LLC	NEL1	CT	009	SWCT	CT	552	49.997	42.559	41.511	42.523	41.511	0.000
567	SHERMAN	567	SHERMAN	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Dec-26	TransCanada Hydro Northeast Inc	TCHN	MA	015	WMA	WCMA	6012	8.100	6.220	6.154	6.220	6.154	0.000
568	SHREWSBURY DIESELS	35657	Shrewsbury Diesels	IC	DFO		OIL INTERNAL COMBUSTION	01-May-78	Shrewsbury Electric & Cable Operations	SELP	MA	027	CMA/NEMA	WCMA	6125	13.760	13.650	13.750	13.650	13.750	0.000
569	SKELTON	569	SKELTON	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-48	Brookfield White Pine Hydro LLC	FPLEMH	ME	031	SME	ME	1505	16.800	21.600	21.600	21.600	21.600	0.000
570	SMITH	570	SMITH	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-48	Public Service Company of New Hampshire	PSNH	NH	007	NH	NH	2368	15.000	15.779	6.473	15.779	6.473	-3.161
572	SO. MEADOW 11	572	SO. MEADOW 11	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Aug-70	NextEra Energy Power Marketing, LLC	FPLP	CT	003	CT	CT	563	41.850	46.921	35.781	46.921	35.781	0.000
573	SO. MEADOW 12	573	SO. MEADOW 12	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Aug-70	NextEra Energy Power Marketing, LLC	FPLP	CT	003	CT	CT	563	41.850	47.815	37.649	47.815	37.649	0.000
574	SO. MEADOW 13	574	SO. MEADOW 13	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Aug-70	NextEra Energy Power Marketing, LLC	FPLP	CT	003	CT	CT	563	41.850	47.917	37.838	47.917	37.838	-0.479
575	SO. MEADOW 14	575	SO. MEADOW 14	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Aug-70	NextEra Energy Power Marketing, LLC	FPLP	CT	003	CT	CT	563	41.850	46.346	36.746	46.346	36.746	0.000
580	SO. MEADOW 5	580	SO. MEADOW 5	ST	MSW		BIO/REFUSE	01-Nov-87	NextEra Energy Power Marketing, LLC	FPLP	CT	003	CT	CT	563	40.000	23.175	21.060	23.175	21.060	2.916
581	SO. MEADOW 6	581	SO. MEADOW 6	ST	MSW		BIO/REFUSE	01-Nov-87	NextEra Energy Power Marketing, LLC	FPLP	CT	003	CT	CT	563	40.000	23.076	24.768	23.076	24.768	1.926
583	STONY BROOK 2A	583	STONY BROOK 2A	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Nov-82	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	013	WMA	WCMA	6081	99.500	87.400	67.400	87.400	67.400	0.000
584	STONY BROOK 2B	584	STONY BROOK 2B	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Nov-82	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	013	WMA	WCMA	6081	99.500	85.300	65.300	85.300	65.300	0.000
587	STEVENSON	587	STEVENSON	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-19	FirstLight Power Resource Management, LLC	NEL1	CT	001	SWCT	CT	553	31.499	28.844	26.346	28.844	26.346	-1.965
590	REENERGY STRATTON	590	BORALEX STRATTON ENERGY	ST	WDS		BIO/REFUSE	01-Sep-89	ReEnergy Stratton LLC	REESTR	ME	007	ME	ME	50650	47.000	44.363	45.024	44.363	45.285	0.261
591	S.D. WARREN-WESTBROOK	591	S.D. WARREN-WESTBROOK	ST	WDS	RFO	BIO/REFUSE	01-Nov-97	NextEra Energy Power Marketing, LLC	FPLP	ME	005	SME	ME	50447	62.688	42.600	42.590	42.600	42.590	35.084
592	TAMWORTH	592	TAMWORTH	ST	WDS		BIO/REFUSE	01-Jan-88	Engie Energy Marketing NA, Inc	SUEZ	NH	003	NH	NH	50739	20.000	18.134	20.700	18.134	20.700	0.886
595	TORRINGTON TERMINAL 10	595	TORRINGTON TERMINAL 10	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Aug-67	NRG Power Marketing LLC	NRGPM	CT	005	CT	CT	565	18.594	20.748	15.638	20.748	15.638	0.000
596	TUNNEL 10	596	TUNNEL 10	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Jan-69	FirstLight Power Resource Management, LLC	NEL1	CT	011	CT	CT	557	17.500	18.114	15.788	18.114	15.788	-0.803
598	VERGENNES 5 AND 6 DIESELS	598	VERGENNES 5 and 6 DIESELS	IC	DFO		OIL INTERNAL COMBUSTION	01-Jan-64	Green Mountain Power Corporation	GMP	VT	001	VT	VT	6519	4.000	4.240	3.940	4.240	3.940	0.000
599	VERNON	599	VERNON	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-09	TransCanada Hydro Northeast Inc	TCHN	VT	025	WMA	WCMA	2352	34.560	32.000	32.000	32.000	32.000	0.000
612	WATERS RIVER JET 1	612	WATERS RIVER JET 1	GT	NG	DFO	GAS/OIL COMBUSTION (GAS) TURBINE	01-Dec-71	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	009	BOSTON	NEMA	1678	21.250	21.974	15.974	21.974	15.974	0.000
613	WATERS RIVER JET 2	613	WATERS RIVER JET 2	GT	NG	DFO	GAS/OIL COMBUSTION (GAS) TURBINE	01-Apr-91	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	009	BOSTON	NEMA	1678	41.921	40.000	0.000	40.000	0.000	-28.500
614	WATERBURY 22	614	WATERBURY 22	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-53	Green Mountain Power Corporation	GMP	VT	023	VT	VT	6520	5.520	5.000	2.646	5.000	2.646	-2.354
616	WEST ENFIELD	616	WEST ENFIELD	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-88	New Brunswick Energy Marketing Corporation	NBPGC	ME	019	BHE	ME	10255	13.000	13.979	6.335	13.979	6.335	-2.983
617	WESTON	617	WESTON	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-20	Brookfield White Pine Hydro LLC	FPLEMH	ME	017	ME	ME	1509	15.542	10.895	5.417	10.895	5.417	-2.728
618	DG WHITEFIELD, LLC	618	DG WHITEFIELD, LLC	ST	WDS		BIO/REFUSE	01-Apr-88	Springfield Power, LLC	SPRING	NH	007	NH	NH	10839	17.680	16.347	16.770	16.347	16.770	0.768
619	WHITE LAKE JET	619	WHITE LAKE JET	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Aug-68	Public Service Company of New Hampshire	PSNH	NH	003	NH	NH	2369	18.594	22.397	17.447	22.397	17.447	0.000
620	WILDER	620	WILDER	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-50	TransCanada Hydro Northeast Inc	TCHN	VT	027	VT	NH	2353	35.640	40.698	39.083	40.698	39.083	0.000
621	WILLIAMS	621	WILLIAMS	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-39	Brookfield White Pine Hydro LLC	FPLEMH	ME	025	ME	ME	1510	13.018	14.855	14.900	14.855	14.900	0.000
622	WINOOSKI 1	622	WINOOSKI 1	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-93	Burlington Electric Department	BED	VT	007	VT	VT	54355	7.425	3.700	0.891	3.700	0.891	-1.464
623	COVANTA PROJECTS WALLINGFORD	623	WALLINGFORD REFUSE	ST	MSW	DFO	BIO/REFUSE	01-Mar-89	Covanta Projects of Wallingford, L.P.	CPW	CT	009	SWCT	CT	50664	11.000	0.000	0.000	0.000	0.000	0.000
624	WMI MILLBURY 1	624	WMI MILLBURY 1	ST	MSW		BIO/REFUSE	01-Sep-87	New England Power Company	NEP	MA	027	CMA/NEMA	WCMA	50878	42.840	39.891	39.811	39.891	39.811	0.000
625	WEST MEDWAY JET 1	625	WEST MEDWAY JET 1	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Jul-70	Exelon Generation Company, LLC	EXGC	MA	021	BOSTON	NEMA	1592	55.080	62.915	42.000	62.915	42.000	0.000
626	WEST MEDWAY JET 2	626	WEST MEDWAY JET 2	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Mar-71	Exelon Generation Company, LLC	EXGC	MA	021	BOSTON	NEMA	1592	55.080	61.598	39.848	61.598	39.848	0.000
627	WEST MEDWAY JET 3	627	WEST MEDWAY JET 3	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Jul-70	Exelon Generation Company, LLC	EXGC	MA	021	RI	SEMA	1592	55.080	60.742	42.001	60.742	42.001	0.000
628	WOODLAND ROAD	628	WOODLAND ROAD	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Jul-69	Essential Power Massachusetts, LLC	NAEA-EM	MA	003	WMA	WCMA	1643	18.594	20.658	15.808	20.658	15.808	0.000
630	WEST SPRINGFIELD 10	630	WEST SPRINGFIELD 10	GT	KER		OIL COMBUSTION (GAS) TURBINE	01-Jan-68	Essential Power Massachusetts, LLC	NAEA-EM	MA	013	WMA	WCMA	1642	18.594	21.928	16.629	21.928	16.629	-0.184
633	WEST SPRINGFIELD 3	633	WEST SPRINGFIELD 3	ST	NG	RFO	GAS/OIL STEAM	01-Jan-57	Essential Power Massachusetts, LLC	NAEA-EM	MA	013	WMA	WCMA	1642	113.636	100.087	94.276	100.087	94.276	0.000
636	WYMAN HYDRO 1	636	WYMAN HYDRO 1	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-30	Brookfield White Pine Hydro LLC	FPLEMH	ME	025	ME	ME	1511	27.000	28.046	29.120	28.046	29.120	1.758
637	WYMAN HYDRO 2	637	WYMAN HYDRO 2	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-31	Brookfield White Pine Hydro LLC	FPLEMH	ME	025	ME	ME	1511	32.818	29.900	29.900	29.900	29.900	0.034
638	WYMAN HYDRO 3	638	WYMAN HYDRO 3	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-40	Brookfield White Pine Hydro LLC	FPLEMH	ME	025	ME	ME	1511	29.700	26.480	28.854	26.480	28.854	3.306
639	YARMOUTH 1	639	YARMOUTH 1	ST	RFO		OIL STEAM	01-Jan-57	NextEra Energy Power Marketing, LLC	FPLP	ME	005	SME	ME	1507	50.000	49.510	50.065	49.510	50.065	0.000
640	YARMOUTH 2	640	YARMOUTH 2	ST	RFO		OIL STEAM	01-Jan-58	NextEra Energy Power Marketing, LLC	FPLP	ME	005	SME	ME	1507	55.118	52.823	48.410	52.823	48.410	0.555
641	YARMOUTH 3	641	YARMOUTH 3	ST	RFO		OIL STEAM	01-Jul-65	NextEra Energy Power Marketing, LLC	FPLP	ME	005	SME	ME	1507	125.668	113.780	110.870	113.780	110.870	0.000
642	YARMOUTH 4	642	YARMOUTH 4	ST	RFO		OIL STEAM	01-Dec-78	NextEra Energy Power Marketing, LLC	FPLP	ME	005	SME	ME	1507	632.400	605.875	602.050	605.875	602.050	0.000
715	ROCHESTER LANDFILL	715	ROCHESTER LANDFILL	GT	LFG		BIO/REFUSE	01-May-98	WM Renewable Energy, L.L.C.	WMRE	NH	017	NH	NH	2007	4.999	2.244	2.055	2.244	2.055	-0.071
737	SIMPSON G LOAD REDUCER	737	SIMPSON G LOAD REDUCER	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-80	Green Mountain Power Corporation	GMP	VT	009	NH	VT	10608	4.850	3.474	1.692	3.474	1.692	-0.965
739	ROCKY RIVER	739	ROCKY RIVER	PS	WAT		HYDRO (PUMPED STORAGE)	01-Jan-28	FirstLight Power Resource Management, LLC	NEL1	CT	009	SWCT	CT	539	35.840	25.946	27.904	28.127	27.904	-0.891
754	BAR MILLS	754	BAR MILLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-56	Brookfield White Pine Hydro LLC	FPLEMH	ME	031	SME	ME	1481	4.000	1.350	0.000	1.350	0.000	0.000
755	BONNY EAGLE/W. BUXTON	755	BONNY EAGLE W. BUXTON	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-10	Brookfield White Pine Hydro LLC	FPLEMH	ME	031	SME	ME	1482, 1508	15.127	11.756	2.020	11.756	2.020	-1.068
757	HARRIS 4	757	HARRIS 4	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-54	Brookfield White Pine Hydro LLC	FPLEMH	ME	025	ME	ME	1492	1.400	1.249	1.436	1.249	1.436	0.000
759	MESSALONSKEE COMPOSITE	759	MESSALONSKEE COMPOSITE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-17	Littleton Electric Light & Water Department	LELWD	ME	011	ME	ME	1497	5.866	3.974	0.000	3.974	0.000	0.000
760	NORTH GORHAM	760	NORTH GORHAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-25	Brookfield White Pine Hydro LLC	FPLEMH	ME	005	SME	ME	1501	2.850	1.470	0.712	1.470	0.712	-0.124
761	SHAWMUT	761	SHAWMUT	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-13	Brookfield White Pine Hydro LLC	FPLEMH	ME	011	ME	ME	1504	8.856	7.025	3.086	7.025	3.086	-2.416
767	SES CONCORD	767	SES CONCORD	ST	MSW		BIO/REFUSE	01-May-89	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH	50873	15.753	12.360	11.816	12.360	11.816	-0.234
768	GARVINS/HOOKSETT	768	GARVINS HOOKSETT	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-02	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH	2357, 2359	13.530	7.087	0.000	7.087	0.000	-2.532
769	HADLEY FALLS 1&2	769	HADLEY FALLS 1&2	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-83	Holyoke Gas & Electric Department	HGE	MA	013	WMA	WCMA	1605	31.095	15.095	0.000	15.095	0.000	0.000
772	NEWPORT HYDRO	772	NEWPORT HYDRO	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-80	Green Mountain Power Corporation	GMP	VT	019	NH	VT	3731	4.500	2.240	0.305	2.240	0.305	-1.721

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
774	LOWER LAMOILLE COMPOSITE	774	LOWER LAMOILLE COMPOSITE	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-48	Green Mountain Power Corporation	GMP	VT	007	VT	VT	3711	16.848	16.000	15.800	16.000	15.800	0.000
775	MIDDLEBURY COMPOSITE	775	MIDDLEBURY COMPOSITE	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-17	Green Mountain Power Corporation	GMP	VT	001	VT	VT	3716	5.200	5.724	1.666	5.724	1.666	-5.084
776	N. RUTLAND COMPOSITE	776	N. RUTLAND COMPOSITE	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-80	Green Mountain Power Corporation	GMP	VT	021	VT	VT	3714	4.480	4.155	4.503	4.155	4.503	0.000
779	MIDDLESEX 2	779	MIDDLESEX 2	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-28	Green Mountain Power Corporation	GMP	VT	023	VT	VT	3740	2.640	1.202	0.000	1.202	0.000	-1.202
781	WEST DANVILLE 1	781	WEST DANVILLE 1	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-86	Green Mountain Power Corporation	GMP	VT	005	VT	VT	3743	2.273	0.392	0.000	0.392	0.000	0.000
783	HIGHGATE FALLS	783	HIGHGATE FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-80	Vermont Public Power Supply Authority	VPPSA	VT	011	VT	VT	6618	9.583	8.791	1.033	8.791	1.033	-5.615
789	CEC 002 PAWTUCKET U5	789	CEC 002 PAWTUCKET U5	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-85	The Narragansett Electric Company	NEC	RI	007	RI	RI	3233	3.454	0.588	0.000	0.588	0.000	0.000
792	CENTENNIAL HYDRO	792	CENTENNIAL HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-90	Sterling Municipal Electric Light Department	SMED	MA	017	CMA/NEMA	WCMA	7112	0.790	0.557	0.000	0.557	0.000	0.000
793	METHUEN HYDRO	793	METHUEN HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Aug-88	Sterling Municipal Electric Light Department	SMED	MA	009	BOSTON	NEMA		0.273	0.104	0.000	0.104	0.000	0.000
794	MINIWAWA	794	MINIWAWA	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-92	Public Service Company of New Hampshire	PSNH	NH	005	VT	NH		1.000	0.639	0.000	0.639	0.000	-0.110
795	RIVER MILL HYDRO	795	RIVER MILL HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jun-89	Middleton Municipal Light Department	MMELD	NH	009	VT	NH	3049	0.200	0.111	0.000	0.111	0.000	0.000
796	GOODWIN DAM	796	GOODWIN DAM	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Feb-86	Connecticut Municipal Electric Energy Cooperative	CMEEC	CT	003	CT	CT	54302	3.300	3.000	3.000	3.000	3.000	0.000
797	WYRE WYND HYDRO	797	CEC 003 WYRE WYND U5	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-97	Gravity Renewables, Inc	GRRN	CT	011	CT	CT		2.780	1.205	0.077	1.205	0.077	-0.004
798	COLEBROOK	798	COLEBROOK	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-88	Connecticut Light and Power Company, The	CLP	CT	005	CT	CT	54301	3.000	0.120	0.000	0.120	0.000	-0.846
800	KINNEYTOWN B	800	KINNEYTOWN B	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-86	CHI Power Marketing, Inc.	CHIPM	CT	009	SWCT	CT	54385	1.510	0.331	0.000	0.331	0.000	-0.047
801	WILLIMANTIC 1	801	WILLIMANTIC 1	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jun-90	Connecticut Light and Power Company, The	CLP	CT	015	CT	CT		0.770	0.188	0.000	0.188	0.000	0.000
802	WILLIMANTIC 2	802	WILLIMANTIC 2	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jun-90	Connecticut Light and Power Company, The	CLP	CT	015	CT	CT		0.770	0.000	0.000	0.000	0.000	0.000
803	TOUTANT	803	TOUTANT	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-94	Connecticut Light and Power Company, The	CLP	CT	015	CT	CT		0.500	0.082	0.000	0.082	0.000	-0.251
804	PUTNAM	804	PUTNAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Oct-87	Putnam Hydropower, Inc.	PUTNAM	CT	015	CT	CT		1.940	0.311	0.000	0.311	0.000	0.000
806	MECHANICSVILLE	806	MECHANICSVILLE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Sep-95	Sterling Municipal Electric Light Department	SMED	CT	015	CT	CT		0.290	0.101	0.000	0.101	0.000	0.000
807	CEC 004 DAYVILLE POND U5	807	CEC 004 DAYVILLE POND U5	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-95	Connecticut Light and Power Company, The	CLP	CT	015	CT	CT		0.100	0.037	0.000	0.037	0.000	0.000
808	SANDY HOOK HYDRO	808	SANDY HOOK HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-89	Connecticut Light and Power Company, The	CLP	CT	001	SWCT	CT		0.190	0.039	0.000	0.039	0.000	0.000
809	PINCHBECK	809	PINCHBECK	ST	WDS		BIO/REFUSE	01-Jul-87	Connecticut Light and Power Company, The	CLP	CT	009	CT	CT		0.150	0.000	0.000	0.000	0.000	0.000
810	QUINEBAUG	810	QUINEBAUG	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Sep-90	Connecticut Light and Power Company, The	CLP	CT	015	CT	CT	543	2.810	0.715	0.037	0.715	0.037	0.000
811	BANTAM	811	BANTAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-05	FirstLight Power Resource Management, LLC	NEL1	CT	005	CT	CT	6457	0.320	0.000	0.000	0.000	0.000	0.000
812	BEEBE HOLBROOK	812	BEEBE HOLBROOK	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-48	Holyoke Gas & Electric Department	HGE	MA	013	WMA	WCMA	1602	0.533	0.165	0.000	0.165	0.000	-0.144
813	TUNNEL	813	TUNNEL	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-19	FirstLight Power Resource Management, LLC	NEL1	CT	011	CT	CT	557	2.122	1.023	0.000	1.023	0.000	0.000
814	PATCH	814	PATCH	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-00	Green Mountain Power Corporation	GMP	VT	021	VT	VT	3719	1.050	0.000	0.000	0.000	0.000	0.000
815	CARVER FALLS	815	CARVER FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	25-Sep-98	Green Mountain Power Corporation	GMP	VT	021	VT	VT	6456	2.496	0.821	0.000	0.821	0.000	0.000
816	CAVENDISH	816	CAVENDISH	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	25-Sep-98	Green Mountain Power Corporation	GMP	VT	027	VT	VT	3710	2.591	0.544	0.000	0.544	0.000	-0.159
817	TAFTSVILLE VT	817	TAFTSVILLE VT	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-00	Green Mountain Power Corporation	GMP	VT	027	VT	VT	3727	0.676	0.150	0.000	0.150	0.000	-0.060
818	PIERCE MILLS	818	PIERCE MILLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-00	Green Mountain Power Corporation	GMP	VT	005	NH	VT	3721	0.400	0.164	0.000	0.164	0.000	-0.161
819	ARNOLD FALLS	819	ARNOLD FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	25-Sep-98	Green Mountain Power Corporation	GMP	VT	005	NH	VT	3707	3.640	0.194	0.000	0.194	0.000	-0.140
820	PASSUMPSIC	820	PASSUMPSIC	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-00	Green Mountain Power Corporation	GMP	VT	005	NH	VT	3718	1.000	0.264	0.015	0.264	0.015	0.015
821	GAGE	821	GAGE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-00	Green Mountain Power Corporation	GMP	VT	005	NH	VT	3713	0.900	0.366	0.000	0.366	0.000	-0.297
822	SMITH (CVPS)	822	SMITH (CVPS)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-00	Green Mountain Power Corporation	GMP	VT	017	VT	VT	3709	2.484	0.513	0.096	0.513	0.096	-0.506
823	EAST BARNET	823	EAST BARNET	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-00	Green Mountain Power Corporation	GMP	VT	005	NH	VT	788	2.700	1.183	0.000	1.183	0.000	-0.907
824	BATH ELECTRIC HYDRO	824	BATH ELECTRIC HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jun-85	Public Service Company of New Hampshire	PSNH	NH	009	NH	NH		0.800	0.295	0.183	0.295	0.183	-0.021
827	SEARSBURG WIND	827	SEARSBURG WIND	WT	WND		WIND TURBINE	01-Jul-97	Green Mountain Power Corporation	GMP	VT	003	WMA	WCMA	7381	1.690	1.055	0.193	1.055	0.193	0.047
828	BARTON HYDRO	828	BARTON HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jul-31	Vermont Public Power Supply Authority	VPPSA	VT	019	NH	VT	3753	1.400	0.000	0.000	0.000	0.000	-0.352
830	ENOSBURG HYDRO	830	ENOSBURG HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-80	Vermont Public Power Supply Authority	VPPSA	VT	011	VT	VT	3757	0.998	0.140	0.000	0.140	0.000	-0.432
831	VAIL & GREAT FALLS	831	VAIL & GREAT FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-80	Vermont Public Power Supply Authority	VPPSA	VT	005	NH	VT	3726	1.708	0.000	0.000	0.000	0.000	-0.291
832	CENTER RUTLAND	832	CENTER RUTLAND	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Aug-01	Green Mountain Power Corporation	GMP	VT	021	VT	VT	6453	1.100	0.000	0.000	0.000	0.000	0.000
833	BARNET	833	BARNET	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-01	Green Mountain Power Corporation	GMP	VT	005	VT	VT		0.490	0.159	0.000	0.159	0.000	-0.143
834	COMTU FALLS	834	COMPTU FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-82	Green Mountain Power Corporation	GMP	VT	027	VT	VT		0.460	0.398	0.000	0.398	0.000	-0.096
835	DEWEY MILLS	835	DEWEY MILLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-01	Green Mountain Power Corporation	GMP	VT	027	VT	VT	10137	2.850	0.584	0.000	0.584	0.000	0.000
836	EMERSON FALLS	836	EMERSON FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Oct-85	Green Mountain Power Corporation	GMP	VT	005	NH	VT		2.300	0.015	0.000	0.015	0.000	0.000
837	KILLINGTON	837	KILLINGTON	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-95	Green Mountain Power Corporation	GMP	VT	021	VT	VT		0.120	0.012	0.000	0.012	0.000	0.000
839	LADD'S MILL	839	LADD'S MILL	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Oct-86	Green Mountain Power Corporation	GMP	VT	023	VT	VT		0.170	0.057	0.000	0.057	0.000	-0.013
840	MARTINSVILLE	840	MARTINSVILLE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-86	Green Mountain Power Corporation	GMP	VT	027	VT	VT		0.280	0.117	0.000	0.117	0.000	-0.024
841	MORETOWN 8	841	MORETOWN 8	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-89	Green Mountain Power Corporation	GMP	VT	023	VT	VT	52033	1.130	0.308	0.000	0.308	0.000	-0.128
842	NANTANA MILL	842	NANTANA MILL	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-86	Green Mountain Power Corporation	GMP	VT	023	VT	VT		0.220	0.089	0.000	0.089	0.000	-0.034
843	NEWBURY	843	NEWBURY	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-88	Green Mountain Power Corporation	GMP	VT	017	VT	VT		0.270	0.193	0.000	0.193	0.000	-0.105
844	OTTAUQUECHEE	844	OTTAUQUECHEE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Sep-87	Green Mountain Power Corporation	GMP	VT	027	VT	VT	50126	2.230	0.381	0.000	0.381	0.000	-0.306
845	SLACK DAM	845	SLACK DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-88	Green Mountain Power Corporation	GMP	VT	027	VT	VT		0.410	0.289	0.000	0.289	0.000	-0.082
846	WINOOSKI 8	846	WINOOSKI 8	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-85	Green Mountain Power Corporation	GMP	VT	023	VT	VT		0.950	0.295	0.000	0.295	0.000	-0.312
847	WOODSIDE	847	WOODSIDE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-87	Green Mountain Power Corporation	GMP	VT	015	VT	VT		0.120	0.040	0.000	0.040	0.000	-0.038
848	WRIGHTSVILLE	848	WRIGHTSVILLE	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-85	Vermont Public Power Supply Authority	VPPSA	VT	023	VT	VT	7051	1.105	0.055	0.000	0.055	0.000	-0.211
849	CRESCENT DAM	849	CRESCENT DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-93	CHI Power Marketing, Inc.	CHIPM	MA	013	WMA	WCMA		1.644	0.616	0.000	0.616	0.000	-0.291
850	GLENDALE HYDRO	850	GLENDALE HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-89	CHI Power Marketing, Inc.	CHIPM	MA	003	WMA	WCMA		1.290	0.635	0.077	0.635	0.077	-0.268
851	GARDNER FALLS	851	GARDNER FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-24	Essential Power Massachusetts, LLC	NAEA-EM	MA	011	WMA	WCMA	1634	3.649	0.000	0.000	0.000	0.000	0.000
852	SOUTH BARRE HYDRO	852	SOUTH BARRE HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Oct-89	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	027	WMA	WCMA		0.150	0.088	0.000	0.088	0.000	0.000
853	WEBSTER HYDRO	853	WEBSTER HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-83	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	027	CMA/NEMA	WCMA	10404	0.150	0.000	0.000	0.000	0.000	0.000
854	ORANGE HYDRO 1	854	ORANGE HYDRO 1	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Aug-87	Templeton Municipal Lighting Plant	TTMLP	MA	011	WMA	WCMA		0.350	0.000	0.000	0.000	0.000	0.000
855	ORANGE HYDRO 2	855	ORANGE HYDRO 2	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-93	Templeton Municipal Lighting Plant	TTMLP	MA	011	WMA	WCMA		0.350	0.174	0.000	0.174	0.000	-0.061
856	HUNT'S POND	856	HUNT'S POND	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Aug-96	Templeton Municipal Lighting Plant	TTMLP	MA	027	WMA	WCMA		0.120	0.043	0.000	0.043	0.000	0.000
857	OAKDALE HYDRO	857	OAKDALE HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jul-94	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA	10824	3.000	0.000	0.000	0.000	0.000	-2.699
859	BOATLOCK	859	BOATLOCK	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-24	Holyoke Gas & Electric Department	HGE	MA	013	WMA	WCMA	1603	3.118	2.353	0.000	2.353	0.000	-2.431
860	BRIAR HYDRO	860	BRIAR HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-88	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH	50351	6.000	2.813	0.000	2.813	0.000	-0.308
861	CANAAN	861	CANAAN	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-27	Public Service Company of New Hampshire	PSNH	VT	009	NH	NH	3750	1.168	0.948	0.349	0.948	0.349	-0.655

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	As of Jan. 2017 SCC Report SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
862	CHEMICAL	862	CHEMICAL	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-35	Holyoke Gas & Electric Department	HGE	MA	013	WMA	WCMA	1604	1.609	0.878	0.000	0.878	0.000	-1.113
863	CLEMENT DAM	863	CLEMENT DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-85	Massachusetts Municipal Wholesale Electric Company	MMWEC	NH	001	NH	NH	10276	2.400	1.096	0.000	1.096	0.000	-0.590
864	DWIGHT	864	DWIGHT	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-20	Essential Power Massachusetts, LLC	NAEA-EM	MA	013	WMA	WCMA	6378	1.746	0.000	0.000	0.000	0.000	0.000
865	ERROL	865	ERROL	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-86	Public Service Company of New Hampshire	PSNH	NH	007	NH	NH	10570	3.000	2.141	1.463	2.141	1.463	-0.429
866	GREGGS	866	GREGGS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-86	Massachusetts Municipal Wholesale Electric Company	MMWEC	NH	011	NH	NH	50384	3.510	1.052	0.000	1.052	0.000	-0.226
867	INDIAN ORCHARD	867	INDIAN ORCHARD	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-28	Essential Power Massachusetts, LLC	NAEA-EM	MA	013	WMA	WCMA	6379	3.330	0.172	0.000	0.172	0.000	0.000
868	MILTON MILLS HYDRO	868	MILTON MILLS HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-29	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH	10519	1.510	0.997	0.000	0.997	0.000	-0.196
869	MINE FALLS	869	MINE FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-85	Power Supply Services, LLC	PSS	NH	011	NH	NH	10183	3.000	0.957	0.000	0.957	0.000	-0.146
870	PEMBROKE	870	PEMBROKE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-86	Massachusetts Municipal Wholesale Electric Company	MMWEC	NH	013	NH	NH	50312	2.600	1.106	0.000	1.106	0.000	0.000
871	PENNACOOK FALLS LOWER	871	PENNACOOK FALLS LOWER	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-84	Unitil Energy Systems, Inc.	UNITIL-ES	NH	013	NH	NH	50351	4.000	2.904	0.000	2.904	0.000	-0.368
872	PENNACOOK FALLS UPPER	872	PENNACOOK FALLS UPPER	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-86	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH	50414	3.120	1.869	0.000	1.869	0.000	-0.344
873	PUTTS BRIDGE	873	PUTTS BRIDGE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-18	Essential Power Massachusetts, LLC	NAEA-EM	MA	013	WMA	WCMA	1637	4.101	1.975	0.000	1.975	0.000	0.000
874	RED BRIDGE	874	RED BRIDGE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-26	Essential Power Massachusetts, LLC	NAEA-EM	MA	013	WMA	WCMA	1638	4.532	0.869	0.000	0.869	0.000	0.000
875	RIVER BEND	875	RIVER BEND	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-86	Massachusetts Municipal Wholesale Electric Company	MMWEC	NH	013	NH	NH		1.790	1.185	0.283	1.185	0.283	-0.220
876	ROBERTSVILLE	876	ROBERTSVILLE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-24	FirstLight Power Resource Management, LLC	NEL1	CT	003	CT	CT	549	0.624	0.000	0.000	0.000	0.000	0.000
877	SCOTLAND	877	SCOTLAND	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-37	FirstLight Power Resource Management, LLC	NEL1	CT	015	CT	CT	551	2.250	0.000	0.000	0.000	0.000	0.000
878	SKINNER	878	SKINNER	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-24	Holyoke Gas & Electric Department	HGE	MA	013	WMA	WCMA	1608	0.280	0.251	0.000	0.251	0.000	-0.252
879	TAFTVILLE CT	879	TAFTVILLE CT	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-06	FirstLight Power Resource Management, LLC	NEL1	CT	011	CT	CT	554	1.874	0.686	0.000	0.686	0.000	0.000
882	FRANKLIN FALLS	882	FRANKLIN FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-78	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH	10109	0.800	0.487	0.306	0.487	0.306	-0.031
883	SALMON FALLS HYDRO	883	SALMON FALLS HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-83	CHI Power Marketing, Inc.	CHIPM	NH	017	SME	ME	50702	1.200	0.424	0.000	0.424	0.000	0.000
884	SWANS FALLS	884	SWANS FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Oct-98	Public Service Company of New Hampshire	PSNH	ME	017	NH	NH	1518	0.400	0.395	0.121	0.395	0.121	-0.160
886	COCHECO FALLS	886	COCHECO FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-83	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH		0.710	0.256	0.000	0.256	0.000	0.000
887	CHINA MILLS DAM	887	CHINA MILLS DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Oct-81	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH	50103	0.900	0.449	0.000	0.449	0.000	0.000
888	NEWFOUND HYDRO	888	NEWFOUND HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-83	Power Supply Services, LLC	PSS	NH	009	NH	NH	50324	1.966	0.775	0.000	0.775	0.000	-0.112
889	SUNAPEE HYDRO	889	SUNAPEE HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-85	Public Service Company of New Hampshire	PSNH	NH	019	NH	NH		0.650	0.244	0.000	0.244	0.000	-0.089
890	NASHUA HYDRO	890	NASHUA HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-84	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH		0.840	0.491	0.000	0.491	0.000	-0.104
891	HILLSBORO MILLS	891	HILLSBORO MILLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-88	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH	10036	0.570	0.132	0.000	0.132	0.000	0.000
892	LAKEPORT DAM	892	LAKEPORT DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-83	Power Supply Services, LLC	PSS	NH	001	NH	NH		0.720	0.288	0.138	0.288	0.138	-0.012
893	WEST HOPKINTON HYDRO	893	WEST HOPKINTON HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-82	CHI Power Marketing, Inc.	CHIPM	NH	013	NH	NH	54384	1.250	0.420	0.000	0.420	0.000	0.000
894	LISBON HYDRO	894	LISBON HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-86	Public Service Company of New Hampshire	PSNH	NH	009	NH	NH		0.515	0.322	0.153	0.322	0.153	-0.094
895	LOWER ROBERTSON DAM	895	LOWER ROBERTSON DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-87	Massachusetts Municipal Wholesale Electric Company	MMWEC	NH	005	VT	NH		0.900	0.592	0.000	0.592	0.000	-0.192
897	OLD NASH DAM	897	OLD NASH DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-84	Public Service Company of New Hampshire	PSNH	NH	005	VT	NH		0.230	0.038	0.000	0.038	0.000	0.000
898	SUGAR RIVER HYDRO	898	SUGAR RIVER HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Sep-86	Public Service Company of New Hampshire	PSNH	NH	019	NH	NH		0.158	0.127	0.000	0.127	0.000	0.000
900	GREAT FALLS LOWER	900	GREAT FALLS LOWER	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jun-84	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH	50704	1.100	0.547	0.000	0.547	0.000	0.000
901	WATERLOOM FALLS	901	WATERLOOM FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Oct-81	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH		0.110	0.022	0.000	0.022	0.000	0.000
902	HOSIERY MILL DAM	902	HOSIERY MILL DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jul-84	Swift River Trading Company LLC	SRTC	NH	011	NH	NH		1.250	0.396	0.000	0.396	0.000	0.000
903	WYANDOTTE HYDRO	903	WYANDOTTE HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-83	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH		0.150	0.047	0.000	0.047	0.000	0.000
904	LOCHMERE DAM	904	LOCHMERE DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-84	Massachusetts Municipal Wholesale Electric Company	MMWEC	NH	001	NH	NH	54572	1.030	0.504	0.198	0.504	0.198	0.000
905	ASHUELOT HYDRO	905	ASHUELOT HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-87	Massachusetts Municipal Wholesale Electric Company	MMWEC	NH	005	VT	NH		0.930	0.482	0.000	0.482	0.000	-0.205
906	ROLLINSFORD HYDRO	906	ROLLINSFORD HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-80	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH	54418	1.500	0.743	0.000	0.743	0.000	0.000
908	OTIS MILL HYDRO	908	OTIS MILL HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-82	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH	50080	0.150	0.022	0.000	0.022	0.000	0.000
909	STEELS POND HYDRO	909	STEELS POND HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-84	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH		0.980	0.385	0.043	0.385	0.043	-0.002
910	CAMPTON DAM	910	CAMPTON DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-85	Public Service Company of New Hampshire	PSNH	NH	009	NH	NH		0.470	0.111	0.000	0.111	0.000	-0.096
911	KELLEYS FALLS	911	KELLEYS FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jun-89	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH		0.429	0.276	0.000	0.276	0.000	0.000
913	GOODRICH FALLS	913	GOODRICH FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jun-81	New Hampshire Electric Cooperative, Inc.	NHEC	NH	003	NH	NH		0.500	0.244	0.016	0.244	0.016	-0.098
914	CHAMBERLAIN FALLS	914	CHAMBERLAIN FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-83	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH		0.130	0.000	0.000	0.000	0.000	0.000
915	MONADNOCK PAPER MILLS	915	MONADNOCK PAPER MILLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jun-75	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH		1.950	0.000	0.000	0.000	0.000	0.000
919	HOPKINTON HYDRO	919	HOPKINTON HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-84	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH		0.250	0.187	0.000	0.187	0.000	-0.111
922	NOONE FALLS	922	NOONE FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-85	Public Service Company of New Hampshire	PSNH	NH	011	VT	NH		0.150	0.000	0.000	0.000	0.000	0.000
925	OTTER LANE HYDRO	925	OTTER LANE HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-84	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH		0.090	0.056	0.000	0.056	0.000	0.000
926	PETERBOROUGH LOWER HYDRO	926	PETERBOROUGH LOWER HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-89	Public Service Company of New Hampshire	PSNH	NH	011	VT	NH		0.280	0.147	0.000	0.147	0.000	-0.010
928	SALMON BROOK STATION 3	928	SALMON BROOK STATION 3	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-85	Public Service Company of New Hampshire	PSNH	NH	013	NH	NH		0.326	0.126	0.000	0.126	0.000	0.000
931	AVERY DAM	931	AVERY DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-85	Public Service Company of New Hampshire	PSNH	NH	001	NH	NH		0.479	0.206	0.156	0.206	0.156	0.002
932	WATSON DAM	932	WATSON DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-85	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH		0.250	0.157	0.000	0.157	0.000	0.000
933	WESTON DAM	933	WESTON DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-87	Public Service Company of New Hampshire	PSNH	NH	007	NH	NH	1509	0.524	0.405	0.123	0.405	0.123	-0.072
935	SUNNYBROOK HYDRO 2	935	SUNNYBROOK HYDRO 2	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-82	Public Service Company of New Hampshire	PSNH	NH	007	NH	NH		0.050	0.012	0.007	0.012	0.007	-0.010
941	PETERBOROUGH UPPER HYDRO	941	PETERBOROUGH UPPER HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-90	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH		0.400	0.116	0.000	0.116	0.000	-0.004
943	FOUR HILLS LANDFILL	943	FOUR HILLS LANDFILL	IC	LFG		BIO/REFUSE	01-Apr-96	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH		0.800	0.537	1.523	0.537	1.523	0.790
947	RIVERDALE MILLS - QF	947	RIVERDALE MILLS - QF	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jul-85	Massachusetts Electric Company	MEC	MA	027	RI	SEMA	50601	0.180	0.000	0.000	0.000	0.000	0.000
948	PEPPERELL HYDRO COMPANY LLC	948	PEPPERELL HYDRO COMPANY LLC	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-20	Power Supply Services, LLC	PSS	MA	017	CMA/NEMA	WCMA	10694	1.600	0.691	0.000	0.691	0.000	-0.165
949	VALLEY HYDRO - QF	949	VALLEY HYDRO - QF	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-84	The Narragansett Electric Company	NEC	RI	003	RI	RI		0.450	0.000	0.000	0.000	0.000	0.000
950	LP ATHOL - QF	950	LP ATHOL - QF	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-31	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.500	0.080	0.000	0.080	0.000	0.000
951	BALTIC MILLS - QF	951	BALTIC MILLS - QF	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-81	Sterling Municipal Electric Light Department	SMED	NH	009	VT	NH		0.300	0.067	0.000	0.067	0.000	-0.011
953	ATTLEBORO LANDFILL - QF	953	ATTLEBORO LANDFILL - QF	IC	OBG		BIO/REFUSE	01-Nov-97	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		1.700	0.096	0.000	0.096	0.000	-0.096
954	MM LOWELL LANDFILL - QF	954	MM LOWELL LANDFILL - QF	IC	LFG		BIO/REFUSE	01-Aug-97	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA	55095	1.500	0.000	0.000	0.000	0.000	0.000
957	HG&E HYDRO/CABOT 1-4	957	HG&E HYDRO CABOT 1-4	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-80	Holyoke Gas & Electric Department	HGE	MA	013	WMA	WCMA	9864	2.675	1.235	0.367	1.235	0.367	-0.950
959	BARTON 1-4 DIESELS	959	BARTON 1-4 DIESELS	IC	DFO		OIL INTERNAL COMBUSTION	01-Jul-56	Vermont Public Power Supply Authority	VPPSA	VT	019	NH	VT	3753	4.400	0.000	0.000	0.000	0.000	0.000
969	POWDER MILL HYDRO	969	POWDER MILL HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-90	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	027	WMA	WCMA		0.130	0.000	0.000	0.000	0.000	0.000
970	DUDLEY HYDRO	970	DUDLEY HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Oct-87	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.324	0.068	0.000	0.068	0.000	0.000
973	CONCORD STEAM		No Resource (1)	ST	WDS		BIO/REFUSE	01-Oct-86	Unitil Energy Systems, Inc.	UNITIL-ES	NH	013	NH	NH		1.300	0.173	0.000	0.173	0.000	0.000

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
978	NEW MILFORD	978	NEW MILFORD	IC	OBG	DFO	BIO/REFUSE	01-Aug-91	Connecticut Light and Power Company, The	CLP	CT	005	SWCT	CT	50564	3.200	1.070	0.991	1.070	0.991	-0.049
1005	DIGHTON POWER LLC	1005	BG DIGHTON POWER LLC	CC	NG		GAS COMBINED CYCLE	01-May-99	Dynegy Marketing and Trade, LLC	DMT1	MA	005	SEMA	SEMA	55026	170.000	185.000	160.539	185.000	160.539	0.000
1028	BUNKER RD #12 GAS TURB	1028	BUNKER RD #12 GAS TURB	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Apr-00	New England Power Company	NEP	MA	019	SEMA	SEMA	1615	3.775	3.012	2.351	3.012	2.351	0.000
1029	BUNKER RD #13 GAS TURB	1029	BUNKER RD #13 GAS TURB	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-Apr-00	New England Power Company	NEP	MA	019	SEMA	SEMA	1615	3.840	3.281	2.806	3.281	2.806	0.000
1030	OAK BLUFFS	1030	OAK BLUFFS	IC	KER		OIL INTERNAL COMBUSTION	01-Jan-70	Genon Energy Management, LLC	MET	MA	007	SEMA	SEMA	1597	7.500	8.120	7.471	8.120	7.471	0.000
1031	WEST TISBURY	1031	WEST TISBURY	IC	KER		OIL INTERNAL COMBUSTION	01-Jan-75	Genon Energy Management, LLC	MET	MA	007	SEMA	SEMA	6049	5.000	5.142	5.005	5.142	5.005	0.011
1032	BRIDGEPORT ENERGY 1	1032	BRIDGEPORT ENERGY 1	CC	NG		GAS COMBINED CYCLE	01-Aug-98	Emera Energy Services Subsidiary No. 5 LLC	EES5	CT	001	SWCT	CT	55042	536.350	576.997	480.424	576.997	480.424	2.750
1034	RIVERSIDE 4-7	1034	RIVERSIDE 4-7	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-21	Holyoke Gas & Electric Department	HGE	MA	013	WMA	WCMA	1607	3.392	2.238	1.616	2.238	1.616	-0.867
1035	RIVERSIDE 8	1035	RIVERSIDE 8	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-31	Holyoke Gas & Electric Department	HGE	MA	013	WMA	WCMA	1607	4.554	3.290	0.000	3.290	0.000	-3.620
1047	FAIRFAX	1047	FAIRFAX	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	25-Sep-98	Green Mountain Power Corporation	GMP	VT	011	VT	VT	3712	4.939	3.695	0.218	3.695	0.218	-1.502
1048	WARE HYDRO	1048	WARE HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-84	Pioneer Hydro Electric Co., Inc.	PHE	MA	015	WMA	WCMA	50419	1.200	0.475	0.000	0.475	0.000	0.000
1049	COLLINS HYDRO	1049	COLLINS HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-84	Ampersand Energy Partners LLC	AMP	MA	013	WMA	WCMA	52166	1.300	0.471	0.157	0.471	0.157	-0.051
1050	CHICOPEE HYDRO	1050	CHICOPEE HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-85	Chicopee Municipal Lighting Plant	CMLP	MA	013	WMA	WCMA	50832	2.600	0.911	0.190	0.911	0.190	-0.223
1054	BLACKSTONE HYDRO ASSOC	1054	BLACKSTONE HYDRO ASSOC	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-89	The Narragansett Electric Company	NEC	RI	007	RI	RI	3245	0.750	0.251	0.000	0.251	0.000	0.000
1057	BLACKSTONE HYDRO LOAD REDUCER	1057	BLACKSTONE HYDRO LOAD REDUCER	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-89	Blackstone Hydro, Inc.	BHI	RI	007	RI	RI	50177	2.000	0.312	0.000	0.312	0.000	-0.157
1059	BARRE LANDFILL	1059	BARRE LANDFILL	IC	LFG		BIO/REFUSE	01-Jul-96	Dominion Energy Marketing, Inc.	DEM	MA	027	WMA	WCMA	55776	1.000	0.592	0.497	0.592	0.497	-0.135
1061	MASCOMA HYDRO	1061	MASCOMA HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-89	TransCanada Hydro Northeast Inc	TCHN	NH	009	VT	NH	54471	1.338	0.545	0.000	0.545	0.000	0.000
1062	MWRA COSGROVE	1062	MWRA COSGROVE	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Oct-95	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA	10825	3.200	0.598	0.119	0.598	0.119	-0.802
1086	BERKSHIRE POWER	1086	BERKSHIRE POWER	CC	NG		GAS COMBINED CYCLE	19-Jun-00	Shell Energy North America (US), L.P.	SENA	MA	013	WMA	WCMA	55041	289.000	246.279	229.279	246.279	229.279	0.000
1107	SAPPI SOMERSET/HINCKLEY	1107	SOMERSET	ST	BLQ	WDS	BIO/REFUSE	01-Jan-76	NextEra Energy Power Marketing, LLC	FPLP	ME	011	ME	ME	50406	110.700	0.000	0.000	0.000	0.000	0.000
1109	MMWAC	1109	MMWAC	ST	MSW		BIO/REFUSE	01-Jun-92	NextEra Energy Power Marketing, LLC	FPLP	ME	001	ME	ME	50035	3.100	2.101	1.725	2.101	1.725	-0.169
1113	BRASSUA HYDRO	1113	BRASSUA HYDRO	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Aug-89	Brookfield Energy Marketing, LP	BEMLP	ME	025	ME	ME	10555	4.203	4.203	4.203	4.203	4.203	0.000
1114	MADISON COMPOSITE	1114	MADISON COMPOSITE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Sep-84	Competitive Energy Services, LLC	CESLLC	ME	025	ME	ME	7469	13.420	0.000	7.701	0.000	7.701	7.701
1117	GREAT WORKS COMPOSITE	1117	GREAT WORKS COMPOSITE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-84	Blackstone Hydro, Inc.	BHI	ME	031	SME	ME		0.918	0.129	0.000	0.129	0.000	0.000
1119	KENNEBAGO HYDRO	1119	KENNEBAGO HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-88	NextEra Energy Power Marketing, LLC	FPLP	ME	029	ME	ME		0.900	0.414	0.000	0.414	0.000	-0.129
1122	CASCADE-DIAMOND-QF	1122	CASCADE-DIAMOND-QF	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	31-Dec-19	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		0.872	0.302	0.000	0.302	0.000	-0.005
1165	CADYS FALLS	1165	CADYS FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-80	Vermont Public Power Supply Authority	VPPSA	VT	015	VT	VT	3765	1.100	0.000	0.000	0.000	0.000	-0.253
1166	MORRISVILLE PLANT #2	1166	MORRISVILLE PLANT #2	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-80	Vermont Public Power Supply Authority	VPPSA	VT	015	VT	VT	3764	1.800	0.000	0.000	0.000	0.000	-0.163
1167	WOLCOTT HYDRO #1	1167	WOLCOTT HYDRO #1	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-37	Vermont Public Power Supply Authority	VPPSA	VT	015	VT	VT	6477	0.860	0.000	0.000	0.000	0.000	-0.399
1168	H.K. SANDERS	1168	H.K. SANDERS	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-83	Vermont Public Power Supply Authority	VPPSA	VT	015	VT	VT	678	2.180	1.800	0.000	1.800	0.000	-1.800
1185	STONY BROOK GT1A	1185	STONY BROOK GT1A	CC	DFO	NG	GAS/OIL COMBINED CYCLE	01-Nov-81	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	013	WMA	WCMA	6081	136.101	113.567	103.714	113.567	103.714	-0.286
1186	STONY BROOK GT1B	1186	STONY BROOK GT1B	CC	DFO	NG	GAS/OIL COMBINED CYCLE	01-Nov-81	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	013	WMA	WCMA	6081	135.900	115.932	99.932	115.932	99.932	0.000
1187	STONY BROOK GT1C	1187	STONY BROOK GT1C	CC	DFO	NG	GAS/OIL COMBINED CYCLE	01-Nov-81	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	013	WMA	WCMA	6081	135.900	114.433	103.774	114.433	103.774	0.204
1209	CRRA HARTFORD LANDFILL	1209	CRRA HARTFORD LANDFILL	IC	LFG		BIO/REFUSE	01-Aug-98	Connecticut Light and Power Company, The	CLP	CT	003	CT	CT	55163	2.853	0.920	0.888	0.920	0.888	-0.183
1210	MILLENNIUM	1210	MILLENNIUM	CC	NG		GAS COMBINED CYCLE	06-Apr-01	Talen Energy Marketing, LLC	EPLU-I	MA	027	WMA	WCMA	55079	427.500	383.904	334.904	383.904	334.904	0.000
1221	ESSEX DIESELS	1221	ESSEX DIESELS	IC	DFO		OIL INTERNAL COMBUSTION	01-Jan-47	Green Mountain Power Corporation	GMP	VT	007	VT	VT	3737	6.400	7.246	7.215	7.246	7.215	0.000
1225	TANNERY DAM	1225	TANNERY DAM	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-00	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA	55924	0.099	0.000	0.000	0.000	0.000	0.000
1226	TIVERTON POWER	1226	TIVERTON POWER	CC	NG		GAS COMBINED CYCLE	18-Aug-00	Emera Energy Services Subsidiary No. 6 LLC	EES6	RI	005	SEMA	RI	55048	273.700	278.756	241.177	278.756	241.177	-1.550
1255	RUMFORD POWER	1255	RUMFORD POWER	CC	NG		GAS COMBINED CYCLE	16-Oct-00	Emera Energy Services Subsidiary No. 7 LLC	EES7	ME	017	ME	ME	55100	272.850	269.091	244.281	269.091	244.281	0.000
1258	BHE SMALL HYDRO COMPOSITE	1258	BHE SMALL HYDRO COMPOSITE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-82	New Brunswick Energy Marketing Corporation	NBPGC	ME	021	BHE	ME		2.810	1.006	0.000	1.006	0.000	-0.502
1266	MARSH POWER	1266	MARSH POWER	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-86	Christopher M. Anthony	CMA	ME	027	BHE	ME	1469	0.400	0.000	0.000	0.000	0.000	0.000
1267	SPARHAWK	1267	SPARHAWK	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jun-85	Union Atlantic Electricity	UNION	ME	005	SME	ME		0.270	0.000	0.000	0.000	0.000	0.000
1270	SYSKO STONY BROOK	1270	SYSKO STONY BROOK	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-00	Union Atlantic Electricity	UNION	ME	017	ME	ME		0.030	0.013	0.000	0.013	0.000	-0.016
1271	SYSKO WIGHT BROOK	1271	SYSKO WIGHT BROOK	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-84	Union Atlantic Electricity	UNION	ME	017	ME	ME		0.030	0.017	0.000	0.017	0.000	0.000
1273	KENNEBEC WATER U5	1273	KENNEBEC WATER U5	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-95	Messalonskee Stream Hydro, LLC	MESSA	ME	011	ME	ME	54148	0.800	0.667	0.000	0.667	0.000	0.000
1286	ANP-BLACKSTONE ENERGY 1	1286	ANP-BLACKSTONE ENERGY CO. #1	CC	NG		GAS COMBINED CYCLE	07-Jun-01	Dynegy Marketing and Trade, LLC	DMT1	MA	027	RI	SEMA	55212	289.000	246.947	239.174	246.947	239.174	0.000
1287	ANP-BLACKSTONE ENERGY 2	1287	ANP-BLACKSTONE ENERGY 2	CC	NG		GAS COMBINED CYCLE	13-Jul-01	Dynegy Marketing and Trade, LLC	DMT1	MA	027	RI	SEMA	55212	289.000	249.338	237.989	249.338	237.989	0.000
1302	TCPMCMPAGF GEN1 U5	1302	TCPMCMPAGF GEN1 U5	IC	OBG		BIO/REFUSE	01-Jun-83	Verso Energy Services LLC	VERSO	ME	007	ME	ME	50081	65.170	0.000	0.000	0.000	0.000	0.000
1342	LAKE ROAD 1	1342	LAKE ROAD 1	CC	NG		GAS COMBINED CYCLE	15-Mar-02	Dynegy Marketing and Trade, LLC	DMT1	CT	015	CT	CT	55149	289.000	271.959	245.792	281.416	245.792	0.000
1343	LAKE ROAD 2	1343	LAKE ROAD 2	CC	NG		GAS COMBINED CYCLE	15-Mar-02	Dynegy Marketing and Trade, LLC	DMT1	CT	015	CT	CT	55149	289.000	276.774	250.016	286.837	250.016	-0.644
1344	LAKE ROAD 3	1344	LAKE ROAD 3	CC	NG		GAS COMBINED CYCLE	22-May-02	Dynegy Marketing and Trade, LLC	DMT1	CT	015	CT	CT	55149	289.000	278.048	254.791	289.076	254.791	0.725
1368	ROCKY GORGE CORPORATION	1368	ROCKY GORGE CORPORATION	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-84	Rocky Gorge Corporation	RGC	ME	031	SME	ME		0.550	0.281	0.000	0.281	0.000	-0.080
1376	WALLINGFORD UNIT 1	1376	PPL WALLINGFORD UNIT 1	GT	NG		GAS COMBUSTION (GAS) TURBINE	31-Dec-01	Twin Eagle Resource Management, LLC	TERM	CT	009	SWCT	CT	55517	60.500	49.181	43.473	49.181	43.473	0.000
1377	WALLINGFORD UNIT 2	1377	PPL WALLINGFORD UNIT 2	GT	NG		GAS COMBUSTION (GAS) TURBINE	07-Feb-02	Twin Eagle Resource Management, LLC	TERM	CT	009	SWCT	CT	55517	60.500	50.000	44.137	50.000	44.137	1.118
1378	WALLINGFORD UNIT 3	1378	PPL WALLINGFORD UNIT 3	GT	NG		GAS COMBUSTION (GAS) TURBINE	31-Dec-01	Twin Eagle Resource Management, LLC	TERM	CT	009	SWCT	CT	55517	60.500	49.177	44.045	49.177	44.045	-0.521
1379	WALLINGFORD UNIT 4	1379	PPL WALLINGFORD UNIT 4	GT	NG		GAS COMBUSTION (GAS) TURBINE	23-Jan-02	Twin Eagle Resource Management, LLC	TERM	CT	009	SWCT	CT	55517	60.500	48.049	42.716	48.049	42.716	-0.441
1380	WALLINGFORD UNIT 5	1380	PPL WALLINGFORD UNIT 5	GT	NG		GAS COMBUSTION (GAS) TURBINE	07-Feb-02	Twin Eagle Resource Management, LLC	TERM	CT	009	SWCT	CT	55517	60.500	50.000	43.625	50.000	43.625	-0.800
1385	MILFORD POWER 1	1385	Milford Power 1 Incremental	CC	NG		GAS COMBINED CYCLE	12-Feb-04	Dynegy Marketing and Trade, LLC	DMT1	CT	009	SWCT	CT	55126	289.000	281.353	253.610	281.353	253.610	0.000
1386	MILFORD POWER 2	1386	MILFORD POWER 2	CC	NG		GAS COMBINED CYCLE	03-May-04	Dynegy Marketing and Trade, LLC	DMT1	CT	009	SWCT	CT	55126	289.000	287.441	253.093	287.441	253.093	0.000
1412	ANP-BELLINGHAM 1	1412	ANP-BELLINGHAM 1	CC	NG		GAS COMBINED CYCLE	24-Oct-02	Dynegy Marketing and Trade, LLC	DMT1	MA	021	RI	SEMA	55211	289.000	284.813	254.704	284.813	254.704	0.000
1415	ANP-BELLINGHAM 2	1415	ANP-BELLINGHAM 2	CC	NG		GAS COMBINED CYCLE	28-Dec-02	Dynegy Marketing and Trade, LLC	DMT1	MA	021	RI	SEMA	55211	289.000	276.788	247.295	276.788	247.295	0.000
1432	GRS-FALL RIVER	1432	GRS-FALL RIVER	GT	LFG		BIO/REFUSE	01-Aug-00	Taunton Municipal Lighting Plant	TMLP	MA	005	SEMA	SEMA	55589	5.300	3.824	3.028	3.824	3.028	0.000
1478	MYSTIC 8	1478	MYSTIC 8	CC	NG		GAS COMBINED CYCLE	13-Apr-03	Exelon Generation Company, LLC	EXGC	MA	025	BOSTON	NEMA	1588	872.330	841.564	703.324	841.564	703.324	0.000
1572	GRANBY SANITARY LANDFILL QF	1572	GRANBY SANITARY LANDFILL QF U5	IC	MSW		BIO/REFUSE	12-Jul-02	Industrial Power Services Corp	IPSC	MA	015	WMA	WCMA		5.845	1.821	1.621	1.821	1.621	-0.329
1616	MYSTIC 9	1616	MYSTIC 9	CC	NG		GAS COMBINED CYCLE	11-Jun-03	Exelon Generation Company, LLC	EXGC	MA	025	BOSTON	NEMA	1588	872.330	858.366	713.900	858.366	713.900	2.759
1625	GRANITE RIDGE ENERGY	1625	GRANITE RIDGE ENERGY	CC	NG		GAS COMBINED CYCLE	01-Apr-03	Calpine Energy Services, LP	CALP	NH	011	NH	NH	55170	790.500	773.010	675.675	773.010	675.675	0.000
1630	RISEP	1630	RISEP	CC	NG		GAS COMBINED CYCLE	05-Nov-02	Rhode Island State Energy Center, LP	RISE	RI	007	RI	RI	55107	592.644	610.632	543.455	610.632	554.656	15.657
1649	EP NEWINGTON ENERGY, LLC	1649	EP Newington Energy, LLC	CC	NG	DFO	GAS/OIL COMBINED CYCLE	18-Sep-02	Essential Power Newington, LLC	EPN	NH	015	NH	NH	55661	605.823	631.510	565.700	631.510	565.700	12.220
1656	HULL WIND TURBINE U5	1656	HULL WIND TURBINE U5	WT	WND		WIND TURBINE	01-Jul-01	Hull Municipal Lighting Plant	HULL	MA	023	SEMA	SEMA		0.165	0.068	0.030	0.068	0.030	-0.006
1672	KENDALL CT	1672	KENDALL CT	CC	NG	DFO	GAS/OIL COMBINED CYCLE	18-Dec-02	Kendall Green Energy, LLC	KENDALL	MA	017	BOSTON	NEMA	1595	186.150	187.400	160.506	187.400	171.659	11.153

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
1693	WEST SPRINGFIELD GT-1	1693	WEST SPRINGFIELD GT-1	GT	NG	DFO	GAS/OIL COMBUSTION (GAS) TURBINE	07-Jun-02	Essential Power Massachusetts, LLC	NAEA-EM	MA	013	WMA	WCMA	1642	60.500	47.510	38.750	47.510	38.750	1.842
1694	WEST SPRINGFIELD GT-2	1694	WEST SPRINGFIELD GT-2	GT	NG	DFO	GAS/OIL COMBUSTION (GAS) TURBINE	07-Jun-02	Essential Power Massachusetts, LLC	NAEA-EM	MA	013	WMA	WCMA	1642	60.500	47.441	37.441	47.441	37.441	0.000
1720	MIDDLEBURY LOWER	1720	MIDDLEBURY LOWER	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-02	Green Mountain Power Corporation	GMP	VT	001	VT	VT	3716	2.345	0.974	0.000	0.974	0.000	-0.323
2278	BARKER LOWER HYDRO	2278	BARKER LOWER HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-80	Blackstone Hydro, Inc.	BHI	ME	001	ME	ME	10728	1.600	0.418	0.000	0.418	0.000	0.000
2279	BARKER UPPER HYDRO	2279	BARKER UPPER HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jul-87	Blackstone Hydro, Inc.	BHI	ME	001	ME	ME	52171	1.262	0.848	0.000	0.848	0.000	0.000
2280	BENTON FALLS HYDRO	2280	BENTON FALLS HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-87	Littleton Electric Light & Water Department	LELWD	ME	011	ME	ME	10523	4.355	3.085	0.000	3.085	0.000	-0.663
2281	BROWNS MILL HYDRO	2281	BROWNS MILL HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jul-83	Blackstone Hydro, Inc.	BHI	ME	021	ME	ME	50688	0.650	0.504	0.000	0.504	0.000	-0.161
2282	DAMARISCOTTA HYDRO	2282	DAMARISCOTTA HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-84	Blackstone Hydro, Inc.	BHI	ME	015	ME	ME	2282	0.550	0.298	0.000	0.298	0.000	0.000
2283	EUSTIS HYDRO	2283	EUSTIS HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-84	Blackstone Hydro, Inc.	BHI	ME	007	ME	ME	50688	0.310	0.186	0.000	0.186	0.000	-0.088
2284	GARDINER HYDRO	2284	GARDINER HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jul-83	Blackstone Hydro, Inc.	BHI	ME	011	ME	ME	50688	1.150	1.034	0.000	1.034	0.000	0.000
2285	GREENVILLE HYDRO	2285	GREENVILLE HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-84	Blackstone Hydro, Inc.	BHI	ME	021	ME	ME	50688	0.550	0.525	0.000	0.525	0.000	-0.132
2286	HACKETT MILLS HYDRO	2286	HACKETT MILLS HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-85	Epico USA, Inc.	EPICO	ME	001	ME	ME	2286	0.500	0.305	0.000	0.305	0.000	0.000
2287	MECHANIC FALLS HYDRO	2287	MECHANIC FALLS HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-84	Blackstone Hydro, Inc.	BHI	ME	001	ME	ME	2287	1.050	0.626	0.000	0.626	0.000	0.000
2288	NORWAY HYDRO	2288	NORWAY HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-85	Blackstone Hydro, Inc.	BHI	ME	017	ME	ME	50688	0.350	0.066	0.000	0.066	0.000	0.000
2290	PITTSFIELD HYDRO	2290	PITTSFIELD HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-84	Blackstone Hydro, Inc.	BHI	ME	025	ME	ME	2290	1.000	0.658	0.000	0.658	0.000	-0.141
2292	YORK HYDRO	2292	YORK HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-84	Blackstone Hydro, Inc.	BHI	ME	031	SME	ME	50688	1.200	0.708	0.000	0.708	0.000	0.000
2425	SPRINGFIELD REFUSE-NEW	2425	SPRINGFIELD REFUSE-NEW	ST	MSW		BIO/REFUSE	01-Sep-88	Covanta Energy Marketing, LLC	CEM	MA	013	WMA	WCMA	50273	10.369	5.223	4.763	5.223	4.763	-0.489
2426	HYDRO KENNEBEC	2426	Hydro Kennebec	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-89	Brookfield Energy Marketing, LP	BEMLP	ME	011	ME	ME	54148	16.293	7.507	4.880	7.507	4.880	4.880
2430	BELDENS-NEW	2430	BELDENS-NEW	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-80	Green Mountain Power Corporation	GMP	VT	001	VT	VT	6451	4.680	1.785	0.000	1.785	0.000	-0.500
2431	DODGE FALLS-NEW	2431	DODGE FALLS-NEW	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-90	Vermont Electric Power Company, Inc.	VELCO	NH	009	VT	VT	10526	5.000	4.475	1.469	4.475	1.469	-2.544
2432	HUNTINGTON FALLS-NEW	2432	HUNTINGTON FALLS-NEW	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-88	Green Mountain Power Corporation	GMP	VT	001	VT	VT	50713	4.400	2.061	0.000	2.061	0.000	-1.170
2433	RYEGATE 1-NEW	2433	RYEGATE 1-NEW	ST	WDS		BIO/REFUSE	01-Nov-92	Vermont Electric Power Company, Inc.	VELCO	VT	005	NH	VT	51026	21.585	19.760	19.940	19.760	19.940	-0.060
2434	GORGE 18 HYDRO-NEW	2434	GORGE 18 HYDRO-NEW	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-28	Green Mountain Power Corporation	GMP	VT	007	VT	VT	6475	3.520	2.699	0.000	2.699	0.000	-1.505
2435	VERGENNES HYDRO-NEW	2435	VERGENNES HYDRO-NEW	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-12	Green Mountain Power Corporation	GMP	VT	001	VT	VT	6519	1.680	1.531	0.394	1.531	0.394	-0.284
2439	BROCKWAY MILLS U5	2439	BROCKWAY MILLS U5	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-03	Green Mountain Power Corporation	GMP	VT	025	VT	VT		0.890	0.000	0.000	0.000	0.000	0.000
2462	PLAINVILLE GEN QF U5	2462	PLAINVILLE GEN QF U5	IC	OBG		BIO/REFUSE	24-Mar-03	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		10.680	1.989	1.652	1.989	1.652	-0.289
2466	CHERRY 7	2466	CHERRY 7	IC	DFO		OIL INTERNAL COMBUSTION	01-Jan-51	Hudson Light & Power Department	HLPD	MA	017	CMA/NEMA	WCMA	9038	3.200	2.700	2.700	2.800	2.700	0.200
2467	CHERRY 8	2467	CHERRY 8	IC	DFO		OIL INTERNAL COMBUSTION	01-Jan-51	Hudson Light & Power Department	HLPD	MA	017	CMA/NEMA	WCMA	9038	4.100	3.400	3.400	3.400	3.400	0.000
2468	CHERRY 10	2468	CHERRY 10	IC	DFO		OIL INTERNAL COMBUSTION	01-Jan-51	Hudson Light & Power Department	HLPD	MA	017	CMA/NEMA	WCMA	9038	2.200	2.100	1.900	2.100	1.900	0.000
2469	CHERRY 11	2469	CHERRY 11	IC	DFO		OIL INTERNAL COMBUSTION	01-Jan-51	Hudson Light & Power Department	HLPD	MA	017	CMA/NEMA	WCMA	9038	2.200	1.900	2.000	2.100	2.000	0.100
2470	CHERRY 12	2470	CHERRY 12	IC	DFO		OIL INTERNAL COMBUSTION	01-Jan-51	Hudson Light & Power Department	HLPD	MA	017	CMA/NEMA	WCMA	9038	14.000	4.999	4.999	4.999	4.999	0.000
10347	KENDALL STEAM 1	37040	KENDALL STEAM	CC	NG		GAS COMBINED CYCLE	01-Jan-50	Kendall Green Energy, LLC	KENDALL	MA	017	BOSTON	NEMA	1595	15.000	14.752	13.813	14.752	0.000	0.000
10348	KENDALL STEAM 2	37040	KENDALL STEAM	CC	NG		GAS COMBINED CYCLE	01-Jan-50	Kendall Green Energy, LLC	KENDALL	MA	017	BOSTON	NEMA	1595	20.000	19.669	12.813	19.669	0.000	0.000
10349	KENDALL STEAM 3	37040	KENDALL STEAM	CC	NG		GAS COMBINED CYCLE	01-Jan-50	Kendall Green Energy, LLC	KENDALL	MA	017	BOSTON	NEMA	1595	23.460	20.141	0.000	20.141	0.000	-20.008
10401	CELLEY MILL U5	10401	CELLEY MILL U5	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-84	Public Service Company of New Hampshire	PSNH	NH	009	NH	NH		0.100	0.060	0.000	0.060	0.000	-0.034
10402	PETTYBORO HYDRO U5	10402	PETTYBORO HYDRO U5	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	09-May-99	Public Service Company of New Hampshire	PSNH	NH	009	NH	NH		0.060	0.000	0.000	0.000	0.000	0.000
10403	EASTMAN BROOK U5	10403	EASTMAN BROOK U5	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jun-85	Public Service Company of New Hampshire	PSNH	NH	009	NH	NH		0.300	0.042	0.000	0.042	0.000	-0.017
10404	WHEELABRATOR CLAREMONT U5	10404	WHEELABRATOR CLAREMONT U5	ST	MSW		BIO/REFUSE	01-Mar-04	Wheelabrator North Andover Inc	WNE	NH	019	NH	NH	50872	5.290	0.000	0.000	0.000		
10406	LOWER VALLEY HYDRO U5	10406	LOWER VALLEY HYDRO U5	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-04	Green Mountain Power Corporation	GMP	NH	019	NH	NH		0.882	0.000	0.000	0.000	0.000	0.000
10407	WOODSVILLE HYDRO U5	10407	WOODSVILLE HYDRO U5	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-87	Green Mountain Power Corporation	GMP	NH	019	NH	NH		0.300	0.000	0.000	0.000	0.000	0.000
10409	SWEETWATER HYDRO U5	10409	SWEETWATER HYDRO U5	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-04	Green Mountain Power Corporation	GMP	NH	019	NH	NH		0.779	0.178	0.000	0.178	0.000	0.000
10424	GREAT LAKES - BERLIN	10424	Great Lakes - Berlin Incremental	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	22-Jun-04	Brookfield Energy Marketing, LP	BEMLP	NH	007	NH	NH	54639	30.400	12.027	3.642	12.027	3.642	-1.833
10615	BLUE SPRUCE FARM U5	10615	BLUE SPRUCE FARM U5	IC	OBG		BIO/REFUSE	01-Nov-04	Green Mountain Power Corporation	GMP	VT	021	VT	VT		0.980	0.367	0.366	0.367	0.366	0.034
10770	WEST SPRINGFIELD HYDRO U5	10770	WEST SPRINGFIELD HYDRO U5	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	10-Jan-05	Littleton Electric Light & Water Department	LELWD	MA	013	WMA	WCMA		1.250	0.796	0.000	0.796	0.000	-0.321
10801	COVENTRY CLEAN ENERGY	10801	COVENTRY CLEAN ENERGY	IC	LFG		BIO/REFUSE	01-Feb-05	Vermont Public Power Supply Authority	VPPSA	VT	019	NH	VT		6.200	3.854	3.527	3.854	3.527	-0.295
10880	GE LYNN EXCESS REPLACEMENT	10880	GE LYNN EXCESS REPLACEMENT	GT	DFO	NG	GAS/OIL COMBUSTION (GAS) TURBINE	11-Oct-05	Constellation NewEnergy, Inc.	CNE	MA	009	BOSTON	NEMA	10029	35.600	0.000	0.000	0.000	0.000	0.000
10959	RRIG EXPANSION PHASE 2	10959	RRIG EXPANSION PHASE 2	IC	LFG		BIO/REFUSE	01-Jun-05	Rhode Island Engine Genco, LLC	RRIG	RI	007	RI	RI	50365	6.400	0.000	0.000	0.000	0.000	0.000
10998	MASSINNOVATION FITCHBURG	10998	MASSINNOVATION FITCHBURG	PV	SUN		PHOTOVOLTAIC	01-Aug-05	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		3.027	0.000	0.000	0.000	0.000	0.000
11052	GRTR NEW BEDFORD LFG UTIL PROJ	11052	GRTR NEW BEDFORD LFG UTIL PROJ	IC	LFG		BIO/REFUSE	15-Aug-05	Commonwealth Resource Management Corporation	CRMC	MA	005	SEMA	SEMA		3.300	2.679	2.430	2.679	2.430	0.029
11126	NORTH HARTLAND HYDRO	11126	NORTH HARTLAND HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	27-Sep-06	Green Mountain Power Corporation	GMP	VT	027	VT	VT		4.922	1.818	0.267	1.818	0.267	-0.182
11408	HULL WIND TURBINE II	11408	HULL WIND TURBINE II	WT	WND		WIND TURBINE	27-Sep-05	Hull Municipal Lighting Plant	HULL	MA	023	SEMA	SEMA	56800	1.800	0.178	0.027	0.178	0.027	-0.028
11424	RUMFORD FALLS	11424	RUMFORD FALLS	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	06-Jul-06	Brookfield Energy Marketing, LP	BEMLP	ME	017	ME	ME	10493	44.175	28.504	18.276	28.504	18.276	-7.180
11827	PORTSMOUTH ABBEY WIND QF		No Resource (1)	WT	WND		WIND TURBINE	25-Jul-06	The Narragansett Electric Company	NEC	RI	005	SEMA	RI		0.660	0.000	0.000	0.000	0.000	0.000
11842	WATERSIDE POWER	11842	WATERSIDE POWER	GT	DFO		OIL COMBUSTION (GAS) TURBINE	01-May-04	Waterside Power, LLC	WATERSIDE	CT	001	NOR	CT	56189	63.750	71.557	70.017	71.557	70.017	0.000
11889	IBEW LOCAL 99 SOLAR QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-06	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.050	0.000	0.000	0.000	0.000	0.000
11925	BROCKTON BRIGHTFIELDS	11925	BROCKTON BRIGHTFIELDS	PV	SUN		PHOTOVOLTAIC	18-Sep-06	Exelon Generation Company, LLC	EXGC	MA	023	SEMA	SEMA		0.425	0.000	0.147	0.000	0.147	-0.002
12108	FIEC DIESEL	12108	FIEC DIESEL	IC	DFO		OIL INTERNAL COMBUSTION	01-Dec-06	Vermont Public Power Supply Authority	VPPSA	ME	013	ME	ME		2.000	1.563	1.540	1.563	1.540	0.000
12180	BERKSHIRE COW POWER	12180	BERKSHIRE COW POWER	IC	OBG		BIO/REFUSE	06-Dec-06	Vermont Electric Cooperative, Inc.	VEC	VT	011	VT	VT		0.600	0.319	0.286	0.319	0.286	0.086
12274	GREEN MOUNTAIN DAIRY	12274	GREEN MOUNTAIN DAIRY	IC	OBG		BIO/REFUSE	01-Feb-07	Green Mountain Power Corporation	GMP	VT	011	VT	VT		0.371	0.220	0.188	0.220	0.188	-0.030
12323	COVENTRY CLEAN ENERGY #4	12323	COVENTRY CLEAN ENERGY #4	IC	LFG		BIO/REFUSE	20-Jan-07	Vermont Public Power Supply Authority	VPPSA	VT	019	NH	VT		3.233	2.760	2.606	2.760	2.606	-0.228
12504	DEVON 15	12504	Devon 15-18	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	12-Jul-10	GenConn Energy LLC	GCE	CT	009	SWCT	CT	57070	60.500	49.200	46.889	49.200	46.889	0.000
12505	MIDDLETOWN 12	12505	Middletown 12-15	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	24-Jun-11	GenConn Energy LLC	GCE	CT	007	CT	CT	57068	60.500	49.200	46.900	49.200	46.900	0.000
12509	UNH POWER PLANT	12509	UNH Power Plant	GT	LFG		BIO/REFUSE	20-Oct-09	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH	58180	4.956	4.378	3.008	4.378	3.008	0.000
12510	SWANTON GT-1	12510	Swanton Gas Turbine 1	GT	DFO		OIL COMBUSTION (GAS) TURBINE	12-Feb-10	Vermont Public Power Supply Authority	VPPSA	VT	011	VT	VT		28.800	23.954	19.288	23.954	19.288	0.000
12511	SWANTON GT-2	12511	Swanton Gas Turbine 2	GT	DFO		OIL COMBUSTION (GAS) TURBINE	24-May-10	Vermont Public Power Supply Authority	VPPSA	VT	011	VT	VT		28.800	23.839	19.349	23.839	19.349	0.435
12529	HOOSAC WIND	38475	Hoosac Wind Project	WT	WND		WIND TURBINE	27-Dec-12	Avangrid Renewables, LLC	PPMI	MA	003	WMA	WCMA	57380	28.500	9.753	4.460	9.753	4.460	0.491
12530	SHEFFIELD WIND PLANT	12530	Sheffield Wind Farm	WT	WND		WIND TURBINE	19-Oct-11	Vermont Wind LLC	VTWIND	VT	005	VT	VT	57080	38.000	9.150	3.970	9.150	3.970	1.285
12551	KIBBY WIND POWER	12551	Kibby Wind Power	WT	WND		WIND TURBINE	16-Sep-09	TransCanada Power Marketing, Ltd.	TCPM	ME	007	ME	ME	56829	143.616	37.095	21.845	37.095	21.845	8.310
12564	WATERBURY GENERATION FACILITY	12564	Waterbury Generation Facility	GT	NG	DFO	GAS/OIL COMBUSTION (GAS) TURBINE	21-May-09	Waterbury Generation LLC	WATERBURY	CT	009	SWCT	CT	56629	108.190	98.749	95.710	98.749	95.710	0.815
13515	PIERCE STATION	12526	Pierce	GT	NG	DFO	GAS/OIL COMBUSTION (GAS) TURBINE	01-Oct-07	Connecticut Municipal Electric Energy Cooperative	CMEEC	CT	009	SWCT	CT	6635	100.985	94.590	74.085	94.590	74.085	0.000

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	As of Jan. 2017 SCC Report SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
13669	EAST WINDSOR NORCAP LFG PLANT	13669	Manchester Methane LLC East Windsor Facility	IC	LFG		BIO/REFUSE	07-May-07	Manchester Methane, LLC	MMLLC	CT	003	CT	CT	55163	2.835	0.000	0.000	0.000	0.000	-0.636
13673	MATEP (DIESEL)	13673	MATEP (DIESEL)	IC	DFO		OIL INTERNAL COMBUSTION	28-Jun-07	MATEP, LLC	MATEP	MA	025	BOSTON	NEMA	10883	20.250	17.460	16.610	17.460	16.610	-0.510
13675	MATEP (COMBINED CYCLE)	13675	MATEP (COMBINED CYCLE)	CC	NG	DFO	GAS/OIL COMBINED CYCLE	28-Jun-07	MATEP, LLC	MATEP	MA	025	BOSTON	NEMA	10883	51.910	46.785	41.910	46.785	41.910	2.300
13703	VERSO COGEN 1	13703	Verso VCG1	GT	NG	DFO	GAS/OIL COMBUSTION (GAS) TURBINE	28-Dec-00	Verso Energy Services LLC	VERSO	ME	007	ME	ME	55031	61.920	53.760	42.606	53.760	42.606	0.000
13704	VERSO COGEN 2	13704	Verso VCG2	GT	NG	DFO	GAS/OIL COMBUSTION (GAS) TURBINE	28-Dec-00	Verso Energy Services LLC	VERSO	ME	007	ME	ME	55031	61.920	56.333	44.380	56.333	44.380	-0.093
13705	VERSO COGEN 3	13705	Verso VCG3	GT	NG	DFO	GAS/OIL COMBUSTION (GAS) TURBINE	28-Dec-00	Verso Energy Services LLC	VERSO	ME	007	ME	ME	55031	61.920	54.668	42.452	54.668	42.452	0.763
13933	JIMINY PEAK WIND QF		No Resource (1)	WT	WND		WIND TURBINE	01-Jul-07	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		1.500	0.006	0.000	0.006	0.000	0.000
13975	CORRIVEAU HYDROELECTRIC LLC	13975	Corriveau Hydroelectric LLC	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	10-Aug-07	Union Atlantic Electricity	UNION	ME	017	ME	ME		0.350	0.000	0.000	0.000	0.000	0.000
14087	MAT3	14087	MAT3	IC	DFO		OIL INTERNAL COMBUSTION	11-Dec-07	MATEP, LLC	MATEP	MA	025	BOSTON	NEMA	10883	20.250	18.630	16.860	18.630	16.860	2.520
14098	FITCHBURG LANDFILL	35485	Fitchburg-FCA-5	IC	LFG		BIO/REFUSE	16-Aug-07	Vermont Public Power Supply Authority	VPPSA	MA	027	WMA	WCMA	56527	4.581	3.065	4.127	3.065	4.127	1.117
14134	MONTAGNE FARM	14134	MONTAGNE FARM	IC	LFG		BIO/REFUSE	17-Sep-07	Green Mountain Power Corporation	GMP	VT	011	VT	VT		0.277	0.064	0.080	0.064	0.080	0.010
14157	COS COB 13	12524	Cos Cob 13&14	GT	KER		OIL COMBUSTION (GAS) TURBINE	29-May-08	NRG Power Marketing LLC	NRGPM	CT	001	NOR	CT	542	18.594	22.852	19.053	22.852	19.053	0.000
14158	COS COB 14	12524	Cos Cob 13&14	GT	KER		OIL COMBUSTION (GAS) TURBINE	29-May-08	NRG Power Marketing LLC	NRGPM	CT	001	NOR	CT	542	18.594	22.602	19.209	22.602	19.209	0.000
14177	WESTBROOK ENERGY CENTER G1	1345	WESTBROOK	CC	NG		GAS COMBINED CYCLE	13-Apr-01	Calpine Energy Services, LP	CALP	ME	005	SME	ME	55294	276.548	284.352	265.200	284.352	265.200	-0.318
14178	WESTBROOK ENERGY CENTER G2	1345	WESTBROOK	CC	NG		GAS COMBINED CYCLE	13-Apr-01	Calpine Energy Services, LP	CALP	ME	005	SME	ME	55294	276.548	286.113	265.200	286.113	265.200	-0.318
14211	INDECK ALEXANDRIA	1631	Indeck-Energy Alexandria, LLC	ST	WDS		BIO/REFUSE	06-Nov-08	Indeck Energy-Alexandria, L.L.C.	IEA	NH	009	NH	NH	58595	17.976	15.049	15.031	15.049	15.031	0.000
14217	NORTHFIELD MOUNTAIN 1	14217	NORTHFIELD MOUNTAIN 1	PS	WAT		HYDRO (PUMPED STORAGE)	30-Nov-72	FirstLight Power Resource Management, LLC	NEL1	MA	011	WMA	WCMA	547	267.900	293.500	293.500	293.500	293.500	21.576
14218	NORTHFIELD MOUNTAIN 2	14218	NORTHFIELD MOUNTAIN 2	PS	WAT		HYDRO (PUMPED STORAGE)	30-Nov-72	FirstLight Power Resource Management, LLC	NEL1	MA	011	WMA	WCMA	547	291.650	293.500	293.500	293.500	293.500	1.118
14219	NORTHFIELD MOUNTAIN 3	14219	NORTHFIELD MOUNTAIN 3	PS	WAT		HYDRO (PUMPED STORAGE)	30-Nov-72	FirstLight Power Resource Management, LLC	NEL1	MA	011	WMA	WCMA	547	291.650	292.000	292.000	292.000	292.000	0.000
14220	NORTHFIELD MOUNTAIN 4	14220	NORTHFIELD MOUNTAIN 4	PS	WAT		HYDRO (PUMPED STORAGE)	30-Nov-72	FirstLight Power Resource Management, LLC	NEL1	MA	011	WMA	WCMA	547	291.650	293.500	293.408	293.500	293.408	-0.092
14271	AMERESCO NORTHAMPTON	14271	Ameresco Northampton	IC	LFG		BIO/REFUSE	01-Nov-07	Exelon Generation Company, LLC	EXGC	MA	015	WMA	WCMA		0.800	0.752	0.748	0.752	0.748	0.003
14595	GRANITE RELIABLE POWER, LLC	14595	Granite Reliable Power	WT	WND		WIND TURBINE	15-Feb-12	Granite Reliable Power, LLC	GRP	NH	007	NH	NH	58004	99.000	29.520	15.024	29.520	15.024	3.216
14610	PRINCETON WIND FARM PROJECT	14610	Princeton Wind Farm Project	WT	WND		WIND TURBINE	01-Sep-09	Princeton Municipal Light Department	PMLD	MA	027	WMA	WCMA	7501	3.000	0.269	0.243	0.269	0.243	0.111
14614	KLEEN ENERGY	14614	Kleen Energy	CC	NG	DFO	GAS/OIL COMBINED CYCLE	12-Jul-11	Exelon Generation Company, LLC	EXGC	CT	007	CT	CT	56798	589.000	620.000	620.000	620.000	620.000	0.000
14623	VALLEY HYDRO (STATION NO. 5)	14623	Valley Hydro (Station No. 5)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-08	Holyoke Gas & Electric Department	HGE	MA	013	WMA	WCMA		0.749	0.679	0.000	0.679	0.000	-0.643
14652	TEMPLETON WIND TURBINE	14652	Templeton Wind Turbine	WT	WND		WIND TURBINE	18-May-11	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	027	WMA	WCMA		1.500	0.099	0.000	0.099	0.000	-0.060
14665	RECORD HILL WIND	14665	Record Hill Wind	WT	WND		WIND TURBINE	31-Jan-12	Record Hill Wind, LLC	RHW	ME	017	ME	ME	57568	50.600	11.212	6.564	11.212	6.900	2.048
14695	ORONO	14695	Orono Hydro Station	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	29-Dec-08	Black Bear Hydro Partners, LLC	BBHP	ME	019	BHE	ME	57184	2.623	1.606	0.070	1.606	0.070	-1.402
14707	COVANTA HAVERHILL - LF GAS	12553	Covanta Haverhill Landfill Gas Engine	IC	LFG		BIO/REFUSE	05-Dec-07	Covanta Haverhill Associates	CHA	MA	009	BOSTON	NEMA	50661	1.603	0.892	0.993	0.892	0.993	-0.047
14767	PINE TREE LFGTE		No Resource (1)	IC	LFG		BIO/REFUSE	01-Jan-08	NextEra Energy Power Marketing, LLC	FPLP	ME	019	BHE	ME		2.893	0.000	0.000	0.000	0.000	0.000
14801	CABOT	766	CABOT TURNERS FALLS	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-05	FirstLight Power Resource Management, LLC	NEL1	MA	011	WMA	WCMA	1629	61.920	61.800	61.800	61.800	61.800	0.000
14808	TURNERSFALLS	766	CABOT TURNERS FALLS	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-05	FirstLight Power Resource Management, LLC	NEL1	MA	011	WMA	WCMA	6388	6.400	6.400	6.400	6.400	6.400	0.000
14816	NORDEN 1	16688	Nor1	IC	DFO		OIL INTERNAL COMBUSTION	26-Feb-09	Connecticut Municipal Electric Energy Cooperative	CMEEC	CT	001	NOR	CT	57689	2.053	1.760	1.788	1.760	1.788	-0.001
14817	NORDEN 2	16750	Norden #2	IC	DFO		OIL INTERNAL COMBUSTION	26-Feb-09	Connecticut Municipal Electric Energy Cooperative	CMEEC	CT	001	NOR	CT	57689	2.053	1.765	1.790	1.765	1.790	0.000
14818	NORDEN 3	16752	Norden #3	IC	DFO		OIL INTERNAL COMBUSTION	26-Feb-09	Connecticut Municipal Electric Energy Cooperative	CMEEC	CT	001	NOR	CT	57689	2.053	1.753	1.776	1.753	1.776	-0.001
14823	NORWICH WWTP	38760	NORWICH WWT	IC	DFO		OIL INTERNAL COMBUSTION	29-May-08	Connecticut Municipal Electric Energy Cooperative	CMEEC	CT	011	CT	CT	57624	2.250	2.000	2.000	2.000	2.000	0.000
14925	ICE HOUSE PARTNERS INC.		No Resource (1)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Apr-08	Littleton Electric Light & Water Department	LELWD	MA	017	CMA/NEMA	WCMA		0.221	0.099	0.000	0.099	0.000	-0.007
14937	UNION GAS STATION	759	MESSALONSKEE COMPOSITE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	19-Mar-08	Littleton Electric Light & Water Department	LELWD	ME	011	ME	ME		1.646	1.341	0.000	1.341	0.000	0.000
15097	KIMB ROCKY RIVER PH2	14706	Kimberly-Clark Corp Energy Independence Project	CC	NG		GAS COMBINED CYCLE	15-Jul-08	Kimberly-Clark Corporation	KCC	CT	005	SWCT	CT	58084	19.600	15.544	13.063	15.544	13.063	0.791
15115	LEMPSTER WIND	14660	Lempster Wind	WT	WND		WIND TURBINE	24-Sep-08	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH	56399	24.000	7.865	3.238	7.865	3.238	1.234
15201	FISKE HYDRO	35593	Fiske Hydro	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jun-08	Public Service Company of New Hampshire	PSNH	NH	005	VT	NH		0.810	0.166	0.000	0.166	0.000	0.000
15462	HOLY NAME CC JR SR HIGH SCHOOL		No Resource (1)	WT	WND		WIND TURBINE	01-Sep-08	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.600	0.000	0.000	0.000	0.000	0.000
15464	STETSON WIND FARM		No Resource (1)	WT	WND		WIND TURBINE	09-Dec-08	Stetson Holdings, LLC	STETSON	ME	029	BHE	ME	56989	53.739	17.102	7.795	17.102	7.795	0.240
15477	NEW HAVEN HARBOR UNIT 2	15477	New Haven Harbor Units 2, 3, & 4	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	30-May-12	PSEG New Haven, LLC	PSEG-NH	CT	009	CT	CT	6156	51.425	48.600	42.985	48.600	42.985	0.124
15484	THOMAS A. WATSON UNIT #1	12500	Thomas A. Watson	GT	NG	DFO	GAS/OIL COMBUSTION (GAS) TURBINE	22-Apr-09	Braintree Electric Light Department, Town of	BELD	MA	021	SEMA	SEMA	1660	58.000	57.400	52.600	57.400	52.600	0.000
15485	THOMAS A. WATSON UNIT #2	12500	Thomas A. Watson	GT	NG	DFO	GAS/OIL COMBUSTION (GAS) TURBINE	14-Apr-09	Braintree Electric Light Department, Town of	BELD	MA	021	SEMA	SEMA	1660	58.000	57.400	52.600	57.400	52.600	0.000
15509	PLAINFIELD RENEWABLE ENERGY	15509	Plainfield Renewable Energy	ST	WDS		BIO/REFUSE	12-Dec-13	Plainfield Renewable Energy, LLC	PRE	CT	015	CT	CT	56847	42.370	38.062	37.500	36.464	37.500	0.000
15617	MORETOWN LFGTE	35728	Moretown LG	IC	LFG		BIO/REFUSE	01-Dec-08	Green Mountain Power Corporation	GMP	VT	023	VT	VT	56891	3.190	3.008	1.862	3.008	1.862	-0.595
15706	BEAVER RIDGE WIND	37072	Beaver_Ridge_Wind	WT	WND		WIND TURBINE	15-Oct-08	New Hampshire Electric Cooperative, Inc.	NHEC	ME	027	ME	ME	57130	1.800	1.213	0.620	1.213	0.620	0.165
15787	WORONOCO HYDRO LLC	37077	Woronoco Hydro LLC	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-08	Power Supply Services, LLC	PSS	MA	013	WMA	WCMA	50166	2.700	0.895	0.000	0.895	0.000	-0.487
15940	DARTMOUTH CT GENERATOR 3	15415	Dartmouth Power Expansion	GT	NG	DFO	GAS/OIL COMBUSTION (GAS) TURBINE	12-Aug-09	Talen Energy Marketing, LLC	EPLU-I	MA	005	SEMA	SEMA	52026	23.248	20.508	19.578	20.508	19.578	0.000
15998	CROSSROADS LANDFILL	14663	WMRE Crossroads	IC	LFG		BIO/REFUSE	31-Dec-08	WM Renewable Energy, L.L.C.	WMRE	ME	025	ME	ME	57016	3.079	2.806	2.984	2.806	2.984	0.356
16089	TURNERS FALLS HYDRO LLC		No Resource (1)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-09	Power Supply Services, LLC	PSS	MA	011	WMA	WCMA		0.947	0.000	0.000	0.000	0.000	0.000
16183	RICHEYWOODWORKINGWIND&PVQF		No Resource (1)	WT	WND		WIND TURBINE	18-Feb-09	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.976	0.000	0.000	0.000	0.000	0.000
16188	WILSON HOLDINGS LLC - PV QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Feb-09	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.135	0.000	0.000	0.000	0.000	0.000
16233	CITY OF MEDFORD WIND QF		No Resource (1)	WT	WND		WIND TURBINE	27-Feb-09	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.100	0.000	0.000	0.000	0.000	0.000
16234	CONSTELLATION-MAJILITE PV QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Feb-09	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.375	0.000	0.000	0.000	0.000	0.000
16296	MILFORD HYDRO	16296	Milford Hydro	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-11	Black Bear Hydro Partners, LLC	BBHP	ME	019	BHE	ME	1475	8.699	6.530	2.790	6.530	2.790	-2.043
16331	QUARRY ENERGY PROJECT		No Resource (1)	IC	LFG		BIO/REFUSE	03-Apr-09	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.571	0.335	0.328	0.335	0.328	-0.052
16386	NATURE'SCLASSROOM-01507WT185NM		No Resource (1)	WT	WND		WIND TURBINE	24-Apr-09	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.185	0.000	0.026	0.000	0.026	0.005
16523	STILLWATER	16523	Stillwater	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-11	Black Bear Hydro Partners, LLC	BBHP	ME	019	BHE	ME	1478	1.964	1.222	1.427	1.222	1.427	-0.287
16525	MEDWAY	16525	Medway	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Jan-11	Black Bear Hydro Partners, LLC	BBHP	ME	019	BHE	ME	55288	4.841	3.457	2.925	3.457	2.925	-0.774
16612	STETSON II WIND FARM		No Resource (1)	WT	WND		WIND TURBINE	12-Mar-10	Stetson Wind II, LLC.	STET2	ME	029	BHE	ME	56991	23.670	6.689	3.328	6.689	3.328	0.316
16614	BERKSHIRE WIND POWER PROJECT	14661	Berkshire Wind Power Project	WT	WND		WIND TURBINE	28-May-11	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	003	WMA	WCMA	57721	15.003	5.667	1.745	5.667	1.745	0.031
16631	VICTORY ROAD DORCHESTER PV	16631	Victory Road Dorchester PV	PV	SUN		PHOTOVOLTAIC	22-Dec-11	Massachusetts Electric Company	MEC	MA	025	BOSTON	NEMA		1.000	0.000	0.513	0.000	0.513	-0.030
16640	HILLDALE AVE HAVERHILL PV	16640	Hilldale Ave Haverhill PV	PV	SUN		PHOTOVOLTAIC	15-Feb-11	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		1.000	0.000	0.373	0.000	0.373	0.001
16642	RAILROAD AVENUE REVERE PV	16642	Railroad Street Revere PV	PV	SUN		PHOTOVOLTAIC	16-Feb-11	Massachusetts Electric Company	MEC	MA	025	BOSTON	NEMA		1.000	0.000	0.340	0.000	0.340	0.061
16643	ROVER STREET EVERETT PV	16643	Rover Street Everett PV	PV	SUN		PHOTOVOLTAIC	18-Feb-11	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.500	0.000	0.233	0.000	0.233	0.001
16644	MAIN STREET WHITINSVILLE PV	16644	Main Street Whitinsville PV	PV	SUN		PHOTOVOLTAIC	01-Jul-10	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		1.000	0.000	0.390	0.000	0.390	-0.026
16653	BURGESS BIOPOWER	16653	Berlin Biopower	PB	WDS		BIO/REFUSE	17-Jun-14	Public Service Company of New Hampshire	PSNH	NH	007	NH	NH	58054	76.500	67.500	67.500	67.500	67.500	0.000

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
16659	IPSWICH WIND FARM 1	16659	Ipswich Wind Farm 1	WT	WND		WIND TURBINE	26-Jul-11	Ipswich Municipal Light Department	IMLD	MA	009	BOSTON	NEMA	57855	1.500	0.303	0.242	0.303	0.242	0.080
16675	FOX ISLAND WIND	16675	Fox Island Wind	WT	WND		WIND TURBINE	01-Sep-09	Vermont Public Power Supply Authority	VPPSA	ME	013	ME	ME	57354	4.500	0.059	0.000	0.059	0.000	0.000
16737	UDR GLASTONBURY	16737	DFC-ERG Hybrid Fuel Cell (3)	FC	NG		GAS FUEL CELL	15-Feb-16	UIL Distributed Resources LLC	UIL	CT	003	CT	CT	60109	3.400	2.774	2.683	2.774	2.683	-0.091
16738	DOMINION BRIDGEPORT FUEL CELL	16738	BFCP Fuel Cell	FC	NG		GAS FUEL CELL	22-Dec-13	Dominion Energy Marketing, Inc.	DEM	CT	001	SWCT	CT	58551	15.206	14.817	12.805	14.817	12.805	-0.941
16926	THUNDERMIST HYDRO QF	37120	Thundermist Hydropower	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	19-Sep-09	The Narragansett Electric Company	NEC	RI	007	RI	RI	54688	1.253	0.632	0.000	0.632	0.000	0.000
17023	NE ENGRS MIDDLETOWN RI WIND QF		No Resource (1)	WT	WND		WIND TURBINE	29-Oct-09	The Narragansett Electric Company	NEC	RI	005	SEMA	RI		0.100	0.000	0.000	0.000	0.000	0.000
17044	DEVON 16	12504	Devon 15-18	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	28-Jun-10	GenConn Energy LLC	GCE	CT	009	SWCT	CT	57070	60.500	49.200	46.900	49.200	46.900	0.000
17045	DEVON 17	12504	Devon 15-18	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	15-Jun-10	GenConn Energy LLC	GCE	CT	009	SWCT	CT	57070	60.500	49.200	46.900	49.200	46.900	0.000
17046	DEVON 18	12504	Devon 15-18	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	09-Jun-10	GenConn Energy LLC	GCE	CT	009	SWCT	CT	57070	60.500	49.200	46.900	49.200	46.900	0.000
17085	AMERESCO-NEWBURYPORT DPW PV QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Nov-09	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.095	0.000	0.030	0.000	0.030	-0.004
17128	OTIS_AF_WIND_TURBINE		No Resource (1)	WT	WND		WIND TURBINE	28-Dec-09	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA	57253	1.500	0.149	0.088	0.149	0.088	0.068
17194	TOWN_OF_FALMOUTH_WIND_TURBINE		No Resource (1)	WT	WND		WIND TURBINE	10-Feb-10	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA	57654	1.000	0.353	0.040	0.353	0.040	-0.177
17223	SUGAR RIVER 2	17359	Sugar River 2	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	08-Mar-10	Public Service Company of New Hampshire	PSNH	NH	019	NH	NH		0.199	0.157	0.000	0.157	0.000	0.000
17229	MOUNT ST MARY-WRENTHAM MA WIND		No Resource (1)	WT	WND		WIND TURBINE	15-Mar-10	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.100	0.006	0.005	0.006	0.005	0.004
17233	RAINBOW UNIT 1	35658	Rainbow_1	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-80	Connecticut Light and Power Company, The	CLP	CT	003	CT	CT	559	4.815	4.100	4.100	4.100	4.100	0.000
17234	RAINBOW UNIT 2	35656	Rainbow_2	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-Jan-80	Connecticut Light and Power Company, The	CLP	CT	003	CT	CT	559	4.986	4.100	4.100	4.100	4.100	0.000
17259	SEAMAN ENERGY LLC	35442	Seaman Energy	IC	LFG		BIO/REFUSE	31-Mar-10	Templeton Municipal Lighting Plant	TTMLP	MA	027	CMA/NEMA	WCMA		0.715	0.195	0.208	0.195	0.208	-0.026
35379	SPAULDING POND HYDRO	35594	Spaulding Pond Hydro	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-10	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH		0.265	0.136	0.000	0.136	0.000	0.000
35555	GMCW	35555	GMCW	WT	WND		WIND TURBINE	31-Dec-12	Burlington Electric Department	BED	VT	007	VT	VT	58238	10.002	3.576	0.762	3.576	0.762	0.057
35693	SPRUCE MOUNTAIN WIND	35693	Spruce Mountain Wind	WT	WND		WIND TURBINE	21-Dec-11	Spruce Mountain Wind, LLC	SPRUCE	ME	017	ME	ME	58026	20.000	7.519	3.197	7.519	3.197	1.105
35979	KINGDOM COMMUNITY WIND	35979	Kingdom Community Wind	WT	WND		WIND TURBINE	16-Nov-12	Green Mountain Power Corporation	GMP	VT	019	VT	VT	57979	64.575	17.460	11.470	17.460	11.470	3.310
36882	NOTUS WIND I		No Resource (1)	WT	WND		WIND TURBINE	23-Jun-10	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA	57414	1.500	0.559	0.268	0.559	0.268	0.256
37050	GROTON WIND	37050	Groton Wind Project	WT	WND		WIND TURBINE	28-Dec-12	Avangrid Renewables, LLC	PPMI	NH	009	NH	NH	58141	48.000	11.943	5.634	11.943	5.634	1.767
37073	SOUTHBRIDGE LANDFILL	38178	Southbridge Landfill Gas to Energy 17-18	IC	LFG		BIO/REFUSE	15-Feb-12	NextEra Energy Power Marketing, LLC	FPLP	MA	027	WMA	WCMA		1.541	1.506	1.438	1.506	1.438	0.006
37105	BINGHAM WIND	37105	BLUE SKY WEST	WT	WND		WIND TURBINE	13-Dec-16	Blue Sky West, LLC	BSWL	ME	025	ME	ME		175.560	0.000	0.000	0.000	42.270	42.270
37175	ROLLINS WIND PLANT		No Resource (1)	WT	WND		WIND TURBINE	26-Jul-11	Evergreen Wind Power III, LLC	EWP3	ME	019	BHE	ME	56990	55.620	17.623	8.179	17.623	8.179	1.812
37224	PATRIOT PL. D FOXBORO MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Oct-10	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.100	0.000	0.036	0.000	0.036	-0.002
37225	PATRIOT PL. E FOXBORO MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Oct-10	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.075	0.000	0.000	0.000	0.000	0.000
37226	PATRIOT PL. F FOXBORO MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Oct-10	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.100	0.000	0.000	0.000	0.000	0.000
37227	PATRIOT PL. H FOXBORO MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Oct-10	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.075	0.000	0.020	0.000	0.020	-0.002
37228	PATRIOT PL. J FOXBORO MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Oct-10	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.100	0.000	0.036	0.000	0.036	-0.002
37229	PATRIOT PL. K FOXBORO MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Oct-10	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.100	0.000	0.030	0.000	0.030	-0.003
37230	UNITED NAT. FOODS PROV. RI PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Oct-10	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.075	0.000	0.000	0.000	0.000	0.000
37266	CARLSON ORCH HARVARD MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Nov-10	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.200	0.000	0.086	0.000	0.086	-0.005
37267	SPRUCE ENV HAVERHILL MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Nov-10	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.082	0.000	0.000	0.000	0.000	0.000
37366	MIDDLETOWN 13	12505	Middletown 12-15	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	23-Jun-11	GenConn Energy LLC	GCE	CT	007	CT	CT	57068	60.500	49.200	46.900	49.200	46.900	0.000
37367	MIDDLETOWN 14	12505	Middletown 12-15	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	01-Jun-11	GenConn Energy LLC	GCE	CT	007	CT	CT	57068	60.500	49.200	46.900	49.200	46.900	0.000
37368	MIDDLETOWN 15	12505	Middletown 12-15	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	01-Jun-11	GenConn Energy LLC	GCE	CT	007	CT	CT	57068	60.500	49.200	46.900	49.200	46.900	0.000
37721	ROYAL MILLS WARWICK RI HYDRO		No Resource (1)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-10	The Narragansett Electric Company	NEC	RI	003	RI	RI		0.179	0.000	0.000	0.000	0.000	0.000
37722	SILVER LAKE SOLAR PV FACILITY	37051	Silver lake PV	PV	SUN		PHOTOVOLTAIC	06-Dec-10	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA	57676	1.500	0.000	0.646	0.000	0.646	-0.121
37751	NM-UNISTRESS		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jan-11	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.097	0.000	0.000	0.000	0.000	0.000
37752	NM-COUNTRY		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jan-11	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.127	0.000	0.000	0.000	0.000	0.000
37753	NM-HANCOCK		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jan-11	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.082	0.000	0.016	0.000	0.016	0.014
37754	NM-QUALITY		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jan-11	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.130	0.000	0.000	0.000	0.000	0.000
37755	NM-WOOD		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jan-11	Western Massachusetts Electric Company	WMECO	MA	011	WMA	WCMA		0.097	0.000	0.037	0.000	0.037	0.003
37756	NM-FOURSTAR		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jan-11	Western Massachusetts Electric Company	WMECO	MA	011	WMA	WCMA		0.067	0.000	0.018	0.000	0.018	0.000
37757	NM-ASTRO		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jan-11	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		0.097	0.000	0.000	0.000	0.000	0.000
37758	NM-MARLEY		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jan-11	Western Massachusetts Electric Company	WMECO	MA	015	WMA	WCMA		0.085	0.000	0.000	0.000	0.000	0.000
37759	NM-STONE		No Resource (1)	WT	WND		WIND TURBINE	01-Jan-11	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.615	0.007	0.000	0.007	0.000	0.000
37760	NM-RIVERVIEW		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jan-11	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.170	0.000	0.000	0.000	0.000	-0.004
37761	NM-PETRICCA		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jan-11	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.086	0.000	0.000	0.000	0.000	0.000
37823	INDIAN RIVER POWER SUPPLY LLC	37079	Indian River Power Supply LLC	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-11	Power Supply Services, LLC	PSS	MA	013	WMA	WCMA		1.300	0.434	0.000	0.434	0.000	-0.200
37955	TRANS MED TYNGSBORO MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Mar-11	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.096	0.000	0.028	0.000	0.028	-0.001
37956	PH HENBIL BILLERICA MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Mar-11	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.075	0.000	0.010	0.000	0.010	0.001
37957	CHELM WTR N CHELMSFORD MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Mar-11	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.500	0.000	0.065	0.000	0.065	0.065
37958	PETER W ELEM LOWELL MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Mar-11	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.138	0.000	0.019	0.000	0.019	0.019
37959	CIRCLE FIN NEWBURYPORT MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Mar-11	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.120	0.000	0.024	0.000	0.024	0.024
37965	BIO-DETEK PAWTUCKET RI PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Mar-11	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.165	0.000	0.000	0.000	0.000	0.000
37966	LTI HARVARD AP HARVARD MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Mar-11	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.085	0.000	0.024	0.000	0.024	0.024
37967	HILLSIDE MARLBOROUGH MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Mar-11	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.125	0.000	0.005	0.000	0.005	-0.003
37968	LOW MEM AUD LOWELL MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Mar-11	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.075	0.000	0.028	0.000	0.028	0.001
37972	DARTMOUTHBUSPARK_PV_ID1592		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Mar-11	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA	57473	1.600	0.000	0.730	0.000	0.730	-0.003
37973	GENERAL MILLS METHUEN MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Mar-11	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.096	0.000	0.000	0.000	0.000	0.000
38083	ORONO B HYDRO	38083	Orono "B" Hydro	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Oct-13	Black Bear Hydro Partners, LLC	BBHP	ME	019	BHE	ME		4.000	3.630	2.632	3.630	2.632	-1.068
38084	STILLWATER B HYDRO	38084	Stillwater "B" Hydro	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	20-Sep-13	Black Bear Hydro Partners, LLC	BBHP	ME	019	BHE	ME		2.400	1.784	0.789	1.784	0.789	-1.251
38115	HARRINGTON STREET PV	38115	HARRINGTON STREET PV PROJECT	PV	SUN		PHOTOVOLTAIC	23-Dec-16	Hampshire Council of Governments	HCG	MA	027	WMA	WCMA		9.263	0.000	0.000	0.000	1.430	0.000
38173	SADDLEBACK RIDGE WIND	38173	Saddleback Ridge Wind	WT	WND		WIND TURBINE	19-Dec-14	Spruce Mountain Wind, LLC	SPRUCE	ME	007	ME	ME	58608	34.200	11.192	5.090	11.192	5.090	4.300
38287	WMA CHESTER SOLAR 1	38287	WMA Chester Solar 1	PV	SUN		PHOTOVOLTAIC	01-Jul-14	Vermont Public Power Supply Authority	VPPSA	MA	013	WMA	WCMA	59767	4.800	0.000	2.487	0.000	2.487	0.044
38302	TOWN_OF_CARVER_PV_1763	38302	Fisher Road Solar I	PV	SUN		PHOTOVOLTAIC	03-Sep-14	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		4.560	0.000	2.649	0.000	2.649	-0.011
38372	BLUEWAVE - CC COMM COLL 2209	38372	Dartmouth Solar	PV	SUN		PHOTOVOLTAIC	12-May-16	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		3.500	0.000	1.593	0.000	1.593	1.593

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report				
																	WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
38373	BLUEWAVE BOURNE-HOLLISTON 2262	38373	Holliston	PV	SUN		PHOTOVOLTAIC	06-Aug-15	NSTAR Electric Company	NSTAR	MA	017	RI	SEMA		3.000	0.000	1.590	0.000	1.590	1.260
38375	BWC FIVEMILE-01569PV3000NM	38375	Uxbridge	PV	SUN		PHOTOVOLTAIC	23-Dec-15	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		3.000	0.021	1.308	0.021	1.308	0.078
38417	PASSADUMKEAG WIND PROJECT	38638	PASSADUMKEAG WIND PROJECT	WT	WND		WIND TURBINE	01-Jul-16	EDF Energy Services, LLC	EDFS	ME	019	BHE	ME	59222	42.900	0.000	6.680	0.000	6.680	4.680
38441	UI RCP BGPT FC	38441	UI RCP BGPT FC	FC	NG		GAS FUEL CELL	16-Nov-15	United Illuminating Company, The	UI	CT	001	SWCT	CT	60054	2.800	2.797	2.680	2.797	2.680	0.321
38442	UI RCP NH FC	38442	UI RCP NH FC	FC	NG		GAS FUEL CELL	03-Aug-15	United Illuminating Company, The	UI	CT	009	CT	CT	60040	2.800	2.725	2.625	2.725	2.625	0.257
38495	BLOCK ISLAND WIND FARM	38495	DEEPWATER WIND BLOCK ISLAND	WT	WND		WIND TURBINE	09-Dec-16	Deepwater Wind Block Island, LLC	DWBI	RI	009	RI	RI		29.250	0.000	0.000	0.000	6.830	6.830
38580	HUNTRDSOLARLLC-01913PV4500NM	38580	AMESBURY	PV	SUN		PHOTOVOLTAIC	22-Mar-17	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		4.500	0.000	0.000	0.000	2.312	2.312
38581	TYNGS.LANDFILL#1-01879PV1692NM	38581	TYNGSBOROUGH	PV	SUN		PHOTOVOLTAIC	23-Mar-17	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		1.656	0.000	0.000	0.000	1.283	1.283
38757	UI RCP WOODBRIDGE FC		No Resource (1)	FC	NG		GAS FUEL CELL	17-Dec-16	United Illuminating Company, The	UI	CT	009	SWCT	CT		2.800	0.000	0.000	0.000	2.200	2.200
39663	BARNSTABLE_DPW_ID1545		No Resource (1)	WT	WND		WIND TURBINE	01-Aug-11	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		0.200	0.019	0.357	0.019	0.357	0.038
39664	DART_BLDG_SUPPLY_ID1470		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Aug-11	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		0.200	0.000	0.060	0.000	0.060	0.011
39665	YARMOUTH_DPW_ID1740		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Aug-11	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		0.265	0.000	0.104	0.000	0.104	-0.011
39675	TURKEY HILL		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Aug-11	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.100	0.000	0.017	0.000	0.017	0.004
39717	HI-GEAR		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Oct-11	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.300	0.000	0.114	0.000	0.114	0.011
39722	GTR_BOSTON_FOODBANKS_ID1628		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Oct-11	NSTAR Electric Company	NSTAR	MA	025	BOSTON	NEMA		0.177	0.000	0.015	0.000	0.015	-0.070
39724	EASTERN_AVE_HOLDINGS_PV_ID1652		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Oct-11	NSTAR Electric Company	NSTAR	MA	025	BOSTON	NEMA		0.160	0.000	0.053	0.000	0.053	-0.031
39738	MWRA_LORING_RD_ID1400		No Resource (1)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Nov-11	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.189	0.126	0.133	0.126	0.133	-0.007
40015	INDIAN ORCHARD SOLAR FACILITY	38081	Indian Orchard Solar PV	PV	SUN		PHOTOVOLTAIC	01-Dec-11	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		1.500	0.000	0.832	0.000	0.832	-0.104
40050	EXETER AGRI ENERGY		No Resource (1)	IC	OBG		BIO/REFUSE	19-Dec-11	Vermont Public Power Supply Authority	VPPSA	ME	019	BHE	ME		0.980	0.779	0.863	0.779	0.863	0.565
40052	NEW HAVEN HARBOR UNIT 3	15477	New Haven Harbor Units 2, 3, & 4	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	30-May-12	PSEG New Haven, LLC	PSEG-NH	CT	009	CT	CT	6156	51.425	48.600	42.985	48.600	42.985	0.124
40053	NEW HAVEN HARBOR UNIT 4	15477	New Haven Harbor Units 2, 3, & 4	GT	KER	NG	OIL COMBUSTION (GAS) TURBINE	30-May-12	PSEG New Haven, LLC	PSEG-NH	CT	009	CT	CT	6156	51.425	48.600	42.985	48.600	42.985	0.124
40054	JOHNSTON LFG TURBINE PLANT	14599	Rhode Island LFG Genco, LLC - ST	CC	LFG		BIO/REFUSE	25-May-13	Rhode Island Engine Genco, LLC	RRIG	RI	007	RI	RI	59254	42.394	27.891	26.291	27.891	26.291	-0.139
40066	OLDBARNST_RD_MASHPEE_PV_ID1798		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Jan-12	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		0.312	0.000	0.068	0.000	0.068	0.007
40067	MARION_DR_KINGSTON_WT_ID1656		No Resource (1)	WT	WND		WIND TURBINE	16-Jan-12	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		6.000	0.961	0.631	0.961	0.631	0.096
40085	QUABBIN 1_ORANGE MA PV NET		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Jan-12	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA		0.095	0.000	0.000	0.000	0.000	0.000
40116	DELAWARE VALLEY CORP PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	31-Jan-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.095	0.000	0.000	0.000	0.000	0.000
40137	BERKSHIRE EAST WIND		No Resource (1)	WT	WND		WIND TURBINE	03-Feb-12	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA		0.900	0.000	0.242	0.000	0.242	-0.008
40176	NFM SOLAR POWER, LLC	38078	NFM Solar Power, LLC	PV	SUN		PHOTOVOLTAIC	18-Feb-12	FirstLight Power Resource Management, LLC	NEL1	MA	011	WMA	WCMA	58210	1.700	0.000	0.724	0.000	0.724	-0.010
40194	MICRON		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Mar-12	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.096	0.000	0.000	0.000	0.000	0.000
40207	KEZAR UPPER FALLS	786	KEZAR LEDGEMERE COMPOSITE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-12	Epico USA, Inc.	EPICO	ME	005	SME	ME	7668	0.404	0.331	0.000	0.331	0.000	0.000
40208	KEZAR LOWER FALLS	786	KEZAR LEDGEMERE COMPOSITE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-12	Epico USA, Inc.	EPICO	ME	005	SME	ME	7668	0.586	0.445	0.000	0.445	0.000	-0.079
40209	LEDGEMERE	786	KEZAR LEDGEMERE COMPOSITE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Mar-12	Epico USA, Inc.	EPICO	ME	005	SME	ME	7668	0.513	0.000	0.000	0.000	0.000	-0.034
40225	MILLIPORE PV - BILLERICA		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Mar-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.143	0.000	0.000	0.000	0.000	0.000
40242	TANTASQUA JR HIGH_PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	30-Mar-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.300	0.000	0.015	0.000	0.015	-0.003
40243	SOLAR SHOP LLC BLDG 14_PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Mar-12	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.256	0.000	0.039	0.000	0.039	0.001
40244	SOLAR SHOP LLC BLDG 10_PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Mar-12	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.120	0.000	0.046	0.000	0.046	0.003
40246	HODGES BADGE CO_WIND		No Resource (1)	WT	WND		WIND TURBINE	30-Mar-12	The Narragansett Electric Company	NEC	RI	005	SEMA	RI		0.225	0.000	0.000	0.000	0.000	0.000
40247	QUABBIN BARRE - WIND		No Resource (1)	WT	WND		WIND TURBINE	29-Mar-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.261	0.000	0.261	-0.165
40248	JJ CARROLL WW PLANT_PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Mar-12	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.300	0.000	0.232	0.000	0.232	0.018
40249	WESTBORO SUITES		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Mar-12	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.266	0.000	0.004	0.000	0.004	0.004
40250	SHAWS SUPER MARKET		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Mar-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.250	0.000	0.000	0.000	0.000	0.000
40251	VETERAN HOMESTEAD PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Mar-12	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.323	0.000	0.012	0.000	0.012	-0.003
40259	COMMERCE_PK_RD_PV_ID1871		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Apr-12	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		0.350	0.000	0.134	0.000	0.134	0.004
40263	MATOUK TEXTILE WORKS		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Apr-12	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.084	0.000	0.000	0.000	0.000	0.000
40270	TECTA AMERICA		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Apr-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.130	0.000	0.021	0.000	0.021	0.004
40327	FORE RIVER 11	1691	FORE RIVER-1	CC	NG	DFO	GAS/OIL COMBINED CYCLE	04-Aug-03	Calpine Energy Services, LP	CALP	MA	021	SEMA	SEMA	55317	436.165	416.611	349.602	416.611	349.602	-6.269
40328	FORE RIVER 12	1691	FORE RIVER-1	CC	NG	DFO	GAS/OIL COMBINED CYCLE	04-Aug-03	Calpine Energy Services, LP	CALP	MA	021	SEMA	SEMA	55317	436.165	421.500	349.602	421.500	349.602	-6.269
40338	MAINE INDEPENDENCE STATION 1	1216	MAINE INDEPENDENCE STATION	CC	NG		GAS COMBINED CYCLE	01-May-00	Dynegy Marketing and Trade, LLC	DMT1	ME	019	BHE	ME	55068	275.655	269.138	244.138	269.138	244.138	0.000
40339	MAINE INDEPENDENCE STATION 2	1216	MAINE INDEPENDENCE STATION	CC	NG		GAS COMBINED CYCLE	01-May-00	Dynegy Marketing and Trade, LLC	DMT1	ME	019	BHE	ME	55068	275.655	269.138	244.138	269.138	244.138	0.000
40343	BULL HILL WIND		No Resource (1)	WT	WND		WIND TURBINE	27-Oct-12	Blue Sky East, LLC	BSE	ME	009	BHE	ME	57083	32.761	13.261	7.361	13.261	7.361	0.352
40365	EAST ISLAND COMMUNITY - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Apr-12	Massachusetts Electric Company	MEC	MA	009	CMA/NEMA	WCMA		0.100	0.000	0.037	0.000	0.037	-0.001
40482	DURFEE UNION MILLS BLDG 9 - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-May-12	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.120	0.000	0.013	0.000	0.013	0.013
40483	TYNGSBOROUGH SPORTS PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-May-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.100	0.000	0.000	0.000	0.000	0.000
40484	BANCROFT SCHOOL PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-May-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.120	0.000	0.000	0.000	0.000	0.000
40485	LITCHFIELD LEOMINSTER PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-May-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.062	0.000	0.000	0.000	0.000	0.000
40520	MANCHESTER-BOSTON REGIONAL PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-May-12	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH		0.500	0.000	0.009	0.000	0.009	-0.021
40524	MOUNT WACHUSSETT CC WIND		No Resource (1)	WT	WND		WIND TURBINE	11-May-12	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		3.300	0.000	0.000	0.000	0.000	0.000
40555	BLACKCOMB WORC MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-May-12	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.430	0.000	0.062	0.000	0.062	-0.004
41782	PAWTUCKET MEMORIAL ELEM SCH		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-May-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.100	0.000	0.000	0.000	0.000	0.000
41783	PHOENIX FINANCE LLC		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-May-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.190	0.000	0.024	0.000	0.024	0.006
41784	NANTUCKET HIGH SCHOOL		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-May-12	Massachusetts Electric Company	MEC	MA	019	SEMA	SEMA		0.100	0.000	0.000	0.000	0.000	0.000
41806	NM-PROPEL		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jun-12	Western Massachusetts Electric Company	WMECO	MA	011	WMA	WCMA		0.260	0.000	0.017	0.000	0.017	0.009
41807	NM-PITTSFIELD WWTP		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jun-12	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA	59060	1.500	0.000	0.689	0.000	0.689	0.036
41808	NM-MASS DEP		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jun-12	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		0.120	0.000	0.006	0.000	0.006	-0.001
41810	NM-FULL BLOOM MARKET		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jun-12	Western Massachusetts Electric Company	WMECO	MA	011	WMA	WCMA		0.100	0.000	0.007	0.000	0.007	-0.017
41811	NM-BERKSHIRE CC		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jun-12	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.386	0.000	0.000	0.000	0.000	0.000
41816	QUABOAG REGIONAL ELEM - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Jun-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.100	0.000	0.032	0.000	0.032	0.002
41819	US PACK - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jun-12	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.200	0.000	0.037	0.000	0.037	0.001
41820	EDMUND TALBOT MS - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jun-12	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.200	0.000	0.016	0.000	0.016	0.016
41821	NEW ENGLAND TECH WIND		No Resource (1)	WT	WND		WIND TURBINE	19-Jun-12	The Narragansett Electric Company	NEC	RI	003	RI	RI		1.000	0.000	0.000	0.000	0.000	0.000

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report				
																	WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
41822	SOLTAS CBIS INC - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jun-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.300	0.000	0.000	0.000	0.000	0.000
41827	TOWN_OF_FAIRHAVEN_WT_ID1663		No Resource (1)	WT	WND		WIND TURBINE	13-Jun-12	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		0.350	0.170	0.279	0.170	0.279	0.087
41828	TOWN_OF_FAIRHAVEN_WT_ID1664		No Resource (1)	WT	WND		WIND TURBINE	13-Jun-12	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		0.350	0.255	0.088	0.255	0.088	-0.157
41829	MWRA_ALFORD_ST_WT_ID1638		No Resource (1)	WT	WND		WIND TURBINE	13-Jun-12	NSTAR Electric Company	NSTAR	MA	025	BOSTON	NEMA		1.500	0.063	0.130	0.063	0.130	0.027
41830	TOWN_OF_KINGSTON_WT_ID1833		No Resource (1)	WT	WND		WIND TURBINE	13-Jun-12	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		2.000	0.197	0.000	0.197	0.000	-0.168
41833	JEM ELECTRONIS PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Jun-12	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.214	0.000	0.024	0.000	0.024	-0.012
41834	CLARKE DISTRIBUTION PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Jun-12	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.375	0.000	0.074	0.000	0.074	0.000
41838	WEST BROOKFIELD ELEM - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Jun-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.096	0.000	0.044	0.000	0.044	-0.007
41839	ARPIN ASSOCIATES - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Jun-12	The Narragansett Electric Company	NEC	RI	003	RI	RI		0.150	0.000	0.000	0.000	0.000	0.000
41840	AERO MANUFACTURING		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Jun-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.096	0.000	0.000	0.000	0.000	0.000
41841	EXAJOULE FRANKLIN PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Jun-12	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.260	0.000	0.000	0.000	0.000	0.000
41842	KB SOLAR LLC - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jun-12	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.250	0.000	0.124	0.000	0.124	0.027
41843	NORTHEAST TREATERS		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Jun-12	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		0.224	0.000	0.056	0.000	0.056	0.010
41844	LOWELL TRANSIT MGMT PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Jun-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.500	0.000	0.028	0.000	0.028	-0.082
41845	TRADER JOES SAUGUS PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Jun-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.225	0.000	0.000	0.000	0.000	0.000
41846	KOLLMORGEN PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Jun-12	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		0.210	0.000	0.000	0.000	0.000	0.000
41847	FISHERMENS MEMORIAL PARK- WIND		No Resource (1)	WT	WND		WIND TURBINE	20-Jun-12	The Narragansett Electric Company	NEC	RI	009	RI	RI		0.100	0.001	0.000	0.001	0.000	0.000
41848	SOLAR SHOP WHITINSVILLE - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Jun-12	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.500	0.000	0.234	0.000	0.234	0.005
41856	MASSASOIT COMMUNITY COLLEGE		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Jun-12	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.370	0.000	0.000	0.000	0.000	0.000
41857	HI- GEAR (QF)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jul-12	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.675	0.000	0.359	0.000	0.359	0.014
41863	THE WHEELER SCHOOL		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Jun-12	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.100	0.000	0.030	0.000	0.030	0.030
41864	NM-EHAMPTON MA LANDFILL		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jul-12	Western Massachusetts Electric Company	WMECO	MA	015	WMA	WCMA	58272	2.000	0.000	1.016	0.000	1.016	0.117
41866	LOWES HOME CENTER QUINCY - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Jul-12	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.340	0.000	0.000	0.000	0.000	0.000
41867	SCITUATE TOWN OF WIND		No Resource (1)	WT	WND		WIND TURBINE	11-Jul-12	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		1.500	0.142	0.131	0.142	0.131	0.131
41868	AGREEN ENERGY (JORDAN DAIRY)		No Resource (1)	IC	OBG		BIO/REFUSE	16-Jul-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.600	0.327	0.149	0.327	0.149	-0.220
41870	EXAJOULE RENEWABLES PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jul-12	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.360	0.000	0.160	0.000	0.160	0.009
41871	QUABBIN SOLAR - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jul-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.217	0.000	0.217	-0.210
41879	WESTFORD SOLAR 1- PV	38181	Westford Solar	PV	SUN		PHOTOVOLTAIC	18-Jul-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA	58534	1.000	0.000	0.498	0.000	0.498	0.002
41880	WESTFORD SOLAR 2- PV	38181	Westford Solar	PV	SUN		PHOTOVOLTAIC	18-Jul-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA	58534	1.000	0.000	0.485	0.000	0.485	-0.003
41881	TOWN OF SWAMPSCOTT HS - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jul-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.350	0.000	0.163	0.000	0.163	-0.008
41882	NEXAMP CAP-NASHOBA VALLEY THS		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Jul-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.096	0.000	0.000	0.000	0.000	0.000
41921	M&I REALTY JAMES ST - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Jul-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.200	0.000	0.000	0.000	0.000	0.000
41922	LIGHTOLIER - WIND		No Resource (1)	WT	WND		WIND TURBINE	23-Jul-12	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		2.000	0.180	0.000	0.180	0.000	-0.121
41923	BLACKCOMB SOLAR III-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Jul-12	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		1.000	0.000	0.412	0.000	0.412	0.049
41924	COREMARK-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Jul-12	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		1.000	0.000	0.166	0.000	0.166	0.050
42041	D.D. BEAN		No Resource (1)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	02-Aug-12	Constellation NewEnergy, Inc.	CNE	NH	005	VT	NH		0.027	0.000	0.000	0.000	0.000	0.000
42043	SWANSEA WATER DISTRICT		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-Aug-12	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.080	0.000	0.000	0.000	0.000	0.000
42045	NM-GREENFIELD MA LANDFILL		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Aug-12	Western Massachusetts Electric Company	WMECO	MA	011	WMA	WCMA		2.000	0.000	0.163	0.000	0.163	-0.762
42046	ST. MARYS HIGH SCHOOL		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-Aug-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.155	0.000	0.000	0.000	0.000	0.000
42048	TANTASQUA HIGH- PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Aug-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.586	0.000	0.000	0.000	0.000	0.000
42050	PETE'S TIRE BARN		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-Aug-12	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA		0.155	0.000	0.072	0.000	0.072	0.005
42083	CANTON_LANDFILL_PV_ID1726		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Aug-12	NSTAR Electric Company	NSTAR	MA	021	SEMA	SEMA		3.000	0.000	2.186	0.000	2.186	-0.267
42091	QUABOAG REGIONAL HS - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Aug-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.096	0.000	0.051	0.000	0.051	0.005
42092	TOWN OF SUTTON MA PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Aug-12	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.175	0.000	0.000	0.000	0.000	0.000
42104	HYDEPARKSTORPV_ID1919		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	025	BOSTON	NEMA		0.190	0.000	0.067	0.000	0.067	-0.008
42105	MILLST_NATICKPV_ID1818		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.202	0.000	0.070	0.000	0.070	-0.002
42106	SUBURBANATHLETIC2_ID1637		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.110	0.000	0.000	0.000	0.000	-0.030
42107	4M_ALDRINRDPV_ID1856		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		0.200	0.000	0.007	0.000	0.007	-0.039
42108	BROADWAY_RENEWABLE_ID1772		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		0.907	0.000	0.402	0.000	0.402	0.020
42109	COCHITUATERD_FRAMPV_ID1873		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.204	0.000	0.085	0.000	0.085	0.003
42110	DOUGLAS_SCHOOLPV_ID1464		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.095	0.000	0.035	0.000	0.035	0.000
42111	HYANNIS_SELF_STOR_ID1946		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		0.475	0.000	0.192	0.000	0.192	0.002
42112	POND_ST_ASHLAND_ID1736		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.500	0.000	0.184	0.000	0.184	-0.010
42113	COBSCOOK BAY TEP TGU 1		No Resource (1)	HTO	WAT		HYDRO - OTHER	04-Sep-12	New Brunswick Energy Marketing Corporation	NBPGC	ME	029	BHE	ME		0.034	0.000	0.000	0.000		
42114	PUMPKIN HILL	1258	BHE SMALL HYDRO COMPOSITE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Dec-82	New Brunswick Energy Marketing Corporation	NBPGC	ME	019	BHE	ME	50699	2.087	0.860	0.000	0.860	0.000	0.000
42115	GLC_ACUSHNETLLC_ID1821_1824		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA	58270	3.500	0.000	1.877	0.000	1.877	-0.121
42116	DSD_REALTY_TRUST_ID1672		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		1.720	0.000	0.544	0.000	0.544	0.008
42117	CONST_SOLAR_NORFOLK_ID1846		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	021	RI	SEMA		1.600	0.000	0.686	0.000	0.686	0.023
42118	CONED_HIXVILLERD_ID1862		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-12	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		2.000	0.000	1.155	0.000	1.155	-0.016
42123	KEZAR MIDDLE FALLS	786	KEZAR LEDGEMERE COMPOSITE	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Oct-12	Epico USA, Inc.	EPICO	ME	005	SME	ME		1.282	0.054	0.037	0.054	0.037	-0.016
42135	18 PHOENIX PARK BLDG DEAST & F		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Sep-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.100	0.000	0.000	0.000	0.000	0.000
42136	18 PHOENIX PARK BLDG DEAST & J		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Sep-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.100	0.000	0.000	0.000	0.000	0.000
42137	18 PHOENIX PARK BLDG DWEST		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Sep-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.100	0.000	0.009	0.000	0.009	-0.006
42149	FAVORITE FOODS PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Oct-12	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH		0.045	0.000	0.000	0.000	0.000	0.000
42155	LEICESTER HS - BWAY RENEWABLE		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Oct-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.175	0.000	0.000	0.000	0.000	-0.035
42156	UMASS LOWELL LEITCH HALL		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Oct-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.120	0.000	0.000	0.000	0.000	0.000
42158	MOHAWK DRIVE CORPORATION		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Oct-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.113	0.000	0.023	0.000	0.023	-0.008
42193	TRUE NORTH ENERGY A	38561	True North	PV	SUN		PHOTOVOLTAIC	16-Nov-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA	59390	1.000	0.000	0.000	0.000	0.000	0.000
42194	TRUE NORTH ENERGY B	38561	True North	PV	SUN		PHOTOVOLTAIC	16-Nov-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA	59390	1.000	0.000	0.493	0.000	0.493	-0.013
42195	TRUE NORTH ENERGY C	38561	True North	PV	SUN		PHOTOVOLTAIC	16-Nov-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.750	0.000	0.000	0.000	0.000	0.000

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report				
																	WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
42196	TRUE NORTH ENERGY D	38561	True North	PV	SUN		PHOTOVOLTAIC	16-Nov-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA	59390	1.000	0.000	0.545	0.000	0.545	0.022
42197	TRUE NORTH ENERGY E	38561	True North	PV	SUN		PHOTOVOLTAIC	16-Nov-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA	59390	1.000	0.000	0.534	0.000	0.534	0.026
42201	MATTHEW KUSS MS		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Nov-12	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.135	0.000	0.000	0.000	0.000	0.000
42202	DR AMP 100 AMES POND - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Nov-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.082	0.000	0.034	0.000	0.034	0.000
42203	WESTFORD SOLAR 3 - PV	38181	Westford Solar	PV	SUN		PHOTOVOLTAIC	08-Nov-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA	58534	1.000	0.000	0.494	0.000	0.494	-0.027
42204	BPV LOWELL		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Nov-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.190	0.000	0.017	0.000	0.017	-0.010
42205	SALEM STATE UNIVERSITY		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-Nov-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.164	0.000	0.000	0.000	0.000	0.000
42212	DR AMP 200 AMES POND - PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Nov-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.095	0.000	0.000	0.000	0.000	0.000
42213	CUMMINGS PROPERTY E GAR		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Nov-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.190	0.000	0.049	0.000	0.049	0.007
42214	ORCHARD MADE PRODUCTS		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-Nov-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.190	0.000	0.005	0.000	0.005	-0.004
42344	CAMELOT_WIND_ID1240		No Resource (1)	WT	WND		WIND TURBINE	01-Dec-12	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		1.500	0.259	0.181	0.259	0.181	0.016
42346	3 RIVERS PALMER-SPRINGFLD-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Dec-12	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		0.582	0.000	0.000	0.000	0.000	0.000
42347	CONSTELLATION SOLAR-UXBRG-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Dec-12	Massachusetts Electric Company	MEC	MA	027	RI	SEMA	57941	2.000	0.000	0.955	0.000	0.955	-0.029
42349	15 UNION SOLAR LLC-LAWRENCE-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Dec-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.490	0.000	0.013	0.000	0.013	-0.041
42350	BARRETT-FRANKLIN-SOLAR		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Dec-12	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.500	0.000	0.245	0.000	0.245	-0.007
42351	OMA GROUP-CHARLTON-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Dec-12	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.429	0.000	0.429	-0.022
42352	OSG SOLAR 1-ORANGE-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-Dec-12	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA	58411	1.000	0.000	0.488	0.000	0.488	0.014
42353	OSG SOLAR 2-ORANGE-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-Dec-12	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA	58411	1.000	0.000	0.492	0.000	0.492	0.016
42354	OSG SOLAR 3-ORANGE-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-Dec-12	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA		0.750	0.000	0.239	0.000	0.239	0.006
42355	CIL CEDAR-MARLBORO-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Dec-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.433	0.000	0.046	0.000	0.046	-0.007
42356	LEEWOOD SWIX-HAVERHILL-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Dec-12	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.496	0.004	0.001	0.004	0.001	-0.138
42357	UP BLACKSTONE WWTP-MILLBURY-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Dec-12	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.300	0.000	0.139	0.000	0.139	0.002
42359	FOREKICKS-MARLBORO-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Dec-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.270	0.000	0.075	0.000	0.075	0.075
42360	35 LYMAN LLC-NORTHBORO-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Dec-12	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.285	0.000	0.093	0.000	0.093	0.005
42364	CAPITAL GROUP-SOUTHBORO-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-12	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		1.000	0.000	0.327	0.000	0.327	-0.076
42365	LOFT 27-LOWELL-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-12	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.275	0.000	0.090	0.000	0.090	-0.024
42366	SOLTAS SPECTOR-LAWRENCE-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Dec-12	Massachusetts Electric Company	MEC	MA	009	CMA/NEMA	WCMA		0.300	0.000	0.155	0.000	0.155	0.002
42375	DEXTER 1	392	DEXTER	CC	NG	DFO	GAS/OIL COMBINED CYCLE	01-May-90	Algonquin Energy Services Inc.	AESR	CT	003	CT	CT	10567	57.000	38.363	37.839	38.363	37.839	0.000
42376	DEXTER 2	392	DEXTER	CC	NG		GAS COMBINED CYCLE	01-May-90	Algonquin Energy Services Inc.	AESR	CT	003	CT	CT	10567	19.000	2.167	4.432	2.167	4.432	0.000
42385	CORNER BROOK-MILFORD-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Dec-12	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.155	0.000	0.056	0.000	0.056	0.001
42394	WINDENERGYDEV-NKINGSTOWN-WIND		No Resource (1)	WT	WND		WIND TURBINE	02-Jan-13	The Narragansett Electric Company	NEC	RI	009	RI	RI		1.500	0.166	0.220	0.166	0.220	0.050
42411	EXTRA SPACE-PLAINVILLE-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Jan-13	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.143	0.000	0.038	0.000	0.038	-0.003
42412	EXTRA SPACE-SAUGUS-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Jan-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.162	0.000	0.031	0.000	0.031	0.002
42413	35 LYMAN LLC - ACTIVE		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Jan-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.190	0.000	0.000	0.000	0.000	0.000
42414	NE ELECTRO-FALL RIVER-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Jan-13	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.190	0.000	0.019	0.000	0.019	0.007
42424	IPSWICH WIND II	38437	Ipswich Wind II	WT	WND		WIND TURBINE	09-Jan-13	Ipswich Municipal Light Department	IMLD	MA	009	BOSTON	NEMA		2.000	0.377	0.153	0.377	0.153	0.023
42431	SOLECT PLUMBING-NORWELL-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Jan-13	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.200	0.000	0.042	0.000	0.042	0.042
42432	VAUGHN CORP-SALISBURY-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Jan-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.190	0.000	0.030	0.000	0.030	0.014
42433	BETHANY CHURCH-MENDON-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Jan-13	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.150	0.000	0.001	0.000	0.001	-0.025
42438	EXTRA SPACE-NORTHBORO-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jan-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.155	0.000	0.035	0.000	0.035	-0.007
42439	CITY OF BROCKTON-SWANSEA-PV1		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jan-13	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		1.000	0.000	0.507	0.000	0.507	-0.006
42440	CITY OF BROCKTON-SWANSEA-PV2		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jan-13	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		1.000	0.000	0.762	0.000	0.762	-0.029
42443	WAL-MART LUN (PV)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Jan-13	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.300	0.000	0.000	0.000	0.000	0.000
42444	MRTA (PV)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Jan-13	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.135	0.000	0.008	0.000	0.008	-0.010
42448	CITY OF GLOUCESTER 1 - WIND		No Resource (1)	WT	WND		WIND TURBINE	06-Feb-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		2.000	0.297	0.178	0.297	0.178	0.073
42449	CITY OF GLOUCESTER 2 - WIND		No Resource (1)	WT	WND		WIND TURBINE	06-Feb-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		2.000	0.238	0.151	0.238	0.151	0.118
42482	CITY_OF_WALTHAM_PV_ID1805		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Feb-13	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.193	0.000	0.064	0.000	0.064	0.008
42483	FIRST_HIGHLAND_PV_ID2021		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Feb-13	NSTAR Electric Company	NSTAR	MA	025	BOSTON	NEMA		0.975	0.000	0.411	0.000	0.411	0.011
42484	UNITEDSALVAGE_PV_ID1966		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Feb-13	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.808	0.000	0.307	0.000	0.307	-0.016
42485	SOLCHEMY_PV_ID1969		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Feb-13	NSTAR Electric Company	NSTAR	MA	007	SEMA	SEMA		0.293	0.000	0.122	0.000	0.122	0.016
42486	AIRPORT_WAY_PV_ID1875		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Feb-13	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		1.238	0.000	0.638	0.000	0.638	0.042
42487	BILL_BENNETT_PV_ID1967		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Feb-13	NSTAR Electric Company	NSTAR	MA	007	SEMA	SEMA		0.593	0.000	0.398	0.000	0.398	0.082
42495	VARIANSEMICON-GLOUCESTER-WT		No Resource (1)	WT	WND		WIND TURBINE	21-Feb-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		2.500	0.000	0.000	0.000	0.000	0.000
42496	HANOVER SOLAR-LEICESTER-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Feb-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.000	0.000	0.000	-0.295
42497	WESTFORD SOLAR 4- PV	38181	Westford Solar	PV	SUN		PHOTOVOLTAIC	21-Feb-13	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA	58534	1.000	0.000	0.500	0.000	0.500	-0.001
42504	BERKSHIRE SREG-GT BARRGTN-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Feb-13	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		0.082	0.000	0.000	0.000	0.000	0.000
42505	CUMMINGS 1000-BEVERLY-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Feb-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.190	0.000	0.079	0.000	0.079	-0.007
42597	GPT JACLEN-BEVERLY-CHP		No Resource (1)	IC	NG		GAS INTERNAL COMBUSTION	26-Mar-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.075	0.000	0.000	0.000	0.000	0.000
42598	NEW BARRE HYDRO	852	SOUTH BARRE HYDRO	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	02-Apr-13	Massachusetts Municipal Wholesale Electric Company	MMWEC	MA	027	WMA	WCMA		0.100	0.025	0.000	0.025	0.000	0.000
42599	MAPREMCT-97GREEN-02035-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Apr-13	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.300	0.000	0.073	0.000	0.073	0.073
42600	HOOSACVALREG-0ORCHARD-01225-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Apr-13	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		0.450	0.000	0.075	0.000	0.075	0.001
42601	CARLSTROMPM-65FISHER-0158-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Apr-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.600	0.000	0.216	0.000	0.216	-0.003
42602	KEYPOLYMER-1 JACOB-01843-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Apr-13	Massachusetts Electric Company	MEC	MA	009	CMA/NEMA	WCMA		0.600	0.000	0.018	0.000	0.018	-0.092
42603	BARRE1-750BARRE-01005-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Apr-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.800	0.000	0.372	0.000	0.372	0.024
42611	AUBUCHON-95AUBUCHON-01473-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Apr-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.500	0.000	0.129	0.000	0.129	0.004
42612	NPPDEVELOP-370PATRIOT-02035-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Apr-13	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.495	0.000	0.239	0.000	0.239	0.009
42613	AMERICOLD-0PEW-01930-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Apr-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.450	0.000	0.000	0.000	0.000	0.000
42631	CABRAL-247BAKER-02777-PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Apr-13	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.500	0.000	0.222	0.000	0.222	-0.016
42632	ALPHA GRAINGER-02038PV250NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Apr-13	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.250	0.000	0.000	0.000	0.000	0.000
42633	NORTHBORSPORTS-01532PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Apr-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.300	0.000	0.075	0.000	0.075	0.014

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
42641	NATICKMEMORIALSCHOOL_PV_ID1892		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Apr-13	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.140	0.000	0.032	0.000	0.032	-0.001
42812	PEGASUS_PV_ID1809		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-May-13	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		1.000	0.000	0.497	0.000	0.497	0.032
42813	BIG Y FOODS-02038PV250NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-May-13	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.250	0.000	0.000	0.000	0.000	0.000
42814	SWANSEA REALTY-02777PV315NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-May-13	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.315	0.000	0.000	0.000	0.000	0.000
42815	WILLETTE REALTY-02762PV225NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-May-13	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.225	0.000	0.044	0.000	0.044	-0.001
42816	JAY CASHMAN-02169PV155NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-May-13	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.155	0.000	0.000	0.000	0.000	0.000
42817	IKEA 158-0223PV520NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-May-13	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.520	0.000	0.000	0.000	0.000	0.000
42819	CUMMINGS PROP 1-0195PV224NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-May-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.224	0.000	0.050	0.000	0.050	0.050
42820	CUMMINGS PROP 2-01915PV224NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-May-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.224	0.000	0.079	0.000	0.079	0.079
42821	GLC-MA ACUSHNET_PV_ID2109		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-May-13	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		0.649	0.000	0.279	0.000	0.279	0.007
42822	CARDINAL SHOE-01840PV250NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-May-13	Massachusetts Electric Company	MEC	MA	009	CMA/NEMA	WCMA		0.250	0.000	0.000	0.000	0.000	0.000
42823	WALDEN LIBERTY-02038PV231NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-May-13	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.231	0.000	0.057	0.000	0.057	-0.002
42893	BISCO FALLS HYDRO		No Resource (1)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	08-May-13	Union Atlantic Electricity	UNION	ME	017	ME	ME		0.093	0.021	0.000	0.021	0.000	0.000
43256	SANDYWOODS-02878WT275NM		No Resource (1)	WT	WND		WIND TURBINE	17-May-13	The Narragansett Electric Company	NEC	RI	005	SEMA	RI		0.275	0.000	0.017	0.000	0.017	0.008
43257	LEICESTER MS C-01524PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-May-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.100	0.000	0.029	0.000	0.029	0.029
43262	BERKSHIRE SCHL-01257PV1750NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-May-13	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA	58624	1.760	0.000	0.040	0.000	0.040	-0.017
43263	JF WHITE-02702PV86NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-May-13	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.086	0.000	0.005	0.000	0.005	0.005
43267	PLANET SUBARU-02339PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-May-13	Massachusetts Electric Company	MEC	MA	023	RI	SEMA		0.075	0.000	0.000	0.000	0.000	0.000
43269	SIGN DESIGN-02301PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-May-13	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.095	0.000	0.000	0.000	0.000	0.000
43270	LEICESTER MS A-01524PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-May-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.100	0.000	0.028	0.000	0.028	0.003
43409	GLC-MA ACUSHNET_PV_ID1827		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-May-13	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		1.304	0.000	0.557	0.000	0.557	0.003
43411	S BARRE-01005PV800NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-May-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.800	0.000	0.442	0.000	0.442	0.032
43416	MIG ACTON-01581PV260NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Jun-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.260	0.000	0.054	0.000	0.054	-0.014
43417	WORCESTER SCHL-01602PV135NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Jun-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.135	0.000	0.000	0.000	0.000	0.000
43418	FALLON AMB-02169PV116NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Jun-13	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.116	0.000	0.000	0.000	0.000	0.000
43420	BANNER MOLD-01453PV111NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Jun-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.111	0.000	0.008	0.000	0.008	0.008
43422	EPG SOLAR 1 - 01550PV1500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Jun-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.500	0.000	0.623	0.000	0.623	0.001
43423	EPG SOLAR 2 - 01550PV1500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Jun-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.500	0.000	0.695	0.000	0.695	-0.035
43424	PINGREE SCHL - 01982PV200NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Jun-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.200	0.000	0.008	0.000	0.008	0.000
43425	NPP DEV - 02035PV125NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Jun-13	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.125	0.000	0.044	0.000	0.044	-0.001
43426	ABBOTT MILL - 01886PV235NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Jun-13	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.235	0.000	0.107	0.000	0.107	-0.001
43489	BOST SCIENT-02171PV1100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Jul-13	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA	57992	1.100	0.000	0.000	0.000	0.000	0.000
43491	146 CAMPANELLI-02072PV332NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Jul-13	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.332	0.000	0.120	0.000	0.120	-0.015
43492	NARR BAY - 02903WT4500NM		No Resource (1)	WT	WND		WIND TURBINE	09-Jul-13	The Narragansett Electric Company	NEC	RI	007	RI	RI		4.500	0.000	0.000	0.000	0.000	0.000
43509	DOUGLAS SOLAR-01516PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Jul-13	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		2.000	0.000	1.088	0.000	1.088	-0.001
43510	SANDF MGMNT-02725PV623NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Jul-13	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.623	0.000	0.151	0.000	0.151	-0.099
43512	WEST GREENWICH - 02817PV2000DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jul-13	The Narragansett Electric Company	NEC	RI	003	RI	RI		2.000	0.000	0.938	0.000	0.938	-0.021
43527	STUART THOMAS - 02842PV500DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jul-13	The Narragansett Electric Company	NEC	RI	005	SEMA	RI		0.500	0.000	0.228	0.000	0.228	0.008
43528	EXTRA SPC MGMT-02035PV102NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Jul-13	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.102	0.000	0.025	0.000	0.025	0.001
43529	CREEDON AND CO-01604PV110NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Jul-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.110	0.000	0.017	0.000	0.017	0.002
43531	28 HASTINGS - 01756PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Jul-13	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.100	0.000	0.000	0.000	0.000	-0.040
43556	CALLAHAN - 02324PV110NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Aug-13	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.110	0.000	0.003	0.000	0.003	-0.001
43557	BRDGWTR RECYCLE-02324PV96NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Aug-13	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.096	0.000	0.039	0.000	0.039	0.001
43558	COMMERCE GRN-02339PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Aug-13	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.100	0.000	0.050	0.000	0.050	0.003
43572	JDH_SOLAR_SYSTEMS_PV_2221		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Aug-13	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		0.650	0.000	0.269	0.000	0.269	0.000
43573	NEW_ENGLAND_RESINS_PV_2309		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Aug-13	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.060	0.000	0.186	0.000	0.186	-0.008
43574	TOWN_OF_FAIRHAVEN_LF_PV_1714		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Aug-13	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		0.500	0.000	0.205	0.000	0.205	0.043
43575	NE_ELEMENTARY_WALTHAM_PV_1872		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Aug-13	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.259	0.000	0.108	0.000	0.108	-0.002
43576	GLC_ACUSHNET_PV_1888		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Aug-13	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		0.917	0.000	0.516	0.000	0.516	0.001
43577	GLC_ACUSHNET_PV_1889		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Aug-13	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		0.917	0.000	0.361	0.000	0.361	-0.011
43578	GLC_ACUSHNET_PV_1890		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Aug-13	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		0.917	0.000	0.482	0.000	0.482	-0.026
43579	GOIS_SOLAR_ONE_PV_2040		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Aug-13	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.822	0.000	0.414	0.000	0.414	0.000
43580	JERICHO WIND	38421	Jericho Power	WT	WND		WIND TURBINE	23-Jan-16	Jericho Power LLC	JERICHO	NH	007	NH	NH	59070	13.538	2.458	1.292	2.458	1.292	-1.208
43586	COMTRAN CABLE-02864PV400DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Aug-13	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.400	0.000	0.232	0.000	0.232	0.006
43587	TRAVIS_HOSPITALITY_PV_2239		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Aug-13	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		0.145	0.000	0.066	0.000	0.066	-0.002
43603	WORC GEAR AND RACK-01537PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Aug-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.095	0.000	0.000	0.000	0.000	0.000
43604	METRO WST PROVIS-01747PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Aug-13	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.095	0.000	0.031	0.000	0.031	0.000
43605	PRECISE PACK-02720PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Sep-13	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.095	0.000	0.000	0.000	0.000	0.000
43606	CITY NORTHAMPTON-02721PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Sep-13	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		0.095	0.000	0.000	0.000	0.000	0.000
43607	COX PRTSMTH-02871PV500DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Sep-13	The Narragansett Electric Company	NEC	RI	005	RI	RI		0.500	0.000	0.162	0.000	0.162	-0.022
43608	35 LYMAN LLC-01532PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Aug-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.095	0.000	0.044	0.000	0.044	0.005
43609	MA CORRECTIONAL-01440WT3300NM		No Resource (1)	WT	WND		WIND TURBINE	05-Sep-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		3.300	0.165	0.000	0.165	0.000	0.000
43623	E BRIDGEWATER-02333PV2000NM	38114	East Bridgewater Solar Energy Project	PV	SUN		PHOTOVOLTAIC	12-Sep-13	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA	58586	2.000	0.000	0.980	0.000	0.980	0.195
43624	TJ MAXX - 02061PV260NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Sep-13	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.260	0.000	0.000	0.000	0.000	0.000
43643	SUNGEN UXBRIDGE1-01569PV950NM	38558	Fall River- Uxbridge	PV	SUN		PHOTOVOLTAIC	25-Sep-13	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.950	0.000	0.543	0.000	0.543	0.543
43644	SUNGEN UXBRIDGE2-01569PV950NM	38558	Fall River- Uxbridge	PV	SUN		PHOTOVOLTAIC	25-Sep-13	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.950	0.000	0.519	0.000	0.519	0.214
43645	SUNGEN UXBRIDGE3-01569PV950NM	38558	Fall River- Uxbridge	PV	SUN		PHOTOVOLTAIC	25-Sep-13	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.950	0.000	0.505	0.000	0.505	-0.016
43652	TWN W BRDGEWTR-02379PV1500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	30-Sep-13	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		1.500	0.000	0.718	0.000	0.718	-0.039
43653	40 WASHINGTON LTD-01581PV750NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	30-Sep-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.750	0.000	0.170	0.000	0.170	0.170
43654	3 COUNTY FAIR ASN-01060PV250NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	30-Sep-13	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		0.250	0.000	0.111	0.000	0.111	0.036

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report				
																	WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
43655	SPRING HILL FARM-01835PV229NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Oct-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.229	0.000	0.066	0.000	0.066	0.003
43656	SVC TIRE TRUCK - 01527PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Oct-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.300	0.000	0.000	0.000	0.000	0.000
43657	RIPTA - 02907PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Sep-13	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.300	0.000	0.000	0.000	0.000	0.000
43658	TWN LANCASTER-01523PV500QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Oct-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.500	0.000	0.129	0.000	0.129	-0.077
43659	TWN OF SCITUATE2-02066PV1500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Oct-13	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		1.500	0.000	0.000	0.000	0.000	-0.772
43678	DISCOVER MARBLE - 01527PV142NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Oct-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.142	0.000	0.000	0.000	0.000	0.000
43682	NEXTSUN ENERGY-01516PV3000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Oct-13	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		3.000	0.000	1.465	0.000	1.465	-0.164
43683	TWN OF SCITUATE1-02066PV1500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Oct-13	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		1.500	0.000	0.000	0.000	0.000	0.000
43684	KEY BOSTON-02038PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Oct-13	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		2.000	0.000	0.780	0.000	0.780	-0.025
43685	CONANICUT MARINE-02835PV120DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Oct-13	The Narragansett Electric Company	NEC	RI	005	SEMA	RI		0.120	0.000	0.052	0.000	0.052	0.000
43686	SHEA CONCRETE-01913PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Oct-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.300	0.000	0.063	0.000	0.063	0.022
43687	SUNGEN ORANGE1-01364PV1500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Oct-13	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA		1.500	0.000	0.760	0.000	0.760	0.013
43688	SUNGEN ORANGE2-01364PV1500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Oct-13	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA		0.500	0.000	0.233	0.000	0.233	-0.001
43689	BOSTON NORTH TECH-01913PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Oct-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.300	0.000	0.000	0.000	0.000	0.000
43690	OXFORD REALTY-01604PV145NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	30-Oct-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.145	0.000	0.031	0.000	0.031	0.002
43691	CRAFT INC-02703PV285NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	30-Oct-13	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.285	0.000	0.051	0.000	0.051	0.007
43695	KOHLS-01906PV252NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Oct-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.252	0.000	0.000	0.000	0.000	0.000
43696	STOP AND SHOP-02155PV200NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Oct-13	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.200	0.000	0.000	0.000	0.000	0.000
43698	NTHBRDGE SOLAR-01560PV1910NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Oct-13	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		1.910	0.000	1.228	0.000	1.228	0.017
43706	CITY OF LOWELL1-01364PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Nov-13	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA		2.000	0.000	0.511	0.000	0.511	0.013
43707	CITY OF LOWELL2-01364PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Nov-13	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA		1.000	0.000	0.886	0.000	0.886	0.007
43708	HANNAFORD-02061PV135NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-Nov-13	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.135	0.000	0.000	0.000	0.000	0.000
43709	CITY OF LOWELL 1-01331PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Nov-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.394	0.000	0.394	-0.036
43710	CITY OF LOWELL 2-01331PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Nov-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.533	0.000	0.533	0.007
43711	CITY OF LOWELL 3-01331PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Nov-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.534	0.000	0.534	0.009
43712	PHOENIX FIN5-01464PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Nov-13	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.095	0.000	0.000	0.000	0.000	0.000
43713	CUMMINGS PROP-01915PV110NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Nov-13	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.110	0.000	0.041	0.000	0.041	-0.002
43714	EXTRA SPC STOR-02189PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-Nov-13	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.095	0.000	0.039	0.000	0.039	0.004
43715	MILFORD IND-01757PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Nov-13	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.100	0.000	0.037	0.000	0.037	-0.003
43716	NEXAMP-02852PV2000DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-Nov-13	The Narragansett Electric Company	NEC	RI	009	RI	RI		2.000	0.000	0.980	0.000	0.980	-0.015
43717	ASSUMPTION-01562PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Nov-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		2.000	0.000	1.095	0.000	1.095	0.423
43729	GRAFTON WATER-01519PV1500NM	38527	Grafton WD	PV	SUN		PHOTOVOLTAIC	18-Nov-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		1.500	0.000	0.726	0.000	0.726	-0.037
43731	JEFFERSON-02720PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Nov-13	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.095	0.000	0.000	0.000	0.000	0.000
43734	TOWN EASTON-02375PV1500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Nov-13	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		1.500	0.000	0.793	0.000	0.793	0.793
43735	28 HASTINGS-01756PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Nov-13	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.095	0.000	0.000	0.000	0.000	-0.034
43736	SMITH COLLEGE-01060NG3500QF		No Resource (1)	IC	NG		GAS INTERNAL COMBUSTION	22-Nov-13	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		3.500	0.142	0.000	0.142	0.000	0.000
43747	PARSONS GRP-01581PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Dec-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.095	0.000	0.000	0.000	0.000	-0.027
43748	ACUMEN-01752PV85NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Dec-13	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.085	0.000	0.038	0.000	0.038	0.001
43749	WILVECO-01821PV82NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Dec-13	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.082	0.000	0.003	0.000	0.003	-0.001
43750	CANTON HIGH SCHOOL 2009		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Dec-13	NSTAR Electric Company	NSTAR	MA	021	SEMA	SEMA		0.500	0.000	0.168	0.000	0.168	-0.033
43751	EAGLE LEASE-01540PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Dec-13	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.094	0.000	0.018	0.000	0.018	0.000
43752	EXTRA SPACE-01607PV91.2NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Dec-13	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.091	0.000	0.000	0.000	0.000	0.000
43762	FORBES STREET 1-02914PV3000DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Dec-13	The Narragansett Electric Company	NEC	RI	007	RI	RI		3.000	0.000	1.342	0.000	1.342	-0.276
43766	EXTRA SPACE-02149PV237NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Dec-13	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.237	0.000	0.000	0.000	0.000	0.000
43840	SOLVENTERRA-01069PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Jan-14	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		1.000	0.000	0.511	0.000	0.511	0.511
43841	FLAIR ONE-01507PV950NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Jan-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.950	0.000	0.382	0.000	0.382	0.009
43842	FORRESTALL-01507PV950NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Jan-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.950	0.000	0.354	0.000	0.354	0.004
43869	FRPV WEST-02720PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Jan-14	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		1.000	0.000	0.297	0.000	0.297	-0.224
43870	FRPV EAST-02720PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-Jan-14	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		1.000	0.000	0.529	0.000	0.529	0.059
43871	SYNAGRO-02895CHP2000QF		No Resource (1)	ST	NG		GAS STEAM	07-Jan-14	The Narragansett Electric Company	NEC	RI	007	RI	RI		2.000	0.000	0.000	0.000	0.000	0.000
43874	MASS MOCA1-01247PV225NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-Jan-14	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		0.225	0.000	0.000	0.000	0.000	0.000
43875	CUMMINGS PROP-01915PV230NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-Jan-14	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.230	0.000	0.071	0.000	0.071	-0.004
43876	KENNEDY CARPET-02189PV95NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Jan-14	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.095	0.000	0.000	0.000	0.000	-0.009
43878	MCI WORLD COMM-01821PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Jan-14	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		1.000	0.000	0.000	0.000	0.000	0.000
43884	MASS MOCA3 01247PV177NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Jan-14	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		0.177	0.000	0.044	0.000	0.044	0.001
43885	NM-HP HOOD AND SONS	38575	Agawam Solar	PV	SUN		PHOTOVOLTAIC	01-Feb-14	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		1.500	0.000	0.701	0.000	0.701	-0.002
43886	NM-FRANKLIN COUNTY SHERIFF	38576	Whately	PV	SUN		PHOTOVOLTAIC	01-Feb-14	Western Massachusetts Electric Company	WMECO	MA	011	WMA	WCMA		1.500	0.000	0.629	0.000	0.629	-0.031
43887	NM-TOWN OF AGAWAM SOLAR	38574	Route 57	PV	SUN		PHOTOVOLTAIC	01-Feb-14	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		1.500	0.000	0.780	0.000	0.780	0.000
43892	SYNCARPHA SOLAR-01740PV4950NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Jan-14	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		4.950	0.000	2.736	0.000	2.736	0.101
43893	HUBBARDSTON-01452PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Jan-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		2.000	0.000	1.113	0.000	1.113	0.068
43903	SUNGEN-02720PV2850NM	38551	Fasll River - Innovation	PV	SUN		PHOTOVOLTAIC	29-Jan-14	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		2.850	0.000	1.413	0.000	1.413	-0.206
43904	CITY OF METHUEN-01523PV3000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Jan-14	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		3.000	0.000	1.264	0.000	1.264	-0.410
43907	PALMER SOLAR-01069PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Feb-14	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA	59866	2.000	0.000	1.054	0.000	1.054	0.062
43908	NEXTSUN ENERGY-02370PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Feb-14	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		2.000	0.000	1.036	0.000	1.036	0.020
43915	CITIZENS-02769PV2000NM	38579	Rehoboth	PV	SUN		PHOTOVOLTAIC	07-Feb-14	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		2.000	0.000	1.069	0.000	1.069	-0.032
43916	TOWN OF ADAMS-01220PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Feb-14	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		1.000	0.000	0.443	0.000	0.443	0.017
43917	CHEER PACK-02397PV1750NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Feb-14	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		1.750	0.000	0.000	0.000	0.000	0.000
43918	CITY OF LOWELL-01851PV1333NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Feb-14	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		1.333	0.000	0.501	0.000	0.501	0.501
43919	SOLVENTERRA 1-01535PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Feb-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.604	0.000	0.604	0.050
43920	SOLVENTERRA 2-01535PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Feb-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.601	0.000	0.601	0.041

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	As of Jan. 2017 SCC Report SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
43921	COXCOM-02893PV135DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Feb-14	The Narragansett Electric Company	NEC	RI	003	RI	RI		0.135	0.000	0.076	0.000	0.076	0.000
43922	SOLVENTERRA 4-01083PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Feb-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.614	0.000	0.614	0.002
43923	PLYMOUTH PUBLIC SCHOOLS-#2062		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Feb-14	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		4.000	0.000	1.824	0.000	1.824	-0.199
43924	TOWN OF DARTMOUTH #1777		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Feb-14	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		1.250	0.000	0.599	0.000	0.599	0.040
43927	SOUTHERN SKY-CARVER #1 (1997)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Feb-14	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		1.000	0.000	0.437	0.000	0.437	-0.021
43928	SOUTHERN SKY-CARVER #2 (1998)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Feb-14	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		1.000	0.000	0.416	0.000	0.416	-0.058
43929	SOUTHERN SKY-CARVER #4 (2000)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Feb-14	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		1.000	0.000	0.411	0.000	0.411	-0.054
43930	SOUTHERN SKY-CARVER #5 (2001)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Feb-14	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		1.000	0.000	0.446	0.000	0.446	-0.020
43932	SOUTHERN SKY-CARVER #3 (1999)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Feb-14	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		1.000	0.000	0.282	0.000	0.282	0.057
43936	SOLVENTERRA 1-01083PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Feb-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.578	0.000	0.578	-0.001
43937	SOLVENTERRA 2-01083PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Feb-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.606	0.000	0.606	0.020
43938	SOLVENTERRA 3-01083PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Feb-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.587	0.000	0.587	0.016
43948	SUNGEN 1-01810PV950NM	38532	Leominster- South St.	PV	SUN		PHOTOVOLTAIC	03-Mar-14	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.950	0.000	0.463	0.000	0.463	-0.033
43949	SUNGEN 2-01810PV950NM	38532	Leominster- South St.	PV	SUN		PHOTOVOLTAIC	03-Mar-14	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.950	0.000	0.450	0.000	0.450	-0.026
43950	SUNGEN 3-01810PV950NM	38532	Leominster- South St.	PV	SUN		PHOTOVOLTAIC	03-Mar-14	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.950	0.000	0.479	0.000	0.479	-0.025
43951	SUNGEN-02720PV950NM	38548	Fall River- Commerce	PV	SUN		PHOTOVOLTAIC	05-Mar-14	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.950	0.000	0.533	0.000	0.533	-0.014
43952	KEARSARGE SOLAR-02038PV3000NM	38562	Franklin 1	PV	SUN		PHOTOVOLTAIC	05-Mar-14	Massachusetts Electric Company	MEC	MA	013	RI	SEMA		3.000	0.000	1.564	0.000	1.564	0.004
43953	KEARSARGE SOLAR-02038PV4000NM	38565	Franklin 2	PV	SUN		PHOTOVOLTAIC	05-Mar-14	Massachusetts Electric Company	MEC	MA	013	RI	SEMA		4.000	0.000	2.130	0.000	2.130	0.009
43954	NM-LUDLOW LANDFILL		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Mar-14	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA	59135	2.000	0.000	0.868	0.000	0.868	-0.220
43955	CITY OF METHUEN-01844PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Mar-14	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		1.000	0.000	0.568	0.000	0.568	0.066
43956	MILLWORK-02920PV495NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Mar-14	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.495	0.000	0.044	0.000	0.044	0.013
43991	PROFETTY-02379PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Mar-14	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.300	0.000	0.122	0.000	0.122	-0.024
43992	CITY OF WORCESTER-01603PV135NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Mar-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.466	0.000	0.000	0.000	0.000	0.000
43993	CITY OF MELROSE-02176PV260NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Mar-14	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.260	0.000	0.106	0.000	0.106	-0.014
43994	NORMANDY GATOR-01752PV110NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Mar-14	Massachusetts Electric Company	MEC	MA	005	CMA/NEMA	WCMA		0.110	0.000	0.000	0.000	0.000	0.000
43995	NORMANDY GATOR-01752PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Mar-14	Massachusetts Electric Company	MEC	MA	005	CMA/NEMA	WCMA		0.100	0.000	0.000	0.000	0.000	0.000
44003	ALTUS-02907PV1225DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Mar-14	The Narragansett Electric Company	NEC	RI	007	RI	RI		1.225	0.000	0.611	0.000	0.611	0.047
44004	ALTUS-02907PV300DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Mar-14	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.300	0.000	0.123	0.000	0.123	-0.009
44005	ALTUS 1-02864PV450DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Mar-14	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.450	0.000	0.210	0.000	0.210	0.001
44006	ALTUS 2-02864PV450DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Mar-14	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.450	0.000	0.214	0.000	0.214	-0.006
44007	MILLBURY SOLAR-01527PV3000NM	38534	Millbury Solar	PV	SUN		PHOTOVOLTAIC	25-Mar-14	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA	58280	3.000	0.000	1.542	0.000	1.542	0.645
44008	PWRR-01610PV130NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Mar-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.130	0.000	0.010	0.000	0.010	0.000
44010	GOLDEN-02920PV300DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	31-Mar-14	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.300	0.000	0.157	0.000	0.157	-0.012
44011	ENDICOTT-01915PV800NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	31-Mar-14	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.800	0.000	0.168	0.000	0.168	0.092
44023	WRTA-01608PV75QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Apr-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.075	0.000	0.000	0.000	0.000	0.000
44026	STONEHILL-02356PV84NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Apr-14	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.084	0.000	0.025	0.000	0.025	0.005
44027	SCITUTATE TENNIS-02066PV281NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Apr-14	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.281	0.000	0.000	0.000	0.000	-0.053
44028	TEAMWORK LABOR-02375PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Apr-14	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.075	0.000	0.000	0.000	0.000	-0.002
44029	C&R TIRE-01606PV81NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Apr-14	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.081	0.000	0.012	0.000	0.012	0.002
44030	WARREN PV	38500	Mass Mid-State Solar	PV	SUN		PHOTOVOLTAIC	30-May-14	Mass Solar 1, LLC	MS1	MA	027	WMA	WCMA	8275, 58276, 5827	14.000	0.000	7.805	0.000	7.805	0.287
44035	TOWER SOLAR-02723PV485NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Apr-14	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.485	0.000	0.243	0.000	0.243	0.017
46206	ENERGY STREAM HYDRO	806	MECHANICSVILLE	HDP	WAT		HYDRO (DAILY CYCLE - PONDAGE)	01-May-14	Sterling Municipal Electric Light Department	SMED	CT	015	CT	CT		0.120	0.063	0.000	0.063	0.000	0.000
46210	NEXAMP-01475PV1900NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Apr-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.900	0.000	1.040	0.000	1.040	0.026
46211	GIGUERE-01524PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Apr-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.075	0.000	0.002	0.000	0.002	-0.004
46212	BODWELL REALTY-02322PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Apr-14	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.075	0.000	0.000	0.000	0.000	0.000
46213	PINGREE SCHOOL-01982PV85NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Apr-14	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.085	0.000	0.023	0.000	0.023	0.022
46220	BERKELEY-01844PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Apr-14	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		2.000	0.000	0.950	0.000	0.950	0.119
46221	JP SULLIVAN-01432PV90NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Apr-14	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.090	0.000	0.022	0.000	0.022	0.022
46267	COTTAGE STREET SOLAR FACILITY	38440	Cottage St PV	PV	SUN		PHOTOVOLTAIC	05-May-14	Western Massachusetts Electric Company	WMECO	MA	019	WMA	WCMA		3.894	0.000	1.674	0.000	1.674	-0.026
46268	OLD TIME SPORTS-01952PV150NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-May-14	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.150	0.000	0.030	0.000	0.030	-0.004
46294	LAWRENCE 1-01840PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-May-14	Massachusetts Electric Company	MEC	MA	009	CMA/NEMA	WCMA		0.100	0.000	0.013	0.000	0.013	-0.022
46295	LAWRENCE 2-01840PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-May-14	Massachusetts Electric Company	MEC	MA	009	CMA/NEMA	WCMA		0.100	0.000	0.040	0.000	0.040	0.017
46479	CANTON_MIDDLE_SCHOOL_2013		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-May-14	NSTAR Electric Company	NSTAR	MA	021	SEMA	SEMA		0.225	0.000	0.136	0.000	0.136	0.008
46480	CEDAR_SOLAR1_2411		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-May-14	NSTAR Electric Company	NSTAR	MA	025	BOSTON	NEMA		0.085	0.000	0.038	0.000	0.038	0.001
46481	TOWN_OF_MARSHFIELD_1865		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-May-14	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA	58410	3.000	0.000	1.789	0.000	1.789	0.073
46482	NEWBEDFORD_DPI_1843_1844		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-May-14	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		3.500	0.000	1.757	0.000	1.757	-0.005
46483	MILFORD INDUSTRIAL-0175PV82NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-May-14	Massachusetts Electric Company	MEC	MA	009	RI	SEMA		0.082	0.000	0.033	0.000	0.033	-0.001
46484	WORCESTER SCHL-01602PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-May-14	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.075	0.000	0.000	0.000	0.000	0.000
46485	NPP DEVELOPMENT-02035PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-May-14	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.075	0.000	0.028	0.000	0.028	-0.001
46486	WB HUNT-02176PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Jun-14	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.075	0.000	0.000	0.000	0.000	0.000
46487	CIDER HILL-01913PV78NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Jun-14	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.078	0.000	0.029	0.000	0.029	-0.002
46537	CUMMINGS-0191PV82NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Jun-14	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.082	0.000	0.023	0.000	0.023	-0.001
46538	SILVIA-02720PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Jun-14	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.075	0.000	0.000	0.000	0.000	0.000
46539	BCC SEA QALIBC-01854PV66NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Jun-14	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.066	0.000	0.029	0.000	0.029	0.001
46540	NPP DEVELOPMENT-02035PV62NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Jun-14	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.062	0.000	0.016	0.000	0.016	-0.001
46541	TEKNOR APEX-02703PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Jun-14	Massachusetts Electric Company	MEC	MA	023	RI	SEMA		0.075	0.000	0.000	0.000	0.000	0.000
46564	EPG SOLAR-01005PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Jun-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		2.000	0.000	0.866	0.000	0.866	0.216
46565	CABOT BEVERLY-01915PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Jun-14	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA	59242	2.000	0.000	0.000	0.000	0.000	0.000
46566	PRECISE PACKAGING-02720PV250NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jul-14	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.250	0.000	0.091	0.000	0.091	0.091
46567	NORTH BROOKFIELD-01535PV3000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jul-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA	58650	3.000	0.000	1.562	0.000	1.562	0.298

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	As of Jan. 2017 SCC Report SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
46568	GLC-MA SOLAR-01440PV1000NM	38510	City of Gardner - Mill St. Solar	PV	SUN		PHOTOVOLTAIC	01-Jul-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.444	0.000	0.444	0.022
46569	NUGEN NCMC (PV)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jul-14	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		1.000	0.000	0.505	0.000	0.505	0.026
46570	NUGEN LUN (PV)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jul-14	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		2.500	0.000	1.501	0.000	1.501	0.089
46607	HARVARD SOLAR-01451PV460NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Jul-14	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.460	0.000	0.224	0.000	0.224	0.109
46636	GOOSE RIVER HYDRO, INC.		No Resource (1)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Aug-14	Goose River Hydro, Inc.	GOOSE	ME	027	ME	ME		0.375	0.040	0.000	0.040	0.000	0.000
46641	205 STURBRIDGE-01010PV3000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Aug-14	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		3.000	0.000	0.935	0.000	0.935	-0.071
46643	EPG SOLAR-01005PV1500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Aug-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.500	0.000	0.868	0.000	0.868	0.034
46644	UGT RENEW ENERGY-01540PV2750NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Aug-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		2.750	0.000	1.525	0.000	1.525	0.011
46645	NEXAMP CAPITAL-01007PV1300NM	38381	Belchertown SEd	PV	SUN		PHOTOVOLTAIC	05-Aug-14	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		1.300	0.000	0.671	0.000	0.671	0.013
46646	SOLTAS ENERGY-01010PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Aug-14	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		2.000	0.000	1.796	0.000	1.796	-0.008
46647	BLUEWAVE CAPITAL-02769PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Aug-14	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		1.000	0.000	0.324	0.000	0.324	0.091
46653	WESTBORO SOLAR-01581PV1820NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Aug-14	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		1.820	0.000	0.895	0.000	0.895	-0.010
46657	INDIAN HILL-01069PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Aug-14	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		1.000	0.000	0.578	0.000	0.578	0.027
46659	BROWN SOLAR-01069PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Aug-14	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		1.000	0.000	0.580	0.000	0.580	0.041
46660	STATE SOLAR-01069PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Aug-14	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		1.000	0.000	0.594	0.000	0.594	0.049
46662	DISTRIBUTOR CORP-02148PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Sep-14	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.300	0.000	0.073	0.000	0.073	0.007
46663	CITY OF LAWRENCE-01841PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Sep-14	Massachusetts Electric Company	MEC	MA	009	CMA/NEMA	WCMA		0.300	0.000	0.000	0.000	0.000	0.000
46664	NEXAMP CAPITAL-01543PV4999NM	38380	Treasure Valley- SE	PV	SUN		PHOTOVOLTAIC	03-Sep-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA	59781	4.999	0.000	2.276	0.000	2.276	1.606
46665	SX INDUSTRIES-02072PV170NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Sep-14	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.170	0.000	0.000	0.000	0.000	0.000
46666	CUMMINGS-01915PV224NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Sep-14	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.224	0.000	0.104	0.000	0.104	0.069
46667	E NAZARENE-02170PV85NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Sep-14	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.085	0.000	0.000	0.000	0.000	0.000
46691	CORNERSTONE-01057PV3000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Sep-14	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		3.000	0.000	1.541	0.000	1.541	0.030
46717	EAST BAY-02915PV70NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Sep-14	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.070	0.000	0.000	0.000	0.000	0.000
46718	EXTRA SPACE-02151PV144.3NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Sep-14	Massachusetts Electric Company	MEC	MA	025	BOSTON	NEMA		0.144	0.000	0.000	0.000	0.000	0.000
46719	STONEHILL COLL-02356PV2225QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Sep-14	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		2.225	0.000	0.824	0.000	0.824	-0.281
46721	ALL AMERICAN-02852PV250DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Sep-14	The Narragansett Electric Company	NEC	RI	009	RI	RI		0.250	0.000	0.132	0.000	0.132	0.011
46731	BILLERICA-01821PV4999NM	38567	Billerica	PV	SUN		PHOTOVOLTAIC	26-Sep-14	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA	59396	4.999	0.000	0.000	0.000	0.000	-0.967
46732	PIONEER SOLAR-01453PV495NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Sep-14	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.495	0.000	0.000	0.000	0.000	0.000
46733	TKS SOLAR-02301PV180NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Sep-14	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.180	0.000	0.073	0.000	0.073	-0.003
46911	NEXTSUN ENERGY-02896PV850DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Dec-14	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.850	0.000	0.451	0.000	0.451	0.042
46913	WOONSOCKET-02895PV190DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Dec-14	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.190	0.000	0.071	0.000	0.071	-0.003
46914	BILLERICA-01523PV2499NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Dec-14	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		2.499	0.000	1.260	0.000	1.260	0.188
46915	NEXAMP-01844PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Dec-14	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		2.000	0.000	1.068	0.000	1.068	0.096
46916	PHILLIPS-01810PV495NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Dec-14	Massachusetts Electric Company	MEC	MA	009	CMA/NEMA	WCMA		0.495	0.000	0.000	0.000	0.000	0.000
46917	NEWPORT VINEYARDS-02882PV50DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Dec-14	The Narragansett Electric Company	NEC	RI	005	SEMA	RI		0.050	0.000	0.018	0.000	0.018	-0.001
46918	TOWN OF WESTFORD-01452PV2800NM	38480	Hubbardston SE	PV	SUN		PHOTOVOLTAIC	17-Dec-14	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		2.800	0.000	0.000	0.000	0.000	0.000
46924	BILLERICA-01523PV2500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Dec-14	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		2.500	0.000	1.233	0.000	1.233	0.113
46925	GLC-MA SOLAR-01440PV1980NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Dec-14	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		1.980	0.000	1.147	0.000	1.147	0.042
46926	STILLWATER-02917PV56DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Dec-14	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.056	0.000	0.021	0.000	0.021	0.000
46947	AMERIPRIDE-01607PV225NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Jan-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.225	0.000	0.000	0.000	0.000	0.000
46948	MILFORD IND-01757PV170NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Jan-15	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.170	0.000	0.092	0.000	0.092	-0.002
46949	NEW SALEM-01452PV675NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Jan-15	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.675	0.000	0.367	0.000	0.367	0.065
46951	OAKFIELD WIND		No Resource (1)	WT	WND		WIND TURBINE	29-Oct-15	Evergreen Wind Power II, LLC	EWP2	ME	003	BHE	ME	57002	140.600	36.788	19.512	36.788	19.512	12.112
46952	TOWN OF WENDELL-01876PV260NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Jan-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.260	0.000	0.118	0.000	0.118	-0.004
46953	MACHINE INC-02072PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Jan-15	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.075	0.000	0.000	0.000	0.000	0.000
46954	PROTECTOWIRE-02359PV70NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Jan-15	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.070	0.000	0.000	0.000	0.000	0.000
46955	MASS FISHERIES-01581PV251NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Jan-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.251	0.000	0.065	0.000	0.065	0.007
46982	GLOBAL LIQUORS-02720PV85NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Jan-15	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.085	0.000	0.014	0.000	0.014	-0.003
46984	FIVEMILE RIVER1-01503PV750NM	38533	Berlin 1	PV	SUN		PHOTOVOLTAIC	29-Jan-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.750	0.000	0.300	0.000	0.300	-0.069
46985	FIVEMILE RIVER2-01503PV750NM	38555	Berlin 2	PV	SUN		PHOTOVOLTAIC	29-Jan-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.750	0.000	0.368	0.000	0.368	0.029
46986	FIVEMILE RIVER3-01503PV750NM	38556	Berlin 3	PV	SUN		PHOTOVOLTAIC	29-Jan-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.750	0.000	0.375	0.000	0.375	0.044
46987	FIVEMILE RIVER4-01503PV750NM	38559	Berlin 4	PV	SUN		PHOTOVOLTAIC	29-Jan-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.750	0.000	0.407	0.000	0.407	0.044
46992	RIN LOGISTICS-02720PV1500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Feb-15	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		1.500	0.000	0.678	0.000	0.678	0.248
46993	PARAGON HOLDINGS-01740PV995NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Feb-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.995	0.000	0.000	0.000	0.000	0.000
46997	BOLTONVILLE HYDRO		No Resource (1)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-Feb-15	Green Mountain Power Corporation	GMP	VT	017	VT	VT		1.318	0.632	0.167	0.632	0.167	-0.258
46998	STEERE ELECTRIC-02814PV72DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Feb-15	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.072	0.000	0.038	0.000	0.038	-0.002
47002	ONE KENWOOD-02038PV266NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Feb-15	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.266	0.000	0.129	0.000	0.129	-0.006
47003	S SHORE MILLWORK-02766PV648NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Feb-15	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.648	0.000	0.108	0.000	0.108	0.038
47004	IRON MOUNTAIN-01532PV760NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Feb-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.760	0.000	0.000	0.000	0.000	0.000
47007	FRANKLIN FORD-02038PV140NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Feb-15	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.140	0.000	0.016	0.000	0.016	-0.004
47008	MCGEE TOYOTA-02339PV85NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Feb-15	Massachusetts Electric Company	MEC	MA	023	RI	SEMA		0.085	0.000	0.000	0.000	0.000	0.000
47020	NEXAMP-02898PV499DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Feb-15	The Narragansett Electric Company	NEC	RI	009	RI	RI		0.499	0.000	0.223	0.000	0.223	0.005
47032	ABINGTON TARGET-02351PV418NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Feb-15	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.418	0.000	0.000	0.000	0.000	0.000
47033	HANOVER TARGET-02339PV441NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Feb-15	Massachusetts Electric Company	MEC	MA	023	RI	SEMA		0.441	0.000	0.000	0.000	0.000	0.000
47034	MARLBORO TARGET-01752PV441NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Feb-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.441	0.000	0.000	0.000	0.000	0.000
47035	MILFORD TARGET-01757PV302NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Mar-15	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.302	0.000	0.000	0.000	0.000	0.000
47036	NORTHBORO WALMART-01532PV368NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Mar-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.368	0.000	0.000	0.000	0.000	0.000
47037	LYNN WALMART-01905PV232NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Mar-15	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.232	0.000	0.000	0.000	0.000	0.000
47046	BOOTHBAY ENERGY STORAGE		No Resource (1)	ES	MWH		ENERGY STORAGE	09-Mar-15	Convergent Energy and Power LLC	CONV	ME	015	ME	ME		0.500	0.000	0.000	0.000	0.000	0.000
47060	HANNAFORD FOOD-01535PV120NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Mar-15	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.120	0.000	0.000	0.000	0.000	0.000

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	As of Jan. 2017 SCC Report SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
47061	WHITTIER FARMS-01590PV114NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Mar-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.114	0.000	0.020	0.000	0.020	-0.041
47062	EASTERN BANK-01901PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Mar-15	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.100	0.000	0.000	0.000	0.000	0.000
47063	SWISS TURN-01540PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Mar-15	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.100	0.000	0.000	0.000	0.000	0.000
47064	1ST CONGREGATION-02176PV90NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Mar-15	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.090	0.000	0.026	0.000	0.026	-0.001
47065	210 UPHAM (PV)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Mar-15	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.072	0.000	0.040	0.000	0.040	0.011
47066	S.D. WARREN SACCARAPPA HYDRO		No Resource (1)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	20-Mar-15	NextEra Energy Power Marketing, LLC	FPLP	ME	005	SME	ME		1.350	0.443	0.319	0.443	0.319	-0.072
47092	3 VENUS WAY-02703PV750NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Apr-15	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.750	0.000	0.127	0.000	0.127	-0.027
47093	SWANSEA MALL-02777PV499NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Apr-15	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.499	0.000	0.091	0.000	0.091	-0.011
47094	MACY'S SAUGUS-01906PV278NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Apr-15	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.278	0.000	0.000	0.000	0.000	0.000
47095	MILFORD IND PLAZA-01757PV170NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Apr-15	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.170	0.000	0.090	0.000	0.090	-0.005
47096	JENIKE AND JO-01879PV150NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Apr-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.150	0.000	0.017	0.000	0.017	0.002
47097	PREFERRED FREEZER-02322PV990NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Apr-15	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.990	0.000	0.051	0.000	0.051	-0.015
47125	BOW STREET HYDRO		No Resource (1)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	01-May-15	Massachusetts Municipal Wholesale Electric Company	MMWEC	NH	013	NH	NH		0.236	0.081	0.095	0.081	0.095	0.095
47126	CITY OF QUINCY-02171PV132NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Apr-15	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.132	0.000	0.032	0.000	0.032	0.032
47127	CITY OF QUINCY-02169PV144NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Apr-15	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.144	0.000	0.036	0.000	0.036	0.036
47128	CITY OF QUINCY-02170PV195NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Apr-15	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.195	0.000	0.000	0.000	0.000	0.000
47129	CITY OF QUINCY-02169PV129NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-May-15	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.129	0.000	0.000	0.000	0.000	0.000
47210	LEICESTER ONE-01524PV4883NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-May-15	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA	58282	4.883	0.000	2.508	0.000	2.508	0.277
47211	SYNCARPHA-01453PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-May-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA	60073	2.000	0.000	0.918	0.000	0.918	-0.136
47263	WARILA-01523PV150NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Jun-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.150	0.000	0.050	0.000	0.050	0.008
47264	MERRIMACK REALITY-01830PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Jun-15	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.100	0.000	0.016	0.000	0.016	0.002
47265	LMP FRANKLIN-02038PV490NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Jun-15	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.490	0.000	0.208	0.000	0.208	-0.012
47266	EAST COASTWELDING-01950PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Jun-15	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.100	0.000	0.000	0.000	0.000	0.000
47267	BLACKMARBLEMOTOR-02151PV241NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Jun-15	Massachusetts Electric Company	MEC	MA	025	BOSTON	NEMA		0.241	0.000	0.000	0.000	0.000	0.000
47281	SWANSEA MALL-02777PV260QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Jun-15	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.260	0.000	0.223	0.000	0.223	0.023
47282	CITY OF QUINCY-02171PV225NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Jun-15	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.225	0.000	0.000	0.000	0.000	0.000
47283	NATIONAL MARKER-02896PV186NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Jun-15	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.186	0.000	0.000	0.000	0.000	0.000
47284	LARRY LUNDIN-02333PV180NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Jun-15	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.180	0.000	0.062	0.000	0.062	0.001
47285	LARSON TOOL-02703PV131NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Jun-15	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.131	0.000	0.000	0.000	0.000	0.000
47311	PETERBOROUGH WWTF PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Jul-15	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH		0.750	0.000	0.333	0.000	0.333	0.333
47312	SKATE 3-01879PV491NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Jul-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.491	0.000	0.000	0.000	0.000	0.000
47313	MACYS MARLBORO-01752PV371NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Jul-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.371	0.000	0.000	0.000	0.000	0.000
47357	JOHNSTON SOLAR-02919PV1375DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Jul-15	The Narragansett Electric Company	NEC	RI	007	RI	RI		1.375	0.000	0.249	0.000	0.249	-0.287
47364	HA MA SOLAR-01222PV999NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Jul-15	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		0.999	0.000	0.570	0.000	0.570	0.009
47365	WILLIAMS COLLEGE-01267PV414NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Jul-15	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		0.414	0.000	0.197	0.000	0.197	0.027
47366	COMERFORD 1	380	COMERFORD	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-30	TransCanada Hydro Northeast Inc	TCHN	NH	009	NH	NH	2349	35.100	21.654	21.400	21.654	21.604	0.000
47367	COMERFORD 2	380	COMERFORD	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-30	TransCanada Hydro Northeast Inc	TCHN	NH	009	NH	NH	2349	48.600	48.485	48.245	48.819	48.245	0.000
47368	COMERFORD 3	380	COMERFORD	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-30	TransCanada Hydro Northeast Inc	TCHN	NH	009	NH	NH	2349	48.600	48.515	48.245	48.819	48.245	0.000
47369	COMERFORD 4	380	COMERFORD	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-30	TransCanada Hydro Northeast Inc	TCHN	NH	009	NH	NH	2349	48.600	48.819	48.245	48.819	48.245	0.000
47370	MOORE 1	496	MOORE	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-56	TransCanada Hydro Northeast Inc	TCHN	NH	009	NH	NH	2351 / 1-4	47.700	47.793	47.258	47.728	47.258	0.000
47371	MOORE 2	496	MOORE	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-56	TransCanada Hydro Northeast Inc	TCHN	NH	009	NH	NH	2351 / 1-4	47.700	47.794	47.258	47.728	47.258	0.000
47372	MOORE 3	496	MOORE	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-56	TransCanada Hydro Northeast Inc	TCHN	NH	009	NH	NH	2351 / 1-4	47.700	47.794	47.258	47.728	47.258	0.000
47373	MOORE 4	496	MOORE	HW	WAT		HYDRO (WEEKLY CYCLE)	01-Jan-56	TransCanada Hydro Northeast Inc	TCHN	NH	009	NH	NH	2351 / 1-4	47.700	47.794	47.258	47.729	47.258	0.000
47374	NEW BEDFORD RED AUTH #2283	38374	Plymouth	PV	SUN		PHOTOVOLTAIC	04-Aug-15	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA	59780	4.260	0.000	2.546	0.000	2.546	0.488
47377	BLUEWAVE - MATTAPOISETT 2260		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Aug-15	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		0.750	0.000	0.388	0.000	0.388	0.022
47378	BLUEWAVE - MATTAPOISETT 2261	38530	Mattapoisett 2	PV	SUN		PHOTOVOLTAIC	07-Aug-15	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		0.750	0.000	0.342	0.000	0.342	-0.031
47379	GARDNER WALMART-01440PV278NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Aug-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.278	0.000	0.000	0.000	0.000	0.000
47390	BUCKSPORT 3-5	1288	BUCKSPORT ENERGY 4	CC	NG	DFO	GAS/OIL COMBINED CYCLE	01-Jan-01	Bucksport Generation LLC	BKSG	ME	009	BHE	ME	50243	282.744	219.432	164.330	219.432	164.330	-27.700
47391	CHELMSFORD DPW-01824PV335NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Aug-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.335	0.000	0.170	0.000	0.170	0.018
47392	MCCARTHY SCHOOL-01824PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Aug-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.300	0.000	0.130	0.000	0.130	0.130
47393	HARRINGTON SCHOOL-01824PV295NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Aug-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.295	0.000	0.136	0.000	0.136	0.021
47397	NM-ALNASCO		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.300	0.000	0.065	0.000	0.065	-0.007
47398	NM-BGREEN ENERGY		No Resource (1)	IC	LFG		BIO/REFUSE	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	015	WMA	WCMA		0.300	0.232	0.218	0.232	0.218	-0.010
47399	NM-BWC ORIGINATION		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	015	WMA	WCMA		0.833	0.000	0.247	0.000	0.247	0.003
47400	NM-CENTER FOR ECOLOGICAL TECH		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		0.142	0.000	0.026	0.000	0.026	0.003
47401	NM-C F FARMS		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	015	WMA	WCMA		0.175	0.000	0.000	0.000	0.000	0.000
47402	NM-CLARKS COVAIR PARTS		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	011	WMA	WCMA		0.082	0.000	0.019	0.000	0.019	-0.003
47403	NM-COWLS BUILDING SUPPLY		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	015	WMA	WCMA		0.100	0.000	0.036	0.000	0.036	0.005
47404	NM-FRANKLIN REGIONAL		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	011	WMA	WCMA		0.100	0.000	0.014	0.000	0.014	0.006
47405	NM-FW WEBB		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		0.266	0.000	0.062	0.000	0.062	0.030
47406	NM-GUIDO QUALITY FOODS		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.168	0.000	0.027	0.000	0.027	0.002
47407	NM-LYNN EDWARDS		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	015	WMA	WCMA		0.095	0.000	0.039	0.000	0.039	0.034
47408	NM-LYON AVIATION		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.100	0.000	0.037	0.000	0.037	0.002
47409	NM-PITTSFIELD RYE		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.499	0.000	0.056	0.000	0.056	-0.034
47410	CHELMSFORD HIGH-01824PV225NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Aug-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.225	0.000	0.117	0.000	0.117	0.015
47411	PARKER SCHOOL-01824PV225NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Aug-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.225	0.000	0.097	0.000	0.097	0.011
47412	BYAM SCHOOL-01824-PV225NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.225	0.000	0.103	0.000	0.103	0.102
47413	SOUTH ROW SCHOOL-01824PV150NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.150	0.000	0.084	0.000	0.084	0.010
47414	WESTLAND SCHOOL-01824PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.100	0.000	0.049	0.000	0.049	0.006
47415	CENTER SCHOOL-01824PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Sep-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.750	0.000	0.038	0.000	0.038	-0.262

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	As of Jan. 2017 SCC Report SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
47419	NM-TOWN OF WEST SPRINGFIELD		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		3.300	0.000	2.109	0.000	2.109	0.134
47420	NM-TOWN OF LONGMEADOW		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		3.340	0.000	1.799	0.000	1.799	0.231
47421	NM-TOWN OF ASHFIELD		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	015	WMA	WCMA		2.500	0.000	1.296	0.000	1.296	0.067
47422	NM-UMASS AMHERST		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-15	Western Massachusetts Electric Company	WMECO	MA	011	WMA	WCMA		2.000	0.000	1.054	0.000	1.054	0.065
47423	BRISTOLCOMMCOLL-02720PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Aug-15	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		2.000	0.000	0.133	0.000	0.133	-0.055
47424	SUN EDISON - SUDBURY 2417	38378	LSRHS	PV	SUN		PHOTOVOLTAIC	01-Sep-15	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		0.980	0.000	0.490	0.000	0.490	0.048
47443	HA MA SOLAR-01036PV3500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Sep-15	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		3.500	0.000	1.977	0.000	1.977	0.577
47444	SUN EDISON ORIG3-02769PV3334NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Sep-15	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		3.334	0.000	1.566	0.000	1.566	0.232
47445	NORTH ADAMS-01247PV2250NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Sep-15	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA	60074	2.250	0.000	1.530	0.000	1.530	0.630
47446	BWC 5 MILE RIVER-01519PV2000NM	38560	Grafton	PV	SUN		PHOTOVOLTAIC	25-Sep-15	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		2.000	0.000	1.008	0.000	1.008	0.208
47447	BWC 5 MILE RIVER-01031PV1890NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Sep-15	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.890	0.000	0.956	0.000	0.956	0.200
47448	BWC 5 MILE RIVER-01031PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Sep-15	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.000	0.000	0.505	0.000	0.505	0.105
47455	BROCKTON WALMART-02301PV252QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Sep-15	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.252	0.000	0.000	0.000	0.000	-0.101
47477	TOWN OF WAREHAM 2155		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Sep-15	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		4.750	0.000	2.818	0.000	2.818	0.918
47484	TOWN OF DARTMOUTH 1924		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Oct-15	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		2.750	0.000	1.413	0.000	1.413	0.313
47485	TOWN OF DARTMOUTH 1925		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Oct-15	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		4.000	0.000	1.593	0.000	1.593	-0.007
47486	PLAINVILLE GAMING-02762PV615QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Oct-15	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.615	0.000	0.000	0.000	0.000	-0.246
47487	N KINGSTOWN SOLAR-02852PV495DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Oct-15	The Narragansett Electric Company	NEC	RI	009	RI	RI		0.495	0.000	0.216	0.000	0.216	0.018
47504	CVEC EDGARTOWN - 1886		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Oct-15	NSTAR Electric Company	NSTAR	MA	007	SEMA	SEMA		1.083	0.000	0.504	0.000	0.504	0.071
47505	CVEC EDGARTOWN - 1887		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Oct-15	NSTAR Electric Company	NSTAR	MA	007	SEMA	SEMA		1.083	0.000	0.400	0.000	0.400	-0.033
47506	CVEC HARWICH - 1913		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Oct-15	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA	59078	4.000	0.000	2.070	0.000	2.070	0.470
47530	SEEKONK WALMART-02771PV230QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Nov-15	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.230	0.000	0.000	0.000	0.000	-0.092
47559	HANNAFORD LUN PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Nov-15	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.170	0.000	0.000	0.000	0.000	-0.068
47699	H&V-01472ST3519QF		No Resource (1)	ST	NG		GAS STEAM	04-Dec-15	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		3.519	0.000	0.000	0.000	0.000	-2.583
47703	WEST ST NOMINEE-01747PV490NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Dec-15	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.490	0.000	0.204	0.000	0.204	0.008
47704	ERVING PAPER-01344ST3519QF		No Resource (1)	ST	NG		GAS STEAM	07-Dec-15	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA		3.519	0.008	0.000	0.008	0.000	-2.583
47731	245 RIVER STREET PLACE LLC		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-15	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.400	0.001	0.173	0.001	0.173	0.013
47741	FUTURE GEN WIND	38669	FUTURE GEN WIND	WT	WND		WIND TURBINE	16-Aug-16	Consolidated Edison Energy, Inc	CEEI	MA	023	SEMA	SEMA	59622	7.600	0.000	1.388	0.000	1.388	0.988
47749	UI RCP BGPT PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Dec-15	United Illuminating Company, The	UI	CT	001	SWCT	CT	60054	2.200	0.000	1.197	0.000	1.197	0.317
47751	WED COVENTRY 1-6		No Resource (1)	WT	WND		WIND TURBINE	31-Aug-16	Green Development, LLC	GRDV	RI	003	RI	RI		13.875	0.000	0.000	0.000	0.000	0.000
47752	AMPERSAND BROOKLYN DAM HYDRO		No Resource (1)	HDR	WAT		HYDRO (DAILY CYCLE - RUN OF RIVER)	18-Dec-15	Public Service Company of New Hampshire	PSNH	NH	007	NH	NH		0.600	0.340	0.091	0.340	0.091	0.091
47822	NECCO GEN	10308	NECCO COGENERATION FACILITY	IC	NG		GAS INTERNAL COMBUSTION	01-Jun-16	New England Confectionery Company, Inc	NECCO	MA	025	BOSTON	NEMA	55999	5.651	5.042	0.000	4.948	0.000	0.000
47836	QUABBIN WIRE-01082PV70NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Dec-15	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		0.070	0.000	0.000	0.000	0.000	-0.028
47837	QUABBIN WIRE-01082PV224NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Dec-15	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		0.224	0.000	0.000	0.000	0.000	-0.090
47838	GOODING FAMILY-02302PV250NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Dec-15	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.250	0.000	0.066	0.000	0.066	-0.034
47926	NM AMHERST DEVELOPMENT ASSOC		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Feb-16	Western Massachusetts Electric Company	WMECO	MA	015	WMA	WCMA		0.095	0.000	0.000	0.000	0.000	-0.038
47927	NM EASTHAMPTON HS		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Feb-16	Western Massachusetts Electric Company	WMECO	MA	015	WMA	WCMA		0.083	0.000	0.000	0.000	0.000	-0.033
47928	NM BIG Y LEE MA		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Feb-16	Western Massachusetts Electric Company	WMECO	MA	003	WMA	WCMA		0.295	0.000	0.000	0.000	0.000	-0.118
47929	NM BIG Y SPRINGFIELD MA		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Feb-16	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		0.500	0.000	0.000	0.000	0.000	-0.200
47930	NM-HONORE LLC		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Feb-16	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		0.095	0.000	0.000	0.000	0.000	-0.038
47931	NM-BETA FOG NOZZLE		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Feb-16	Western Massachusetts Electric Company	WMECO	MA	011	WMA	WCMA		0.135	0.000	0.000	0.000	0.000	-0.054
47932	NM GIRARD LIMITED		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Feb-16	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		0.080	0.000	0.000	0.000	0.000	-0.032
47933	NM WALMART SPRINGFIELD MA		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Feb-16	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		0.333	0.000	0.000	0.000	0.000	-0.133
47934	NM WINTON CORP		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Feb-16	Western Massachusetts Electric Company	WMECO	MA	013	WMA	WCMA		0.110	0.000	0.000	0.000	0.000	-0.044
47950	NATIONAL GRID 1-01005PV480NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Feb-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.480	0.030	0.261	0.030	0.261	0.069
47951	NATIONAL GRID 2-01005PV480NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Feb-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.480	0.032	0.303	0.032	0.303	0.111
47952	NATIONAL GRID 3-01005PV480NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Feb-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.480	0.025	0.137	0.025	0.137	-0.055
47953	NATIONAL GRID 4-01005PV480NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Feb-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.480	0.020	0.051	0.020	0.051	-0.141
47954	WINN SOLAR THREE-01841PV115NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Feb-16	Massachusetts Electric Company	MEC	MA	009	CMA/NEMA	WCMA		0.115	0.004	0.050	0.004	0.050	0.004
47955	BELLINGHAM PLAZA-02019PV198QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Feb-16	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.198	0.000	0.000	0.000	0.000	-0.079
47956	ANDOVER COMPANIES-01810PV494NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Feb-16	Massachusetts Electric Company	MEC	MA	009	CMA/NEMA	WCMA		0.494	0.004	0.238	0.004	0.238	0.040
47959	ZORENA-01590PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Feb-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.100	0.003	0.050	0.003	0.050	0.010
47983	JLS MAILING SVS-01876PV490NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Mar-16	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.490	0.000	0.118	0.000	0.118	-0.078
47984	BJ'S WHOLESALE-01532PV460NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Mar-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.460	0.000	0.000	0.000	0.000	-0.184
47985	DENNISON LUBRICANT01607PV308QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Mar-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.308	0.000	0.105	0.000	0.105	-0.018
47986	TARGET LEOMINSTER-01453PV184QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Mar-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.184	0.000	0.000	0.000	0.000	-0.074
47987	LAMOUREUX FORD-01515PV100NMNM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Mar-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.100	0.000	0.021	0.000	0.021	-0.019
47991	SOLTERRA LLC SOLAR PROJECT		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Jan-17	NRG Power Marketing LLC	NRGPM	MA	027	WMA	WCMA	60391	15.704	0.000	0.000	0.000	5.999	5.999
47992	BREAKAWAY ICE-01876PV120NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Mar-16	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.120	0.000	0.000	0.000	0.000	-0.048
47993	217 EAST RD SOLAR-01220PV996NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Mar-16	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		0.996	0.159	0.625	0.159	0.625	0.227
47994	NAT GRID ATTLEBORO02703PV996QF	38704	Richardson Ave Attleboro PV 2	PV	SUN		PHOTOVOLTAIC	24-Mar-16	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.996	0.059	0.306	0.059	0.306	-0.092
47995	NATL GRID SHIRLEY-01464PV996QF	38538	Groton Road Shirley PV	PV	SUN		PHOTOVOLTAIC	24-Mar-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.996	0.057	0.359	0.057	0.359	-0.039
47996	NAT GRID CHARLTON-01507PV684QF	38528	29 Oxford Rd Charlton PV	PV	SUN		PHOTOVOLTAIC	28-Mar-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.684	0.051	0.190	0.051	0.190	-0.084
48022	WINN SOLAR THREE-01852PV120NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	30-Mar-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.120	0.017	0.067	0.017	0.067	0.019
48075	STONY HILL SOLAR-01036PV499NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Apr-16	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		0.499	0.016	0.211	0.016	0.211	0.011
48081	APOLLO SOLAR-01876PV268NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Apr-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.268	0.000	0.000	0.000	0.000	-0.107
48082	HANCOCK WIND		No Resource (1)	WT	WND		WIND TURBINE	14-Dec-16	Hancock Wind, LLC	HCWL	ME	009	BHE	ME		61.370	0.000	0.000	0.000	8.125	8.125
48083	FRENCH RIVER		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Dec-16	Boston Energy Trading and Marketing LLC	EMMT-I	MA	027	WMA	WCMA		12.350	0.000	0.000	0.000	4.718	4.718
48166	MAYBURY ASSOC-01028PV250QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Apr-16	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		0.250	0.011	0.054	0.011	0.054	0.054
48167	RANDOLP & BALDWIN-01432PV80QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Apr-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.080	0.004	0.020	0.004	0.020	0.020

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
48170	SYNCARPHA PALMER-01069PV4995NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Apr-16	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA	60056	4.995	0.548	2.759	0.548	2.759	2.759
48171	HALIFAX SOLAR NG-02338PV2500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Apr-16	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		2.500	0.282	1.361	0.282	1.361	1.361
48172	BLUEWAVE CAPITAL-02769PV1670NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Apr-16	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		1.670	0.223	0.994	0.223	0.994	0.994
48177	PARKRIDGE-01835PV92.4QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Apr-16	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.092	0.015	0.037	0.015	0.037	0.037
48178	PLAINVILLE TARGET-02762PV414QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Apr-16	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.414	0.000	0.000	0.000	0.000	0.000
48205	GENERAL WOODWKNG2-01851PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Apr-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.100	0.010	0.031	0.010	0.031	0.031
48206	GENERAL WOODWKNG1-01851PV224NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Apr-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.224	0.011	0.054	0.011	0.054	0.054
48221	146 SUPPLY CTR-01527PV98NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-May-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.098	0.000	0.022	0.000	0.022	0.022
48225	SWANSEA TARGET-02777PV483QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-May-16	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.483	0.000	0.036	0.000	0.036	0.036
48226	UXBRIDGE PRO STGE-01569PV265QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-May-16	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.265	0.000	0.000	0.000	0.000	0.000
48232	TOWN OF WENDELL-01473PV600NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-May-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.600	0.000	0.040	0.000	0.040	0.040
48239	CYN OIL CORP-02072PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-May-16	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.100	0.000	0.010	0.000	0.010	0.010
48249	WORC BURNCOAT-01606PV252QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-May-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.252	0.000	0.075	0.000	0.075	0.075
48250	WORC FOREST GROVE-01605PV87QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-May-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.087	0.000	0.000	0.000	0.000	0.000
48314	NAT GRID MILLBURY-01527PV684QF	38539	40 Auburn Rd Millbury PV	PV	SUN		PHOTOVOLTAIC	18-May-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.684	0.000	0.184	0.000	0.184	0.184
48321	WORC CHANDLER-01602PV100QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-May-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.100	0.000	0.000	0.000	0.000	0.000
48400	SOMERSET SCHOOL-02726PV240NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-May-16	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.240	0.000	0.020	0.000	0.020	0.020
48401	EVERSOURCE PV N2123		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-May-16	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH		0.121	0.000	0.000	0.000	0.000	0.000
48402	MERCURY WIRE-01562PV224NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-May-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.224	0.000	0.000	0.000	0.000	0.000
48403	FACILITY MGT CORP-01747PV200NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-May-16	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.200	0.000	0.010	0.000	0.010	0.010
48406	HERRICKS INC-01364PV112NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-May-16	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA		0.112	0.000	0.032	0.000	0.032	0.032
48407	ENRIGHT LLC-01879PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-May-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.300	0.000	0.138	0.000	0.138	0.138
48426	19 POND RD LLC-01930PV200NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-May-16	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.200	0.000	0.076	0.000	0.076	0.076
48583	HYDE TOOLS INC-01550PV263NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jun-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.263	0.000	0.000	0.000	0.000	0.000
48584	LAND OF THE SKY1-01550PV480NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jun-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.480	0.000	0.284	0.000	0.284	0.284
48585	LAND OF THE SKY2-01550PV480NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jun-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.480	0.000	0.301	0.000	0.301	0.301
48586	LAND OF THE SKY3-01550PV480NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jun-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.480	0.000	0.292	0.000	0.292	0.292
48587	LAND OF THE SKY4-01550PV480NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jun-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.480	0.000	0.301	0.000	0.301	0.301
48588	SOLARCITY CORP-01096PV2266NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Jun-16	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		2.266	0.000	1.226	0.000	1.226	1.226
48643	DURHAM PV N3524		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Jun-16	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH		0.504	0.000	0.262	0.000	0.262	0.262
48645	PISGAH MOUNTAIN WIND		No Resource (1)	WT	WND		WIND TURBINE	16-Dec-16	SWEB Development USA, LLC	SWEB	ME	019	BHE	ME		9.500	0.000	0.000	0.000	1.258	1.258
48649	ALPHA RHO		No Resource (1)	PV	SUN		PHOTOVOLTAIC	05-Jul-16	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.200	0.000	0.062	0.000	0.062	0.062
48650	LONG SUBARU-01570PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-Jul-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.075	0.000	0.002	0.000	0.002	0.002
48651	TRINITY EMS-01853PV64.8QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-Jul-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.065	0.000	0.007	0.000	0.007	0.007
48659	MILTON PV N3084		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Jul-16	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH		0.750	0.000	0.183	0.000	0.183	0.183
48664	S COUNTY-02822PV878DG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Jul-16	The Narragansett Electric Company	NEC	RI	009	RI	RI		0.878	0.000	0.242	0.000	0.242	0.242
48665	IMPERIAL DELTAH-02914PV264NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Jul-16	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.264	0.000	0.019	0.000	0.019	0.019
48672	THEDODGECO-01821PV172NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Jul-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.172	0.000	0.029	0.000	0.029	0.029
48674	RES.RD.HOLDINGS-02136PV2500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Jul-16	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		2.500	0.000	1.290	0.000	1.290	1.290
48675	HARBOR SOLAR LLC-02324PV989NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Jul-16	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.989	0.000	0.343	0.000	0.343	0.343
48676	HARBOR SOLAR 2-02324PV1978NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Jul-16	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		1.978	0.000	0.990	0.000	0.990	0.990
48694	MERCURY (198)-01543PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		2.000	0.000	0.706	0.000	0.706	0.706
48697	MCI TELECOM-01507PV772.8QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.772	0.000	0.000	0.000	0.000	0.000
48698	STORZ 2101B-01507PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		2.000	0.000	0.000	0.000	0.000	0.000
48705	SUN E. BRDGEWTR-02324PV3000NM	38376	Landcraft	PV	SUN		PHOTOVOLTAIC	02-Aug-16	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		3.000	0.000	0.966	0.000	0.966	0.966
48713	STORZ 2101A-01507PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		2.000	0.000	0.000	0.000	0.000	0.000
48714	ONSET EAST	38701	Onset East	PV	SUN		PHOTOVOLTAIC	04-Aug-16	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		1.000	0.000	0.571	0.000	0.571	0.571
48715	ONSET WEST	38702	Onset West	PV	SUN		PHOTOVOLTAIC	04-Aug-16	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		1.000	0.000	0.567	0.000	0.567	0.567
48718	BRODIE MT RD-01237PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Aug-16	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		2.000	0.000	1.102	0.000	1.102	1.102
48719	HOUSATONIC-WARE-01092PV960NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	04-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.960	0.000	0.523	0.000	0.523	0.523
48720	WESTBROOKFIELD-01585PV1400NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.400	0.000	0.614	0.000	0.614	0.614
48721	HOUSATONIC SPRING-01092PV952NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.952	0.000	0.512	0.000	0.512	0.512
48722	BURTON VILLAGE-01452PV96QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Aug-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.096	0.000	0.022	0.000	0.022	0.022
48723	INDEPENDENCE2575-02072PV1725NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Aug-16	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		1.725	0.000	0.745	0.000	0.745	0.745
48724	CASCO BAY ENERGY STORAGE		No Resource (1)	ES	MWH		ENERGY STORAGE	31-Dec-16	NextEra Energy Power Marketing, LLC	FPLP	ME	005	SME	ME		16.699	0.000	0.000	0.000	1.446	1.446
48726	510PV DEV. 2-01566PV996QF	38545	90 River Rd Sturbridge PV	PV	SUN		PHOTOVOLTAIC	08-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.996	0.000	0.418	0.000	0.418	0.418
48727	510PVDEVKELLY1-01566PV996QF	38544	17 Kelly Rd Sturbridge PV	PV	SUN		PHOTOVOLTAIC	08-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.996	0.000	0.268	0.000	0.268	0.268
48728	MECO.LCSTR-01524PV684QF	38494	24 Boutilier Rd Leicester PV	PV	SUN		PHOTOVOLTAIC	11-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.684	0.000	0.230	0.000	0.230	0.230
48741	CECSOLAR#1050-01569PV950NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Aug-16	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.950	0.000	0.448	0.000	0.448	0.448
48742	HOUSATONIC 1734-01236PV2100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Aug-16	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		2.100	0.000	1.173	0.000	1.173	1.173
48743	ECASOLAR39TOZERRD-01915PV840NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Aug-16	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.840	0.000	0.000	0.000	0.000	0.000
48747	BRAUNSEXPRESS-01747PV164NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Aug-16	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.164	0.000	0.043	0.000	0.043	0.043
48748	RANDOLPH&BALDWIN-01432PV79.2NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Aug-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.079	0.000	0.014	0.000	0.014	0.014
48749	ARSENAULT2103-01585PV800NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.800	0.000	0.374	0.000	0.374	0.374
48750	BLUEWAVE 8861-01540PV1500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.500	0.000	0.592	0.000	0.592	0.592
48751	BLUEWAVE5149-02766PV750NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-16	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.750	0.000	0.291	0.000	0.291	0.291
48752	BLUEWAVE 5161-02766PV750NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-16	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.750	0.000	0.317	0.000	0.317	0.317
48753	CEREBRAL PALSY-02072PV112QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Aug-16	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.112	0.000	0.000	0.000	0.000	0.000
48756	QUINCYSCHOOLS4785-02169PV135NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Aug-16	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.135	0.000	0.000	0.000	0.000	0.000
48757	SAFEHARBOROTIS-01581PV741NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Aug-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.741	0.000	0.318	0.000	0.318	0.318

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report				
																	WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
48758	CEDEV.MEETINGST-02905PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Aug-16	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.075	0.000	0.000	0.000	0.000	0.000
48764	QUINCYPALMERST-02169PV120NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Aug-16	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.120	0.000	0.023	0.000	0.023	0.023
48765	QUINCYQPSOFFICE-02169PV96NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Aug-16	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.096	0.000	0.000	0.000	0.000	0.000
48766	CECSOLAR#1045-01569PV728NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Aug-16	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.728	0.000	0.324	0.000	0.324	0.324
48767	510PVDEVNASHUARD-01463PV990NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Aug-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.990	0.000	0.497	0.000	0.497	0.497
48768	QUINCY_BILLINGS-02171PV63NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Aug-16	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.063	0.000	0.000	0.000	0.000	0.000
48774	FOSTER-SOLAR-02857PV1170RIDG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Aug-16	The Narragansett Electric Company	NEC	RI	007	RI	RI		1.170	0.000	0.491	0.000	0.491	0.491
48778	CECSOLAR#1051-01569PV450NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Aug-16	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.450	0.000	0.179	0.000	0.179	0.179
48787	KNIGHT FARM-02828PV70NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Aug-16	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.070	0.000	0.008	0.000	0.008	0.008
48788	HOWLANDASS.-02865PV136NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Aug-16	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.136	0.000	0.000	0.000	0.000	0.000
48801	BELLAENERGY5140-02715PV499NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Aug-16	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.499	0.000	0.213	0.000	0.213	0.213
48810	510PVDEV.ELLIS RD-01473PV480NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.480	0.000	0.262	0.000	0.262	0.262
48811	ALVES238E.MAINRD-02842PV86.4NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Sep-16	The Narragansett Electric Company	NEC	RI	005	RI	RI		0.086	0.000	0.030	0.000	0.030	0.030
48812	PRINTGUARD-01527PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	30-Aug-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.100	0.000	0.046	0.000	0.046	0.046
48813	WINDSORWOOD-02148PV140NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Aug-16	Massachusetts Electric Company	MEC	MA	017	BOSTON	NEMA		0.140	0.000	0.050	0.000	0.050	0.050
48814	PALMERFOUNDRY-01069PV252NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Aug-16	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		0.252	0.000	0.000	0.000	0.000	0.000
48815	NEXTSUNWALKERRD-01464PV2000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	31-Aug-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		2.000	0.000	0.554	0.000	0.554	0.554
48816	510PVDEVBARRE-01005PV480NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	31-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.480	0.000	0.276	0.000	0.276	0.276
48817	TARGET#T2430-02886PV112NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Aug-16	The Narragansett Electric Company	NEC	RI	003	RI	RI		0.112	0.000	0.000	0.000	0.000	0.000
48818	510PV_NBROOKFIELD-01535PV480NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	31-Aug-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.480	0.000	0.291	0.000	0.291	0.291
48819	BLUEWAVE7629-02766PV500NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	30-Aug-16	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.750	0.000	0.239	0.000	0.239	0.239
48820	WNEWBURYMAINSTLLC-01985PV354NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Sep-16	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.354	0.000	0.000	0.000	0.135	0.135
48821	EJRREALESTATE-01752PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Sep-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.300	0.000	0.000	0.000	0.115	0.115
48823	LONG SUB.3685-01570PV140NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Sep-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.140	0.000	0.000	0.000	0.053	0.053
48824	KJA PROPERTIES-02842PV63NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Sep-16	The Narragansett Electric Company	NEC	RI	005	SEMA	RI		0.063	0.000	0.000	0.000	0.024	0.024
48825	MOTOMANCHESTER-02035PV255NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Sep-16	Massachusetts Electric Company	MEC	MA	021	RI	SEMA		0.255	0.000	0.000	0.000	0.097	0.097
48826	BROOKFIELDWIRECO-01585PV1414NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Sep-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.414	0.000	0.000	0.000	0.540	0.540
48827	UNIONSQUARERLTY-01453PV260NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Sep-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.260	0.000	0.000	0.000	0.099	0.099
48828	WINNSOLARWATERST-01604PV75.6NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Sep-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.076	0.000	0.000	0.000	0.029	0.029
48840	JPSULLIVAN-01434PV230NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Sep-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.230	0.000	0.000	0.000	0.088	0.088
48841	EXTRASPACEMAN.INC-01862PV76NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Sep-16	Massachusetts Electric Company	MEC	MA	017	BOSTON	WCMA		0.076	0.000	0.000	0.000	0.029	0.029
48847	EXTRASPACEBROCKTON-02301PV92NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Sep-16	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.092	0.000	0.000	0.000	0.035	0.035
48848	DANAWALLSUPPLY-01879PV68.4NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Sep-16	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.068	0.000	0.000	0.000	0.026	0.026
48849	RUTLANDPLAZALLC-01543PV70NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Sep-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.070	0.000	0.000	0.000	0.027	0.027
48850	AIRTIGHTHOLDERS-01257PV250NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Sep-16	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		0.250	0.000	0.000	0.000	0.096	0.096
48856	JIMARYLANDTRUST-01930PV108NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-Sep-16	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.108	0.000	0.000	0.000	0.041	0.041
48857	E.CALIGARI&SONS-01240PV112NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Sep-16	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		0.112	0.000	0.000	0.000	0.043	0.043
48858	530MAINSTR.E.LLC-01510PV183NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Sep-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.183	0.000	0.000	0.000	0.070	0.070
48859	BROOKFIELDWASTE-01506PV333NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Sep-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.333	0.000	0.000	0.000	0.127	0.127
48860	DUVAL'SPHARMACY-02382PV70NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Sep-16	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.070	0.000	0.000	0.000	0.027	0.027
48861	WILLIAMSTOWNYOUTH-01267PV80NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Sep-16	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		0.080	0.000	0.000	0.000	0.031	0.031
48862	R.E.DEV.WILBRAHAM-01095PV750NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-Sep-16	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		0.750	0.000	0.000	0.000	0.287	0.287
48863	WESTBOROTENNIS-01510PV72NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Sep-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.072	0.000	0.000	0.000	0.028	0.028
48872	PLUMBERSSUPPLY-01453PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Sep-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.100	0.000	0.000	0.000	0.038	0.038
48874	CLARKUNIVERSITY-01610PV140NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Sep-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.140	0.000	0.000	0.000	0.053	0.053
48876	CVEC_CHATHAM_ID1911		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		1.500	0.000	0.000	0.000	0.573	0.573
48877	CVEC_BREWSTER_ID1912		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		1.083	0.000	0.000	0.000	0.414	0.414
48878	ATHENS ENERGY LLC		No Resource (1)	ST	WDS		BIO/REFUSE	01-Oct-16	Athens Energy LLC	AELC	ME	025	ME	ME		8.500	0.000	0.000	0.000		0.000
48879	WAREHAM_MA1_LLC_ID1972361		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		2.000	0.000	0.000	0.000	0.764	0.764
48880	TOWN_OF_MASHPEE_ID2049		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		1.500	0.000	0.000	0.000	0.573	0.573
48881	CITY_OF_NEWBEDFORD_ID1939		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		1.500	0.000	0.000	0.000	0.573	0.573
48882	CVEC_MARSTON_MILLS_ID1965		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		1.416	0.000	0.000	0.000	0.541	0.541
48883	TOWN_OF_DENNIS_ID1712		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		1.250	0.000	0.000	0.000	0.478	0.478
48884	CVEC_HYANNIS_ID2181		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		4.500	0.000	0.000	0.000	1.719	1.719
48885	UMASS_DARTMOUTH_ID1849		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		4.200	0.000	0.000	0.000	1.604	1.604
48886	TOWN_OF_SANDWICH_ID2043		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		3.500	0.000	0.000	0.000	1.337	1.337
48887	PLYMOUTH_PUB_SCHS_ID1895		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		2.900	0.000	0.000	0.000	1.108	1.108
48888	TOWN_OF_DENNIS_ID2115		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		2.500	0.000	0.000	0.000	0.955	0.955
48889	CVEC_MARSTON_MILLS_ID1964		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Oct-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		2.000	0.000	0.000	0.000	0.764	0.764
48895	COSTAPROPMGMTLLC-02724PV150NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Oct-16	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.150	0.000	0.000	0.000	0.057	0.057
48896	SHAHEENBROSLLC-01913PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Oct-16	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.300	0.000	0.000	0.000	0.115	0.115
48899	BRANDYWICKLLC-02896PV1000RIDG		No Resource (1)	PV	SUN		PHOTOVOLTAIC	11-Oct-16	The Narragansett Electric Company	NEC	RI	007	RI	RI		1.000	0.000	0.000	0.000	0.382	0.382
48913	VALLEYST.MILL-02909PV98NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Oct-16	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.098	0.000	0.000	0.000	0.037	0.037
48914	DRACUTHOUS.AUTH-01507PV1980NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Oct-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.980	0.000	0.000	0.000	0.756	0.756
48915	510PVMOSSBERG-02703PV684QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Oct-16	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.684	0.000	0.000	0.000	0.261	0.261
48916	BEVOVATIONSLLC-01453PV252NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Oct-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.252	0.000	0.000	0.000	0.096	0.096
48949	77LEICESTERLLC-01540PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	28-Oct-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		0.100	0.000	0.000	0.000	0.038	0.038
48955	PATEL-REALTY-02721PV72NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Nov-16	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.072	0.000	0.000	0.000	0.028	0.028
48960	ATHENS ENERGY LLC_1		No Resource (1)	ST	WDS		BIO/REFUSE	18-Feb-17	Athens Energy LLC	AELC	ME	025	ME	ME		8.500	0.000	0.000	0.000	0.000	0.000
48963	BROOKSSTDEV-01606PV476NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Nov-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.476	0.000	0.000	0.000	0.182	0.182

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
48975	FISHER ROAD PV		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Dec-16	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.540	0.000	0.000	0.000	0.206	0.206
49000	AQUILACURTISHILL-01507PV1980NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Dec-16	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.980	0.000	0.000	0.000	0.756	0.756
49001	NEXAMPFACTORYST-02893PV384NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Dec-16	The Narragansett Electric Company	NEC	RI	003	RI	RI		0.384	0.000	0.000	0.000	0.147	0.147
49002	SOMERSETELEM.-02726PV270NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Dec-16	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.270	0.000	0.000	0.000	0.103	0.103
49003	APE.VINEYARDRD-02771PV150NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Dec-16	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.150	0.000	0.000	0.000	0.057	0.057
49010	ROCHESTER PV N3365		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Dec-16	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH		0.500	0.000	0.000	0.000	0.191	0.191
49011	BEDFORD PV N3787		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Dec-16	Public Service Company of New Hampshire	PSNH	NH	011	NH	NH		0.364	0.000	0.000	0.000	0.139	0.139
49012	NASHUA PV N3791		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Dec-16	Public Service Company of New Hampshire	PSNH	NH	011	VT	NH		0.364	0.000	0.000	0.000	0.139	0.139
49013	KEENE PV N3792		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Dec-16	Public Service Company of New Hampshire	PSNH	NH	005	VT	NH		0.364	0.000	0.000	0.000	0.139	0.139
49014	GREENLAND PV N3788		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Dec-16	Public Service Company of New Hampshire	PSNH	NH	015	NH	NH		0.364	0.000	0.000	0.000	0.139	0.139
49017	AMERICANATHLETIC-01082PV75NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Dec-16	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		0.075	0.000	0.000	0.000	0.029	0.029
49031	C.H.YATESRUBBER-02720PV972NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Dec-16	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.972	0.000	0.000	0.000	0.371	0.371
49055	TOWN_OF_SUDBURY_ID2176		No Resource (1)	PV	SUN		PHOTOVOLTAIC	12-Dec-16	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA	58839	1.333	0.000	0.000	0.000	0.509	0.509
49063	TOWN_OF_MEDWAY_ID1972386		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Dec-16	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		4.500	0.000	0.000	0.000	1.719	1.719
49064	TOWN_OF_WESTON_ID2055868		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Dec-16	NSTAR Electric Company	NSTAR	MA	017	BOSTON	NEMA		1.795	0.000	0.000	0.000	0.686	0.686
49065	DOVER PV N3015		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Dec-16	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH		0.267	0.000	0.000	0.000	0.102	0.102
49070	TOWN_OF_NEEDHAM_ID1989732		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Dec-16	NSTAR Electric Company	NSTAR	MA	021	BOSTON	NEMA	60110	3.120	0.000	0.000	0.000	1.192	1.192
49071	CVEC_INC_VINEYARDHAVEN_ID1923		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Dec-16	NSTAR Electric Company	NSTAR	MA	007	SEMA	SEMA		1.083	0.000	0.000	0.000	0.414	0.414
49072	TOWN_OF_ACTON_ID2056		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Dec-16	NSTAR Electric Company	NSTAR	MA	017	Boston	NEMA		1.500	0.000	0.000	0.000	0.573	0.573
49073	CES_TIHONET_SOLAR_ID2350		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA	58749	1.000	0.000	0.000	0.000	0.382	0.382
49074	WAREHAM_FIRE_DISTRICT_ID2128		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		0.583	0.000	0.000	0.000	0.223	0.223
49075	TOPEKA_SOLAR1_ID2191		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		1.000	0.000	0.000	0.000	0.382	0.382
49076	MASSDOT_ID1977739		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		0.500	0.000	0.000	0.000	0.191	0.191
49077	IGS_SOLARLLC_ID2094068		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		0.300	0.000	0.000	0.000	0.115	0.115
49078	BWC_ORIGIN_FAIRHAVEN_ID1964211		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		0.750	0.000	0.000	0.000	0.287	0.287
49081	TOWN_OF_DUXBURY_ID2143		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		0.500	0.000	0.000	0.000	0.191	0.191
49082	GLC_ACUSHNET_ID1819		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		1.000	0.000	0.000	0.000	0.382	0.382
49083	TOWN_OF_CHILMARK_ID1981127		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	007	SEMA	SEMA		0.173	0.000	0.000	0.000	0.066	0.066
49084	CVEC_INC_WESTTISBURY_ID2189		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	007	SEMA	SEMA		0.600	0.000	0.000	0.000	0.229	0.229
49085	MARGUERITE_SMALL_SCHOOL_ID2168		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		0.750	0.000	0.000	0.000	0.287	0.287
49086	BRALEY_ROAD_SOLAR4_ID1896		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		1.000	0.000	0.000	0.000	0.382	0.382
49087	SIPPICAN_COMM_SOLAR_ID2029145		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		0.783	0.000	0.000	0.000	0.299	0.299
49088	CVEC_INC_ORLEANS_ID2217		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		0.500	0.000	0.000	0.000	0.191	0.191
49089	CANAM (PV)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Dec-16	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.084	0.000	0.000	0.000	0.032	0.032
49093	S&E (PV)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Dec-16	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.239	0.000	0.000	0.000	0.091	0.091
49094	FRIENDS_ACADEMY_ID2326		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	005	SEMA	SEMA		0.134	0.000	0.000	0.000	0.051	0.051
49095	DY_HIGH_SCHOOL_ID2173		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	001	SEMA	SEMA		0.500	0.000	0.000	0.000	0.191	0.191
49096	MCCARTHY_PROPERTIES_ID2077939		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		0.200	0.000	0.000	0.000	0.076	0.076
49097	815_MAIN_ST_SOLARLLC_ID2077567		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Dec-16	NSTAR Electric Company	NSTAR	MA	023	SEMA	SEMA		0.130	0.000	0.000	0.000	0.050	0.050
49197	SHREDKING-02343PV180NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Dec-16	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.180	0.000	0.000	0.000	0.069	0.069
49198	HOLYNAMESCHOOL-02720PV144NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Dec-16	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.144	0.000	0.000	0.000	0.055	0.055
49202	WORC.ROOSEVELT-01604PV100NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Dec-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.100	0.000	0.000	0.000	0.038	0.038
49203	WORC.BELMONTST-01605PV200NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Dec-16	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.200	0.000	0.000	0.000	0.076	0.076
49213	JUDSONHOUSE-01830PV82NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Dec-16	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.082	0.000	0.000	0.000	0.031	0.031
49214	APE.1788GARHWY-02777PV476NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Dec-16	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.476	0.000	0.000	0.000	0.182	0.182
49215	REINGOLD SCHOOL (PV)		No Resource (1)	PV	SUN		PHOTOVOLTAIC	22-Dec-16	Fitchburg Gas & Electric Light Company	FGE	MA	027	WMA	WCMA		0.195	0.000	0.000	0.000	0.074	0.074
49216	MISCOHILLELEM-01756PV386NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	30-Dec-16	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.386	0.000	0.000	0.000	0.147	0.147
49217	NOHOARTSTRUST-01060PV176NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	30-Dec-16	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		0.176	0.000	0.000	0.000	0.067	0.067
49222	NEXAMP-LOGEE-02895PV153RE		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Jan-17	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.153	0.000	0.000	0.000	0.058	0.058
49240	QUINCYCODDINGTON-02169PV183NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	13-Jan-17	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.183	0.000	0.000	0.000	0.070	0.070
49241	DINO'SPARK&SHOP-02814PV196RE		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jan-17	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.196	0.000	0.000	0.000	0.075	0.075
49242	WORCESTERNORTHHS-01604PV101NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Jan-17	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.101	0.000	0.000	0.000	0.039	0.039
49243	510PVDEVDIGHTON-01851PV996QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Jan-17	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.996	0.000	0.000	0.000	0.380	0.380
49244	510PVDEVGRAFTON-01519PV672QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Jan-17	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.672	0.000	0.000	0.000	0.257	0.257
49245	510PVDEVAYER-01432PV996QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Jan-17	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.996	0.000	0.000	0.000	0.380	0.380
49247	510PVDEVABINGTON-02351PV996QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Jan-17	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.996	0.000	0.000	0.000	0.380	0.380
49248	GE.TINKHAMRD-01095PV496NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Jan-17	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		0.496	0.000	0.000	0.000	0.189	0.189
49249	SHAFIIREALESTATE-01028PV468NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	19-Jan-17	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		0.468	0.000	0.000	0.000	0.179	0.179
49250	ORANGEINNOVATION-01364PV80NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	18-Jan-17	Massachusetts Electric Company	MEC	MA	011	WMA	WCMA		0.080	0.000	0.000	0.000	0.031	0.031
49251	SUTTONSOLARLLC-01590PV1950NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Jan-17	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		1.950	0.000	0.000	0.000	0.745	0.745
49252	BUXTONRDSOLARLLC-01569PV1000NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Jan-17	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		1.000	0.000	0.000	0.000	0.382	0.382
49253	VIRGINIOSARDINIA-01757PV236QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Jan-17	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.236	0.000	0.000	0.000	0.090	0.090
49254	TANGLEWOODFARM-02814PV196RE		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Jan-17	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.196	0.000	0.000	0.000	0.075	0.075
49255	CONWELLSEMINARY-01982PV187QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	24-Jan-17	Massachusetts Electric Company	MEC	MA	009	BOSTON	NEMA		0.187	0.000	0.000	0.000	0.071	0.071
49256	RICARBIDETOOLCO-02917PV196RE		No Resource (1)	PV	SUN		PHOTOVOLTAIC	23-Jan-17	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.196	0.000	0.000	0.000	0.075	0.075
49260	USFLUIDS-01028PV110QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	25-Jan-17	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		0.110	0.000	0.000	0.000	0.042	0.042
49276	ROCKY'SELONGMEADOW-01028PV86QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Jan-17	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		0.086	0.000	0.000	0.000	0.033	0.033
49277	KEARSARGE188EAST-01033PV450NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	26-Jan-17	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		0.450	0.000	0.000	0.000	0.172	0.172
49278	KEARSARGE190EAST-01033PV450NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Feb-17	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		0.450	0.000	0.000	0.000	0.172	0.172
49279	PEGASUSSOLAR-01752PV300NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Jan-17	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.300	0.000	0.000	0.000	0.115	0.115

ASSET ID	ASSET NAME	RE-SOURCE ID	RESOURCE NAME	GEN TYPE ID	PRIM FUEL TYPE	ALT FUEL TYPE	FUEL GEN TYPE DESC	IN-SERVICE DATE	LEAD PARTICIPANT NAME	LEAD PARTICI-PANT ACRONYM	STATE	FIPS COUNTY	RSP AREA	LOAD ZONE NAME	EIA PLANT NUMBER	NAMEPLATE (MW)	As of Jan. 2017 SCC Report WINTER SCC (MW)	SUMMER SCC (MW)	ACTUAL WINTER PEAK SCC DEC 15, 2016	EXPECTED SUMMER PEAK SCC JUL 1, 2017	Change in Expected Summer SCC from 8/1/16 (2)
49280	KEARSARGE229REAST-01033PV450NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Feb-17	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		0.450	0.000	0.000	0.000	0.172	0.172
49282	KEARSARGE914WEST-01056PV450NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Feb-17	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		0.450	0.000	0.000	0.000	0.172	0.172
49283	KEARSARGE220REAST-01033PV450NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Feb-17	Massachusetts Electric Company	MEC	MA	015	WMA	WCMA		0.450	0.000	0.000	0.000	0.172	0.172
49288	BLUEWAVEWEBSTER-01570PV1380NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Feb-17	Massachusetts Electric Company	MEC	MA	027	WMA	WCMA		1.380	0.000	0.000	0.000	0.527	0.527
49289	FUREYROOFINGCO-02888PV29NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	03-Feb-17	The Narragansett Electric Company	NEC	RI	003	RI	RI		0.029	0.000	0.000	0.000	0.011	0.011
49290	CRISSEYFARMS-01230PV113NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Feb-17	Massachusetts Electric Company	MEC	MA	003	WMA	WCMA		0.113	0.000	0.000	0.000	0.043	0.043
49291	NANTUCKETICE-02554PV284NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Feb-17	Massachusetts Electric Company	MEC	MA	019	SEMA	SEMA		0.284	0.000	0.000	0.000	0.108	0.108
49292	NATCOPRODUCTS-02893PV375NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Feb-17	The Narragansett Electric Company	NEC	RI	003	RI	RI		0.375	0.000	0.000	0.000	0.143	0.143
49306	SAFEHARBORSOLAR-01581PV886NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	16-Feb-17	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.886	0.000	0.000	0.000	0.338	0.338
49327	NANTUCKETPAVERS-02771PV240NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Feb-17	Massachusetts Electric Company	MEC	MA	005	RI	SEMA		0.240	0.000	0.000	0.000	0.092	0.092
49328	MILLREALTYTRUST-02370PV86QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	01-Mar-17	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.086	0.000	0.000	0.000	0.033	0.033
49331	SHALOMHOUSING-02886WT100NM		No Resource (1)	WT	WND		WIND TURBINE	01-Mar-17	The Narragansett Electric Company	NEC	RI	003	RI	RI		0.100	0.000	0.000	0.000	0.013	0.013
49335	WESTBOROWWTP-01581PV660NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Feb-17	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		0.660	0.000	0.000	0.000	0.252	0.252
49354	SEAVIEWINNLLC-02842PV180NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	02-Mar-17	The Narragansett Electric Company	NEC	RI	005	SEMA	RI		0.180	0.000	0.000	0.000	0.069	0.069
49359	MILFORDGERIATRIC-01757PV225QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	07-Mar-17	Massachusetts Electric Company	MEC	MA	027	RI	SEMA		0.225	0.000	0.000	0.000	0.086	0.086
49360	TYNGS.LANDFILL#2-01879PV900NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	08-Mar-17	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.900	0.000	0.000	0.000	0.344	0.344
49361	CROMWELLVENTURES-02907PV69NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	06-Mar-17	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.069	0.000	0.000	0.000	0.026	0.026
49365	NORTONLANDFILL-02766PV1500NM	38582	NORTON MA	PV	SUN		PHOTOVOLTAIC	08-Mar-17	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		1.500	0.000	0.000	0.000	0.573	0.573
49366	RUTLANDSOLAR-01543PV990NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-Mar-17	Massachusetts Electric Company	MEC	MA	021	WMA	WCMA		0.990	0.000	0.000	0.000	0.378	0.378
49369	PLYMOUTHREALTY-02333PV143NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	09-Mar-17	Massachusetts Electric Company	MEC	MA	023	SEMA	SEMA		0.143	0.000	0.000	0.000	0.055	0.055
49371	ECASOLARAFF.INT.-01453PV2800QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	10-Mar-17	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		2.800	0.000	0.000	0.000	1.070	1.070
49374	BLUEWAVE CAPITAL-01069PV3800NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	14-Mar-17	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		3.800	0.000	0.000	0.000	1.452	1.452
49376	SYNC.STILLRIVER-01740PV1980NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Mar-17	Massachusetts Electric Company	MEC	MA	027	CMA/NEMA	WCMA		1.980	0.000	0.000	0.000	0.756	0.756
49383	EASTONHS-02356PV370NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	15-Mar-17	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.370	0.000	0.000	0.000	0.141	0.141
49393	IBCCORPORATION-02375PV240QF		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Mar-17	Massachusetts Electric Company	MEC	MA	005	SEMA	SEMA		0.240	0.000	0.000	0.000	0.092	0.092
49394	STRAFELLOINC-02322PV266NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	17-Mar-17	Massachusetts Electric Company	MEC	MA	017	SEMA	SEMA		0.266	0.000	0.000	0.000	0.102	0.102
49396	ELITEENVELOPE-02368PV105NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	20-Mar-17	Massachusetts Electric Company	MEC	MA	021	SEMA	SEMA		0.105	0.000	0.000	0.000	0.040	0.040
49397	NEXTSUNSHIRLEY-01464PV920NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	21-Mar-17	Massachusetts Electric Company	MEC	MA	017	CMA/NEMA	WCMA		0.920	0.000	0.000	0.000	0.351	0.351
49398	MADBURY PV N5466		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Mar-17	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH		0.222	0.000	0.000	0.000	0.085	0.085
49399	PORTSMOUTH PV N5465A		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Mar-17	Public Service Company of New Hampshire	PSNH	NH	015	NH	NH		0.108	0.000	0.000	0.000	0.041	0.041
49400	PORTSMOUTH PV N5465		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Mar-17	Public Service Company of New Hampshire	PSNH	NH	015	NH	NH		0.144	0.000	0.000	0.000	0.055	0.055
49401	ROCHESTER PV N5486		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Mar-17	Public Service Company of New Hampshire	PSNH	NH	017	NH	NH		0.200	0.000	0.000	0.000	0.076	0.076
49402	NASHUA PV N5606		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Mar-17	Public Service Company of New Hampshire	PSNH	NH	011	VT	NH		0.833	0.000	0.000	0.000	0.318	0.318
49404	PKPROPERTIES-02914PV120NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	27-Mar-17	The Narragansett Electric Company	NEC	RI	007	RI	RI		0.120	0.000	0.000	0.000	0.046	0.046
49408	CAVALLO-INC.-01069PV499NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	29-Mar-17	Massachusetts Electric Company	MEC	MA	013	WMA	WCMA		0.499	0.000	0.000	0.000	0.191	0.191
49409	GMHMIL.HOUSING-02842PV612NM		No Resource (1)	PV	SUN		PHOTOVOLTAIC	30-Mar-17	The Narragansett Electric Company	NEC	RI	005	SEMA	RI		0.612	0.000	0.000	0.000	0.234	0.234
															TOTAL	37,372.911	33,129.551	30,523.286	33,156.828	29,174.071	57.217

NOTES:

Appendix A - defines the codes used.

Generator details, including Lead Market Participant, as of January 1, 2017.

Additional information and changes to generating asset Lead Participant since January 1, 2017 may be found in the Endnotes following Section 2.1.

The Expected Summer Peak SCC is based on existing capacity as of the April 2017 SCC Report. The expected SCC values also include full and partial retirements pursuant to the FCM.

SCC values may change throughout the year. Refer to the monthly SCC Reports at http://www.iso-ne.com/isoexpress/web/reports/operations/-/tree/seasonal-claimed-capability for the most recent values.

For the Expected Summer Peak SCC values, new PV and wind resources that do not yet have an SCC value due to a lack of historical generation data have an assumed summer SCC that is based on FCM Qualified Capacity, if applicable. Otherwise, the ratings of new PV resources are assumed to be 38.2% of nameplate (summer), and the ratings of new wind resources are 13.24% of nameplate (summer).

When an alternate fuel is listed, the unit may not necessarily be fully operable on both fuels.

FOOTNOTES:

(1) This an existing Asset that has no associated Resource at this time.

(2) This column is the difference in the August 1st Expected Summer Peak SCC from the 2016 CELT Report to the July 1st Expected Summer Peak SCC from the 2017 CELT Report

2.1 Endnotes

(1) All generator details in Section 2.1, other than the capabilities during the winter and summer peaks, are as of January 1, 2017.

(2) Effective February 1, 2017, Exelon Generation Company, LLC (EXGC) has replaced BP Energy Company (BPEC) as the Lead Market Participant for the following asset:

ECO MAINE, Asset #794

(3) Effective February 18, 2017, Covanta Energy Marketing, LLC (CEM) has replaced Connecticut Light and Power Company, The (CLP as the Lead Market Participant for the following asset:

SECREC-PRESTON, Asset #1415

(4) Effective April 1, 2017, TransCanada Hydro Northeast Inc (TCHN) has replaced TransCanada Power Marketing, Ltd. (TCPM) as the Lead Market Participant for the following assets:

BELLOWS FALLS, Asset #562
COMERFORD 1, Asset #47373
COMERFORD 2, Asset #47366
COMERFORD 3, Asset #47367
COMERFORD 4, Asset #47368
DEERFIELD 2/LWR DRFIELD, Asset #435
DEERFIELD 5, Asset #335
HARRIMAN, Asset #393
MCINDOES, Asset #465
MOORE 1, Asset #737
MOORE 2, Asset #47370
MOORE 3, Asset #47371
MOORE 4, Asset #47372
SEARSBURG, Asset #473
SHERMAN, Asset #561
VERNON, Asset #567
WILDER, Asset #599

(5) Effective April 1, 2017, Vermont Electric Power Company, Inc. (VELCO) has replaced Green Mountain Power Corporation (GMP) as the Lead Market Participant for the following asset:

SIMPSON G LOAD REDUCER, Asset #620

2.2 Net of Imports and Exports [1]

CAPACITY IMPORT/EXPORT FROM	CAPABILITY - MW	
	Winter 1/1/2017	Summer 8/1/2017
Quebec [2]	317	391
New Brunswick	290	208
New York [3]	460	677
NET OF IMPORTS AND EXPORTS [4]	1067	1276

FOOTNOTES:

(1) Summer and winter values are based on FCM Capacity Supply Obligations.

(2) The Citizens Block Load CSO, which is treated as a generating resource in Sec. 3.1 and Appendix D, is treated here as an import from Quebec.

(3) New York values reflect a 100 MW Administrative Export. That export is treated as a reduction to the generation CSO in Sec. 1.

(4) A positive value indicates net imports and a negative value indicates net exports.

3.1.1 - Forecast of Solar PV Resources by Category and State

Category	Sub-Category	States	Annual Total Incremental MW - Nameplate Rating											Totals
			Through 2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	
PV in Markets	FCM PV	CT	0.7	0.0	0.0	0.0	5.8	0.0	0.0	0.0	0.0	0.0	0.0	6.5
		MA	26.2	0.0	37.0	84.8	11.0	0.0	0.0	0.0	0.0	0.0	0.0	159.0
		ME	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
		NH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
		RI	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4
		VT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	Total	Annual	27.4	0.0	37.0	84.8	16.7	0.0	0.0	0.0	0.0	0.0	0.0	165.9
		Cumulative	27.4	27.4	64.4	149.2	165.9	165.9	165.9	165.9	165.9	165.9	165.9	165.9
	Non-FCM PV	CT	2.2	1.0	1.0	1.0	0.5	0.3	0.3	0.3	0.3	0.3	0.3	7.7
		MA	577.8	104.6	76.5	-13.1	58.8	67.8	65.9	64.0	31.0	30.0	29.1	1,092.5
		ME	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
		NH	4.9	1.6	1.1	0.7	0.7	0.6	0.6	0.6	0.6	0.6	0.5	12.5
		RI	21.0	23.6	23.6	20.2	18.2	8.7	6.5	6.3	6.2	6.1	5.9	146.3
		VT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	Total	Annual	605.9	130.9	102.3	8.8	78.1	77.5	73.3	71.2	38.1	37.0	35.8	1,259.0
		Cumulative	605.9	736.8	839.1	847.9	926.0	1003.5	1076.8	1148.1	1186.2	1223.1	1259.0	1,259.0
Markets Total		**Annual**	**633.3**	**130.9**	**139.2**	**93.6**	**94.8**	**77.5**	**73.3**	**71.2**	**38.1**	**37.0**	**35.8**	**1,424.9**
		Cumulative	**633.3**	**764.2**	**903.5**	**997.1**	**1091.9**	**1169.4**	**1242.7**	**1314.0**	**1352.1**	**1389.0**	**1424.9**	**1,424.9**
Behind-the-Meter PV		CT	278.6	131.8	131.8	131.8	52.7	44.4	43.1	41.9	40.6	39.3	38.1	974.0
		MA	720.7	169.3	146.7	92.7	90.2	87.7	85.2	82.7	40.1	38.8	37.6	1,591.8
		ME	22.1	6.8	6.8	6.8	6.2	5.8	5.8	5.8	5.8	5.8	5.8	83.7
		NH	49.4	16.4	11.0	6.8	6.6	6.4	6.2	6.0	5.8	5.7	5.5	125.7
		RI	15.3	17.7	17.7	15.1	13.6	6.5	4.8	4.7	4.6	4.5	4.4	109.2
		VT	198.4	25.0	25.0	25.0	22.5	21.3	21.3	21.3	21.3	21.3	21.3	423.4
Behind-the Meter Total		**Annual**	**1284.6**	**367.0**	**339.0**	**278.2**	**191.8**	**172.1**	**166.4**	**162.4**	**118.2**	**115.4**	**112.6**	**3,307.8**
		Cumulative	**1284.6**	**1651.7**	**1990.6**	**2268.8**	**2460.6**	**2632.7**	**2799.1**	**2961.5**	**3079.7**	**3195.2**	**3307.8**	**3,307.8**
Annual Total	All PV Categories	CT	281.5	132.8	132.8	132.8	58.9	44.7	43.5	42.2	40.9	39.6	38.4	988.2
		MA	1324.8	273.9	260.2	164.4	160.0	155.6	151.1	146.7	71.1	68.9	66.7	2,843.3
		ME	22.1	6.8	6.8	6.8	6.2	5.8	5.8	5.8	5.8	5.8	5.8	83.7
		NH	54.3	18.1	12.0	7.4	7.2	7.0	6.8	6.6	6.4	6.2	6.0	138.2
		RI	36.8	41.3	41.3	35.3	31.8	15.2	11.3	11.1	10.8	10.6	10.4	255.9
		VT	198.4	25.0	25.0	25.0	22.5	21.3	21.3	21.3	21.3	21.3	21.3	423.4
All PV Categories Total		**Annual**	**1918.0**	**497.9**	**478.2**	**371.8**	**286.6**	**249.6**	**239.8**	**233.6**	**156.3**	**152.4**	**148.5**	**4,732.7**
Cumulative Total	All PV Categories	CT	281.5	414.3	547.1	679.9	738.9	783.6	827.1	869.3	910.2	949.8	988.2	988.2
		MA	1324.8	1598.7	1858.9	2023.3	2183.3	2338.9	2490.0	2636.7	2707.8	2776.7	2843.3	2,843.3
		ME	22.1	29.0	35.8	42.7	48.8	54.6	60.4	66.3	72.1	77.9	83.7	83.7
		NH	54.3	72.4	84.4	91.8	99.1	106.1	112.9	119.5	125.9	132.2	138.2	138.2
		RI	36.8	78.1	119.5	154.8	186.6	201.8	213.1	224.1	235.0	245.6	255.9	255.9
		VT	198.4	223.4	248.4	273.4	295.9	317.1	338.4	359.6	380.9	402.1	423.4	423.4
All PV Categories Total		**Cumulative**	**1918.0**	**2415.9**	**2894.1**	**3265.9**	**3552.5**	**3802.1**	**4041.9**	**4275.5**	**4431.8**	**4584.2**	**4732.7**	**4,732.7**

3.1.1 - Forecast of Solar PV Resources by Category and State

NOTES:

1) Explanation of all PV forecast assumptions and methodology is available at:
http://www.iso-ne.com/system-planning/system-forecasting/distributed-generation-forecast

2) The forecast reflects values after applying discount factors developed to reflect a degree of uncertainty in future PV development

3) FCM PV consists of supply or demand-side resources with Capacity Suppliy Obligations (CSO), which may also be Settlement Only Resources

4) Non-FCM PV includes Settlement only Resources (SORs) and Generators (per OP-14) that participate only in the energy market. Negative values in this category are due to the transfer of certain resources from Non-FCM PV to the FCM PV category.

5) Forecast values represent end-of-year installed capacities

6) Values shown may not sum correctly due to rounding

3.1.2 - Forecast of Cumulative BTM Solar PV Estimated Summer Seasonal (July 1st) Peak Load Reduction by State [1]

		Cumulative Total MW - Estimated Summer Seasonal Peak Load Reduction										
Category	**States**	**2016**	**2017**	**2018**	**2019**	**2020**	**2021**	**2022**	**2023**	**2024**	**2025**	**2026**
Behind-the-Meter PV	CT	94.9	132.6	178.4	220.9	251.2	262.4	271.4	279.5	287.5	296.0	303.8
	MA	255.0	317.3	366.9	400.3	421.3	442.2	461.8	479.5	491.8	496.9	501.4
	ME	8.2	10.0	12.2	14.3	16.3	18.0	19.6	21.1	22.6	24.1	25.6
	NH	14.2	22.5	27.2	29.6	31.2	32.7	34.1	35.4	36.6	37.9	39.1
	RI	5.0	8.9	15.4	21.1	25.7	28.9	30.3	31.2	32.1	33.1	34.0
	VT	61.2	84.1	90.4	96.3	102.1	107.3	112.1	116.7	121.3	126.3	131.1
Total	**Cumulative**	438.6	575.4	690.5	782.5	847.8	891.5	929.3	963.3	991.8	1014.3	1035.0

Estimated Summer Seasonal Peak Load Reduction - % of BTM AC nameplate	39.1%	37.5%	36.0%	34.6%	33.5%	32.7%	31.9%	31.2%	30.6%	30.1%	29.6%

Monthly PV Growth Table (as a % of Annual Growth)

Month	**1**	**2**	**3**	**4**	**5**	**6**	**7**	**8**	**9**	**10**	**11**	**12**
Incremental	6%	4%	6%	7%	6%	8%	9%	9%	7%	8%	7%	23%
Cumulative	6%	10%	16%	23%	29%	37%	46%	55%	62%	70%	77%	100%

The above percentages are based on four years of historical installation data and reflect end of month values.

FOOTNOTES:

1) BTM PV peak load reductions relate to coincident summer peak loads only; values for non-coincident summer peak loads (for example, at the state level) may be different

NOTES:

1) Explanation of all PV forecast assumptions and methodology is available at:
http://www.iso-ne.com/system-planning/system-forecasting/distributed-generation-forecast

2) The forecast reflects values after applying discount factors developed to reflect a degree of uncertainty in future PV development

3) Values include the effect of diminishing PV production as increasing PV penetrations shift the timing of peaks later in the day, which is reflected in the % of BTM AC nameplate values shown above.

4) These values are as of July 1 of each year, and include an 8% transmission and distribution loss gross-up. The July 1 values were calculated based on the cumulative growth percentage through June as shown in the Monthly PV Growth Table above.

5) In Sections 1.1 and 1.2 of the CELT Report, the Behind-the-Meter (BTM) PV estimated summer seasonal peak load reductions are reflected in line 1.1.1.

6) Different planning studies may use different values based on the intent of the study.

3.1.3 - Forecast of BTM Solar PV Energy (GWh) by State

		Estimated Annual Energy (GWh)										
Category	**States**	**2016**	**2017**	**2018**	**2019**	**2020**	**2021**	**2022**	**2023**	**2024**	**2025**	**2026**
Behind-the-Meter PV	CT	341	435	612	789	928	995	1054	1112	1167	1221	1273
	MA	947	1046	1262	1434	1557	1677	1793	1906	1997	2051	2102
	ME	27	33	42	51	60	68	76	84	92	99	107
	NH	51	74	93	106	115	124	132	141	149	156	164
	RI	17	29	53	75	95	110	118	124	130	137	143
	VT	197	278	311	345	377	407	435	464	492	521	549
Behind-the Meter Total		**1581**	**1894**	**2373**	**2800**	**3133**	**3381**	**3609**	**3830**	**4027**	**4185**	**4338**

NOTES:

1) Explanation of all PV forecast assumptions and methodology is available at:
http://www.iso-ne.com/system-planning/system-forecasting/distributed-generation-forecast

2) Monthly in-service dates of PV assumed based on historical development

3) All values are grossed up by 6.5% to reflect avoided transmission and distribution losses

4.1 Summary of Capacity Supply Obligations (CSO) MW[(1)(2)(3)(4)(5)(6)]

			Capacity Commitment Period									
			2016-17 [(7)]		2017-18 [(8)]		2018-19 [(9)]		2019-20 [(10)]		2020-21 [(11)]	
Load Zone Name	Resource Type	Resource Sub Type	Summer CSO	Winter CSO	Summer CSO	Winter CSO	Summer CSO	Winter CSO	Summer CSO	Winter CSO	Summer CSO	Winter CSO
CT	ACTIVE DR	REAL TIME DR	90.660	91.006	105.685	97.895	62.105	62.662	19.686	19.570	83.743	82.481
		REAL-TIME EG	97.569	97.569	1.504	1.504	39.320	39.320	7.996	7.997	0.000	0.000
		TOTAL ACTIVE	**188.229**	**188.575**	**107.189**	**99.399**	**101.425**	**101.982**	**27.682**	**27.567**	**83.743**	**82.481**
	PASSIVE DR	ON-PEAK	59.027	59.027	60.325	59.755	58.394	58.394	56.632	56.632	71.369	65.402
		SEASONAL PEAK	355.436	355.436	457.831	457.831	363.379	363.379	437.607	437.607	549.233	567.238
		TOTAL PASSIVE	**414.463**	**414.463**	**518.156**	**517.586**	**421.773**	**421.773**	**494.239**	**494.239**	**620.602**	**632.640**
	DR Total		602.692	603.038	625.345	616.985	523.198	523.755	521.921	521.806	704.345	715.121
	GEN	Intermittent	152.399	162.995	162.971	177.017	161.339	176.820	158.094	173.817	140.637	153.165
		Non Intermittent	8077.890	8080.241	8261.071	8311.531	9105.794	9118.895	9643.573	9694.309	9703.168	9703.168
	GEN Total		8230.289	8243.236	8424.042	8488.548	9267.133	9295.715	9801.667	9868.126	9843.805	9856.333
CT Total			**8832.981**	**8846.274**	**9049.387**	**9105.533**	**9790.331**	**9819.470**	**10323.588**	**10389.932**	**10548.150**	**10571.454**
ME	ACTIVE DR	REAL TIME DR	130.920	133.394	98.045	108.605	134.737	141.439	130.322	136.238	102.178	102.178
		REAL-TIME EG	4.870	2.396	0.000	0.000	6.182	3.898	5.493	3.835	0.000	0.000
		TOTAL ACTIVE	**135.790**	**135.790**	**98.045**	**108.605**	**140.919**	**145.337**	**135.815**	**140.073**	**102.178**	**102.178**
	PASSIVE DR	ON-PEAK	121.876	121.876	163.837	163.875	174.981	174.981	181.204	181.204	139.101	139.101
		SEASONAL PEAK	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
		TOTAL PASSIVE	**121.876**	**121.876**	**163.837**	**163.875**	**174.981**	**174.981**	**181.204**	**181.204**	**139.101**	**139.101**
	DR Total		257.666	257.666	261.882	272.480	315.900	320.318	317.019	321.277	241.279	241.279
	GEN	Intermittent	162.975	271.332	240.663	364.913	211.000	334.008	216.124	341.764	221.475	345.167
		Non Intermittent	2929.496	2929.207	2972.744	2973.999	2897.748	2894.224	2933.340	2936.119	2754.067	2754.067
	GEN Total		3092.471	3200.539	3213.407	3338.912	3108.748	3228.232	3149.464	3277.883	2975.542	3099.234
ME Total			**3350.137**	**3458.205**	**3475.289**	**3611.392**	**3424.648**	**3548.550**	**3466.483**	**3599.160**	**3216.821**	**3340.513**
NEMA	ACTIVE DR	REAL TIME DR	40.421	40.421	37.119	38.490	65.336	65.336	45.028	45.028	55.357	55.357
		REAL-TIME EG	11.999	11.999	0.000	-0.228	4.046	4.046	0.000	0.000	0.000	0.000
		TOTAL ACTIVE	**52.420**	**52.420**	**37.119**	**38.262**	**69.382**	**69.382**	**45.028**	**45.028**	**55.357**	**55.357**
	PASSIVE DR	ON-PEAK	487.533	486.988	581.226	580.416	544.134	544.134	594.300	594.300	754.441	753.896
		SEASONAL PEAK	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
		TOTAL PASSIVE	**487.533**	**486.988**	**581.226**	**580.416**	**544.134**	**544.134**	**594.300**	**594.300**	**754.441**	**753.896**
	DR Total		539.953	539.408	618.345	618.678	613.516	613.516	639.328	639.328	809.798	809.253
	GEN	Intermittent	71.150	72.758	70.226	71.674	70.651	72.023	77.148	72.260	77.545	73.211
		Non Intermittent	2555.781	2556.326	3175.674	3179.925	3230.637	3510.237	3226.238	3426.238	3214.659	3214.659
	GEN Total		2626.931	2629.084	3245.900	3251.599	3301.288	3582.260	3303.386	3498.498	3292.204	3287.870
NEMA Total			**3166.884**	**3168.492**	**3864.245**	**3870.277**	**3914.804**	**4195.776**	**3942.714**	**4137.826**	**4102.002**	**4097.123**

			Capacity Commitment Period									
			2016-17 (7)		2017-18 (8)		2018-19 (9)		2019-20 (10)		2020-21 (11)	
Load Zone Name	Resource Type	Resource Sub Type	Summer CSO	Winter CSO	Summer CSO	Winter CSO	Summer CSO	Winter CSO	Summer CSO	Winter CSO	Summer CSO	Winter CSO
NH	ACTIVE DR	REAL TIME DR	11.132	11.041	13.763	13.042	10.067	9.347	3.676	3.676	17.208	16.489
		REAL-TIME EG	13.474	11.497	0.000	0.000	11.011	9.034	11.724	11.253	0.000	0.000
		TOTAL ACTIVE	**24.606**	**22.538**	**13.763**	**13.042**	**21.078**	**18.381**	**15.400**	**14.929**	**17.208**	**16.489**
	PASSIVE DR	ON-PEAK	70.673	70.673	76.272	76.272	83.036	83.036	88.882	88.882	120.207	102.202
		SEASONAL PEAK	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
		TOTAL PASSIVE	**70.673**	**70.673**	**76.272**	**76.272**	**83.036**	**83.036**	**88.882**	**88.882**	**120.207**	**102.202**
	DR Total		95.279	93.211	90.035	89.314	104.114	101.417	104.282	103.811	137.415	118.691
	GEN	Intermittent	129.904	175.031	145.069	204.212	166.327	220.640	164.107	228.539	165.885	232.111
		Non Intermittent	4094.900	4089.082	4082.426	4082.426	4079.833	4079.833	4073.959	4076.239	4112.453	4112.453
	GEN Total		4224.804	4264.113	4227.495	4286.638	4246.160	4300.473	4238.066	4304.778	4278.338	4344.564
NH Total			**4320.083**	**4357.324**	**4317.530**	**4375.952**	**4350.274**	**4401.890**	**4342.348**	**4408.589**	**4415.753**	**4463.255**
RI	ACTIVE DR	REAL TIME DR	16.820	13.975	19.130	15.629	47.324	47.354	23.868	23.868	26.868	26.868
		REAL-TIME EG	17.541	14.616	0.000	0.000	5.125	5.125	10.249	10.249	0.000	0.000
		TOTAL ACTIVE	**34.361**	**28.591**	**19.130**	**15.629**	**52.449**	**52.479**	**34.117**	**34.117**	**26.868**	**26.868**
	PASSIVE DR	ON-PEAK	174.074	174.016	208.338	208.058	197.823	197.823	216.850	216.850	266.873	266.873
		SEASONAL PEAK	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
		TOTAL PASSIVE	**174.074**	**174.016**	**208.338**	**208.058**	**197.823**	**197.823**	**216.850**	**216.850**	**266.873**	**266.873**
	DR Total		208.435	202.607	227.468	223.687	250.272	250.302	250.967	250.967	293.741	293.741
	GEN	Intermittent	0.635	1.891	0.455	2.281	0.735	2.486	7.264	16.458	7.295	16.212
		Non Intermittent	1833.214	1844.058	1914.009	1916.385	1899.796	1899.796	2364.339	2373.058	2407.116	2425.394
	GEN Total		1833.849	1845.949	1914.464	1918.666	1900.531	1902.282	2371.603	2389.516	2414.411	2441.606
RI Total			**2042.284**	**2048.556**	**2141.932**	**2142.353**	**2150.803**	**2152.584**	**2622.570**	**2640.483**	**2708.152**	**2735.347**
SEMA	ACTIVE DR	REAL TIME DR	13.723	11.846	25.750	25.623	49.325	49.325	33.873	33.873	32.675	32.675
		REAL-TIME EG	11.109	11.109	0.000	0.000	9.137	9.137	0.000	0.000	0.000	0.000
		TOTAL ACTIVE	**24.832**	**22.955**	**25.750**	**25.623**	**58.462**	**58.462**	**33.873**	**33.873**	**32.675**	**32.675**
	PASSIVE DR	ON-PEAK	232.556	232.292	299.106	298.902	285.606	285.606	305.718	305.718	373.639	372.505
		SEASONAL PEAK	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
		TOTAL PASSIVE	**232.556**	**232.292**	**299.106**	**298.902**	**285.606**	**285.606**	**305.718**	**305.718**	**373.639**	**372.505**
	DR Total		257.388	255.247	324.856	324.525	344.068	344.068	339.591	339.591	406.314	405.180
	GEN	Intermittent	74.954	75.509	77.401	81.889	84.026	77.907	95.101	78.057	101.459	80.821
		Non Intermittent	5814.220	5831.599	4533.385	4572.565	4688.163	4852.763	4348.552	4479.385	4418.249	4418.249
	GEN Total		5889.174	5907.108	4610.786	4654.454	4772.189	4930.670	4443.653	4557.442	4519.708	4499.070
SEMA Total			**6146.562**	**6162.355**	**4935.642**	**4978.979**	**5116.257**	**5274.738**	**4783.244**	**4897.033**	**4926.022**	**4904.250**

			Capacity Commitment Period									
			2016-17 (7)		2017-18 (8)		2018-19 (9)		2019-20 (10)		2020-21 (11)	
Load Zone Name	Resource Type	Resource Sub Type	Summer CSO	Winter CSO	Summer CSO	Winter CSO	Summer CSO	Winter CSO	Summer CSO	Winter CSO	Summer CSO	Winter CSO
VT	ACTIVE DR	REAL TIME DR	32.666	32.971	32.103	40.897	30.499	35.666	30.499	33.055	34.079	34.079
		REAL-TIME EG	4.266	4.266	0.000	0.000	3.829	3.267	2.308	2.632	0.000	0.000
		TOTAL ACTIVE	**36.932**	**37.237**	**32.103**	**40.897**	**34.328**	**38.933**	**32.807**	**35.687**	**34.079**	**34.079**
	PASSIVE DR	ON-PEAK	106.625	106.625	124.574	132.571	119.195	119.195	114.063	114.063	97.751	97.668
		SEASONAL PEAK	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
		TOTAL PASSIVE	**106.625**	**106.625**	**124.574**	**132.571**	**119.195**	**119.195**	**114.063**	**114.063**	**97.751**	**97.668**
	DR Total		143.557	143.862	156.677	173.468	153.523	158.128	146.870	149.750	131.830	131.747
	GEN	Intermittent	79.734	133.621	63.161	120.152	82.417	124.933	72.502	126.322	76.413	128.101
		Non Intermittent	214.438	239.429	246.586	246.586	255.002	255.099	248.596	248.596	248.066	248.149
	GEN Total		294.172	373.050	309.747	366.738	337.419	380.032	321.098	374.918	324.479	376.250
VT Total			**437.729**	**516.912**	**466.424**	**540.206**	**490.942**	**538.160**	**467.968**	**524.668**	**456.309**	**507.997**
WCMA	ACTIVE DR	REAL TIME DR	35.209	31.356	48.842	46.452	49.091	45.436	36.112	34.123	67.820	64.165
		REAL-TIME EG	24.074	23.638	0.000	0.000	18.875	18.321	6.516	5.982	0.000	0.000
		TOTAL ACTIVE	**59.283**	**54.994**	**48.842**	**46.452**	**67.966**	**63.757**	**42.628**	**40.105**	**67.820**	**64.165**
	PASSIVE DR	ON-PEAK	225.688	225.386	288.205	287.941	282.732	282.731	337.588	337.588	392.441	392.441
		SEASONAL PEAK	51.414	51.414	49.016	49.016	40.916	40.916	33.939	33.939	25.964	25.964
		TOTAL PASSIVE	**277.102**	**276.800**	**337.221**	**336.957**	**323.648**	**323.647**	**371.527**	**371.527**	**418.405**	**418.405**
	DR Total		336.385	331.794	386.063	383.409	391.614	387.404	414.155	411.632	486.225	482.570
	GEN	Intermittent	63.423	84.074	63.216	95.980	76.919	104.034	102.849	122.172	103.508	120.676
		Non Intermittent	3632.854	3630.478	3647.710	3623.334	3626.858	3628.181	3623.949	3611.419	3637.026	3637.026
	GEN Total		3696.277	3714.552	3710.926	3719.314	3703.777	3732.215	3726.798	3733.591	3740.534	3757.702
WCMA Total			**4032.662**	**4046.346**	**4096.989**	**4102.723**	**4095.391**	**4119.619**	**4140.953**	**4145.223**	**4226.759**	**4240.272**

			Capacity Commitment Period									
			2016-17 (7)		2017-18 (8)		2018-19 (9)		2019-20 (10)		2020-21 (11)	
Load Zone Name	**Resource Type**	**Resource Sub Type**	**Summer CSO**	**Winter CSO**	**Summer CSO**	**Winter CSO**	**Summer CSO**	**Winter CSO**	**Summer CSO**	**Winter CSO**	**Summer CSO**	**Winter CSO**
ISO NEW ENGLAND Total	ACTIVE DR	REAL TIME DR	371.551	366.010	380.437	386.633	448.484	456.565	323.064	329.431	419.928	414.292
		REAL-TIME EG	184.902	177.090	1.504	1.276	97.525	92.148	44.286	41.948	0.000	0.000
		TOTAL ACTIVE	**556.453**	**543.100**	**381.941**	**387.909**	**546.009**	**548.713**	**367.350**	**371.379**	**419.928**	**414.292**
	PASSIVE DR	ON-PEAK	1478.052	1476.883	1801.883	1807.790	1745.901	1745.900	1895.237	1895.237	2215.822	2190.088
		SEASONAL PEAK	406.850	406.850	506.847	506.847	404.295	404.295	471.546	471.546	575.197	593.202
		TOTAL PASSIVE	**1884.902**	**1883.733**	**2308.730**	**2314.637**	**2150.196**	**2150.195**	**2366.783**	**2366.783**	**2791.019**	**2783.290**
	DR Total		2441.355	2426.833	2690.671	2702.546	2696.205	2698.908	2734.133	2738.162	3210.947	3197.582
	GEN	Intermittent	735.174	977.211	823.162	1118.118	853.414	1112.851	893.189	1159.389	894.217	1149.464
		Non Intermittent	29152.793	29200.420	28833.605	28906.751	29783.831	30239.028	30462.546	30845.363	30494.804	30513.165
	GEN Total		29887.967	30177.631	29656.767	30024.869	30637.245	31351.879	31355.735	32004.752	31389.021	31662.629
ISO NEW ENGLAND Total			**32329.322**	**32604.464**	**32347.438**	**32727.415**	**33333.450**	**34050.787**	**34089.868**	**34742.914**	**34599.968**	**34860.211**
Import Total			1162.202	1137.202	1345.998	1301.898	1449.000	987.000	1449.800	1038.800	1235.400	1235.400
Grand Total			**33491.524**	**33741.666**	**33693.436**	**34029.313**	**34782.450**	**35037.787**	**35539.668**	**35781.714**	**35835.368**	**36095.611**

FOOTNOTES:

(1) Values are not capped by RTEG or Interface limits.

(2) Includes all Resources without distinction of qualification as a New Capacity Resource or Existing Capacity Resource.

(3) De-listed MW and Non-Price Retirement MWs have been removed.

(4) The Citizens Block Load Capacity Supply Obligation is treated as a generating resource in this table, whereas in the Section 1 summaries it is treated as an import.

(5) All Capacity Supply Obligation values are current as of March 18, 2017.

(6) The totals in this table will not necessarily match those in Appendix D because these values are current as of March 18, 2017, whereas the Appendix D values are snapshots taken at the time of the particular auction or bilateral period.

(7) Capacity Supply Obligation values include results for the Annual Reconfiguration Auction 3.

(8) Capacity Supply Obligation values include results for the Annual Reconfiguration Auction 3.

(9) Capacity Supply Obligation values include results for the Annual Reconfiguration Auction 1.

(10) Capacity Supply Obligation values include results for the 2019-2020 FCA.

(11) Capacity Supply Obligation values include results for the 2019-2020 FCA.

4.2 Summary of Renewable Technology Resource (RTR) Allotments in the Forward Capacity Market

Forward Capacity Auction	Resource Type	Summer Cleared Capacity (MW)	Allowance (MW)	Maximum Capacity (MW)	RTR Remaining (MW)
FCA #9	*Demand Resource*	0			
	Generator	16.251			
	Total	**16.251**	**200**	**200**	**183.749**
FCA #10	*Demand Resource*	0.293			
	Generator	55.643			
	Total	**55.936**	**400**	**383.749**	**327.813**
FCA #11	*Demand Resource*	19.413			
	Generator	11.087			
	Total	**30.5**	**600**	**527.813**	**497.313**
FCA #12	*Demand Resource*	TBD			
	Generator	TBD			
	Total	**TBD**	**600**	**513.564**	**TBD**

NOTES:

1) Determination of Renewable Technology Resource Qualified Capacity comes from Market Rule 1, Section III.13.1.1.2.10.

2) For more details on electing RTR during FCM Qualifications, see Market Rule 1, Section III.13.1.1.2.9 Renewable Technology Resource Election.

4.3 FCA 11 Qualified and Cleared Capacity [1]

Note that this list includes all Resources that qualified to participate in FCA 11. Terminations that may have occurred after the initial qualification would not be reflected here.

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
9100	CL&P Connecticut Portfolio	Demand				ON_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	22.819	10.349	10.349	10.349
9102	CLM Residential Energy Effic	Demand				SEASONAL_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	1.239	0.000	0.000	0.000
9103	CLM C&I Energy Efficiency	Demand				SEASONAL_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	3.639	3.813	3.639	3.639
9104	EI C&I Energy Efficiency	Demand				SEASONAL_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	1.325	2.027	1.325	1.325
9105	PSNH CORE EE Pgm Portfolio I	Demand				ON_PEAK	Passive	Northern New England		NH	NH		Existing	4.013	2.237	2.237	2.237
9108	Residential Energy Efficienc	Demand				ON_PEAK	Passive	Northern New England		VT	VT		Existing	0.008	0.000	0.008	0.000
9109	Commercial Energy Efficiency	Demand				ON_PEAK	Passive	Northern New England		VT	VT		Existing	0.085	0.089	0.085	0.085
9114	ngrid nh odr eeproject_1	Demand				ON_PEAK	Passive	Northern New England		NH	NH		Existing	0.659	0.664	0.659	0.659
9115	CL&P Dist Gen 2007	Demand				ON_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	0.293	0.293	0.293	0.293
9116	ngrid ri odr eeproject_1	Demand				ON_PEAK	Passive	Southeast New England		RI	RI		Existing	2.583	4.158	2.583	2.583
9118	Unitil EE Project -2007	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	0.000	0.006	0.000	0.000
9120	ngrid sema odr eeproject_1	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	2.562	3.305	2.562	2.562
9121	ngrid wcma odr eeproject_1	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	2.920	3.415	2.920	2.920
9122	ngrid nema odr eeproject_1	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		Existing	2.378	2.624	2.378	2.378
9123	NSTAR SEMA	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	2.074	2.310	2.074	2.074
9127	CL&P CT Portfolio - 2007	Demand				ON_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	1.388	0.000	0.000	0.000
9128	NHEC CORE EE Pgm Portfolio 1	Demand				ON_PEAK	Passive	Rest-of-Pool		NH	NH		Existing	0.085	0.000	0.000	0.000
9129	UMass Amherst - 4 MW Steam Turbine	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	1.620	1.620	1.620	1.620
9131	WMECO MA Portfolio 2006	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	0.764	0.000	0.000	0.000
10091	MWRA Deer Island	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	Boston	Existing	15.660	15.660	12.517	12.517
10106	Citizens Group A	Demand				REAL_TIME	Active	Northern New England		VT	VT	Northwest Vermont	Existing	5.076	5.492	5.076	5.076
10361	BOC Kittery Load	Demand				REAL_TIME	Active	Northern New England		ME	ME	Portland Maine	Existing	13.500	9.396	9.396	9.396
12581	CL&P - Conservation & Load Management (CL&M) - Energy Efficiency Project	Demand				SEASONAL_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	359.014	336.473	359.014	336.473
12581	CL&P - Conservation & Load Management (CL&M) - Energy Efficiency Project	Demand				SEASONAL_PEAK	Passive	Rest-of-Pool		CT	CT		New	100.972	181.255	100.972	141.518
12583	CL&P Distributed Generation FCM 2010	Demand				ON_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	34.232	34.232	34.232	34.232
12584	Conservation and Load Management Program	Demand				ON_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	9.818	3.030	3.030	3.030
12586	Efficiency Maine Residential Efficient Products	Demand				ON_PEAK	Passive	Northern New England		ME	ME		Existing	19.416	0.000	7.657	0.000
12590	Ameresco CT DSM	Demand				ON_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	6.029	6.034	6.029	6.029
12597	Cambridge Energy Alliance-1	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		Existing	0.653	0.653	0.653	0.653
12598	Cambridge Energy Alliance-2	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		Existing	4.736	4.736	4.736	4.736
12600	UI Conservation and Load Management Programs	Demand				SEASONAL_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	70.788	69.649	70.788	69.649
12600	UI Conservation and Load Management Programs	Demand				SEASONAL_PEAK	Passive	Rest-of-Pool		CT	CT		New	9.412	10.551	9.412	10.551
12657	Unitil CORE Energy Efficiency Programs-2	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	8.874	7.940	7.940	7.940
12657	Unitil CORE Energy Efficiency Programs-2	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		New	1.152	1.193	1.152	1.152
12670	ngrid_nema_fca1_eeodr	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		Existing	125.352	102.498	125.351	102.498
12670	ngrid_nema_fca1_eeodr	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		New	44.112	66.965	44.112	66.965
12671	ngrid_nh_fca1_eeodr	Demand				ON_PEAK	Passive	Northern New England		NH	NH		Existing	7.460	7.214	7.214	7.214
12671	ngrid_nh_fca1_eeodr	Demand				ON_PEAK	Passive	Northern New England		NH	NH		New	0.696	0.770	0.696	0.696
12672	ngrid_ri_fca1_eeodr	Demand				ON_PEAK	Passive	Southeast New England		RI	RI		Existing	194.020	172.912	194.020	172.912
12672	ngrid_ri_fca1_eeodr	Demand				ON_PEAK	Passive	Southeast New England		RI	RI		New	58.429	79.537	58.429	79.537
12673	ngrid_sema_fca1_eeodr	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	166.447	136.730	166.447	136.730
12673	ngrid_sema_fca1_eeodr	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		New	40.608	70.325	40.608	70.325
12674	ngrid_wcma_fca1_eeodr	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	231.857	200.810	231.857	200.810
12674	ngrid_wcma_fca1_eeodr	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		New	42.108	73.155	42.108	73.155
12684	NSTAR EE NEMA	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		Existing	430.123	387.598	401.577	387.598
12684	NSTAR EE NEMA	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		New	130.169	144.148	130.169	144.148
12685	NSTAR EE SEMA	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	89.298	80.314	80.617	80.314
12685	NSTAR EE SEMA	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		New	19.748	20.051	19.748	20.051
12693	PSNH CORE Energy Efficiency Programs	Demand				ON_PEAK	Passive	Northern New England		NH	NH		Existing	69.919	55.761	69.919	55.761
12693	PSNH CORE Energy Efficiency Programs	Demand				ON_PEAK	Passive	Northern New England		NH	NH		New	18.203	14.356	18.203	14.356
12694	Acushnet Company - Ball Plant II - Combined Heat and Power Project	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	2.111	2.111	2.111	2.111
12696	7.9 MW CHP Plant	Demand				ON_PEAK	Passive	Northern New England		NH	NH		Existing	10.800	10.800	10.800	10.800
12705	Cape Light Compact Energy Efficiency Portfolio	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	40.805	37.783	40.805	37.783
12705	Cape Light Compact Energy Efficiency Portfolio	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		New	16.837	25.137	8.000	11.022
12749	Bridgewater Correctional Complex Cogeneration	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	1.412	1.412	1.412	1.412
12753	MA SEMA state colleges	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	0.147	0.147	0.147	0.147
12754	Tewksbury State Hospital Cogenerator	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	0.734	0.734	0.734	0.734

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
12757	NHEC Energy Efficiency Programs	Demand				ON_PEAK	Passive	Northern New England		NH	NH		Existing	2.679	0.940	0.940	0.940
12757	NHEC Energy Efficiency Programs	Demand				ON_PEAK	Passive	Northern New England		NH	NH		New	0.444	0.563	0.444	0.444
12779	CPLN CT On-Peak	Demand				ON_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	1.004	1.004	1.004	1.004
12779	CPLN CT On-Peak	Demand				ON_PEAK	Passive	Rest-of-Pool		CT	CT		New	1.852	1.285	1.852	1.285
12786	CSG Aggregation of DG and 24 hr lighting EE - NEMA1	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		Existing	12.318	12.318	12.318	12.318
12790	CSG Aggregation of DG and 24 hr lighting EE -RI	Demand				ON_PEAK	Passive	Southeast New England		RI	RI		Existing	0.217	0.217	0.217	0.217
12791	CSG Aggregation of DG and 24 hr lighting EE - SEMA1	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	1.517	1.517	1.517	1.517
12799	CSG Aggregation of DG and 24 hr lighting EE - WCMA1	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	1.053	1.053	1.053	1.053
12799	CSG Aggregation of DG and 24 hr lighting EE - WCMA1	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		New	1.215	1.215	1.053	1.053
12801	UES CORE Energy Efficiency Programs	Demand				ON_PEAK	Passive	Northern New England		NH	NH		Existing	9.764	7.935	7.935	7.935
12801	UES CORE Energy Efficiency Programs	Demand				ON_PEAK	Passive	Northern New England		NH	NH		New	0.943	0.889	0.889	0.889
12802	University of Massachusetts Central Heating Plant-3	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	10.260	10.260	10.260	10.260
12806	WMECO - Conservation & Load Management (CL&M) - Energy Efficiency Project	Demand				SEASONAL_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	45.251	25.964	25.964	25.964
12822	Burlington Electric Department - On-Peak Efficiency	Demand				ON_PEAK	Passive	Northern New England		VT	VT		Existing	5.734	5.659	5.734	5.659
12822	Burlington Electric Department - On-Peak Efficiency	Demand				ON_PEAK	Passive	Northern New England		VT	VT		New	0.000	0.464	0.000	0.000
12832	CPLN MA NEMA OP	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		Existing	7.106	6.561	7.106	6.561
12835	CPLN MA SEMA OP	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	0.231	0.230	0.230	0.230
12835	CPLN MA SEMA OP	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		New	1.512	0.378	1.512	0.378
12838	CPLN MA WC OP	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	7.492	7.491	7.491	7.491
12841	CPLN ME OP	Demand				ON_PEAK	Passive	Northern New England		ME	ME		Existing	0.038	0.038	0.038	0.038
12841	CPLN ME OP	Demand				ON_PEAK	Passive	Northern New England		ME	ME		New	4.158	1.890	0.000	0.000
12843	CPLN RI OP	Demand				ON_PEAK	Passive	Southeast New England		RI	RI		Existing	0.280	0.280	0.280	0.280
12845	Vermont Efficiency Portfolio-1	Demand				ON_PEAK	Passive	Northern New England		VT	VT		Existing	75.212	63.469	75.212	63.469
12845	Vermont Efficiency Portfolio-1	Demand				ON_PEAK	Passive	Northern New England		VT	VT		New	16.712	40.751	16.712	28.455
14579	FGE Energy Efficiency Portfolio 2011	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	0.222	0.278	0.222	0.222
14580	UES Energy Efficiency Portfolio 2011	Demand				ON_PEAK	Passive	Northern New England		NH	NH		Existing	0.920	0.271	0.271	0.271
15586	Gardner Wind Turbine	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	0.359	0.318	0.318	0.318
16547	UI C&LM Programs	Demand				SEASONAL_PEAK	Passive	Rest-of-Pool		CT	CT		Existing	4.153	4.083	4.083	4.083
16651	Efficiency Maine Trust Efficient Products	Demand				ON_PEAK	Passive	Northern New England		ME	ME		Existing	31.022	0.000	27.920	0.000
16700	RI CoolSentry	Demand				REAL_TIME	Active	Southeast New England		RI	RI	Rhode Island	Existing	3.338	3.338	0.000	0.000
16713	Comverge CoolSentry 2	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Eastern CT	Existing	1.072	1.351	1.072	1.072
16713	Comverge CoolSentry 2	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Eastern CT	New	20.520	20.520	20.520	20.520
16718	Comverge CoolSentry 4	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Norwalk - Stamford	Existing	0.947	0.947	0.000	0.000
16790	WCMA Project E	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	0.400	0.400	0.400	0.400
17321	RTEG_76_Springfield MA (7516)	Demand				REAL_TIME_EG	Active	Rest-of-Pool		MA	WCMA	Springfield MA	Existing	3.866	3.866	0.000	0.000
35453	Efficiency Maine Trust	Demand				ON_PEAK	Passive	Northern New England		ME	ME		Existing	11.857	4.643	11.136	4.643
37112	Efficiency Maine Trust FCA6	Demand				ON_PEAK	Passive	Northern New England		ME	ME		Existing	1.890	1.890	1.890	1.890
37855	Hess DR Northwest VT 2015-16	Demand				REAL_TIME	Active	Northern New England		VT	VT	Northwest Vermont	New	1.200	1.200	1.200	1.200
37917	RTDR_50744_Boston (7507) - Grp C	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	Boston	Existing	18.710	18.710	7.910	7.910
37918	RTDR_50744_Central MA (7515) - Grp A	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Central MA	Existing	2.280	2.280	0.000	0.000
37919	RTDR_50744_Lower SEMA (7511) - Grp C	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	Lower SEMA	Existing	0.939	0.939	0.000	0.000
37920	RTDR_50744_North Shore (7508) - Grp C	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	North Shore	Existing	1.599	1.599	0.000	0.000
37922	RTDR_50744_Northern CT (7501) - Grp B	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Northern CT	Existing	10.331	10.331	10.331	10.331
37924	RTDR_50744_SEMA (7512) - Grp C	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	SEMA	Existing	5.684	5.684	0.000	0.000
37925	RTDR_50744_Springfield MA (7516) - Grp A	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Springfield MA	Existing	1.380	1.380	1.380	1.380
37927	RTDR_50744_Western CT (7503) - Grp B	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Western CT	Existing	5.297	5.297	0.000	0.000
37928	RTDR_50786_Boston (7507)	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	Boston	Existing	1.022	1.022	1.022	1.022
37928	RTDR_50786_Boston (7507)	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	Boston	New	1.210	1.210	1.210	1.210
37929	RTDR_50786_Central MA (7515)	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Central MA	Existing	0.924	0.924	0.924	0.924
37929	RTDR_50786_Central MA (7515)	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Central MA	New	0.512	0.512	0.512	0.512
37930	RTDR_50786_Eastern CT (7500)	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Eastern CT	Existing	0.012	0.012	0.012	0.012
37930	RTDR_50786_Eastern CT (7500)	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Eastern CT	New	0.249	0.249	0.249	0.249
37931	RTDR_50786_Lower SEMA (7511)	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	Lower SEMA	New	1.392	1.392	1.392	1.392
37933	RTDR_50786_New Hampshire (7509)	Demand				REAL_TIME	Active	Northern New England		NH	NH	New Hampshire	New	0.219	0.219	0.219	0.219
37934	RTDR_50786_North Shore (7508)	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	North Shore	New	1.488	1.488	1.488	1.488
37935	RTDR_50786_Northern CT (7501)	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Northern CT	Existing	2.789	2.789	2.789	2.789
37936	RTDR_50786_Norwalk - Stamford (7502)	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Norwalk - Stamford	Existing	0.043	0.043	0.043	0.043
37936	RTDR_50786_Norwalk - Stamford (7502)	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Norwalk - Stamford	New	0.108	0.108	0.108	0.108
37937	RTDR_50786_Portland Maine (7506)	Demand				REAL_TIME	Active	Northern New England		ME	ME	Portland Maine	New	0.145	0.145	0.145	0.145
37938	RTDR_50786_Rhode Island (7518)	Demand				REAL_TIME	Active	Southeast New England		RI	RI	Rhode Island	Existing	0.000	0.030	0.000	0.000
37938	RTDR_50786_Rhode Island (7518)	Demand				REAL_TIME	Active	Southeast New England		RI	RI	Rhode Island	New	3.000	3.000	3.000	3.000
37939	RTDR_50786_SEMA (7512)	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	SEMA	New	0.759	0.759	0.759	0.759
37940	RTDR_50786_Seacoast (7510)	Demand				REAL_TIME	Active	Northern New England		NH	NH	Seacoast	New	0.208	0.208	0.208	0.208
37941	RTDR_50786_Springfield MA (7516)	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Springfield MA	Existing	0.692	0.692	0.692	0.692

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
37941	RTDR_50786_Springfield MA (7516)	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Springfield MA	New	0.781	0.781	0.781	0.781
37942	RTDR_50786_Vermont (7514)	Demand				REAL_TIME	Active	Northern New England		VT	VT	Vermont	New	0.491	0.491	0.491	0.491
37943	RTDR_50786_Western CT (7503)	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Western CT	Existing	0.309	0.309	0.309	0.309
37943	RTDR_50786_Western CT (7503)	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Western CT	New	4.250	4.250	4.250	4.250
37944	RTDR_50786_Western MA (7517)	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Western MA	Existing	0.117	0.117	0.117	0.117
37944	RTDR_50786_Western MA (7517)	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Western MA	New	2.436	2.436	2.436	2.436
37990	RTEG_50017_Bangor Hydro (7504)	Demand				REAL_TIME_EG	Active	Northern New England		ME	ME	Bangor Hydro	Existing	0.581	0.433	0.000	0.000
37991	RTEG_50017_Boston (7507)	Demand				REAL_TIME_EG	Active	Southeast New England		MA	NEMA	Boston	Existing	5.479	5.251	0.000	0.000
37993	RTEG_50017_Eastern CT (7500)	Demand				REAL_TIME_EG	Active	Rest-of-Pool		CT	CT	Eastern CT	Existing	4.468	4.468	0.000	0.000
37994	RTEG_50017_Lower SEMA (7511)	Demand				REAL_TIME_EG	Active	Southeast New England		MA	SEMA	Lower SEMA	Existing	4.293	4.293	0.000	0.000
37995	RTEG_50017_Maine (7505)	Demand				REAL_TIME_EG	Active	Northern New England		ME	ME	Maine	Existing	4.912	3.402	0.000	0.000
37996	RTEG_50017_New Hampshire (7509)	Demand				REAL_TIME_EG	Active	Northern New England		NH	NH	New Hampshire	Existing	11.616	11.253	0.000	0.000
37997	RTEG_50017_North Shore (7508)	Demand				REAL_TIME_EG	Active	Southeast New England		MA	NEMA	North Shore	Existing	0.711	0.711	0.000	0.000
37998	RTEG_50017_Northern CT (7501)	Demand				REAL_TIME_EG	Active	Rest-of-Pool		CT	CT	Northern CT	Existing	2.988	2.988	0.000	0.000
37999	RTEG_50017_Northwest Vermont (7513)	Demand				REAL_TIME_EG	Active	Northern New England		VT	VT	Northwest Vermont	Existing	1.768	2.200	0.000	0.000
38001	RTEG_50017_Portland Maine (7506)	Demand				REAL_TIME_EG	Active	Northern New England		ME	ME	Portland Maine	Existing	0.909	0.715	0.000	0.000
38004	RTEG_50017_Seacoast (7510)	Demand				REAL_TIME_EG	Active	Northern New England		NH	NH	Seacoast	Existing	0.684	0.684	0.000	0.000
38005	RTEG_50017_Springfield MA (7516)	Demand				REAL_TIME_EG	Active	Rest-of-Pool		MA	WCMA	Springfield MA	Existing	2.650	2.116	0.000	0.000
38006	RTEG_50017_Vermont (7514)	Demand				REAL_TIME_EG	Active	Northern New England		VT	VT	Vermont	Existing	2.432	2.157	0.000	0.000
38008	RTEG_50017_Western MA (7517)	Demand				REAL_TIME_EG	Active	Rest-of-Pool		MA	WCMA	Western MA	Existing	3.162	3.142	0.000	0.000
38057	Efficiency Maine Trust FCA6 B	Demand				ON_PEAK	Passive	Northern New England		ME	ME		Existing	68.720	110.790	68.720	110.790
38057	Efficiency Maine Trust FCA6 B	Demand				ON_PEAK	Passive	Northern New England		ME	ME		New	40.025	17.691	17.691	17.691
38120	RTDR_50017_Bangor Hydro (7504) - 3	Demand				REAL_TIME	Active	Northern New England		ME	ME	Bangor Hydro	Existing	2.430	2.652	2.430	2.430
38122	RTDR_50017_Central MA (7515) - 3	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Central MA	Existing	8.457	6.873	8.457	6.873
38122	RTDR_50017_Central MA (7515) - 3	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Central MA	New	3.240	3.240	0.000	0.000
38123	RTDR_50017_Eastern CT (7500) - 3	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Eastern CT	Existing	5.806	6.084	5.806	5.806
38124	RTDR_50017_Lower SEMA (7511) - 3	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	Lower SEMA	Existing	2.094	1.871	0.000	0.000
38124	RTDR_50017_Lower SEMA (7511) - 3	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	Lower SEMA	New	2.160	2.160	0.000	0.000
38125	RTDR_50017_Maine (7505) - 3	Demand				REAL_TIME	Active	Northern New England		ME	ME	Maine	Existing	58.299	78.975	25.899	25.899
38126	RTDR_50017_New Hampshire (7509) - 3	Demand				REAL_TIME	Active	Northern New England		NH	NH	New Hampshire	Existing	6.390	5.671	6.390	5.671
38126	RTDR_50017_New Hampshire (7509) - 3	Demand				REAL_TIME	Active	Northern New England		NH	NH	New Hampshire	New	3.240	3.240	0.000	0.000
38127	RTDR_50017_North Shore (7508) - 3	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	North Shore	New	2.160	2.160	0.000	0.000
38128	RTDR_50017_Northern CT (7501) - 3	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Northern CT	Existing	9.953	9.612	9.953	9.612
38129	RTDR_50017_Northwest Vermont (7513) - 3	Demand				REAL_TIME	Active	Northern New England		VT	VT	Northwest Vermont	Existing	21.382	28.510	21.382	24.622
38129	RTDR_50017_Northwest Vermont (7513) - 3	Demand				REAL_TIME	Active	Northern New England		VT	VT	Northwest Vermont	New	6.480	0.000	3.240	0.000
38130	RTDR_50017_Norwalk - Stamford (7502) - 3	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Norwalk - Stamford	Existing	2.131	2.131	2.131	2.131
38131	RTDR_50017_Portland Maine (7506) - 3	Demand				REAL_TIME	Active	Northern New England		ME	ME	Portland Maine	Existing	2.110	3.212	2.110	2.110
38132	RTDR_50017_Rhode Island (7518) - 3	Demand				REAL_TIME	Active	Southeast New England		RI	RI	Rhode Island	Existing	9.818	6.287	0.000	0.000
38132	RTDR_50017_Rhode Island (7518) - 3	Demand				REAL_TIME	Active	Southeast New England		RI	RI	Rhode Island	New	3.240	3.240	0.000	0.000
38133	RTDR_50017_SEMA (7512) - 3	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	SEMA	Existing	4.290	2.638	0.000	0.000
38133	RTDR_50017_SEMA (7512) - 3	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	SEMA	New	3.240	3.240	0.000	0.000
38134	RTDR_50017_Seacoast (7510) - 3	Demand				REAL_TIME	Active	Northern New England		NH	NH	Seacoast	Existing	1.392	1.391	1.391	1.391
38134	RTDR_50017_Seacoast (7510) - 3	Demand				REAL_TIME	Active	Northern New England		NH	NH	Seacoast	New	2.160	2.160	0.000	0.000
38135	RTDR_50017_Springfield MA (7516) - 3	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Springfield MA	Existing	7.423	6.256	7.423	6.256
38135	RTDR_50017_Springfield MA (7516) - 3	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Springfield MA	New	3.240	3.240	0.000	0.000
38136	RTDR_50017_Vermont (7514) - 3	Demand				REAL_TIME	Active	Northern New England		VT	VT	Vermont	Existing	2.690	3.992	2.690	2.690
38137	RTDR_50017_Western CT (7503) - 3	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Western CT	Existing	18.576	17.655	18.576	17.655
38138	RTDR_50017_Western MA (7517) - 3	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Western MA	Existing	14.008	13.104	14.008	13.104
38138	RTDR_50017_Western MA (7517) - 3	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Western MA	New	3.240	3.240	0.000	0.000
38139	RTEG_50017_Central MA (7515) - 3	Demand				REAL_TIME_EG	Active	Rest-of-Pool		MA	WCMA	Central MA	Existing	14.016	14.016	0.000	0.000
38140	RTEG_50017_Norwalk - Stamford (7502) - 3	Demand				REAL_TIME_EG	Active	Rest-of-Pool		CT	CT	Norwalk - Stamford	Existing	7.456	7.456	0.000	0.000
38141	RTEG_50017_Rhode Island (7518) - 3	Demand				REAL_TIME_EG	Active	Southeast New England		RI	RI	Rhode Island	Existing	14.640	10.249	0.000	0.000
38142	RTEG_50017_SEMA (7512) - 3	Demand				REAL_TIME_EG	Active	Southeast New England		MA	SEMA	SEMA	Existing	7.889	7.889	0.000	0.000
38143	RTEG_50017_Western CT (7503) - 3	Demand				REAL_TIME_EG	Active	Rest-of-Pool		CT	CT	Western CT	Existing	38.029	37.515	0.000	0.000
38210	RTDR_50689_North_Shore_38210	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	North Shore	Existing	11.326	11.326	11.326	11.326
38216	WCMA CHP	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	10.058	10.058	10.058	10.058
38217	RI CHP	Demand				ON_PEAK	Passive	Southeast New England		RI	RI		Existing	10.399	10.399	10.399	10.399
38217	RI CHP	Demand				ON_PEAK	Passive	Southeast New England		RI	RI		New	0.969	0.945	0.945	0.945
38219	WMECO EE WCMA	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	64.805	64.127	64.805	64.127
38219	WMECO EE WCMA	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		New	5.415	14.221	5.415	6.093
38268	NEMA 1 EG	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	Boston	Existing	1.620	1.620	1.620	1.620
38270	NEMA 2 EG	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	North Shore	Existing	1.620	1.620	1.620	1.620
38272	SEMA 1 EG	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	SEMA	Existing	0.540	0.540	0.540	0.540

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
38274	WCMA 1 EG	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Central MA	Existing	0.540	0.540	0.540	0.540
38276	RI 1 EG	Demand				REAL_TIME	Active	Southeast New England		RI	RI	Rhode Island	Existing	1.080	1.080	1.080	1.080
38311	NEMA CHP	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		Existing	2.238	2.238	2.238	2.238
38322	DRCR_Central MA_201403	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Central MA	Existing	10.000	10.000	10.000	10.000
38324	DRCR_Lower SEMA_201403	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	Lower SEMA	Existing	3.038	3.038	3.038	3.038
38331	DRCR_Rhode Island_201403	Demand				REAL_TIME	Active	Southeast New England		RI	RI	Rhode Island	Existing	18.900	18.900	18.900	18.900
38334	DRCR_SEMA_201403	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	SEMA	Existing	20.034	20.034	20.034	20.034
38360	DRCR_Boston_201403	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	Boston	Existing	10.000	10.000	10.000	10.000
38387	CSG Aggregation of DG and 24 hr lighting EE - NEMA1_2	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		Existing	2.743	2.743	2.743	2.743
38387	CSG Aggregation of DG and 24 hr lighting EE - NEMA1_2	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		New	16.926	16.926	9.180	9.180
38388	CSG Aggregation of DG and 24 hr lighting EE - SEMA1_2	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	2.333	2.333	2.333	2.333
38388	CSG Aggregation of DG and 24 hr lighting EE - SEMA1_2	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		New	0.528	0.528	0.528	0.528
38389	CSG Aggregation of DG and 24 hr lighting EE - WCMA1_2	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		Existing	2.333	2.333	2.333	2.333
38389	CSG Aggregation of DG and 24 hr lighting EE - WCMA1_2	Demand				ON_PEAK	Passive	Rest-of-Pool		MA	WCMA		New	4.593	4.593	0.702	0.702
38390	Efficiency Maine Trust FCA9	Demand				ON_PEAK	Passive	Northern New England		ME	ME		Existing	4.049	4.049	4.049	4.049
38393	RTDR_51325_Maine (7505)	Demand				REAL_TIME	Active	Northern New England		ME	ME	Maine	Existing	59.400	59.400	59.400	59.400
38396	NEMA 1 - New T4	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	Boston	Existing	1.000	1.000	1.000	1.000
38396	NEMA 1 - New T4	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	Boston	New	2.160	2.160	0.000	0.000
38398	NEMA 2 - New T4	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	North Shore	Existing	1.000	1.000	1.000	1.000
38398	NEMA 2 - New T4	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	North Shore	New	3.240	3.240	0.000	0.000
38400	RI 1 - New T4	Demand				REAL_TIME	Active	Southeast New England		RI	RI	Rhode Island	Existing	2.592	2.592	2.592	2.592
38401	RI 1 - Retrofit	Demand				REAL_TIME	Active	Southeast New England		RI	RI	Rhode Island	Existing	1.296	1.296	1.296	1.296
38402	SEMA 1 - New T4	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	SEMA	Existing	4.644	4.644	4.644	4.644
38403	SEMA 1 - Retrofit	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	SEMA	Existing	2.268	2.268	2.268	2.268
38404	WCMA 1 - New T4	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Central MA	Existing	1.000	1.000	1.000	1.000
38447	Boston_PeakDR	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		Existing	2.700	2.700	2.700	2.700
38468	Norfolk-Walpole Co-Gen	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	1.296	1.296	1.296	1.296
38483	Ngrid_SEMA_CHP	Demand				ON_PEAK	Passive	Southeast New England		MA	SEMA		Existing	1.692	1.692	1.692	1.692
38487	CT_RTDR	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Western CT	Existing	2.160	2.160	0.250	0.250
38502	WestMA_RTEG	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Western MA	Existing	1.296	1.296	0.250	0.250
38512	SEMA 1 - New	Demand				REAL_TIME	Active	Southeast New England		MA	SEMA	SEMA	New	10.800	10.800	0.000	0.000
38513	RI 1 - New	Demand				REAL_TIME	Active	Southeast New England		RI	RI	Rhode Island	New	5.400	5.400	0.000	0.000
38514	CT 1 - New	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Northern CT	New	5.400	5.400	0.000	0.000
38517	CT 1A - New	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Eastern CT	New	2.700	2.700	0.000	0.000
38518	CT 1B - New	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Western CT	New	2.700	2.700	0.000	0.000
38521	CT 2 - Auto	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Northern CT	New	2.700	2.700	2.700	2.700
38522	CT 2A - Auto	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Eastern CT	New	1.350	1.350	1.350	1.350
38523	CT 2B - Auto	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Western CT	New	1.350	1.350	1.350	1.350
38524	ME 1 - New	Demand				REAL_TIME	Active	Northern New England		ME	ME	Maine	New	5.400	5.400	0.000	0.000
38684	Bloom Energy SOFC	Demand				ON_PEAK	Passive	Southeast New England		MA	NEMA		New	9.180	9.180	9.180	9.180
38689	Bloom Energy CT SOFC	Demand				ON_PEAK	Passive	Rest-of-Pool		CT	CT		New	9.180	9.180	9.180	9.180
38693	NEMA_ActiveDR	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	Boston	New	1.620	1.620	1.620	1.620
38694	RTDR_Maine	Demand				REAL_TIME	Active	Northern New England		ME	ME	Maine	New	2.798	2.798	2.798	2.798
38754	VT Small DER	Demand				REAL_TIME	Active	Northern New England		VT	VT	Vermont	New	1.080	1.080	0.000	0.000
38756	WMCA Small Gen	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Springfield MA	New	1.944	1.944	0.000	0.000
38758	CT Small Gen	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Western CT	New	1.944	1.944	1.944	1.944
38759	ME Small Gen	Demand				REAL_TIME	Active	Northern New England		ME	ME	Portland Maine	New	1.944	1.944	0.000	0.000
38761	NEMA Small Gen	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	North Shore	New	1.944	1.944	1.944	1.944
38773	Backyard Farms Unit 1A	Demand				ON_PEAK	Passive	Northern New England		ME	ME		New	3.564	3.564	0.000	0.000
38787	CT On-Peak Solar	Demand				ON_PEAK	Passive	Rest-of-Pool		CT	CT		New	5.400	0.000	5.400	0.000
38789	NEMA_ActiveLM	Demand				REAL_TIME	Active	Southeast New England		MA	NEMA	Boston	New	1.080	1.080	1.080	1.080
38800	DRCR_Western MA_2016	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Western MA	New	39.442	27.076	14.000	14.000
38801	DRCR_Western CT_2016	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Western CT	New	21.784	15.595	0.000	0.000
38802	DRCR_Vermont_2016	Demand				REAL_TIME	Active	Northern New England		VT	VT	Vermont	New	7.668	9.593	0.000	0.000
38803	DRCR_Springfield MA_2016	Demand				REAL_TIME	Active	Rest-of-Pool		MA	WCMA	Springfield MA	New	18.965	13.835	5.300	5.300
38810	DRCR_Northern CT_2016	Demand				REAL_TIME	Active	Rest-of-Pool		CT	CT	Northern CT	New	9.990	5.519	0.000	0.000
38813	DRCR_New Hampshire_2016	Demand				REAL_TIME	Active	Northern New England		NH	NH	New Hampshire	New	24.505	39.409	9.000	9.000
253	TURNKEY LANDFILL	Generator	Yes	IC	Landfill Gas			Northern New England		NH	NH		Existing	0.650	0.780	0.650	0.780
321	MANCHESTER 10 10A CC	Generator	No	CC	Natural Gas			Southeast New England		RI	RI		Existing	157	170	157.000	157.000
322	MANCHESTER 11 11A CC	Generator	No	CC	Natural Gas			Southeast New England		RI	RI		Existing	157.000	170.000	157.000	157.000
323	MANCHESTER 9 9A CC	Generator	No	CC	Natural Gas			Southeast New England		RI	RI		Existing	154.000	170.000	154.000	154.000
324	CDECCA	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		Existing	55.254	61.334	55.254	55.254
326	ALTRESCO	Generator	No	CC	Natural Gas			Rest-of-Pool		MA	WCMA		Existing	150.972	178.879	150.972	150.972
327	AMOSKEAG	Generator	No	HDP	Water			Northern New England		NH	NH		Existing	16.781	17.500	16.781	16.781
328	GULF ISLAND COMPOSITE Incremental	Generator	No	HW	Water			Northern New England		ME	ME		Existing	33.440	33.440	33.440	33.440
329	ASCUTNEY GT	Generator	No	GT	Distillate Fuel Oil			Northern New England		VT	VT		Existing	8.503	12.581	8.503	8.503

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
330	AYERS ISLAND	Generator	No	HDP	Water			Northern New England		NH	NH		Existing	8.474	9.080	8.474	8.474
331	AZISCOHOS HYDRO	Generator	No	HDP	Water			Northern New England		ME	ME		Existing	6.8	6.8	6.800	6.800
335	BELLOWS FALLS	Generator	No	HDP	Water			Northern New England		NH	NH		Existing	48.540	48.540	48.540	48.540
336	BERLIN 1 GT	Generator	No	GT	Kerosene			Northern New England		VT	VT		Existing	34.830	45.777	34.830	34.830
337	BETHLEHEM	Generator	Yes	ST	Wood/Wood Waste Solids			Northern New England		NH	NH		Existing	15.249	15.348	15.249	15.348
340	BRIDGEPORT HARBOR 3	Generator	No	ST	Coal			Rest-of-Pool		CT	CT		Existing	383.426	384.984	383.426	383.426
341	BRIDGEPORT HARBOR 4	Generator	No	GT	Jet Fuel			Rest-of-Pool		CT	CT		Existing	17.024	21.924	17.024	17.024
346	BOLTON FALLS	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.997	3.879	0.997	3.879
348	BOOT MILLS	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	7.529	12.262	7.529	12.262
349	WHEELABRATOR BRIDGEPORT, L.P.	Generator	Yes	ST	Municipal Solid Waste			Rest-of-Pool		CT	CT		Existing	58.969	59.357	58.969	59.357
355	BRANFORD 10	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	15.840	20.950	15.840	15.840
355	BRANFORD 10	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		New	15.840	20.950	0.000	0.000
356	BRISTOL REFUSE	Generator	Yes	ST	Municipal Solid Waste			Rest-of-Pool		CT	CT		Existing	12.561	12.729	12.561	12.729
357	BRIDGEWATER	Generator	Yes	ST	Wood/Wood Waste Solids			Northern New England		NH	NH		Existing	14.475	14.565	14.475	14.565
358	BRUNSWICK	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	9.073	12.821	9.073	12.821
359	J. COCKWELL 1	Generator	No	PS	Water			Rest-of-Pool		MA	WCMA		Existing	284.100	292.275	184.100	184.100
359	J. COCKWELL 1	Generator	No	PS	Water			Rest-of-Pool		MA	WCMA		New	47.400	39.225	0.000	0.000
360	J. COCKWELL 2	Generator	No	PS	Water			Rest-of-Pool		MA	WCMA		Existing	286.880	292.113	286.880	286.880
360	J. COCKWELL 2	Generator	No	PS	Water			Rest-of-Pool		MA	WCMA		New	44.620	38.737	0.000	0.000
362	BULLS BRIDGE	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	2.974	5.427	2.974	5.427
363	BURLINGTON GT	Generator	No	GT	Distillate Fuel Oil			Northern New England		VT	VT		Existing	19.104	23.354	19.104	19.187
365	CANAL 1	Generator	No	ST	Residual Fuel Oil			Southeast New England		MA	SEMA		Existing	554.640	555.815	554.640	554.640
366	CANAL 2	Generator	No	ST	Residual Fuel Oil			Southeast New England		MA	SEMA		Existing	545.125	547.000	545.125	545.125
367	CAPE GT 4	Generator	No	GT	Distillate Fuel Oil			Northern New England		ME	ME		Existing	13.750	20.011	13.750	13.750
368	CAPE GT 5	Generator	No	GT	Distillate Fuel Oil			Northern New England		ME	ME		Existing	15.822	20.272	15.822	15.822
369	CATARACT EAST	Generator	No	HDP	Water			Northern New England		ME	ME		Existing	7.775	8.000	7.775	7.775
370	COS COB 10	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	18.932	23.000	18.932	18.932
371	COS COB 11	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	18.724	23.000	18.724	18.724
372	COS COB 12	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	18.660	23.000	18.660	18.660
375	CLEARY 9 9A CC	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		Existing	104.931	109.931	104.931	104.931
376	CLEARY 8	Generator	No	ST	Residual Fuel Oil			Southeast New England		MA	SEMA		Existing	24.825	22.253	22.253	22.253
379	COBBLE MOUNTAIN	Generator	No	HW	Water			Rest-of-Pool		MA	WCMA		Existing	31.126	32.480	31.126	31.126
380	COMERFORD	Generator	No	HW	Water			Northern New England		NH	NH		Existing	166.135	167.116	166.135	166.135
382	MERRIMACK CT1	Generator	No	GT	Kerosene			Northern New England		NH	NH		Existing	16.826	21.676	16.826	16.826
383	MERRIMACK CT2	Generator	No	GT	Kerosene			Northern New England		NH	NH		Existing	16.804	21.304	16.804	16.804
388	DARTMOUTH POWER	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		Existing	62.149	67.656	62.149	62.149
389	DERBY DAM	Generator	No	HDP	Water			Rest-of-Pool		CT	CT		Existing	7.050	7.050	7.050	7.050
392	DEXTER	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		Existing	45.000	46.525	45.000	45.000
393	DEERFIELD 5	Generator	No	HDP	Water			Rest-of-Pool		MA	WCMA		Existing	13.703	13.990	13.703	13.703
395	DOREEN	Generator	No	GT	Kerosene			Rest-of-Pool		MA	WCMA		Existing	15.820	20.670	15.820	15.820
396	DEVON 10	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	14.407	19.186	14.407	14.407
396	DEVON 10	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		New	14.407	19.186	0.000	0.000
397	DEVON 11	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	29.299	38.819	29.299	29.299
398	DEVON 12	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	29.227	38.437	29.227	29.227
399	DEVON 13	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	29.967	38.967	29.967	29.967
400	DEVON 14	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	29.704	40.274	29.704	29.704
401	EASTMAN FALLS	Generator	No	HDP	Water			Northern New England		NH	NH		Existing	5.582	6.470	5.582	5.582
405	ELLSWORTH HYDRO	Generator	No	HW	Water			Northern New England		ME	ME		Existing	9.044	9.050	9.044	9.044
407	EASTPORT DIESELS 1-3	Generator	No	IC	Distillate Fuel Oil			Northern New England		ME	ME		Existing	2.000	2.100	2.000	2.000
410	ESSEX 19 HYDRO	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	3.051	5.284	3.051	5.284
412	FALLS VILLAGE	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	2.467	5.265	2.467	5.265
413	FIFE BROOK	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	3.225	5.635	3.225	5.635
417	FRAMINGHAM JET 1	Generator	No	GT	Distillate Fuel Oil			Southeast New England		MA	NEMA		Existing	10.145	14.175	10.145	10.145
418	FRAMINGHAM JET 2	Generator	No	GT	Distillate Fuel Oil			Southeast New England		MA	NEMA		Existing	10.049	15.686	10.049	10.049
419	FRAMINGHAM JET 3	Generator	No	GT	Distillate Fuel Oil			Southeast New England		MA	NEMA		Existing	11.250	15.250	11.250	11.250
420	FRANKLIN DRIVE 10	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	15.417	20.527	15.417	15.417
420	FRANKLIN DRIVE 10	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		New	15.417	20.527	0.000	0.000
421	FRONT STREET DIESELS 1-3	Generator	No	IC	Distillate Fuel Oil			Rest-of-Pool		MA	WCMA		Existing	7.433	7.700	7.433	7.433
424	GREAT LAKES - MILLINOCKET	Generator	No	HW	Water			Northern New England		ME	ME		Existing	74.958	71.822	71.822	71.822
426	GORGE 1 DIESEL	Generator	No	GT	Distillate Fuel Oil			Northern New England		VT	VT		Existing	7.090	11.000	7.090	7.090
427	GORHAM	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	1.177	1.599	1.177	1.599
432	HARRIS 1	Generator	No	HW	Water			Northern New England		ME	ME		Existing	16.790	16.776	16.776	16.776
433	HARRIS 2	Generator	No	HW	Water			Northern New England		ME	ME		Existing	34.865	34.500	34.500	34.500
434	HARRIS 3	Generator	No	HW	Water			Northern New England		ME	ME		Existing	34.000	33.905	33.905	33.905
435	HARRIMAN	Generator	No	HW	Water			Rest-of-Pool		MA	WCMA		Existing	40.943	38.663	38.663	38.663
436	HEMPHILL 1	Generator	Yes	ST	Wood/Wood Waste Solids			Northern New England		NH	NH		Existing	17.500	17.500	17.500	17.500

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
440	HIRAM	Generator	No	HDP	Water			Northern New England		ME	ME		Existing	11.189	11.600	11.189	11.189
445	COVANTA WEST ENFIELD	Generator	No	ST	Wood/Wood Waste Solids			Northern New England		ME	ME		Existing	20.461	21.446	0.000	0.000
446	COVANTA JONESBORO	Generator	No	ST	Wood/Wood Waste Solids			Northern New England		ME	ME		Existing	20.226	20.226	0.000	0.000
448	IPSWICH DIESELS	Generator	No	IC	Distillate Fuel Oil			Southeast New England		MA	NEMA		Existing	10.240	9.495	9.495	9.495
449	JACKMAN	Generator	No	HW	Water			Northern New England		NH	NH		Existing	3.583	3.541	3.541	3.541
452	KENDALL JET 1	Generator	No	GT	Distillate Fuel Oil			Southeast New England		MA	NEMA		Existing	18.000	23.000	18.000	18.000
457	LAWRENCE HYDRO	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	6.159	9.207	6.159	9.207
460	LOCKWOOD	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	3.797	4.392	3.797	4.392
462	LISBON RESOURCE RECOVERY	Generator	Yes	ST	Municipal Solid Waste			Rest-of-Pool		CT	CT		Existing	13.500	13.475	13.500	13.475
463	AEI LIVERMORE	Generator	No	ST	Wood/Wood Waste Solids			Northern New England		ME	ME		Existing	34.695	34.430	34.430	34.430
464	LOST NATION	Generator	No	GT	Distillate Fuel Oil			Northern New England		NH	NH		Existing	13.979	17.992	13.979	13.979
465	DEERFIELD 2 LWR DRFIELD	Generator	No	HDP	Water			Rest-of-Pool		MA	WCMA		Existing	19.275	19.500	19.275	19.275
467	MARBLEHEAD DIESELS	Generator	No	IC	Distillate Fuel Oil			Southeast New England		MA	NEMA		Existing	5.000	5.000	5.000	5.000
468	MARSHFIELD 6 HYDRO	Generator	No	HW	Water			Northern New England		VT	VT		Existing	4.412	4.380	4.380	4.380
472	M STREET JET	Generator	No	GT	Kerosene			Southeast New England		MA	NEMA		Existing	47.000	67.200	47.000	47.000
473	MCINDOES	Generator	No	HDP	Water			Northern New England		NH	NH		Existing	10.066	10.571	10.066	10.066
474	J C MCNEIL	Generator	No	ST	Wood/Wood Waste Solids			Northern New England		VT	VT		Existing	52.000	54.000	52.000	52.000
478	MIDDLETOWN 10	Generator	No	GT	Jet Fuel			Rest-of-Pool		CT	CT		Existing	15.515	20.015	15.515	15.515
478	MIDDLETOWN 10	Generator	No	GT	Jet Fuel			Rest-of-Pool		CT	CT		New	17.123	22.023	0.000	0.000
480	MIDDLETOWN 2	Generator	No	ST	Residual Fuel Oil			Rest-of-Pool		CT	CT		Existing	117.000	120.000	117.000	117.000
481	MIDDLETOWN 3	Generator	No	ST	Residual Fuel Oil			Rest-of-Pool		CT	CT		Existing	233.679	244.398	233.679	233.679
482	MIDDLETOWN 4	Generator	No	ST	Residual Fuel Oil			Rest-of-Pool		CT	CT		Existing	399.923	402.000	399.923	399.923
484	MILLSTONE POINT 2	Generator	No	ST	Nuclear			Rest-of-Pool		CT	CT		Existing	872.258	875.912	872.258	872.258
485	MILLSTONE POINT 3	Generator	No	ST	Nuclear			Rest-of-Pool		CT	CT		Existing	1225.000	1235.001	1225.000	1225.000
486	MILFORD POWER	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		Existing	149.000	170.730	0.000	0.000
486	MILFORD POWER	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		New	202.000	216.730	202.000	202.000
487	MILLER HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	8.124	11.486	8.124	11.486
489	MERRIMACK 1	Generator	No	ST	Coal			Northern New England		NH	NH		Existing	108.000	108.050	108.000	108.000
490	MERRIMACK 2	Generator	No	ST	Coal			Northern New England		NH	NH		Existing	330.000	330.513	330.000	330.000
492	MONTVILLE 10 and 11	Generator	No	IC	Kerosene			Rest-of-Pool		CT	CT		Existing	5.296	5.354	5.296	5.296
493	MONTVILLE 5	Generator	No	ST	Residual Fuel Oil			Rest-of-Pool		CT	CT		Existing	81.000	81.590	81.000	81.000
494	MONTVILLE 6	Generator	No	ST	Residual Fuel Oil			Rest-of-Pool		CT	CT		Existing	405.050	408.852	405.050	405.050
495	MONTY	Generator	No	HDP	Water			Northern New England		ME	ME		Existing	28.000	28.000	28.000	28.000
496	MOORE	Generator	No	HW	Water			Northern New England		NH	NH		Existing	189.032	190.913	189.032	189.032
496	MOORE	Generator	No	HW	Water			Northern New England		NH	NH		New	4.600	4.600	0.000	0.000
497	MASS POWER	Generator	No	CC	Natural Gas			Rest-of-Pool		MA	WCMA		Existing	245.259	276.000	245.259	245.259
502	MYSTIC 7	Generator	No	ST	Natural Gas			Southeast New England		MA	NEMA		Existing	570.800	559.775	570.800	559.775
503	MYSTIC JET	Generator	No	GT	Distillate Fuel Oil			Southeast New England		MA	NEMA		Existing	8.589	12.739	8.589	8.589
507	NEA BELLINGHAM	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		Existing	282.865	331.747	282.865	282.865
508	NEWINGTON 1	Generator	No	ST	Residual Fuel Oil			Northern New England		NH	NH		Existing	400.200	400.200	400.200	400.200
513	NEW HAVEN HARBOR	Generator	No	ST	Residual Fuel Oil			Rest-of-Pool		CT	CT		Existing	447.894	453.384	447.894	447.894
515	NORWICH JET	Generator	No	GT	Distillate Fuel Oil			Rest-of-Pool		CT	CT		Existing	15.255	18.800	15.255	15.255
527	OGDEN-MARTIN 1	Generator	Yes	ST	Municipal Solid Waste			Southeast New England		MA	NEMA		Existing	39.529	42.386	39.529	42.386
528	OCEAN ST PWR GT1 GT2 ST1	Generator	No	CC	Natural Gas			Southeast New England		RI	RI		Existing	277.762	323.915	277.762	277.762
529	OCEAN ST PWR GT3 GT4 ST2	Generator	No	CC	Natural Gas			Southeast New England		RI	RI		Existing	278.308	325.879	278.308	278.308
531	PAWTUCKET POWER	Generator	No	CC	Natural Gas			Southeast New England		RI	RI		Existing	52.954	57.117	52.954	52.954
532	PEJEPSCOT	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	7.293	9.404	7.293	9.404
536	PERC-ORRINGTON 1	Generator	Yes	ST	Municipal Solid Waste			Northern New England		ME	ME		Existing	21.406	20.894	21.406	20.894
538	PINETREE POWER	Generator	No	ST	Wood/Wood Waste Solids			Rest-of-Pool		MA	WCMA		Existing	15.783	16.787	15.783	15.783
539	PONTOOK HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	4.761	8.301	4.761	8.301
540	POTTER 2 CC	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		Existing	72.558	89.998	72.558	72.558
540	POTTER 2 CC	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		New	59.310	63.390	0.000	0.000
541	PROCTOR	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	2.915	6.263	2.915	6.263
542	ECO MAINE	Generator	Yes	ST	Municipal Solid Waste			Northern New England		ME	ME		Existing	11.094	10.470	11.094	10.470
546	RESCO SAUGUS	Generator	No	ST	Municipal Solid Waste			Southeast New England		MA	NEMA		Existing	30.845	30.114	30.114	30.114
547	WHEELABRATOR NORTH ANDOVER	Generator	Yes	ST	Municipal Solid Waste			Southeast New England		MA	NEMA		Existing	29.864	29.994	29.864	29.994
549	RUTLAND 5 GT	Generator	No	GT	Distillate Fuel Oil			Northern New England		VT	VT		Existing	7.919	12.816	7.919	7.919
555	SEABROOK	Generator	No	ST	Nuclear			Northern New England		NH	NH		Existing	1247.075	1246.650	1246.650	1246.650
556	SCHILLER 4	Generator	No	ST	Coal			Northern New England		NH	NH		Existing	47.500	48.000	47.500	47.500
557	SCHILLER 5	Generator	No	ST	Wood/Wood Waste Solids			Northern New England		NH	NH		Existing	43.082	42.594	42.594	42.594
558	SCHILLER 6	Generator	No	ST	Coal			Northern New England		NH	NH		Existing	47.820	48.580	47.820	47.820
559	SCHILLER CT 1	Generator	No	GT	Kerosene			Northern New England		NH	NH		Existing	17.621	18.500	17.621	17.621
561	SEARSBURG	Generator	No	HDP	Water			Rest-of-Pool		MA	WCMA		Existing	4.755	4.960	4.755	4.755
562	SECREC-PRESTON	Generator	Yes	ST	Municipal Solid Waste			Rest-of-Pool		CT	CT		Existing	15.984	16.276	0.000	0.000
563	SEMASS 1	Generator	Yes	ST	Municipal Solid Waste			Southeast New England		MA	SEMA		Existing	46.955	50.184	46.955	50.184
564	SEMASS 2	Generator	Yes	ST	Municipal Solid Waste			Southeast New England		MA	SEMA		Existing	22.500	22.500	22.500	22.500

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
565	SHELDON SPRINGS	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	4.263	8.925	4.263	8.925
566	SHEPAUG	Generator	No	HW	Water			Rest-of-Pool		CT	CT		Existing	41.511	42.559	41.511	41.511
567	SHERMAN	Generator	No	HW	Water			Rest-of-Pool		MA	WCMA		Existing	6.154	6.220	6.154	6.154
569	SKELTON	Generator	No	HDP	Water			Northern New England		ME	ME		Existing	21.600	21.600	21.600	21.600
570	SMITH	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	9.263	13.645	9.263	13.645
572	SO. MEADOW 11	Generator	No	GT	Distillate Fuel Oil			Rest-of-Pool		CT	CT		Existing	35.781	46.921	35.781	35.781
573	SO. MEADOW 12	Generator	No	GT	Distillate Fuel Oil			Rest-of-Pool		CT	CT		Existing	37.649	47.815	37.649	37.649
574	SO. MEADOW 13	Generator	No	GT	Distillate Fuel Oil			Rest-of-Pool		CT	CT		Existing	38.317	47.917	38.317	38.317
575	SO. MEADOW 14	Generator	No	GT	Distillate Fuel Oil			Rest-of-Pool		CT	CT		Existing	36.746	46.346	36.746	36.746
580	SO. MEADOW 5	Generator	Yes	ST	Municipal Solid Waste			Rest-of-Pool		CT	CT		Existing	23.674	23.404	23.674	23.404
581	SO. MEADOW 6	Generator	Yes	ST	Municipal Solid Waste			Rest-of-Pool		CT	CT		Existing	20.576	22.424	20.576	22.424
583	STONY BROOK 2A	Generator	No	GT	Distillate Fuel Oil			Rest-of-Pool		MA	WCMA		Existing	67.000	87.000	67.000	67.000
584	STONY BROOK 2B	Generator	No	GT	Distillate Fuel Oil			Rest-of-Pool		MA	WCMA		Existing	65.000	85.000	65.000	65.000
587	STEVENSON	Generator	No	HW	Water			Rest-of-Pool		CT	CT		Existing	28.311	28.900	28.311	28.311
590	BORALEX STRATTON ENERGY	Generator	No	ST	Wood/Wood Waste Solids			Northern New England		ME	ME		Existing	45.024	44.363	44.363	44.363
591	S.D. WARREN-WESTBROOK	Generator	No	ST	Wood/Wood Waste Solids			Northern New England		ME	ME		Existing	42.590	49.103	42.590	42.590
592	TAMWORTH	Generator	Yes	ST	Wood/Wood Waste Solids			Northern New England		NH	NH		Existing	19.498	19.057	19.498	19.057
595	TORRINGTON TERMINAL 10	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	15.638	20.748	15.638	15.638
595	TORRINGTON TERMINAL 10	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		New	15.638	20.748	0.000	0.000
596	TUNNEL 10	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	16.591	21.691	16.591	16.591
598	VERGENNES 5 and 6 DIESELS	Generator	No	IC	Distillate Fuel Oil			Northern New England		VT	VT		Existing	3.940	4.240	3.940	3.940
599	VERNON	Generator	No	HDP	Water			Rest-of-Pool		MA	WCMA		Existing	32.000	32.000	32.000	32.000
612	WATERS RIVER JET 1	Generator	No	GT	Natural Gas			Southeast New England		MA	NEMA		Existing	15.974	21.974	15.974	15.974
613	WATERS RIVER JET 2	Generator	No	GT	Natural Gas			Southeast New England		MA	NEMA		Existing	29.889	45.806	29.889	29.889
614	WATERBURY 22	Generator	No	HW	Water			Northern New England		VT	VT		Existing	5.000	5.000	5.000	5.000
616	WEST ENFIELD	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	10.899	13.076	10.899	13.076
617	WESTON	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	8.733	10.829	8.733	10.829
618	DG WHITEFIELD, LLC	Generator	Yes	ST	Wood/Wood Waste Solids			Northern New England		NH	NH		Existing	16.043	16.409	16.043	16.409
619	WHITE LAKE JET	Generator	No	GT	Kerosene			Northern New England		NH	NH		Existing	17.447	22.397	17.447	17.447
620	WILDER	Generator	No	HW	Water			Northern New England		NH	NH		Existing	39.083	41.156	39.083	39.083
621	WILLIAMS	Generator	No	HDP	Water			Northern New England		ME	ME		Existing	14.900	14.900	14.900	14.900
622	WINOOSKI 1	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	1.991	3.267	1.991	3.267
624	WMI MILLBURY 1	Generator	No	ST	Municipal Solid Waste			Rest-of-Pool		MA	WCMA		Existing	39.811	39.891	39.811	39.811
625	WEST MEDWAY JET 1	Generator	No	GT	Distillate Fuel Oil			Southeast New England		MA	NEMA		Existing	42.000	63.458	42.000	53.025
626	WEST MEDWAY JET 2	Generator	No	GT	Distillate Fuel Oil			Southeast New England		MA	NEMA		Existing	39.848	61.598	39.848	39.848
627	WEST MEDWAY JET 3	Generator	No	GT	Distillate Fuel Oil			Southeast New England		MA	SEMA		Existing	35.441	55.841	35.441	35.441
628	WOODLAND ROAD	Generator	No	GT	Kerosene			Rest-of-Pool		MA	WCMA		Existing	15.808	20.658	15.808	15.808
630	WEST SPRINGFIELD 10	Generator	No	GT	Kerosene			Rest-of-Pool		MA	WCMA		Existing	17.143	21.928	17.143	17.143
633	WEST SPRINGFIELD 3	Generator	No	ST	Natural Gas			Rest-of-Pool		MA	WCMA		Existing	94.276	100.087	94.276	94.276
636	WYMAN HYDRO 1	Generator	No	HW	Water			Northern New England		ME	ME		Existing	28.500	28.500	28.500	28.500
637	WYMAN HYDRO 2	Generator	No	HW	Water			Northern New England		ME	ME		Existing	29.866	29.900	29.866	29.866
638	WYMAN HYDRO 3	Generator	No	HW	Water			Northern New England		ME	ME		Existing	26.520	26.672	26.520	26.520
639	YARMOUTH 1	Generator	No	ST	Residual Fuel Oil			Northern New England		ME	ME		Existing	50.328	51.018	0.000	0.000
640	YARMOUTH 2	Generator	No	ST	Residual Fuel Oil			Northern New England		ME	ME		Existing	50.805	52.823	0.000	0.000
641	YARMOUTH 3	Generator	No	ST	Residual Fuel Oil			Northern New England		ME	ME		Existing	110.870	114.720	57.453	57.453
642	YARMOUTH 4	Generator	No	ST	Residual Fuel Oil			Northern New England		ME	ME		Existing	602.050	605.875	602.050	602.050
715	ROCHESTER LANDFILL	Generator	No	GT	Landfill Gas			Northern New England		NH	NH		Existing	2.192	2.261	2.192	2.192
737	SIMPSON G LOAD REDUCER	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	2.378	2.968	2.378	2.968
739	ROCKY RIVER	Generator	No	PS	Water			Rest-of-Pool		CT	CT		Existing	28.853	28.383	28.383	28.383
754	BAR MILLS	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.936	2.065	0.936	2.065
755	BONNY EAGLE W. BUXTON	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	5.659	10.884	5.659	10.884
757	HARRIS 4	Generator	No	HW	Water			Northern New England		ME	ME		Existing	1.436	1.249	1.249	1.249
759	MESSALONSKEE COMPOSITE	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	2.117	5.287	2.117	5.287
760	NORTH GORHAM	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	1.150	1.138	1.150	1.138
761	SHAWMUT	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	5.922	6.970	5.922	6.970
766	CABOT TURNERS FALLS	Generator	No	HDP	Water			Rest-of-Pool		MA	WCMA		Existing	67.881	68.200	67.881	67.881
767	SES CONCORD	Generator	Yes	ST	Municipal Solid Waste			Northern New England		NH	NH		Existing	12.111	12.466	12.111	12.466
768	GARVINS HOOKSETT	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	4.461	7.082	4.461	7.082
769	HADLEY FALLS 1&2	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	12.302	27.822	12.302	27.822
772	NEWPORT HYDRO	Generator	Yes	HW	Water			Northern New England		VT	VT		Existing	1.456	1.906	1.456	1.906
774	LOWER LAMOILLE COMPOSITE	Generator	No	HW	Water			Northern New England		VT	VT		Existing	15.800	16.000	15.800	15.800
775	MIDDLEBURY COMPOSITE	Generator	No	HW	Water			Northern New England		VT	VT		Existing	5.678	5.724	5.678	5.678
776	N. RUTLAND COMPOSITE	Generator	No	HW	Water			Northern New England		VT	VT		Existing	4.503	4.360	4.360	4.360
779	MIDDLESEX 2	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.815	1.674	0.815	1.674
783	HIGHGATE FALLS	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	3.376	7.807	3.376	7.807
786	KEZAR LEDGEMERE COMPOSITE	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.468	1.018	0.468	1.018

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
789	CEC 002 PAWTUCKET U5	Generator	Yes	HDR	Water			Southeast New England		RI	RI		Existing	0.168	0.570	0.168	0.570
792	CENTENNIAL HYDRO	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.160	0.544	0.160	0.544
793	METHUEN HYDRO	Generator	Yes	HDR	Water			Southeast New England		MA	NEMA		Existing	0.004	0.151	0.004	0.151
794	MINIWAWA	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.142	0.528	0.142	0.528
795	RIVER MILL HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.000	0.039	0.000	0.039
796	GOODWIN DAM	Generator	No	HDP	Water			Rest-of-Pool		CT	CT		Existing	3.000	3.000	3.000	3.000
797	CEC 003 WYRE WYND U5	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.493	1.129	0.493	1.129
798	COLEBROOK	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.682	0.553	0.682	0.553
800	KINNEYTOWN B	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.114	0.607	0.114	0.607
801	WILLIMANTIC 1	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.046	0.127	0.046	0.127
802	WILLIMANTIC 2	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.012	0.122	0.012	0.122
803	TOUTANT	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.054	0.154	0.054	0.154
804	PUTNAM	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.139	0.382	0.139	0.382
806	MECHANICSVILLE	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.000	0.162	0.000	0.162
807	CEC 004 DAYVILLE POND U5	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.005	0.052	0.005	0.052
808	SANDY HOOK HYDRO	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.000	0.066	0.000	0.066
810	QUINEBAUG	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.266	0.935	0.266	0.935
811	BANTAM	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.026	0.093	0.026	0.093
812	BEEBE HOLBROOK	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.066	0.066	0.066	0.066
813	TUNNEL	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.360	1.147	0.360	1.147
814	PATCH	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.006	0.054	0.006	0.054
815	CARVER FALLS	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.082	0.958	0.082	0.958
816	CAVENDISH	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.289	0.676	0.289	0.676
817	TAFTSVILLE VT	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.012	0.034	0.012	0.034
818	PIERCE MILLS	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.091	0.161	0.091	0.161
819	ARNOLD FALLS	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.124	0.140	0.124	0.140
820	PASSUMPSIC	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.123	0.228	0.123	0.228
821	GAGE	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.176	0.324	0.176	0.324
822	SMITH (CVPS)	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.475	0.557	0.475	0.557
823	EAST BARNET	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.617	0.813	0.617	0.813
824	BATH ELECTRIC HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.225	0.211	0.225	0.211
827	SEARSBURG WIND	Generator	Yes	WT	Wind			Rest-of-Pool		MA	WCMA		Existing	0.198	1.031	0.198	1.031
832	CENTER RUTLAND	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.019	0.028	0.019	0.028
833	BARNET	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.062	0.122	0.062	0.122
834	COMPTU FALLS	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.174	0.352	0.174	0.352
835	DEWEY MILLS	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.384	0.764	0.384	0.764
836	EMERSON FALLS	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.006	0.043	0.006	0.043
837	KILLINGTON	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.003	0.026	0.003	0.026
839	LADD'S MILL	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.019	0.051	0.019	0.051
840	MARTINSVILLE	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.036	0.089	0.036	0.089
841	MORETOWN 8	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.098	0.217	0.098	0.217
842	NANTANA MILL	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.033	0.086	0.033	0.086
843	NEWBURY	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.071	0.119	0.071	0.119
844	OTTAUQUECHEE	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.429	0.733	0.429	0.733
845	SLACK DAM	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.134	0.271	0.134	0.271
846	WINOOSKI 8	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.299	0.396	0.299	0.396
847	WOODSIDE	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.054	0.066	0.054	0.066
849	CRESCENT DAM	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.338	0.644	0.338	0.644
850	GLENDALE HYDRO	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.245	0.471	0.245	0.471
851	GARDNER FALLS	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.099	0.784	0.099	0.784
852	SOUTH BARRE HYDRO	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.032	0.140	0.032	0.140
853	WEBSTER HYDRO	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.000	0.043	0.000	0.043
854	ORANGE HYDRO 1	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.017	0.122	0.017	0.122
855	ORANGE HYDRO 2	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.075	0.152	0.075	0.152
856	HUNT'S POND	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.001	0.009	0.001	0.009
857	OAKDALE HYDRO	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	2.681	0.475	2.681	0.475
859	BOATLOCK	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	1.482	2.041	1.482	2.041
860	BRIAR HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.968	2.863	0.968	2.863
861	CANAAN	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.691	0.943	0.691	0.943
862	CHEMICAL	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.504	0.409	0.504	0.409
863	CLEMENT DAM	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.429	0.550	0.429	0.550
864	DWIGHT	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.166	0.326	0.166	0.326
865	ERROL	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	1.877	2.043	1.877	2.043
866	GREGGS	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.421	1.212	0.421	1.212
867	INDIAN ORCHARD	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.278	0.867	0.278	0.867
868	MILTON MILLS HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.297	0.828	0.297	0.828

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
869	MINE FALLS	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.543	1.379	0.543	1.379
870	PEMBROKE	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.323	1.166	0.323	1.166
871	PENNACOOK FALLS LOWER	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	1.384	2.996	1.384	2.996
872	PENNACOOK FALLS UPPER	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.979	2.116	0.979	2.116
873	PUTTS BRIDGE	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.816	2.093	0.816	2.093
874	RED BRIDGE	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.578	1.392	0.578	1.392
875	RIVER BEND	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.592	0.890	0.592	0.890
876	ROBERTSVILLE	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.000	0.018	0.000	0.018
877	SCOTLAND	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.000	1.068	0.000	1.068
878	SKINNER	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.100	0.200	0.100	0.200
879	TAFTVILLE CT	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		Existing	0.187	0.868	0.187	0.868
882	FRANKLIN FALLS	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.415	0.514	0.415	0.514
883	SALMON FALLS HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.029	0.456	0.029	0.456
884	SWANS FALLS	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.335	0.380	0.335	0.380
886	COCHECO FALLS	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.082	0.296	0.082	0.296
887	CHINA MILLS DAM	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.005	0.244	0.005	0.244
888	NEWFOUND HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.309	0.888	0.309	0.888
889	SUNAPEE HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.123	0.306	0.123	0.306
890	NASHUA HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.216	0.705	0.216	0.705
891	HILLSBORO MILLS	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.006	0.147	0.006	0.147
892	LAKEPORT DAM	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.220	0.223	0.220	0.223
893	WEST HOPKINTON HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.212	0.393	0.212	0.393
894	LISBON HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.238	0.288	0.238	0.288
895	LOWER ROBERTSON DAM	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.314	0.550	0.314	0.550
897	OLD NASH DAM	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.015	0.089	0.015	0.089
898	SUGAR RIVER HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.012	0.099	0.012	0.099
900	GREAT FALLS LOWER	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.103	0.560	0.103	0.560
901	WATERLOOM FALLS	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.004	0.034	0.004	0.034
902	HOSIERY MILL DAM	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.000	0.048	0.000	0.048
903	WYANDOTTE HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.000	0.051	0.000	0.051
904	LOCHMERE DAM	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.256	0.432	0.256	0.432
905	ASHUELOT HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.338	0.537	0.338	0.537
906	ROLLINSFORD HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.118	0.815	0.118	0.815
908	OTIS MILL HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.000	0.009	0.000	0.009
909	STEELS POND HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.009	0.054	0.009	0.054
910	CAMPTON DAM	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.101	0.127	0.101	0.127
911	KELLEYS FALLS	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.021	0.130	0.021	0.130
913	GOODRICH FALLS	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.147	0.268	0.147	0.268
914	CHAMBERLAIN FALLS	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.000	0.004	0.000	0.004
919	HOPKINTON HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.094	0.163	0.094	0.163
922	NOONE FALLS	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.000	0.069	0.000	0.069
925	OTTER LANE HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.008	0.034	0.008	0.034
926	PETERBOROUGH LOWER HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.017	0.093	0.017	0.093
928	SALMON BROOK STATION 3	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.023	0.095	0.023	0.095
931	AVERY DAM	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.176	0.191	0.176	0.191
932	WATSON DAM	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.027	0.115	0.027	0.115
933	WESTON DAM	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.229	0.297	0.229	0.297
935	SUNNYBROOK HYDRO 2	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.012	0.008	0.012	0.008
941	PETERBOROUGH UPPER HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.011	0.159	0.011	0.159
943	FOUR HILLS LANDFILL	Generator	Yes	IC	Landfill Gas			Northern New England		NH	NH		Existing	0.569	0.411	0.569	0.411
948	PEPPERELL HYDRO COMPANY LLC	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.408	0.573	0.408	0.573
949	VALLEY HYDRO - QF	Generator	Yes	HDR	Water			Southeast New England		RI	RI		Existing	0.017	0.075	0.017	0.075
950	LP ATHOL - QF	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.063	0.070	0.063	0.070
951	BALTIC MILLS - QF	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.036	0.062	0.036	0.062
953	ATTLEBORO LANDFILL - QF	Generator	Yes	IC	Other Biomass Gas			Southeast New England		MA	SEMA		Existing	0.103	0.168	0.000	0.000
957	HG&E HYDRO CABOT 1-4	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	1.214	1.173	1.214	1.173
959	BARTON 1-4 DIESELS	Generator	No	IC	Distillate Fuel Oil			Northern New England		VT	VT		Existing	0.586	0.653	0.586	0.586
969	POWDER MILL HYDRO	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.000	0.068	0.000	0.068
970	DUDLEY HYDRO	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.021	0.102	0.021	0.102
978	NEW MILFORD	Generator	Yes	IC	Other Biomass Gas			Rest-of-Pool		CT	CT		Existing	1.281	1.382	1.281	1.382
1005	BG DIGHTON POWER LLC	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		Existing	164.039	186.990	164.039	164.039
1028	BUNKER RD #12 GAS TURB	Generator	No	GT	Distillate Fuel Oil			Southeast New England		MA	SEMA		Existing	2.351	3.012	2.351	2.351
1029	BUNKER RD #13 GAS TURB	Generator	No	GT	Distillate Fuel Oil			Southeast New England		MA	SEMA		Existing	2.806	3.281	2.806	2.806
1030	OAK BLUFFS	Generator	No	IC	Kerosene			Southeast New England		MA	SEMA		Existing	7.471	8.120	7.471	7.471
1031	WEST TISBURY	Generator	No	IC	Kerosene			Southeast New England		MA	SEMA		Existing	5.005	5.524	5.005	5.005
1032	BRIDGEPORT ENERGY 1	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		Existing	476.000	566.000	476.000	476.000

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
1032	BRIDGEPORT ENERGY 1	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		New	8.000	19.000	8.000	8.000
1034	RIVERSIDE 4-7	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	1.428	1.647	1.428	1.647
1035	RIVERSIDE 8	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	3.180	3.055	3.180	3.055
1047	FAIRFAX	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	1.761	3.647	1.761	3.647
1048	WARE HYDRO	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.139	0.636	0.139	0.636
1049	COLLINS HYDRO	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.349	0.667	0.349	0.667
1050	CHICOPEE HYDRO	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.704	1.284	0.704	1.284
1054	BLACKSTONE HYDRO ASSOC	Generator	Yes	HDR	Water			Southeast New England		RI	RI		Existing	0.000	0.138	0.000	0.138
1057	BLACKSTONE HYDRO LOAD REDUCER	Generator	Yes	HDR	Water			Southeast New England		RI	RI		Existing	0.280	0.601	0.280	0.601
1059	BARRE LANDFILL	Generator	Yes	IC	Landfill Gas			Rest-of-Pool		MA	WCMA		Existing	0.604	0.641	0.604	0.641
1061	MASCOMA HYDRO	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.133	0.594	0.133	0.594
1062	MWRA COSGROVE	Generator	Yes	HW	Water			Rest-of-Pool		MA	WCMA		Existing	0.883	0.321	0.883	0.321
1086	BERKSHIRE POWER	Generator	No	CC	Natural Gas			Rest-of-Pool		MA	WCMA		Existing	229.279	246.279	229.279	229.279
1109	MMWAC	Generator	Yes	ST	Municipal Solid Waste			Northern New England		ME	ME		Existing	1.848	2.021	1.848	2.021
1113	BRASSUA HYDRO	Generator	No	HDP	Water			Northern New England		ME	ME		Existing	4.203	4.203	4.203	4.203
1117	GREAT WORKS COMPOSITE	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.015	0.121	0.015	0.121
1119	KENNEBAGO HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.190	0.449	0.190	0.449
1122	CASCADE-DIAMOND-QF	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.083	0.188	0.083	0.188
1185	STONY BROOK GT1A	Generator	No	CC	Distillate Fuel Oil			Rest-of-Pool		MA	WCMA		Existing	103.167	118.500	103.167	103.167
1186	STONY BROOK GT1B	Generator	No	CC	Distillate Fuel Oil			Rest-of-Pool		MA	WCMA		Existing	99.932	115.932	99.932	99.932
1187	STONY BROOK GT1C	Generator	No	CC	Distillate Fuel Oil			Rest-of-Pool		MA	WCMA		Existing	103.167	118.500	103.167	103.167
1209	CRRA HARTFORD LANDFILL	Generator	Yes	IC	Landfill Gas			Rest-of-Pool		CT	CT		Existing	1.374	1.393	1.374	1.393
1210	MILLENNIUM	Generator	No	CC	Natural Gas			Rest-of-Pool		MA	WCMA		Existing	331.000	383.904	331.000	331.000
1216	MAINE INDEPENDENCE STATION	Generator	No	CC	Natural Gas			Northern New England		ME	ME		Existing	492.658	538.276	492.658	492.658
1221	ESSEX DIESELS	Generator	No	IC	Distillate Fuel Oil			Northern New England		VT	VT		Existing	7.215	7.305	7.215	7.215
1225	TANNERY DAM	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.000	0.006	0.000	0.006
1226	TIVERTON POWER	Generator	No	CC	Natural Gas			Southeast New England		RI	RI		Existing	267.424	293.653	267.424	267.424
1255	RUMFORD POWER	Generator	No	CC	Natural Gas			Northern New England		ME	ME		Existing	244.281	269.091	244.281	244.281
1258	BHE SMALL HYDRO COMPOSITE	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.900	1.713	0.900	1.713
1267	SPARHAWK	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.001	0.017	0.001	0.017
1270	SYSKO STONY BROOK	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.016	0.015	0.016	0.015
1271	SYSKO WIGHT BROOK	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.003	0.023	0.003	0.023
1273	KENNEBEC WATER U5	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.102	0.480	0.102	0.480
1286	ANP-BLACKSTONE ENERGY CO. #1	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		Existing	239.174	262.947	239.174	239.174
1286	ANP-BLACKSTONE ENERGY CO. #1	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		New	20.000	20.000	0.000	0.000
1287	ANP-BLACKSTONE ENERGY 2	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		Existing	250.295	268.974	250.295	250.295
1287	ANP-BLACKSTONE ENERGY 2	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		New	20.000	20.000	0.000	0.000
1288	BUCKSPORT ENERGY 4	Generator	No	CC	Natural Gas			Northern New England		ME	ME		Existing	160.300	185.700	160.300	160.300
1342	LAKE ROAD 1	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		Existing	269.792	299.416	269.792	269.792
1343	LAKE ROAD 2	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		Existing	275.213	304.837	275.213	275.213
1344	LAKE ROAD 3	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		Existing	279.000	307.076	279.000	279.000
1345	WESTBROOK	Generator	No	CC	Natural Gas			Northern New England		ME	ME		Existing	530.000	554.430	530.000	530.000
1368	ROCKY GORGE CORPORATION	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.086	0.269	0.086	0.269
1376	PPL WALLINGFORD UNIT 1	Generator	No	GT	Natural Gas			Rest-of-Pool		CT	CT		Existing	43.473	48.583	43.473	43.473
1377	PPL WALLINGFORD UNIT 2	Generator	No	GT	Natural Gas			Rest-of-Pool		CT	CT		Existing	43.019	49.000	43.019	43.019
1378	PPL WALLINGFORD UNIT 3	Generator	No	GT	Natural Gas			Rest-of-Pool		CT	CT		Existing	44.566	49.000	44.566	44.566
1379	PPL WALLINGFORD UNIT 4	Generator	No	GT	Natural Gas			Rest-of-Pool		CT	CT		Existing	43.157	47.157	43.157	43.157
1380	PPL WALLINGFORD UNIT 5	Generator	No	GT	Natural Gas			Rest-of-Pool		CT	CT		Existing	44.425	49.000	44.425	44.425
1385	Milford Power 1 Incremental	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		Existing	267.610	299.847	267.610	267.610
1386	MILFORD POWER 2	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		Existing	267.093	305.425	267.093	267.093
1412	ANP-BELLINGHAM 1	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		Existing	254.473	284.813	254.473	254.473
1415	ANP-BELLINGHAM 2	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		Existing	247.067	276.788	247.067	247.067
1432	GRS-FALL RIVER	Generator	No	GT	Landfill Gas			Southeast New England		MA	SEMA		Existing	3.028	3.824	3.028	3.028
1478	MYSTIC 8	Generator	No	CC	Natural Gas			Southeast New England		MA	NEMA		Existing	703.324	841.564	703.324	703.324
1572	GRANBY SANITARY LANDFILL QF U5	Generator	Yes	IC	Municipal Solid Waste			Rest-of-Pool		MA	WCMA		Existing	2.392	2.636	2.392	2.636
1616	MYSTIC 9	Generator	No	CC	Natural Gas			Southeast New England		MA	NEMA		Existing	709.676	858.366	709.676	709.676
1625	GRANITE RIDGE ENERGY	Generator	No	CC	Natural Gas			Northern New England		NH	NH		Existing	675.675	773.010	675.675	675.675
1630	RISEP	Generator	No	CC	Natural Gas			Southeast New England		RI	RI		Existing	551.668	610.632	551.668	569.946
1631	Indeck-Energy Alexandria, LLC	Generator	No	ST	Wood/Wood Waste Solids			Northern New England		NH	NH		Existing	15.031	15.200	15.031	15.031
1649	EP Newington Energy, LLC	Generator	No	CC	Natural Gas			Northern New England		NH	NH		Existing	522.014	561.500	522.014	522.014
1649	EP Newington Energy, LLC	Generator	No	CC	Natural Gas			Northern New England		NH	NH		New	37.486	73.400	37.486	37.486
1656	HULL WIND TURBINE U5	Generator	Yes	WT	Wind			Southeast New England		MA	SEMA		Existing	0.032	0.108	0.032	0.108
1672	KENDALL CT	Generator	No	CC	Natural Gas			Southeast New England		MA	NEMA		Existing	170.000	181.505	170.000	170.000
1691	FORE RIVER-1	Generator	No	CC	Natural Gas			Southeast New England		MA	SEMA		Existing	708.000	837.372	708.000	708.000
1693	WEST SPRINGFIELD GT-1	Generator	No	GT	Natural Gas			Rest-of-Pool		MA	WCMA		Existing	36.908	46.908	36.908	36.908
1694	WEST SPRINGFIELD GT-2	Generator	No	GT	Natural Gas			Rest-of-Pool		MA	WCMA		Existing	37.441	47.441	37.441	37.441

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
1720	MIDDLEBURY LOWER	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.710	1.103	0.710	1.103
2278	BARKER LOWER HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.312	0.833	0.312	0.833
2279	BARKER UPPER HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.377	0.700	0.377	0.700
2280	BENTON FALLS HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.794	1.997	0.794	1.997
2281	BROWNS MILL HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.200	0.516	0.200	0.516
2282	DAMARISCOTTA HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.000	0.237	0.000	0.237
2283	EUSTIS HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.074	0.137	0.074	0.137
2284	GARDINER HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.388	0.941	0.388	0.941
2285	GREENVILLE HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.077	0.334	0.077	0.334
2286	HACKETT MILLS HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.022	0.275	0.022	0.275
2287	MECHANIC FALLS HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.188	0.459	0.188	0.459
2288	NORWAY HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.000	0.015	0.000	0.015
2289	PIONEER DAM HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.075	0.065	0.075	0.065
2290	PITTSFIELD HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.225	0.632	0.225	0.632
2291	WAVERLY AVENUE HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.175	0.225	0.175	0.225
2292	YORK HYDRO	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.138	0.697	0.138	0.697
2424	CITIZENS BLOCK LOAD	Generator	No		Steam			Northern New England		VT	VT		Existing	30.000	30.000	30.000	30.000
2425	SPRINGFIELD REFUSE-NEW	Generator	Yes	ST	Municipal Solid Waste			Rest-of-Pool		MA	WCMA		Existing	5.082	5.714	5.082	5.714
2426	Hydro Kennebec	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	6.844	9.860	6.844	9.860
2430	BELDENS-NEW	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	1.130	2.477	1.130	2.477
2431	DODGE FALLS-NEW	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	3.472	3.756	3.472	3.756
2432	HUNTINGTON FALLS-NEW	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	1.564	2.413	1.564	2.413
2432	HUNTINGTON FALLS-NEW	Generator	Yes	HDR	Water			Northern New England		VT	VT		New	1.720	3.350	1.720	3.350
2433	RYEGATE 1-NEW	Generator	Yes	ST	Wood/Wood Waste Solids			Northern New England		VT	VT		Existing	19.000	18.908	19.000	18.908
2434	GORGE 18 HYDRO-NEW	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.517	0.888	0.517	0.888
2435	VERGENNES HYDRO-NEW	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	1.015	1.237	1.015	1.237
2439	BROCKWAY MILLS U5	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	0.029	0.162	0.029	0.162
2462	PLAINVILLE GEN QF U5	Generator	Yes	IC	Other Biomass Gas			Southeast New England		MA	SEMA		Existing	2.276	2.478	2.276	2.478
2466	CHERRY 7	Generator	No	IC	Distillate Fuel Oil			Rest-of-Pool		MA	WCMA		Existing	2.800	2.800	2.800	2.800
2467	CHERRY 8	Generator	No	IC	Distillate Fuel Oil			Rest-of-Pool		MA	WCMA		Existing	3.400	3.400	3.400	3.400
2468	CHERRY 10	Generator	No	IC	Distillate Fuel Oil			Rest-of-Pool		MA	WCMA		Existing	2.100	2.100	2.100	2.100
2469	CHERRY 11	Generator	No	IC	Distillate Fuel Oil			Rest-of-Pool		MA	WCMA		Existing	2.100	2.100	2.100	2.100
2470	CHERRY 12	Generator	No	IC	Distillate Fuel Oil			Rest-of-Pool		MA	WCMA		Existing	4.999	4.999	4.999	4.999
10308	NECCO COGENERATION FACILITY	Generator	No	IC	Natural Gas			Southeast New England		MA	NEMA		Existing	4.743	4.948	4.743	4.743
10401	CELLEY MILL U5	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.028	0.080	0.028	0.080
10402	PETTYBORO HYDRO U5	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.000	0.002	0.000	0.002
10403	EASTMAN BROOK U5	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.011	0.041	0.011	0.041
10406	LOWER VALLEY HYDRO U5	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.088	0.253	0.088	0.253
10407	WOODSVILLE HYDRO U5	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.117	0.084	0.117	0.084
10409	SWEETWATER HYDRO U5	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.135	0.285	0.135	0.285
10424	Great Lakes - Berlin Incremental	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	8.948	13.398	8.948	13.398
10615	BLUE SPRUCE FARM U5	Generator	Yes	IC	Other Biomass Gas			Northern New England		VT	VT		Existing	0.275	0.263	0.275	0.263
10770	WEST SPRINGFIELD HYDRO U5	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.361	0.903	0.361	0.903
10801	COVENTRY CLEAN ENERGY	Generator	Yes	IC	Landfill Gas			Northern New England		VT	VT		Existing	3.464	3.559	3.464	3.559
10959	RRIG EXPANSION PHASE 2	Generator	Yes	IC	Landfill Gas			Southeast New England		RI	RI		Existing	1.966	1.876	0.000	0.000
11052	GRTR NEW BEDFORD LFG UTIL PROJ	Generator	Yes	IC	Landfill Gas			Southeast New England		MA	SEMA		Existing	2.424	2.441	2.424	2.441
11126	NORTH HARTLAND HYDRO	Generator	Yes	HDR	Water			Northern New England		VT	VT		Existing	1.403	2.403	1.403	2.403
11408	HULL WIND TURBINE II	Generator	Yes	WT	Wind			Southeast New England		MA	SEMA		Existing	0.047	0.310	0.047	0.310
11424	RUMFORD FALLS	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	29.005	35.036	29.005	35.036
11842	WATERSIDE POWER	Generator	No	GT	Distillate Fuel Oil			Rest-of-Pool		CT	CT		Existing	70.017	71.557	70.017	70.017
11925	BROCKTON BRIGHTFIELDS	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	0.146	0.000	0.146	0.000
12108	FIEC DIESEL	Generator	No	IC	Distillate Fuel Oil			Northern New England		ME	ME		Existing	1.540	1.596	1.540	1.540
12180	BERKSHIRE COW POWER	Generator	Yes	IC	Other Biomass Gas			Northern New England		VT	VT		Existing	0.226	0.291	0.226	0.291
12274	GREEN MOUNTAIN DAIRY	Generator	Yes	IC	Other Biomass Gas			Northern New England		VT	VT		Existing	0.198	0.214	0.198	0.214
12323	COVENTRY CLEAN ENERGY #4	Generator	Yes	IC	Landfill Gas			Northern New England		VT	VT		Existing	2.391	2.440	2.391	2.440
12500	Thomas A. Watson	Generator	No	GT	Natural Gas			Southeast New England		MA	SEMA		Existing	105.200	114.800	105.200	105.200
12504	Devon 15-18	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	187.589	187.600	187.589	187.589
12505	Middletown 12-15	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	187.600	187.600	187.600	187.600
12509	UNH Power Plant	Generator	No	GT	Landfill Gas			Northern New England		NH	NH		Existing	2.000	2.000	2.000	2.000
12510	Swanton Gas Turbine 1	Generator	No	GT	Distillate Fuel Oil			Northern New England		VT	VT		Existing	19.304	23.954	19.304	19.304
12511	Swanton Gas Turbine 2	Generator	No	GT	Distillate Fuel Oil			Northern New England		VT	VT		Existing	19.349	23.839	19.349	19.349
12521	Lowell Power Reactivation	Generator	No	CC	Natural Gas			Rest-of-Pool		MA	WCMA		Existing	74.000	74.000	74.000	74.000
12524	Cos Cob 13&14	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	36.000	36.000	36.000	36.000
12526	Pierce	Generator	No	GT	Natural Gas			Rest-of-Pool		CT	CT		Existing	74.085	87.000	74.085	74.085
12530	Sheffield Wind Farm	Generator	Yes	WT	Wind			Northern New England		VT	VT		Existing	2.893	8.873	2.893	8.873
12551	Kibby Wind Power	Generator	Yes	WT	Wind			Northern New England		ME	ME		Existing	14.719	32.115	14.719	32.115

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
12553	Covanta Haverhill Landfill Gas Engine	Generator	No	IC	Landfill Gas			Southeast New England		MA	NEMA		Existing	1.188	1.190	1.188	1.188
12564	Waterbury Generation Facility	Generator	No	GT	Natural Gas			Rest-of-Pool		CT	CT		Existing	96.349	98.749	96.349	96.349
13669	Manchester Methane LLC East Windsor Facility	Generator	Yes	IC	Landfill Gas			Rest-of-Pool		CT	CT		Existing	0.811	0.697	0.811	0.697
13673	MATEP (DIESEL)	Generator	No	IC	Distillate Fuel Oil			Southeast New England		MA	NEMA		Existing	17.120	17.460	8.120	8.120
13675	MATEP (COMBINED CYCLE)	Generator	No	CC	Natural Gas			Southeast New England		MA	NEMA		Existing	42.515	48.275	39.515	39.515
13703	Verso VCG1	Generator	No	GT	Natural Gas			Northern New England		ME	ME		Existing	42.606	53.760	42.606	42.606
13704	Verso VCG2	Generator	No	GT	Natural Gas			Northern New England		ME	ME		Existing	44.826	56.321	44.826	44.826
13705	Verso VCG3	Generator	No	GT	Natural Gas			Northern New England		ME	ME		Existing	42.681	55.123	42.681	42.681
13975	Corriveau Hydroelectric LLC	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	0.042	0.046	0.042	0.046
14087	MAT3	Generator	No	IC	Distillate Fuel Oil			Southeast New England		MA	NEMA		Existing	14.340	18.065	14.340	14.340
14217	NORTHFIELD MOUNTAIN 1	Generator	No	PS	Water			Rest-of-Pool		MA	WCMA		Existing	292.000	292.000	292.000	292.000
14218	NORTHFIELD MOUNTAIN 2	Generator	No	PS	Water			Rest-of-Pool		MA	WCMA		Existing	292.000	292.000	292.000	292.000
14219	NORTHFIELD MOUNTAIN 3	Generator	No	PS	Water			Rest-of-Pool		MA	WCMA		Existing	292.000	292.000	292.000	292.000
14220	NORTHFIELD MOUNTAIN 4	Generator	No	PS	Water			Rest-of-Pool		MA	WCMA		Existing	292.000	292.000	292.000	292.000
14271	Ameresco Northampton	Generator	No	IC	Landfill Gas			Rest-of-Pool		MA	WCMA		Existing	0.748	0.752	0.748	0.748
14595	Granite Reliable Power	Generator	Yes	WT	Wind			Northern New England		NH	NH		Existing	12.426	29.632	12.426	29.632
14599	Rhode Island LFG Genco, LLC - ST	Generator	No	CC	Landfill Gas			Southeast New England		RI	RI		Existing	26.000	26.000	26.000	26.000
14610	Princeton Wind Farm Project	Generator	Yes	WT	Wind			Rest-of-Pool		MA	WCMA		Existing	0.123	0.412	0.123	0.412
14614	Kleen Energy	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		Existing	620.000	620.000	620.000	620.000
14623	Valley Hydro (Station No. 5)	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.239	0.458	0.239	0.458
14652	Templeton Wind Turbine	Generator	Yes	WT	Wind			Rest-of-Pool		MA	WCMA		Existing	0.058	0.118	0.058	0.118
14660	Lempster Wind	Generator	Yes	WT	Wind			Northern New England		NH	NH		Existing	2.501	8.365	2.501	8.365
14661	Berkshire Wind Power Project	Generator	Yes	WT	Wind			Rest-of-Pool		MA	WCMA		Existing	1.746	6.235	1.746	6.235
14663	WMRE Crossroads	Generator	No	IC	Landfill Gas			Northern New England		ME	ME		Existing	2.628	2.806	2.628	2.628
14665	Record Hill Wind	Generator	Yes	WT	Wind			Northern New England		ME	ME		Existing	5.255	11.432	5.255	11.432
14706	Kimberly-Clark Corp Energy Independence Project	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		Existing	13.016	14.000	13.016	13.016
15415	Dartmouth Power Expansion	Generator	No	GT	Natural Gas			Southeast New England		MA	SEMA		Existing	19.578	21.300	19.578	19.578
15477	New Haven Harbor Units 2, 3, & 4	Generator	No	GT	Kerosene			Rest-of-Pool		CT	CT		Existing	129.600	129.600	129.600	129.600
15509	Plainfield Renewable Energy	Generator	No	ST	Wood/Wood Waste Solids			Rest-of-Pool		CT	CT		Existing	37.500	36.464	36.464	36.464
16296	Milford Hydro	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	5.335	5.783	5.335	5.783
16523	Stillwater	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	1.568	1.296	1.568	1.296
16525	Medway	Generator	Yes	HDR	Water			Northern New England		ME	ME		Existing	3.443	2.869	3.443	2.869
16631	Victory Road Dorchester PV	Generator	Yes	PV	Solar			Southeast New England		MA	NEMA		Existing	0.316	0.000	0.316	0.000
16640	Hilldale Ave Haverhill PV	Generator	Yes	PV	Solar			Southeast New England		MA	NEMA		Existing	0.270	0.000	0.270	0.000
16642	Railroad Street Revere PV	Generator	Yes	PV	Solar			Southeast New England		MA	NEMA		Existing	0.245	0.000	0.245	0.000
16643	Rover Street Everett PV	Generator	Yes	PV	Solar			Southeast New England		MA	NEMA		Existing	0.168	0.000	0.168	0.000
16644	Main Street Whitinsville PV	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	0.280	0.000	0.280	0.000
16653	Berlin Biopower	Generator	No	PB	Wood/Wood Waste Solids			Northern New England		NH	NH		Existing	65.380	65.380	65.380	65.380
16659	Ipswich Wind Farm 1	Generator	Yes	WT	Wind			Southeast New England		MA	NEMA		Existing	0.151	0.303	0.151	0.303
16688	Nor1	Generator	No	IC	Distillate Fuel Oil			Rest-of-Pool		CT	CT		Existing	1.789	1.958	1.789	1.789
16737	DFC-ERG Hybrid Fuel Cell (3)	Generator	No	FC	Natural Gas			Rest-of-Pool		CT	CT		Existing	2.500	2.500	2.500	2.500
16738	BFCP Fuel Cell	Generator	No	FC	Natural Gas			Rest-of-Pool		CT	CT		Existing	13.054	13.054	13.054	13.054
16750	Norden #2	Generator	No	IC	Distillate Fuel Oil			Rest-of-Pool		CT	CT		Existing	1.948	1.947	1.947	1.947
16752	Norden #3	Generator	No	IC	Distillate Fuel Oil			Rest-of-Pool		CT	CT		Existing	1.942	1.942	1.942	1.942
17359	Sugar River 2	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.014	0.117	0.014	0.117
35442	Seaman Energy	Generator	Yes	IC	Landfill Gas			Rest-of-Pool		MA	WCMA		Existing	0.285	0.326	0.285	0.326
35485	Fitchburg-FCA-5	Generator	No	IC	Landfill Gas			Rest-of-Pool		MA	WCMA		Existing	3.093	3.694	3.093	3.093
35555	GMCW	Generator	Yes	WT	Wind			Northern New England		VT	VT		Existing	0.814	2.753	0.814	2.753
35594	Spaulding Pond Hydro	Generator	Yes	HDR	Water			Northern New England		NH	NH		Existing	0.024	0.172	0.024	0.172
35656	Rainbow_2	Generator	No	HDP	Water			Rest-of-Pool		CT	CT		Existing	4.100	4.100	4.100	4.100
35657	Shrewsbury Diesels	Generator	No	IC	Distillate Fuel Oil			Rest-of-Pool		MA	WCMA		Existing	13.750	13.650	13.650	13.650
35658	Rainbow_1	Generator	No	HDP	Water			Rest-of-Pool		CT	CT		Existing	4.100	4.100	4.100	4.100
35693	Spruce Mountain Wind	Generator	Yes	WT	Wind			Northern New England		ME	ME		Existing	2.302	6.452	2.302	6.452
35728	Moretown LG	Generator	No	IC	Landfill Gas			Northern New England		VT	VT		Existing	3.017	3.008	3.008	3.008
35979	Kingdom Community Wind	Generator	Yes	WT	Wind			Northern New England		VT	VT		Existing	8.773	20.083	8.773	20.083
37040	KENDALL STEAM	Generator	No	CC	Natural Gas			Southeast New England		MA	NEMA		Existing	27.750	27.750	27.750	27.750
37050	Groton Wind Project	Generator	Yes	WT	Wind			Northern New England		NH	NH		Existing	5.100	10.884	5.100	10.884
37072	Beaver_Ridge_Wind	Generator	Yes	WT	Wind			Northern New England		ME	ME		Existing	0.436	1.187	0.436	1.187
37077	Woronoco Hydro LLC	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.490	1.157	0.490	1.157
37105	Blue Sky West	Generator	Yes	WT	Wind			Northern New England		ME	ME		Existing	42.270	87.300	42.270	87.300
37120	Thundermist Hydropower	Generator	Yes	HDR	Water			Southeast New England		RI	RI		Existing	0.000	0.728	0.000	0.728
38078	NFM Solar Power, LLC	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.507	0.000	0.507	0.000
38089	Footprint Combined Cycle	Generator	No	CC	Natural Gas			Southeast New England		MA	NEMA		Existing	674.000	674.000	674.000	674.000
38114	East Bridgewater Solar Energy Project	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	0.850	0.000	0.850	0.000
38115	Harrington Street PV Project	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	1.430	0.000	1.430	0.000
38115	Harrington Street PV Project	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		New	2.656	0.000	0.000	0.000

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
38173	Saddleback Ridge Wind	Generator	Yes	WT	Wind			Northern New England		ME	ME		Existing	3.750	10.230	3.750	10.230
38178	Southbridge Landfill Gas to Energy 17-18	Generator	No	IC	Landfill Gas			Rest-of-Pool		MA	WCMA		Existing	2.400	2.400	2.400	2.400
38181	Westford Solar	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	1.800	0.000	1.800	0.000
38182	MAT-2 (MATEP Combined Cycle)	Generator	No	GT	Natural Gas			Southeast New England		MA	NEMA		Existing	13.850	13.850	13.850	13.850
38206	Bridgeport Harbor 5	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		Existing	484.300	484.300	484.300	484.300
38249	Silver lake Photovoltaic Facility	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.458	0.000	0.458	0.000
38250	Indian Orchard Photovoltaic Facility	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.595	0.000	0.595	0.000
38252	Indian River Power Supply# LLC	Generator	Yes	HDR	Water			Rest-of-Pool		MA	WCMA		Existing	0.181	0.339	0.181	0.339
38278	Wallingford Unit 6 and Unit 7	Generator	No	GT	Natural Gas			Rest-of-Pool		CT	CT		Existing	90.000	90.000	90.000	90.000
38287	WMA Chester Solar 1	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	1.904	0.000	1.904	0.000
38289	Medway Peaker - SEMARI	Generator	No	GT	Natural Gas			Southeast New England		MA	SEMA		Existing	194.800	194.800	194.800	194.800
38297	CPV_Towantic	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		Existing	750.500	750.500	750.500	750.500
38302	Fisher Road Solar I	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	1.920	0.000	1.920	0.000
38310	Canal 3	Generator	No	GT	Natural Gas			Southeast New England		MA	SEMA		Existing	333.000	333.000	333.000	333.000
38372	Dartmouth Solar	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	1.430	0.000	1.430	0.000
38373	Holliston	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	1.523	0.000	1.523	0.000
38374	Plymouth	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	1.900	0.000	1.900	0.000
38375	Uxbridge	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	1.230	0.000	1.230	0.000
38376	Landcraft	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	1.350	0.000	1.350	0.000
38378	LSRHS	Generator	Yes	PV	Solar			Southeast New England		MA	NEMA		Existing	0.420	0.000	0.420	0.000
38380	Treasure Valley- SE	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	2.070	0.000	2.070	0.000
38381	Belchertown SEd	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.530	0.000	0.530	0.000
38421	Jericho Power	Generator	Yes	WT	Wind			Northern New England		NH	NH		Existing	2.500	3.900	2.500	3.900
38437	Ipswich Wind II	Generator	Yes	WT	Wind			Southeast New England		MA	NEMA		New	0.130	0.377	0.130	0.377
38438	Deerfield Wind Project	Generator	Yes	WT	Wind			Rest-of-Pool		MA	WCMA		Existing	8.100	13.600	8.100	13.600
38440	Cottage St PV	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	1.635	0.000	1.635	0.000
38441	UI RCP BGPT FC	Generator	No	FC	Natural Gas			Rest-of-Pool		CT	CT		Existing	2.520	2.520	2.520	2.520
38442	UI RCP NH FC	Generator	No	FC	Natural Gas			Rest-of-Pool		CT	CT		Existing	2.520	2.520	2.520	2.520
38475	Hoosac Wind Project	Generator	Yes	WT	Wind			Rest-of-Pool		MA	WCMA		Existing	3.942	10.412	3.942	10.412
38480	Hubbardston SE	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	1.295	0.000	1.295	0.000
38481	OSP Phase III	Generator	No	GT	Natural Gas			Southeast New England		RI	RI		New	238.000	238.000	0.000	0.000
38494	24 Boutilier Rd Leicester PV	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.248	0.000	0.248	0.000
38495	Deepwater Wind Block Island	Generator	Yes	WT	Wind			Southeast New England		RI	RI		Existing	6.830	14.100	6.830	14.100
38500	Mass Mid-State Solar	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	7.110	0.000	7.110	0.000
38504	Burrillville Energy Center 3	Generator	No	CC	Natural Gas			Southeast New England		RI	RI		Existing	485.000	485.000	485.000	485.000
38510	City of Gardner - Mill St. Solar	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.392	0.000	0.392	0.000
38527	Grafton WD	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.715	0.000	0.715	0.000
38528	29 Oxford Rd Charlton PV	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.275	0.000	0.275	0.000
38530	Mattapoisett 2	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	0.316	0.000	0.316	0.000
38531	Mattapoisett 1	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	0.316	0.000	0.316	0.000
38532	Leominster- South St.	Generator	Yes	PV	Solar			Southeast New England		MA	NEMA		Existing	1.409	0.000	1.409	0.000
38533	Berlin 1	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.347	0.000	0.347	0.000
38534	Millbury Solar	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	1.638	0.000	1.638	0.000
38538	Groton Road Shirley PV	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.415	0.000	0.415	0.000
38539	40 Auburn Rd Millbury PV	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.248	0.000	0.248	0.000
38543	Carpenter Hill Rd Charlton PV	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.368	0.000	0.368	0.000
38544	17 Kelly Rd Sturbridge PV	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.372	0.000	0.372	0.000
38545	90 River Rd Sturbridge PV	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.372	0.000	0.372	0.000
38548	Fall River- Commerce	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	0.535	0.000	0.535	0.000
38551	Fasll River - Innovation	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	1.619	0.000	1.619	0.000
38553	Antrim Wind Resource	Generator	Yes	WT	Wind			Northern New England		NH	NH		Existing	5.000	9.900	5.000	9.900
38555	Berlin 2	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.347	0.000	0.347	0.000
38556	Berlin 3	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.347	0.000	0.347	0.000
38558	Fall River- Uxbridge	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	1.474	0.000	1.474	0.000
38559	Berlin 4	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.347	0.000	0.347	0.000
38560	Grafton	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.925	0.000	0.925	0.000
38561	True North	Generator	Yes	PV	Solar			Southeast New England		MA	NEMA		Existing	2.368	0.000	2.368	0.000
38562	Franklin 1	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	1.499	0.000	1.499	0.000
38565	Franklin 2	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	2.121	0.000	2.121	0.000
38567	Billerica	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	2.307	0.000	2.307	0.000
38574	Route 57	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.739	0.000	0.739	0.000
38575	Agawam Solar	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.702	0.000	0.702	0.000
38576	Whately	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.617	0.000	0.617	0.000
38577	Holiday Hill Community Wind	Generator	Yes	WT	Wind			Rest-of-Pool		MA	WCMA		Existing	0.784	1.200	0.784	1.200
38579	Rehoboth	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	1.093	0.000	1.093	0.000

Asset ID	Name	Type	Intermittent	Prime Mover Code	Generating Fuel Type	DR Type	Active/ Passive	Capacity Zone Name	Interface Name	State	Load Zone	Dispatch Zone Name	Status	Summer Qual	Winter Qual	Summer Cleared	Winter Cleared
38580	Amesbury	Generator	Yes	PV	Solar			Southeast New England		MA	NEMA		Existing	2.312	0.000	2.312	0.000
38581	Tyngsborough	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	1.283	0.000	1.283	0.000
38582	Norton MA	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	0.675	0.000	0.675	0.000
38583	Agawam II	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		Existing	0.804	0.000	0.804	0.000
38584	Bridgewater	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		Existing	0.462	0.000	0.462	0.000
38655	Barrett Distribution - Franklin Solar	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		New	0.230	0.000	0.230	0.000
38663	Killingly Energy Center	Generator	No	CC	Natural Gas			Rest-of-Pool		CT	CT		New	531.000	591.000	0.000	0.000
38669	Future Gen Wind	Generator	Yes	WT	Wind			Southeast New England		MA	SEMA		New	2.700	2.800	2.700	2.800
38681	Boltonville Hydro	Generator	Yes	HDR	Water			Northern New England		VT	VT		New	0.425	0.632	0.000	0.000
38692	MMWEC Simple Cycle Gas Turbine	Generator	No	GT	Natural Gas			Southeast New England		MA	NEMA		New	57.967	69.257	0.000	0.000
38695	NEHC - Hanover Pond Hydro	Generator	Yes	HDR	Water			Rest-of-Pool		CT	CT		New	0.066	0.129	0.066	0.129
38696	Blossom Rd 1 Fall River PV	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		New	0.414	0.000	0.414	0.000
38698	Blossom Rd 2 Fall River PV	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		New	0.417	0.000	0.417	0.000
38699	Groveland St Abington PV	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		New	0.390	0.000	0.390	0.000
38700	Stafford St Leicester PV 2	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		New	0.228	0.000	0.228	0.000
38701	Onset East	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		New	0.520	0.000	0.520	0.000
38702	Onset West	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		New	0.520	0.000	0.520	0.000
38704	Richardson Ave Attleboro PV 2	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		New	0.418	0.000	0.418	0.000
38706	Old Upton Rd Grafton PV 2	Generator	Yes	PV	Solar			Rest-of-Pool		MA	WCMA		New	0.228	0.000	0.228	0.000
38708	Groton School Rd Ayer PV 2	Generator	Yes	PV	Solar			Southeast New England		MA	NEMA		New	0.359	0.000	0.359	0.000
38709	Frank Mossberg Dr Atteleboro PV	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		New	0.244	0.000	0.244	0.000
38725	Bow Street Hydro	Generator	Yes	HDR	Water			Northern New England		NH	NH		New	0.132	0.154	0.000	0.000
38738	Canton Mountain Wind Project	Generator	Yes	WT	Wind			Northern New England		ME	ME		New	3.600	7.200	3.600	7.200
38757	WOODBRIDGE FUEL CELL	Generator	No	FC	Natural Gas			Rest-of-Pool		CT	CT		New	2.200	2.100	2.100	2.100
38760	Norwich WWT	Generator	No	IC	Distillate Fuel Oil			Rest-of-Pool		CT	CT		New	2.000	2.000	2.000	2.000
38791	Branch Solar	Generator	Yes	PV	Solar			Southeast New England		MA	SEMA		New	0.633	0.000	0.633	0.000
38814	Burrillville Energy Center 4	Generator	No	CC	Natural Gas			Southeast New England		RI	RI		New	512.000	582.000	0.000	0.000
12450	NYPA - CMR	Import						Rest-of-Pool	New York AC Ties				Existing	68.800	68.800	68.800	68.800
12451	NYPA - VT	Import						Rest-of-Pool	New York AC Ties				Existing	14.000	14.000	14.000	14.000
12452	VJO - Highgate	Import						Rest-of-Pool	Hydro-Quebec Highgate				Existing	6.000	0.000	0.000	0.000
38629	HQ_HG_Yearly_20-21	Import						Northern New England	Hydro-Quebec Highgate				New	55.000	55.000	55.000	55.000
38631	HQ_NB_Yearly_20-21	Import						Northern New England	New Brunswick				New	200.000	200.000	100.000	100.000
38635	HQ_NY_Yearly_20-21	Import						Rest-of-Pool	New York AC Ties				New	300.000	300.000	300.000	300.000
38637	HQ_PII_Yearly_20-21	Import						Rest-of-Pool	Phase I/II HQ Excess				New	441.000	441.000	441.000	441.000
38664	Rensselaer Cogen 20-21	Import						Rest-of-Pool	New York AC Ties				New	77.400	82.700	77.400	77.400
38665	Roseton 1 20-21	Import						Rest-of-Pool	New York AC Ties				New	610.500	612.200	0.000	0.000
38666	Roseton 2 20-21	Import						Rest-of-Pool	New York AC Ties				New	596.200	602.500	0.000	0.000
38667	RFF 20-21	Import						Northern New England	New Brunswick				New	31.000	31.000	31.000	31.000
38668	RAH 20-21	Import						Northern New England	New Brunswick				New	32.000	32.000	0.000	0.000
38672	Seneca Grandfathered FCA11	Import						Rest-of-Pool	New York AC Ties				New	45.000	45.000	45.000	45.000
38673	Seneca Non-Grandfathered FCA11	Import						Rest-of-Pool	New York AC Ties				New	6.000	6.000	6.000	6.000
38679	SITHE___MASSENA 2020-21	Import						Rest-of-Pool	New York AC Ties				New	80.700	92.000	0.000	0.000
38683	BROOME_2_LFGE 2020-21	Import						Rest-of-Pool	New York AC Ties				New	1.800	1.800	1.800	1.800
38690	Control Area Backed 2020-2021	Import						Northern New England	New Brunswick				New	170.000	170.000	69.000	69.000
38726	Bayside Power	Import						Northern New England	New Brunswick				New	250.000	0.000	0.000	0.000
38729	Chaffee FCA11	Import						Rest-of-Pool	New York AC Ties				New	6.100	6.100	6.100	6.100
38730	High Acres I FCA11	Import						Rest-of-Pool	New York AC Ties				New	3.200	3.200	3.200	3.200
38731	High Acres II FCA11	Import						Rest-of-Pool	New York AC Ties				New	6.400	6.400	6.400	6.400
38732	Madison County FCA11	Import						Rest-of-Pool	New York AC Ties				New	1.4	1.4	1.400	1.400
38733	Mill Seat FCA11	Import						Rest-of-Pool	New York AC Ties				New	6.100	6.100	6.100	6.100
38734	Oneida Herkimer FCA11	Import						Rest-of-Pool	New York AC Ties				New	3.200	3.200	3.200	3.200
38737	Erie Boulevard Hydro Import 2020-21	Import						Rest-of-Pool	New York AC Ties				New	364.000	364.000	0.000	0.000
38741	Carr Street Generating station Import 2020-21	Import						Rest-of-Pool	New York AC Ties				New	83.000	83.000	0.000	0.000

(1) Most of the data from this table can be found in the 2020-2021 Forward Capacity Auction Obligations spreadsheet. However, the Prime Mover codes are from CELT Sec. 2.1 for existing units, the Queue for those future resources with Interconnection Agreements, and the Forward Capacity Tracking System (FCTS) for the remaining resources.

https://www.iso-ne.com/isoexpress/web/reports/auctions/-/tree/fca-results

5.1 Network Resource Capability (NRC) & Capacity Network Resource Capability (CNRC) List[1][2]
- Effective June 1, 2017, as of March 18, 2017

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50^{0}F)	Winter (0^{0}F)	Summer (90^{0}F)	Winter (20^{0}F)					
253	TURNKEY LANDFILL	253	TURNKEY LANDFILL	3.306	3.306	3.306	3.306	Historic Capability	NH	017	NH	PSNH
321	MANCHESTER 10 10A CC	321	MANCHESTER 10/10A CC	170.000	170.000	157.000	164.000	IA	RI	007	RI	DEM
322	MANCHESTER 11 11A CC	322	MANCHESTER 11/11A CC	170.000	170.000	157.000	164.000	IA	RI	007	RI	DEM
323	MANCHESTER 9 9A CC	323	MANCHESTER 9/9A CC	170.000	170.000	154.000	164.000	IA	RI	007	RI	DEM
324	CDECCA	324	CDECCA	64.000	64.000	56.000	64.000	IA	CT	003	CT	PPH
326	ALTRESCO	326	ALTRESCO	160.000	192.500	151.400	183.401	IA	MA	003	WMA	PPH
327	AMOSKEAG	327	AMOSKEAG	17.500	17.500	17.500	17.500	Historic Capability	NH	011	NH	PSNH
328	GULF ISLAND COMPOSITE Incremental	328	GULF ISLAND COMPOSITE	38.915	38.915	33.440	33.440	IA	ME	001	ME	FPLEMH
329	ASCUTNEY GT	329	ASCUTNEY GT	11.460	14.700	10.300	14.700	Historic Capability	VT	027	VT	GMP
330	AYERS ISLAND	330	AYERS ISLAND	9.080	9.080	9.080	9.080	Historic Capability	NH	009	NH	PSNH
331	AZISCOHOS HYDRO	331	AZISCOHOS HYDRO	6.800	6.800	6.800	6.800	IA	ME	019	ME	BEMLP
335	BELLOWS FALLS	335	BELLOWS FALLS	49.000	49.000	49.000	49.000	IA	VT	025	VT	TCHN
336	BERLIN 1 GT	336	BERLIN 1 GT	41.200	58.000	41.200	58.000	Historic Capability	VT	023	VT	GMP
337	BETHLEHEM	337	BETHLEHEM	15.750	15.700	15.750	15.700	Historic Capability	NH	007	NH	SUEZ
340	BRIDGEPORT HARBOR 3	340	BRIDGEPORT HARBOR 3	385.000	385.000	383.426	384.984	IA	CT	001	SWCT	PSEG
341	BRIDGEPORT HARBOR 4	341	BRIDGEPORT HARBOR 4	18.000	22.000	18.000	22.000	IA	CT	001	SWCT	PSEG
345	MEAD	345	CATALYST CO-GEN	75.000	75.000	0.000	0.000	Historic Capability	ME	017	ME	APNM
346	BOLTON FALLS	346	BOLTON FALLS	7.800	7.800	7.800	7.800	Historic Capability	VT	023	VT	GMP
348	BOOT MILLS	348	BOOT MILLS	18.000	18.000	18.000	18.000	IA	MA	017	CMA/NEMA	NSTAR
349	WHEELABRATOR BRIDGEPORT, L.P.	349	WHEELABRATOR BRIDGEPORT, L.P.	59.650	60.500	59.650	60.500	Historic Capability	CT	001	SWCT	WB
350	BRAYTON PT 1	350	BRAYTON PT 1	0.000	0.000	0.000	0.000	IA	MA	005	RI	BPE
351	BRAYTON PT 2	351	BRAYTON PT 2	0.000	0.000	0.000	0.000	IA	MA	005	RI	BPE
352	BRAYTON PT 3	352	BRAYTON PT 3	0.000	0.000	0.000	0.000	IA	MA	005	RI	BPE
353	BRAYTON PT 4	353	BRAYTON PT 4	0.000	0.000	0.000	0.000	IA	MA	005	RI	BPE
354	Brayton Diesels 1-4 Incremental	354	BRAYTON DIESELS 1-4	0.000	0.000	0.000	0.000	IA	MA	005	RI	BPE
355	BRANFORD 10	355	BRANFORD 10	19.019	21.284	16.174	21.284	Historic Capability	CT	009	SWCT	NRGPM
356	BRISTOL REFUSE	356	BRISTOL REFUSE	13.517	13.578	13.517	13.578	Historic Capability	CT	003	CT	CEM
357	BRIDGEWATER	357	BRIDGEWATER	15.750	15.701	15.750	15.701	Historic Capability	NH	009	NH	BPCLP
358	BRUNSWICK	358	BRUNSWICK	20.200	20.200	20.200	20.200	IA	ME	005	ME	FPLEMH
359	J. COCKWELL 1	359	J. COCKWELL 1	298.500	298.500	294.500	294.500	IA	MA	003	WMA	BSP
360	J. COCKWELL 2	360	J. COCKWELL 2	298.500	298.500	294.500	294.500	IA	MA	003	WMA	BSP
362	BULLS BRIDGE	362	BULLS BRIDGE	8.400	8.400	8.400	8.400	IA	CT	005	SWCT	NEL1
363	BURLINGTON GT	363	BURLINGTON GT	21.440	25.000	20.378	25.000	Historic Capability	VT	007	VT	BED
365	CANAL 1	365	CANAL 1	573.000	573.000	573.000	573.000	Historic Capability	MA	001	SEMA	MET
366	CANAL 2	366	CANAL 2	576.370	586.000	576.370	586.000	Historic Capability	MA	001	SEMA	MET
367	CAPE GT 4	367	CAPE GT 4	13.750	20.550	13.750	20.550	IA	ME	005	SME	FPLP
368	CAPE GT 5	368	CAPE GT 5	16.600	20.750	16.600	20.750	IA	ME	005	SME	FPLP
369	CATARACT EAST	369	CATARACT EAST	8.900	8.900	8.900	8.900	IA	ME	031	SME	FPLEMH
370	COS COB 10	370	COS COB 10	22.084	23.000	19.497	23.000	IA	CT	001	NOR	NRGPM
371	COS COB 11	371	COS COB 11	21.875	23.000	21.841	23.000	IA	CT	001	NOR	NRGPM
372	COS COB 12	372	COS COB 12	22.143	23.000	18.660	23.000	IA	CT	001	NOR	NRGPM
375	CLEARY 9 9A CC	375	CLEARY 9/9A CC	106.875	110.000	105.000	110.000	Historic Capability	MA	005	SEMA	TMLP
376	CLEARY 8	376	CLEARY 8	26.000	26.000	26.000	26.000	Historic Capability	MA	005	SEMA	TMLP
379	COBBLE MOUNTAIN	379	COBBLE MOUNTAIN	33.990	33.960	33.990	33.960	Historic Capability	MA	013	WMA	HGE
380	COMERFORD	47366	COMERFORD 1	169.300	170.300	166.135	167.116	IA	NH	009	NH	TCHN
		47367	COMERFORD 2									
		47368	COMERFORD 3									
		47369	COMERFORD 4									
382	MERRIMACK CT1	382	MERRIMACK CT1	17.800	22.500	17.800	22.500	IA	NH	013	NH	PSNH
383	MERRIMACK CT2	383	MERRIMACK CT2	17.600	23.500	17.600	23.500	IA	NH	013	NH	PSNH
388	DARTMOUTH POWER	388	DARTMOUTH POWER	62.900	68.400	62.900	68.400	PPA	MA	005	SEMA	EPLU-I

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
389	DERBY DAM	389	DERBY DAM	7.050	7.050	7.050	7.050	Historic Capability	CT	001	SWCT	CLP
392	DEXTER	42375	DEXTER 1	47.500	47.500	45.000	46.525	IA	CT	003	CT	AESR
		42376	DEXTER 2									
393	DEERFIELD 5	393	DEERFIELD 5	14.000	14.000	14.000	14.000	IA	MA	011	WMA	TCHN
395	DOREEN	395	DOREEN	19.400	21.100	16.600	21.100	IA	MA	003	WMA	NAEA-EM
396	DEVON 10	396	DEVON 10	18.000	19.208	17.200	19.208	PPA	CT	009	SWCT	NRGPM
397	DEVON 11	397	DEVON 11	33.120	42.820	33.120	42.820	PPA	CT	009	SWCT	NRGPM
398	DEVON 12	398	DEVON 12	33.120	42.820	33.120	42.820	PPA	CT	009	SWCT	NRGPM
399	DEVON 13	399	DEVON 13	33.120	42.820	33.120	42.820	PPA	CT	009	SWCT	NRGPM
400	DEVON 14	400	DEVON 14	33.120	42.820	33.120	42.820	PPA	CT	009	SWCT	NRGPM
401	EASTMAN FALLS	401	EASTMAN FALLS	6.470	6.470	6.470	6.470	Historic Capability	NH	013	NH	PSNH
405	ELLSWORTH HYDRO	405	ELLSWORTH HYDRO	9.210	9.050	9.210	9.050	Historic Capability	ME	009	BHE	BBHP
407	EASTPORT DIESELS 1-3	407	EASTPORT DIESEL #3	4.050	4.100	4.050	4.100	Historic Capability	ME	029	BHE	NBPGC
410	ESSEX 19 HYDRO	410	ESSEX 19 HYDRO	7.800	7.800	7.800	7.800	Historic Capability	VT	007	VT	GMP
412	FALLS VILLAGE	412	FALLS VILLAGE	9.760	11.000	9.760	11.000	IA	CT	005	CT	NEL1
413	FIFE BROOK	413	FIFE BROOK	9.900	9.900	9.900	9.900	Historic Capability	MA	003	WMA	BSP
417	FRAMINGHAM JET 1	417	FRAMINGHAM JET 1	14.100	18.100	14.100	18.100	Historic Capability	MA	017	BOSTON	EXGC
418	FRAMINGHAM JET 2	418	FRAMINGHAM JET 2	14.100	18.100	14.100	18.100	Historic Capability	MA	017	BOSTON	EXGC
419	FRAMINGHAM JET 3	419	FRAMINGHAM JET 3	14.100	18.100	14.100	18.100	Historic Capability	MA	017	BOSTON	EXGC
420	FRANKLIN DRIVE 10	420	FRANKLIN DRIVE 10	18.596	20.952	17.200	20.952	Historic Capability	CT	005	CT	NRGPM
421	FRONT STREET DIESELS 1-3	421	FRONT STREET DIESELS 1-3	8.300	8.250	8.300	8.250	Historic Capability	MA	013	WMA	CMLP
424	GREAT LAKES - MILLINOCKET	424	GREAT LAKES - MILLINOCKET	126.000	126.000	126.000	126.000	PPA	ME	019	BHE	BEMLP
426	GORGE 1 DIESEL	426	GORGE 1 DIESEL	10.800	16.110	10.800	16.110	Historic Capability	VT	007	VT	GMP
427	GORHAM	427	GORHAM	2.050	2.050	2.050	2.050	Historic Capability	NH	007	NH	PSNH
432	HARRIS 1	432	HARRIS 1	17.000	17.000	17.000	17.000	IA	ME	025	ME	FPLEMH
433	HARRIS 2	433	HARRIS 2	35.000	35.500	35.000	35.500	IA	ME	025	ME	FPLEMH
434	HARRIS 3	434	HARRIS 3	34.000	34.500	34.000	34.500	IA	ME	025	ME	FPLEMH
435	HARRIMAN	435	HARRIMAN	41.135	39.000	41.135	39.000	Historic Capability	VT	025	WMA	TCHN
436	HEMPHILL 1	436	HEMPHILL 1	17.500	17.500	14.137	14.450	IA	NH	019	NH	SPRING
440	HIRAM	440	HIRAM	11.600	11.600	11.600	11.600	IA	ME	005	SME	FPLEMH
445	COVANTA WEST ENFIELD	445	COVANTA WEST ENFIELD	24.500	24.500	24.500	24.500	PPA	ME	019	BHE	IESI-I
446	COVANTA JONESBORO	446	COVANTA JONESBORO	24.500	24.500	24.500	24.500	PPA	ME	029	BHE	IESI-I
448	IPSWICH DIESELS	448	IPSWICH DIESELS	16.000	13.277	16.000	13.277	Historic Capability	MA	009	BOSTON	IMLD
449	JACKMAN	449	JACKMAN	3.600	19.750	3.600	19.750	Historic Capability	NH	011	NH	PSNH
452	KENDALL JET 1	452	KENDALL JET 1	20.858	24.428	18.000	23.000	IA	MA	017	BOSTON	KENDALL
457	LAWRENCE HYDRO	457	LAWRENCE HYDRO	9.400	14.100	9.400	14.100	Historic Capability	MA	009	CMA/NEMA	CHIPM
460	LOCKWOOD	460	LOCKWOOD	7.500	7.500	7.500	7.500	IA	ME	011	ME	BEMLP
462	LISBON RESOURCE RECOVERY	462	LISBON RESOURCE RECOVERY	13.500	13.500	13.500	13.500	IA	CT	011	CT	CLP
463	AEI LIVERMORE	463	REENERGY LIVERMORE FALLS	35.300	35.630	35.300	35.630	Historic Capability	ME	001	ME	REESTR
464	LOST NATION	464	LOST NATION	16.652	19.300	14.100	19.300	Historic Capability	NH	007	NH	PSNH
465	DEERFIELD 2 LWR DRFIELD	465	DEERFIELD 2/LWR DRFIELD	19.500	19.500	19.500	19.500	Historic Capability	MA	011	WMA	TCHN
466	L STREET JET	466	L STREET JET	19.400	22.500	16.600	22.250	Historic Capability	MA	025	BOSTON	EXGC
467	MARBLEHEAD DIESELS	467	MARBLEHEAD DIESELS	5.000	5.000	5.000	5.000	Historic Capability	MA	009	BOSTON	MMLD
468	MARSHFIELD 6 HYDRO	468	MARSHFIELD 6 HYDRO	5.000	5.000	5.000	5.000	Historic Capability	VT	023	NH	GMP
472	M STREET JET	472	M STREET JET	47.000	67.200	47.000	67.200	PPA	MA	025	BOSTON	MBTA
473	MCINDOES	473	MCINDOES	13.000	13.000	13.000	13.000	Historic Capability	NH	009	NH	TCHN
474	J C MCNEIL	474	J C MCNEIL	52.000	54.000	52.000	54.000	Historic Capability	VT	007	VT	BED
478	MIDDLETOWN 10	478	MIDDLETOWN 10	20.423	22.100	17.200	22.100	Historic Capability	CT	007	CT	NRGPM
480	MIDDLETOWN 2	480	MIDDLETOWN 2	117.000	120.000	117.000	120.000	Historic Capability	CT	007	CT	NRGPM
481	MIDDLETOWN 3	481	MIDDLETOWN 3	236.000	245.000	236.000	245.000	Historic Capability	CT	007	CT	NRGPM
482	MIDDLETOWN 4	482	MIDDLETOWN 4	402.000	402.000	402.000	402.000	Historic Capability	CT	007	CT	NRGPM
484	MILLSTONE POINT 2	484	MILLSTONE POINT 2	897.500	905.700	897.500	905.700	IA	CT	007	CT	DEM
485	MILLSTONE POINT 3	485	MILLSTONE POINT 3	1225.000	1245.000	1225.000	1245.000	IA	CT	011	CT	DEM
486	MILFORD POWER	486	MILFORD POWER	149.000	171.000	149.000	170.730	IA	MA	027	RI	DMT1
487	MILLER HYDRO	487	WORUMBO HYDRO	19.400	19.400	19.400	19.400	IA	ME	001	ME	ENE
489	MERRIMACK 1	489	MERRIMACK 1	113.500	122.730	112.500	122.730	IA	NH	013	NH	PSNH

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW) Summer (50°F)	NRC (MW) Winter (0°F)	CNRC (MW) Summer (90°F)	CNRC (MW) Winter (20°F)	Instrument Used to Identify Capability(4)	State	County	RSP Area	Lead Participant
490	MERRIMACK 2	490	MERRIMACK 2	340.000	353.500	335.487	353.500	IA	NH	013	NH	PSNH
492	MONTVILLE 10 and 11	492	MONTVILLE 10 AND 11	5.500	5.500	5.500	5.500	Historic Capability	CT	011	CT	NRGPM
493	MONTVILLE 5	493	MONTVILLE 5	81.000	82.000	81.000	82.000	Historic Capability	CT	011	CT	NRGPM
494	MONTVILLE 6	494	MONTVILLE 6	410.000	410.000	410.000	410.000	Historic Capability	CT	011	CT	NRGPM
495	MONTY	495	MONTY	28.000	28.000	28.000	28.000	IA	ME	025	ME	FPLEMH
496	MOORE	47370	MOORE 1	191.300	191.300	191.300	191.300	IA	NH	009	NH	TCHN
		47371	MOORE 2									
		47372	MOORE 3									
		47373	MOORE 4									
497	MASS POWER	497	MASS POWER	256.100	279.900	245.259	276.000	IA	MA	013	WMA	DMT1
498	MT TOM	498	MT TOM	146.000	147.000	146.000	147.000	IA	MA	013	WMA	SUEZ
502	MYSTIC 7	502	MYSTIC 7	592.000	592.000	592.000	592.000	Historic Capability	MA	025	BOSTON	EXGC
503	MYSTIC JET	503	MYSTIC JET	10.960	13.800	9.750	13.800	Historic Capability	MA	025	BOSTON	EXGC
507	NEA BELLINGHAM	507	NEA BELLINGHAM	313.307	340.241	277.621	340.241	Historic Capability	MA	021	RI	FPLP
508	NEWINGTON 1	508	NEWINGTON 1	407.500	420.830	407.500	420.830	Historic Capability	NH	015	NH	PSNH
513	NEW HAVEN HARBOR	513	NEW HAVEN HARBOR	466.000	466.000	466.000	466.000	IA	CT	009	CT	PSEG
515	NORWICH JET	515	NORWICH JET	17.820	19.160	15.255	18.800	Historic Capability	CT	011	CT	CMEEC
527	OGDEN-MARTIN 1	527	OGDEN-MARTIN 1	41.680	42.870	41.680	42.870	Historic Capability	MA	009	BOSTON	CHA
528	OCEAN ST PWR GT1 GT2 ST1	528	OCEAN ST PWR GT1/GT2/ST1	297.187	318.342	272.342	318.342	Historic Capability	RI	007	RI	TCPM
529	OCEAN ST PWR GT3 GT4 ST2	529	OCEAN ST PWR GT3/GT4/ST2	297.609	322.815	274.815	322.815	Historic Capability	RI	007	RI	TCPM
531	PAWTUCKET POWER	531	PAWTUCKET POWER	62.000	67.000	62.000	67.000	IA	RI	007	RI	PPH
532	PEJEPSCOT	532	PEJEPSCOT	10.210	13.550	10.210	13.550	Historic Capability	ME	023	ME	BBHP
536	PERC-ORRINGTON 1	536	PERC-ORRINGTON 1	21.760	21.930	21.760	21.930	Historic Capability	ME	019	BHE	NBPGC
537	PILGRIM NUCLEAR POWER STATION	537	PILGRIM NUCLEAR POWER STATION	701.500	708.500	701.500	708.500	PPA	MA	023	SEMA	ENPM
538	PINETREE POWER	538	PINETREE POWER	17.550	17.490	17.550	17.490	Historic Capability	MA	027	WMA	SUEZ
539	PONTOOK HYDRO	539	PONTOOK HYDRO	9.600	10.160	9.600	10.160	IA	NH	007	NH	BEMLP
540	POTTER 2 CC	540	POTTER 2 CC	84.474	97.500	79.500	97.500	Historic Capability	MA	021	SEMA	BELD
541	PROCTOR	541	PROCTOR	9.841	9.841	6.650	6.650	IA	VT	021	VT	GMP
542	ECO MAINE	542	ECO MAINE	13.705	13.705	13.705	13.705	Historic Capability	ME	005	SME	EXGC
546	RESCO SAUGUS	546	RESCO SAUGUS	32.790	31.000	32.790	31.000	Historic Capability	MA	009	BOSTON	WNE
547	WHEELABRATOR NORTH ANDOVER	547	WHEELABRATOR NORTH ANDOVER	40.000	40.000	40.000	40.000	IA	MA	009	BOSTON	WNE
549	RUTLAND 5 GT	549	RUTLAND 5 GT	12.397	15.547	10.400	14.800	Historic Capability	VT	021	VT	GMP
555	SEABROOK	555	SEABROOK	1257.275	1257.275	1257.275	1257.275	IA	NH	015	NH	FPLP
556	SCHILLER 4	556	SCHILLER 4	47.500	48.000	47.500	48.000	Historic Capability	NH	015	NH	PSNH
557	SCHILLER 5	557	SCHILLER 5	49.600	49.600	49.600	49.600	Historic Capability	NH	015	NH	PSNH
558	SCHILLER 6	558	SCHILLER 6	48.000	49.000	48.000	49.000	Historic Capability	NH	015	NH	PSNH
559	SCHILLER CT 1	559	SCHILLER CT 1	18.132	22.000	17.621	22.000	Historic Capability	NH	015	NH	PSNH
561	SEARSBURG	561	SEARSBURG	4.960	4.960	4.960	4.960	Historic Capability	VT	003	WMA	TCHN
562	SECREC-PRESTON	562	SECREC-PRESTON	16.449	17.070	16.449	17.070	Historic Capability	CT	011	CT	CEM
563	SEMASS 1	563	SEMASS 1	46.955	52.960	46.955	52.690	Historic Capability	MA	023	SEMA	NSTAR
564	SEMASS 2	564	SEMASS 2	22.500	22.500	22.500	22.500	PPA	MA	023	SEMA	NSTAR
565	SHELDON SPRINGS	565	SHELDON SPRINGS	14.832	26.380	14.832	26.380	Historic Capability	VT	011	VT	VELCO
566	SHEPAUG	566	SHEPAUG	42.950	43.400	42.950	43.400	IA	CT	009	SWCT	NEL1
567	SHERMAN	567	SHERMAN	6.500	6.500	6.500	6.500	IA	MA	015	WMA	TCHN
569	SKELTON	569	SKELTON	22.080	22.080	21.600	21.600	IA	ME	031	SME	FPLEMH
570	SMITH	570	SMITH	17.600	16.669	17.600	16.669	Historic Capability	NH	007	NH	PSNH
572	SO. MEADOW 11	572	SO. MEADOW 11	43.121	49.000	38.800	49.000	Historic Capability	CT	003	CT	FPLP
573	SO. MEADOW 12	573	SO. MEADOW 12	45.200	49.000	39.000	49.000	Historic Capability	CT	003	CT	FPLP
574	SO. MEADOW 13	574	SO. MEADOW 13	44.117	49.917	39.000	48.600	Historic Capability	CT	003	CT	FPLP
575	SO. MEADOW 14	575	SO. MEADOW 14	42.546	49.000	39.000	49.000	Historic Capability	CT	003	CT	FPLP
580	SO. MEADOW 5	580	SO. MEADOW 5	29.700	31.240	29.700	31.240	Historic Capability	CT	003	CT	FPLP
581	SO. MEADOW 6	581	SO. MEADOW 6	29.700	31.250	29.700	31.250	Historic Capability	CT	003	CT	FPLP
583	STONY BROOK 2A	583	STONY BROOK 2A	79.000	90.000	67.000	87.000	PPA	MA	013	WMA	MMWEC
584	STONY BROOK 2B	584	STONY BROOK 2B	77.000	90.000	65.000	85.000	PPA	MA	013	WMA	MMWEC
587	STEVENSON	587	STEVENSON	28.900	28.900	28.900	28.900	IA	CT	001	SWCT	NEL1
590	BORALEX STRATTON ENERGY	590	REENERGY STRATTON	46.520	47.510	46.520	47.510	Historic Capability	ME	007	ME	REESTR

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW) Summer (50°F)	NRC (MW) Winter (0°F)	CNRC (MW) Summer (90°F)	CNRC (MW) Winter (20°F)	Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
591	S.D. WARREN-WESTBROOK	591	S.D. WARREN-WESTBROOK	43.070	49.103	43.070	49.103	Historic Capability	ME	005	SME	FPLP
592	TAMWORTH	592	TAMWORTH	21.145	21.143	21.145	21.143	IA	NH	003	NH	SUEZ
595	TORRINGTON TERMINAL 10	595	TORRINGTON TERMINAL 10	18.817	21.800	17.200	21.800	Historic Capability	CT	005	CT	NRGPM
596	TUNNEL 10	596	TUNNEL 10	20.800	22.100	17.102	22.100	IA	CT	011	CT	NEL1
598	VERGENNES 5 and 6 DIESELS	598	VERGENNES 5 AND 6 DIESELS	4.200	4.240	4.200	4.240	Historic Capability	VT	001	VT	GMP
599	VERNON	599	VERNON	32.000	32.000	32.000	32.000	IA	VT	025	WMA	TCHN
612	WATERS RIVER JET 1	612	WATERS RIVER JET 1	19.550	22.437	16.437	22.437	Historic Capability	MA	009	BOSTON	MMWEC
613	WATERS RIVER JET 2	613	WATERS RIVER JET 2	39.400	45.800	31.750	47.050	PPA	MA	009	BOSTON	MMWEC
614	WATERBURY 22	614	WATERBURY 22	5.000	5.000	5.000	5.000	Historic Capability	VT	023	VT	GMP
616	WEST ENFIELD	616	WEST ENFIELD	11.470	19.100	11.470	19.100	Historic Capability	ME	019	BHE	NBPGC
617	WESTON	617	WESTON	14.810	14.810	13.200	13.200	IA	ME	017	ME	FPLEMH
618	DG WHITEFIELD, LLC	618	DG WHITEFIELD, LLC	18.000	18.200	18.000	18.200	Historic Capability	NH	007	NH	SPRING
619	WHITE LAKE JET	619	WHITE LAKE JET	20.070	23.165	18.100	23.165	Historic Capability	NH	003	NH	PSNH
620	WILDER	620	WILDER	42.920	43.880	42.920	43.880	Historic Capability	VT	027	VT	TCHN
621	WILLIAMS	621	WILLIAMS	14.900	14.900	14.900	14.900	IA	ME	025	ME	FPLEMH
622	WINOOSKI 1	622	WINOOSKI 1	7.500	7.500	7.500	7.500	PPA	VT	007	VT	BED
623	WALLINGFORD REFUSE	623	COVANTA PROJECTS WALLINGFORD	8.005	7.892	8.005	7.892	Historic Capability	CT	009	SWCT	CPW
624	WMI MILLBURY 1	624	WMI MILLBURY 1	40.940	40.940	40.940	40.940	Historic Capability	MA	027	CMA/NEMA	NEP
625	WEST MEDWAY JET 1	625	WEST MEDWAY JET 1	57.600	72.900	57.600	72.900	Historic Capability	MA	021	BOSTON	EXGC
626	WEST MEDWAY JET 2	626	WEST MEDWAY JET 2	57.600	72.900	57.600	72.900	Historic Capability	MA	021	BOSTON	EXGC
627	WEST MEDWAY JET 3	627	WEST MEDWAY JET 3	57.500	72.800	57.500	72.800	Historic Capability	MA	021	RI	EXGC
628	WOODLAND ROAD	628	WOODLAND ROAD	19.582	21.000	16.700	21.000	IA	MA	003	WMA	NAEA-EM
630	WEST SPRINGFIELD 10	630	WEST SPRINGFIELD 10	20.250	22.000	17.200	22.000	IA	MA	013	WMA	NAEA-EM
633	WEST SPRINGFIELD 3	633	WEST SPRINGFIELD 3	107.000	107.000	107.000	107.000	IA	MA	013	WMA	NAEA-EM
636	WYMAN HYDRO 1	636	WYMAN HYDRO 1	30.000	30.000	28.500	28.500	IA	ME	025	ME	FPLEMH
637	WYMAN HYDRO 2	637	WYMAN HYDRO 2	29.900	29.900	29.900	29.900	IA	ME	025	ME	FPLEMH
638	WYMAN HYDRO 3	638	WYMAN HYDRO 3	30.000	30.000	26.700	26.990	IA	ME	025	ME	FPLEMH
639	YARMOUTH 1	639	YARMOUTH 1	53.500	53.500	53.500	53.500	IA	ME	005	SME	FPLP
640	YARMOUTH 2	640	YARMOUTH 2	53.500	53.500	53.500	53.500	IA	ME	005	SME	FPLP
641	YARMOUTH 3	641	YARMOUTH 3	116.000	119.000	116.000	119.000	IA	ME	005	SME	FPLP
642	YARMOUTH 4	642	YARMOUTH 4	614.500	620.000	614.500	620.000	IA	ME	005	SME	FPLP
715	ROCHESTER LANDFILL	715	ROCHESTER LANDFILL	4.980	4.980	4.980	4.980	Historic Capability	NH	017	NH	WMRE
737	SIMPSON G LOAD REDUCER	737	SIMPSON G LOAD REDUCER	3.840	4.850	3.840	4.850	Historic Capability	VT	009	NH	GMP
739	ROCKY RIVER	739	ROCKY RIVER	29.350	30.400	29.350	30.400	IA	CT	009	SWCT	NEL1
754	BAR MILLS	754	BAR MILLS	4.000	4.000	4.000	4.000	IA	ME	031	SME	FPLEMH
755	BONNY EAGLE W. BUXTON	755	BONNY EAGLE/W. BUXTON	17.500	17.500	17.500	17.500	IA	ME	031	SME	FPLEMH
757	HARRIS 4	757	HARRIS 4	1.500	1.500	1.500	1.500	IA	ME	025	ME	FPLEMH
759	MESSALONSKEE COMPOSITE	759	MESSALONSKEE COMPOSITE	6.100	6.100	6.100	6.100	IA	ME	011	ME	LELWD
		14937	UNION GAS STATION									
760	NORTH GORHAM	760	NORTH GORHAM	1.500	1.500	1.600	1.900	IA	ME	005	SME	FPLEMH
761	SHAWMUT	761	SHAWMUT	9.500	9.500	9.500	9.500	IA	ME	011	ME	FPLEMH
766	CABOT TURNERS FALLS	14801	CABOT	68.200	68.200	68.200	68.200	IA	MA	011	WMA	NEL1
		14808	TURNERSFALLS									
767	SES CONCORD	767	SES CONCORD	13.000	13.140	13.000	13.140	IA	NH	013	NH	PSNH
768	GARVINS HOOKSETT	768	GARVINS/HOOKSETT	14.805	14.000	14.805	14.000	Historic Capability	NH	013	NH	PSNH
769	HADLEY FALLS 1&2	769	HADLEY FALLS 1&2	33.400	33.400	33.400	33.400	Historic Capability	MA	013	WMA	HGE
772	NEWPORT HYDRO	772	NEWPORT HYDRO	3.880	4.030	3.880	4.030	Historic Capability	VT	019	NH	GMP
774	LOWER LAMOILLE COMPOSITE	774	LOWER LAMOILLE COMPOSITE	15.800	16.350	15.800	16.350	Historic Capability	VT	007	VT	GMP
775	MIDDLEBURY COMPOSITE	775	MIDDLEBURY COMPOSITE	6.750	6.000	6.750	6.000	Historic Capability	VT	001	VT	GMP
776	N. RUTLAND COMPOSITE	776	N. RUTLAND COMPOSITE	5.200	5.450	5.200	5.450	Historic Capability	VT	021	VT	GMP
779	MIDDLESEX 2	779	MIDDLESEX 2	3.300	3.300	3.300	3.300	Historic Capability	VT	023	VT	GMP
781	WEST DANVILLE 1	781	WEST DANVILLE 1	1.100	1.100	1.100	1.100	Historic Capability	VT	005	VT	GMP
783	HIGHGATE FALLS	783	HIGHGATE FALLS	9.570	9.520	9.570	9.520	Historic Capability	VT	011	VT	VPPSA

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW) Summer (50^{0}F)	NRC (MW) Winter (0^{0}F)	CNRC (MW) Summer (90^{0}F)	CNRC (MW) Winter (20^{0}F)	Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
786	KEZAR LEDGEMERE COMPOSITE	40207	KEZAR UPPER FALLS	0.560	1.282	0.560	1.282	Historic Capability	ME	005	SME	EPICO
		40208	KEZAR LOWER FALLS									
		40209	LEDGEMERE									
		42123	KEZAR MIDDLE FALLS									
789	CEC 002 PAWTUCKET U5	789	CEC 002 PAWTUCKET U5	1.200	1.240	1.200	1.240	Historic Capability	RI	007	RI	NEC
792	CENTENNIAL HYDRO	792	CENTENNIAL HYDRO	0.640	0.790	0.640	0.790	IA	MA	017	CMA/NEMA	SMED
793	METHUEN HYDRO	793	METHUEN HYDRO	0.120	0.273	0.120	0.273	Historic Capability	MA	009	BOSTON	SMED
794	MINIWAWA	794	MINIWAWA	0.437	0.959	0.437	0.959	PPA	NH	005	VT	PSNH
795	RIVER MILL HYDRO	795	RIVER MILL HYDRO	0.080	0.200	0.080	0.200	IA	NH	009	VT	MMELD
796	GOODWIN DAM	796	GOODWIN DAM	3.000	3.067	3.000	3.067	Historic Capability	CT	003	CT	CMEEC
797	CEC 003 WYRE WYND U5	797	WYRE WYND HYDRO	1.800	2.780	1.800	2.780	Historic Capability	CT	011	CT	GRRN
798	COLEBROOK	798	COLEBROOK	2.967	2.967	2.967	2.967	Historic Capability	CT	005	CT	CLP
800	KINNEYTOWN B	800	KINNEYTOWN B	0.654	1.510	0.654	1.510	Historic Capability	CT	009	SWCT	CHIPM
801	WILLIMANTIC 1	801	WILLIMANTIC 1	0.423	0.770	0.423	0.770	Historic Capability	CT	015	CT	CLP
802	WILLIMANTIC 2	802	WILLIMANTIC 2	0.388	0.770	0.388	0.770	Historic Capability	CT	015	CT	CLP
803	TOUTANT	803	TOUTANT	0.400	0.400	0.400	0.400	Historic Capability	CT	015	CT	CLP
804	PUTNAM	804	PUTNAM	0.580	1.940	0.580	1.940	Historic Capability	CT	015	CT	PUTNAM
806	MECHANICSVILLE	806	MECHANICSVILLE	0.430	0.430	0.101	0.267	IA	CT	015	CT	SMED
		46206	ENERGY STREAM HYDRO									
807	CEC 004 DAYVILLE POND U5	807	CEC 004 DAYVILLE POND U5	0.061	0.100	0.061	0.100	Historic Capability	CT	015	CT	CLP
808	SANDY HOOK HYDRO	808	SANDY HOOK HYDRO	0.077	0.105	0.077	0.105	Historic Capability	CT	001	SWCT	CLP
809	PINCHBECK	809	PINCHBECK	0.011	0.010	0.011	0.010	Historic Capability	CT	009	CT	CLP
810	QUINEBAUG	810	QUINEBAUG	0.980	2.810	0.980	2.810	Historic Capability	CT	015	CT	CLP
811	BANTAM	811	BANTAM	0.320	0.320	0.320	0.320	IA	CT	005	CT	NEL1
812	BEEBE HOLBROOK	812	BEEBE HOLBROOK	0.586	0.586	0.586	0.586	Historic Capability	MA	013	WMA	HGE
813	TUNNEL	813	TUNNEL	2.100	2.100	2.100	2.100	IA	CT	011	CT	NEL1
814	PATCH	814	PATCH	0.300	0.300	0.300	0.300	Historic Capability	VT	021	VT	GMP
815	CARVER FALLS	815	CARVER FALLS	1.480	1.900	1.480	1.900	Historic Capability	VT	021	VT	GMP
816	CAVENDISH	816	CAVENDISH	1.180	1.428	1.180	1.428	Historic Capability	VT	027	VT	GMP
817	TAFTSVILLE VT	817	TAFTSVILLE VT	0.330	0.400	0.330	0.400	Historic Capability	VT	027	VT	GMP
818	PIERCE MILLS	818	PIERCE MILLS	0.245	0.245	0.245	0.245	Historic Capability	VT	005	NH	GMP
819	ARNOLD FALLS	819	ARNOLD FALLS	0.300	0.300	0.300	0.300	Historic Capability	VT	005	NH	GMP
820	PASSUMPSIC	820	PASSUMPSIC	0.700	0.700	0.700	0.700	Historic Capability	VT	005	NH	GMP
821	GAGE	821	GAGE	0.760	0.800	0.760	0.800	Historic Capability	VT	005	NH	GMP
822	SMITH (CVPS)	822	SMITH (CVPS)	0.930	1.310	0.930	1.310	Historic Capability	VT	017	VT	GMP
823	EAST BARNET	823	EAST BARNET	1.600	1.900	1.600	1.900	Historic Capability	VT	005	NH	GMP
824	BATH ELECTRIC HYDRO	824	BATH ELECTRIC HYDRO	0.400	0.800	0.400	0.800	Historic Capability	NH	009	NH	PSNH
827	SEARSBURG WIND	827	SEARSBURG WIND	0.700	1.690	0.620	1.680	PPA	VT	003	WMA	GMP
828	BARTON HYDRO	828	BARTON HYDRO	1.300	1.300	1.300	1.300	Historic Capability	VT	019	NH	VPPSA
830	ENOSBURG HYDRO	830	ENOSBURG HYDRO	0.950	0.950	0.950	0.950	Historic Capability	VT	011	VT	VPPSA
831	VAIL & GREAT FALLS	831	VAIL & GREAT FALLS	2.100	2.100	2.100	2.100	Historic Capability	VT	005	NH	VPPSA
832	CENTER RUTLAND	832	CENTER RUTLAND	0.350	0.350	0.350	0.350	Historic Capability	VT	021	VT	GMP
833	BARNET	833	BARNET	0.350	0.490	0.350	0.490	Historic Capability	VT	005	VT	GMP
834	COMPTU FALLS	834	COMTU FALLS	0.323	0.460	0.323	0.460	Historic Capability	VT	027	VT	GMP
835	DEWEY MILLS	835	DEWEY MILLS	1.570	2.790	1.570	2.790	Historic Capability	VT	027	VT	GMP
836	EMERSON FALLS	836	EMERSON FALLS	0.230	0.230	0.230	0.230	Historic Capability	VT	005	NH	GMP
837	KILLINGTON	837	KILLINGTON	0.070	0.100	0.070	0.100	Historic Capability	VT	021	VT	GMP
839	LADD'S MILL	839	LADD'S MILL	0.170	0.170	0.170	0.170	Historic Capability	VT	023	VT	GMP
840	MARTINSVILLE	840	MARTINSVILLE	0.250	0.250	0.250	0.250	Historic Capability	VT	027	VT	GMP
841	MORETOWN 8	841	MORETOWN 8	1.096	1.096	1.096	1.096	Historic Capability	VT	023	VT	GMP
842	NANTANA MILL	842	NANTANA MILL	0.106	0.220	0.106	0.220	Historic Capability	VT	023	VT	GMP
843	NEWBURY	843	NEWBURY	0.220	0.270	0.220	0.270	Historic Capability	VT	017	VT	GMP
844	OTTAUQUECHEE	844	OTTAUQUECHEE	1.547	2.180	1.547	2.180	Historic Capability	VT	027	VT	GMP
845	SLACK DAM	845	SLACK DAM	0.230	0.410	0.230	0.410	Historic Capability	VT	027	VT	GMP
846	WINOOSKI 8	846	WINOOSKI 8	0.403	0.950	0.403	0.950	Historic Capability	VT	023	VT	GMP
847	WOODSIDE	847	WOODSIDE	0.110	0.120	0.110	0.120	Historic Capability	VT	015	VT	GMP

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW) Summer (50^{0}F)	NRC (MW) Winter (0^{0}F)	CNRC (MW) Summer (90^{0}F)	CNRC (MW) Winter (20^{0}F)	Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
848	WRIGHTSVILLE	848	WRIGHTSVILLE	0.750	0.754	0.750	0.754	Historic Capability	VT	023	VT	VPPSA
849	CRESCENT DAM	849	CRESCENT DAM	1.617	1.617	1.000	1.000	IA	MA	013	WMA	CHIPM
850	GLENDALE HYDRO	850	GLENDALE HYDRO	1.245	1.245	0.958	1.138	IA	MA	003	WMA	CHIPM
851	GARDNER FALLS	851	GARDNER FALLS	3.700	3.700	3.700	3.700	Historic Capability	MA	011	WMA	NAEA-EM
852	SOUTH BARRE HYDRO	852	SOUTH BARRE HYDRO	0.750	0.240	0.650	0.140	IA	MA	027	WMA	MMWEC
		42598	NEW BARRE HYDRO									
853	WEBSTER HYDRO	853	WEBSTER HYDRO	0.000	0.290	0.000	0.290	IA	MA	027	CMA/NEMA	MMWEC
854	ORANGE HYDRO 1	854	ORANGE HYDRO 1	0.150	0.150	0.150	0.150	IA	MA	011	WMA	TTMLP
855	ORANGE HYDRO 2	855	ORANGE HYDRO 2	0.120	0.172	0.120	0.172	IA	MA	011	WMA	TTMLP
856	HUNT'S POND	856	HUNT'S POND	0.023	0.064	0.023	0.064	Historic Capability	MA	027	WMA	TTMLP
857	OAKDALE HYDRO	857	OAKDALE HYDRO	3.200	3.200	3.200	3.200	Historic Capability	MA	027	CMA/NEMA	MEC
859	BOATLOCK	859	BOATLOCK	3.094	3.094	3.094	3.094	Historic Capability	MA	013	WMA	HGE
860	BRIAR HYDRO	860	BRIAR HYDRO	2.865	4.081	2.865	4.081	Historic Capability	NH	013	NH	PSNH
861	CANAAN	861	CANAAN	1.100	1.100	1.100	1.100	Historic Capability	VT	009	NH	PSNH
862	CHEMICAL	862	CHEMICAL	1.600	1.600	1.600	1.600	Historic Capability	MA	013	WMA	HGE
863	CLEMENT DAM	863	CLEMENT DAM	1.115	2.400	1.115	2.400	Historic Capability	NH	001	NH	MMWEC
864	DWIGHT	864	DWIGHT	1.340	1.746	1.700	1.700	Historic Capability	MA	013	WMA	NAEA-EM
865	ERROL	865	ERROL	2.625	3.000	2.625	3.000	Historic Capability	NH	007	NH	PSNH
866	GREGGS	866	GREGGS	2.070	2.070	2.070	2.070	Historic Capability	NH	011	NH	MMWEC
867	INDIAN ORCHARD	867	INDIAN ORCHARD	3.700	3.700	3.700	3.700	Historic Capability	MA	013	WMA	NAEA-EM
868	MILTON MILLS HYDRO	868	MILTON MILLS HYDRO	1.150	1.510	1.150	1.510	Historic Capability	NH	017	NH	PSNH
869	MINE FALLS	869	MINE FALLS	0.827	1.787	0.827	1.787	Historic Capability	NH	011	NH	PSS
870	PEMBROKE	870	PEMBROKE	0.520	1.663	0.520	1.663	Historic Capability	NH	013	NH	MMWEC
871	PENNACOOK FALLS LOWER	871	PENNACOOK FALLS LOWER	2.869	3.991	2.869	3.991	Historic Capability	NH	013	NH	UNITIL-ES
872	PENNACOOK FALLS UPPER	872	PENNACOOK FALLS UPPER	2.243	3.120	2.243	3.120	Historic Capability	NH	013	NH	PSNH
873	PUTTS BRIDGE	873	PUTTS BRIDGE	3.750	4.100	4.100	4.100	Historic Capability	MA	013	WMA	NAEA-EM
874	RED BRIDGE	874	RED BRIDGE	1.563	4.532	4.500	4.500	Historic Capability	MA	013	WMA	NAEA-EM
875	RIVER BEND	875	RIVER BEND	0.965	1.790	0.965	1.790	Historic Capability	NH	013	NH	MMWEC
876	ROBERTSVILLE	876	ROBERTSVILLE	0.354	0.624	0.354	0.624	IA	CT	003	CT	NEL1
877	SCOTLAND	877	SCOTLAND	1.690	2.200	1.690	2.200	IA	CT	015	CT	NEL1
878	SKINNER	878	SKINNER	0.280	0.280	0.280	0.280	Historic Capability	MA	013	WMA	HGE
879	TAFTVILLE CT	879	TAFTVILLE CT	2.030	2.030	2.030	2.030	IA	CT	011	CT	NEL1
882	FRANKLIN FALLS	882	FRANKLIN FALLS	0.673	0.800	0.673	0.800	Historic Capability	NH	013	NH	PSNH
883	SALMON FALLS HYDRO	883	SALMON FALLS HYDRO	1.200	1.200	0.953	0.824	Historic Capability	NH	017	SME	CHIPM
884	SWANS FALLS	884	SWANS FALLS	0.410	0.410	0.410	0.410	Historic Capability	ME	017	NH	PSNH
886	COCHECO FALLS	886	COCHECO FALLS	0.630	0.549	0.630	0.549	Historic Capability	NH	017	NH	PSNH
887	CHINA MILLS DAM	887	CHINA MILLS DAM	0.711	0.711	0.711	0.711	Historic Capability	NH	013	NH	PSNH
888	NEWFOUND HYDRO	888	NEWFOUND HYDRO	1.966	1.303	1.966	1.303	Historic Capability	NH	009	NH	PSS
889	SUNAPEE HYDRO	889	SUNAPEE HYDRO	0.593	0.433	0.593	0.433	Historic Capability	NH	019	NH	PSNH
890	NASHUA HYDRO	890	NASHUA HYDRO	1.031	1.031	1.031	1.031	Historic Capability	NH	011	NH	PSNH
891	HILLSBORO MILLS	891	HILLSBORO MILLS	0.405	0.568	0.405	0.568	Historic Capability	NH	011	NH	PSNH
892	LAKEPORT DAM	892	LAKEPORT DAM	0.537	0.711	0.537	0.711	Historic Capability	NH	001	NH	PSS
893	WEST HOPKINTON HYDRO	893	WEST HOPKINTON HYDRO	0.735	1.250	0.735	1.250	Historic Capability	NH	013	NH	CHIPM
894	LISBON HYDRO	894	LISBON HYDRO	0.332	0.515	0.332	0.515	Historic Capability	NH	009	NH	PSNH
895	LOWER ROBERTSON DAM	895	LOWER ROBERTSON DAM	0.860	0.900	0.860	0.900	Historic Capability	NH	005	VT	MMWEC
897	OLD NASH DAM	897	OLD NASH DAM	0.135	0.175	0.135	0.175	Historic Capability	NH	005	VT	PSNH
898	SUGAR RIVER HYDRO	898	SUGAR RIVER HYDRO	0.158	0.150	0.158	0.150	Historic Capability	NH	019	NH	PSNH
900	GREAT FALLS LOWER	900	GREAT FALLS LOWER	1.700	1.700	1.700	1.700	Historic Capability	NH	017	NH	PSNH
901	WATERLOOM FALLS	901	WATERLOOM FALLS	0.081	0.086	0.081	0.086	Historic Capability	NH	011	NH	PSNH
902	HOSIERY MILL DAM	902	HOSIERY MILL DAM	0.435	0.993	0.435	0.993	Historic Capability	NH	011	NH	SRTC
903	WYANDOTTE HYDRO	903	WYANDOTTE HYDRO	0.084	0.150	0.084	0.150	Historic Capability	NH	017	NH	PSNH
904	LOCHMERE DAM	904	LOCHMERE DAM	0.892	1.025	0.892	1.025	Historic Capability	NH	001	NH	MMWEC
905	ASHUELOT HYDRO	905	ASHUELOT HYDRO	0.808	0.930	0.808	0.930	Historic Capability	NH	005	VT	MMWEC
906	ROLLINSFORD HYDRO	906	ROLLINSFORD HYDRO	1.500	1.500	1.500	1.500	Historic Capability	NH	017	NH	PSNH
908	OTIS MILL HYDRO	908	OTIS MILL HYDRO	0.122	0.127	0.122	0.127	Historic Capability	NH	011	NH	PSNH
909	STEELS POND HYDRO	909	STEELS POND HYDRO	0.429	0.975	0.429	0.975	Historic Capability	NH	011	NH	PSNH

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
910	CAMPTON DAM	910	CAMPTON DAM	0.416	0.416	0.416	0.416	Historic Capability	NH	009	NH	PSNH
911	KELLEYS FALLS	911	KELLEYS FALLS	0.429	0.400	0.429	0.400	Historic Capability	NH	011	NH	PSNH
913	GOODRICH FALLS	913	GOODRICH FALLS	0.487	0.307	0.487	0.307	Historic Capability	NH	003	NH	NHEC
914	CHAMBERLAIN FALLS	914	CHAMBERLAIN FALLS	0.123	0.094	0.123	0.094	Historic Capability	NH	011	NH	PSNH
915	MONADNOCK PAPER MILLS	915	MONADNOCK PAPER MILLS	0.305	1.114	0.305	1.114	Historic Capability	NH	011	NH	PSNH
919	HOPKINTON HYDRO	919	HOPKINTON HYDRO	0.229	0.250	0.229	0.250	Historic Capability	NH	013	NH	PSNH
922	NOONE FALLS	922	NOONE FALLS	0.130	0.146	0.130	0.146	Historic Capability	NH	011	VT	PSNH
925	OTTER LANE HYDRO	925	OTTER LANE HYDRO	0.084	0.090	0.084	0.090	Historic Capability	NH	013	NH	PSNH
926	PETERBOROUGH LOWER HYDRO	926	PETERBOROUGH LOWER HYDRO	0.284	0.284	0.284	0.284	Historic Capability	NH	011	VT	PSNH
928	SALMON BROOK STATION 3	928	SALMON BROOK STATION 3	0.326	0.250	0.326	0.250	Historic Capability	NH	013	NH	PSNH
931	AVERY DAM	931	AVERY DAM	0.460	0.479	0.460	0.479	Historic Capability	NH	001	NH	PSNH
932	WATSON DAM	932	WATSON DAM	0.225	0.250	0.225	0.250	Historic Capability	NH	017	NH	PSNH
933	WESTON DAM	933	WESTON DAM	0.456	0.524	0.456	0.524	Historic Capability	NH	007	NH	PSNH
935	SUNNYBROOK HYDRO 2	935	SUNNYBROOK HYDRO 2	0.050	0.050	0.050	0.050	Historic Capability	NH	007	NH	PSNH
941	PETERBOROUGH UPPER HYDRO	941	PETERBOROUGH UPPER HYDRO	0.400	0.400	0.400	0.400	Historic Capability	NH	011	NH	PSNH
943	FOUR HILLS LANDFILL	943	FOUR HILLS LANDFILL	0.932	0.932	0.932	0.932	Historic Capability	NH	011	NH	PSNH
947	RIVERDALE MILLS - QF	947	RIVERDALE MILLS - QF	0.084	0.001	0.084	0.001	Historic Capability	MA	027	RI	MEC
948	PEPPERELL HYDRO COMPANY LLC	948	PEPPERELL HYDRO COMPANY LLC	0.863	0.863	0.863	0.863	Historic Capability	MA	017	CMA/NEMA	PSS
949	VALLEY HYDRO - QF	949	VALLEY HYDRO - QF	0.205	0.205	0.205	0.205	Historic Capability	RI	003	RI	NEC
950	LP ATHOL - QF	950	LP ATHOL - QF	0.200	0.200	0.200	0.200	Historic Capability	MA	027	CMA/NEMA	MEC
951	BALTIC MILLS - QF	951	BALTIC MILLS - QF	0.104	0.104	0.104	0.104	Historic Capability	NH	009	VT	SMED
953	ATTLEBORO LANDFILL - QF	953	ATTLEBORO LANDFILL - QF	1.535	1.535	1.535	1.535	Historic Capability	MA	005	RI	MEC
954	MM LOWELL LANDFILL - QF	954	MM LOWELL LANDFILL - QF	1.105	1.105	1.104	1.104	Historic Capability	MA	017	CMA/NEMA	MEC
957	HG&E HYDRO CABOT 1-4	957	HG&E HYDRO/CABOT 1-4	3.147	3.147	3.147	3.147	Historic Capability	MA	013	WMA	HGE
959	BARTON 1-4 DIESELS	959	BARTON 1-4 DIESELS	4.400	4.400	4.400	4.400	Historic Capability	VT	019	NH	VPPSA
969	POWDER MILL HYDRO	969	POWDER MILL HYDRO	0.140	0.140	0.140	0.140	Historic Capability	MA	027	WMA	MMWEC
970	DUDLEY HYDRO	970	DUDLEY HYDRO	0.102	0.324	0.102	0.324	IA	MA	027	WMA	MEC
978	NEW MILFORD	978	NEW MILFORD	3.014	3.014	3.014	3.014	Historic Capability	CT	005	SWCT	CLP
1005	BG DIGHTON POWER LLC	1005	DIGHTON POWER LLC	180.000	197.000	168.000	185.000	IA	MA	005	SEMA	DMT1
1028	BUNKER RD #12 GAS TURB	1028	BUNKER RD #12 GAS TURB	3.000	3.700	3.000	3.700	Historic Capability	MA	019	SEMA	NEP
1029	BUNKER RD #13 GAS TURB	1029	BUNKER RD #13 GAS TURB	3.000	3.700	3.000	3.700	Historic Capability	MA	019	SEMA	NEP
1030	OAK BLUFFS	1030	OAK BLUFFS	8.250	8.250	8.250	8.250	IA	MA	007	SEMA	MET
1031	WEST TISBURY	1031	WEST TISBURY	5.633	5.633	5.633	5.633	IA	MA	007	SEMA	MET
1032	BRIDGEPORT ENERGY 1	1032	BRIDGEPORT ENERGY 1	560.000	588.000	479.999	575.498	IA	CT	001	SWCT	EES5
1034	RIVERSIDE 4-7	1034	RIVERSIDE 4-7	3.435	3.435	3.435	3.435	Historic Capability	MA	013	WMA	HGE
1035	RIVERSIDE 8	1035	RIVERSIDE 8	4.500	4.500	4.500	4.500	Historic Capability	MA	013	WMA	HGE
1047	FAIRFAX	1047	FAIRFAX	4.009	4.009	4.009	4.009	Historic Capability	VT	011	VT	GMP
1048	WARE HYDRO	1048	WARE HYDRO	1.250	1.250	1.250	1.250	Historic Capability	MA	015	WMA	PHE
1049	COLLINS HYDRO	1049	COLLINS HYDRO	1.300	1.300	1.300	1.300	IA	MA	013	WMA	AMP
1050	CHICOPEE HYDRO	1050	CHICOPEE HYDRO	2.170	2.600	2.170	2.600	Historic Capability	MA	013	WMA	CMLP
1054	BLACKSTONE HYDRO ASSOC	1054	BLACKSTONE HYDRO ASSOC	0.000	0.198	0.000	0.198	Historic Capability	RI	007	RI	NEC
1057	BLACKSTONE HYDRO LOAD REDUCER	1057	BLACKSTONE HYDRO LOAD REDUCER	1.800	1.800	1.800	1.800	Historic Capability	RI	007	RI	BHI
1059	BARRE LANDFILL	1059	BARRE LANDFILL	1.000	1.000	1.000	1.000	IA	MA	027	WMA	DEM
1061	MASCOMA HYDRO	1061	MASCOMA HYDRO	0.834	0.834	0.834	0.834	Historic Capability	NH	009	VT	TCHN
1062	MWRA COSGROVE	1062	MWRA COSGROVE	1.901	1.901	1.901	1.901	Historic Capability	MA	027	CMA/NEMA	MEC
1086	BERKSHIRE POWER	1086	BERKSHIRE POWER	270.000	284.000	270.000	284.000	IA	MA	013	WMA	SENA
1107	SOMERSET	1107	SAPPI SOMERSET/HINCKLEY	10.604	10.604	10.604	10.604	Historic Capability	ME	011	ME	FPLP
1109	MMWAC	1109	MMWAC	3.034	3.034	3.034	3.034	Historic Capability	ME	001	ME	FPLP
1113	BRASSUA HYDRO	1113	BRASSUA HYDRO	4.203	4.203	4.203	4.203	Historic Capability	ME	025	ME	BEMLP
1114	MADISON COMPOSITE	1114	MADISON COMPOSITE	22.000	22.000	22.000	22.000	Historic Capability	ME	025	ME	CESLLC
1117	GREAT WORKS COMPOSITE	1117	GREAT WORKS COMPOSITE	0.165	0.918	0.165	0.918	Historic Capability	ME	031	SME	BHI
1119	KENNEBAGO HYDRO	1119	KENNEBAGO HYDRO	0.686	0.725	0.686	0.725	Historic Capability	ME	029	ME	FPLP
1122	CASCADE-DIAMOND-QF	1122	CASCADE-DIAMOND-QF	0.440	0.440	0.440	0.440	Historic Capability	MA	013	WMA	MEC
1165	CADYS FALLS	1165	CADYS FALLS	1.100	1.100	1.100	1.100	Historic Capability	VT	015	VT	VPPSA
1166	MORRISVILLE PLANT #2	1166	MORRISVILLE PLANT #2	1.430	1.800	1.430	1.800	Historic Capability	VT	015	VT	VPPSA
1167	WOLCOTT HYDRO #1	1167	WOLCOTT HYDRO #1	0.490	0.800	0.490	0.800	Historic Capability	VT	015	VT	VPPSA

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW) Summer (50°F)	NRC (MW) Winter (0°F)	CNRC (MW) Summer (90°F)	CNRC (MW) Winter (20°F)	Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
1168	H.K. SANDERS	1168	H.K. SANDERS	1.800	1.800	1.800	1.800	Historic Capability	VT	015	VT	VPPSA
1185	STONY BROOK GT1A	1185	STONY BROOK GT1A	107.500	124.000	103.167	118.500	PPA	MA	013	WMA	MMWEC
1186	STONY BROOK GT1B	1186	STONY BROOK GT1B	107.500	124.000	101.667	117.000	PPA	MA	013	WMA	MMWEC
1187	STONY BROOK GT1C	1187	STONY BROOK GT1C	107.000	122.000	103.167	118.500	PPA	MA	013	WMA	MMWEC
1209	CRRA HARTFORD LANDFILL	1209	CRRA HARTFORD LANDFILL	2.853	2.852	2.853	2.852	Historic Capability	CT	003	CT	CLP
1210	MILLENNIUM	1210	MILLENNIUM	354.963	405.540	331.000	388.000	IA	MA	027	WMA	EPLU-I
1216	MAINE INDEPENDENCE STATION	40338	MAINE INDEPENDENCE STATION 1	516.846	563.000	492.658	563.000	PPA	ME	019	BHE	DMT1
		40339	MAINE INDEPENDENCE STATION 2									
1221	ESSEX DIESELS	1221	ESSEX DIESELS	8.000	8.225	8.000	8.225	Historic Capability	VT	007	VT	GMP
1225	TANNERY DAM	1225	TANNERY DAM	0.200	0.200	0.200	0.200	Historic Capability	MA	027	WMA	MEC
1226	TIVERTON POWER	1226	TIVERTON POWER	287.500	305.500	267.450	296.540	PPA	RI	005	SEMA	EES6
1255	RUMFORD POWER	1255	RUMFORD POWER	270.795	275.059	244.940	275.059	Historic Capability	ME	017	ME	EES7
1258	BHE SMALL HYDRO COMPOSITE	1258	BHE SMALL HYDRO COMPOSITE	2.087	2.087	2.087	2.087	Historic Capability	ME	021	BHE	NBPGC
		42114	PUMPKIN HILL									
1266	MARSH POWER	1266	MARSH POWER	0.519	0.519	0.519	0.519	IA	ME	027	BHE	CMA
1267	SPARHAWK	1267	SPARHAWK	0.257	0.257	0.257	0.257	IA	ME	005	SME	UNION
1270	SYSKO STONY BROOK	1270	SYSKO STONY BROOK	0.025	0.025	0.025	0.025	Historic Capability	ME	017	ME	UNION
1271	SYSKO WIGHT BROOK	1271	SYSKO WIGHT BROOK	0.025	0.025	0.025	0.025	Historic Capability	ME	017	ME	UNION
1273	KENNEBEC WATER U5	1273	KENNEBEC WATER U5	0.800	0.800	0.800	0.800	IA	ME	011	ME	MESSA
1286	ANP-BLACKSTONE ENERGY CO. #1	1286	ANP-BLACKSTONE ENERGY 1	292.768	307.500	271.822	307.500	PPA	MA	027	RI	DMT1
1287	ANP-BLACKSTONE ENERGY 2	1287	ANP-BLACKSTONE ENERGY 2	292.880	307.500	271.317	307.500	PPA	MA	027	RI	DMT1
1288	BUCKSPORT ENERGY 4	47390	BUCKSPORT 3-5	279.046	289.310	160.300	185.700	PPA	ME	009	BHE	BKSG
1302	TCPMCMPAGF GEN1 U5	1302	TCPMCMPAGF GEN1 U5	65.170	65.170	0.000	0.000	N/A [5]	ME	007	ME	VERSO
1342	LAKE ROAD 1	1342	LAKE ROAD 1	279.157	299.024	255.000	293.000	IA	CT	015	CT	DMT1
1343	LAKE ROAD 2	1343	LAKE ROAD 2	278.636	298.910	255.000	293.000	IA	CT	015	CT	DMT1
1344	LAKE ROAD 3	1344	LAKE ROAD 3	274.371	297.891	255.000	293.000	IA	CT	015	CT	DMT1
1345	WESTBROOK	14177	WESTBROOK ENERGY CENTER G1	538.000	597.000	530.000	574.000	IA	ME	005	SME	CALP
		14178	WESTBROOK ENERGY CENTER G2									
1368	ROCKY GORGE CORPORATION	1368	ROCKY GORGE CORPORATION	0.362	0.362	0.362	0.362	Historic Capability	ME	031	SME	RGC
1376	PPL WALLINGFORD UNIT 1	1376	WALLINGFORD UNIT 1	50.000	50.000	43.473	49.583	PPA	CT	009	SWCT	TERM
1377	PPL WALLINGFORD UNIT 2	1377	WALLINGFORD UNIT 2	50.000	50.000	43.019	50.000	PPA	CT	009	SWCT	TERM
1378	PPL WALLINGFORD UNIT 3	1378	WALLINGFORD UNIT 3	50.000	50.000	44.566	50.000	PPA	CT	009	SWCT	TERM
1379	PPL WALLINGFORD UNIT 4	1379	WALLINGFORD UNIT 4	50.000	50.000	43.157	48.049	PPA	CT	009	SWCT	TERM
1380	PPL WALLINGFORD UNIT 5	1380	WALLINGFORD UNIT 5	50.000	50.000	44.425	50.000	PPA	CT	009	SWCT	TERM
1385	Milford Power 1 Incremental	1385	MILFORD POWER 1	276.394	300.000	267.700	287.425	PPA	CT	009	SWCT	DMT1
1386	MILFORD POWER 2	1386	MILFORD POWER 2	276.394	300.000	267.700	287.425	PPA	CT	009	SWCT	DMT1
1412	ANP-BELLINGHAM 1	1412	ANP-BELLINGHAM 1	292.494	307.500	272.387	307.500	PPA	MA	021	RI	DMT1
1415	ANP-BELLINGHAM 2	1415	ANP-BELLINGHAM 2	292.466	307.500	272.617	307.500	PPA	MA	021	RI	DMT1
1432	GRS-FALL RIVER	1432	GRS-FALL RIVER	5.200	5.900	5.200	5.900	Historic Capability	MA	005	SEMA	TMLP
1478	MYSTIC 8	1478	MYSTIC 8	800.000	841.564	703.324	841.564	PPA	MA	025	BOSTON	EXGC
1572	GRANBY SANITARY LANDFILL QF U5	1572	GRANBY SANITARY LANDFILL QF	3.200	3.200	2.800	2.800	Historic Capability	MA	015	WMA	IPSC
1616	MYSTIC 9	1616	MYSTIC 9	800.000	858.463	709.676	858.436	PPA	MA	025	BOSTON	EXGC
1625	GRANITE RIDGE ENERGY	1625	GRANITE RIDGE ENERGY	762.000	812.000	678.000	805.700	IA	NH	011	NH	CALP
1630	RISEP	1630	RISEP	613.000	625.000	551.668	610.632	IA	RI	007	RI	RISE
1631	Indeck-Energy Alexandria, LLC	14211	INDECK ALEXANDRIA	16.500	16.500	16.500	16.500	Historic Capability	NH	009	NH	IEA
1649	EP Newington Energy, LLC	1649	EP NEWINGTON ENERGY, LLC	596.100	634.900	522.014	561.500	IA	NH	015	NH	EPN
1656	HULL WIND TURBINE U5	1656	HULL WIND TURBINE U5	0.165	0.165	0.165	0.165	Historic Capability	MA	023	SEMA	HULL
1672	KENDALL CT	1672	KENDALL CT	187.400	187.400	170.000	187.000	IA	MA	017	BOSTON	KENDALL
1691	FORE RIVER-1	40327	FORE RIVER 11	800.000	843.000	710.651	843.000	IA	MA	021	SEMA	CALP
		40328	FORE RIVER 12									
1693	WEST SPRINGFIELD GT-1	1693	WEST SPRINGFIELD GT-1	47.000	48.000	39.000	48.000	PPA	MA	013	WMA	NAEA-EM
1694	WEST SPRINGFIELD GT-2	1694	WEST SPRINGFIELD GT-2	47.000	48.000	39.000	48.000	PPA	MA	013	WMA	NAEA-EM
1720	MIDDLEBURY LOWER	1720	MIDDLEBURY LOWER	1.810	1.850	1.810	1.850	Historic Capability	VT	001	VT	GMP
2278	BARKER LOWER HYDRO	2278	BARKER LOWER HYDRO	0.652	1.250	0.652	1.250	Historic Capability	ME	001	ME	BHI
2279	BARKER UPPER HYDRO	2279	BARKER UPPER HYDRO	0.377	1.262	0.377	1.262	Historic Capability	ME	001	ME	BHI
2280	BENTON FALLS HYDRO	2280	BENTON FALLS HYDRO	3.776	4.355	3.776	4.355	Historic Capability	ME	011	ME	LELWD

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW) Summer (50°F)	NRC (MW) Winter (0°F)	CNRC (MW) Summer (90°F)	CNRC (MW) Winter (20°F)	Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
2281	BROWNS MILL HYDRO	2281	BROWNS MILL HYDRO	0.318	0.650	0.318	0.650	Historic Capability	ME	021	ME	BHI
2282	DAMARISCOTTA HYDRO	2282	DAMARISCOTTA HYDRO	0.005	0.500	0.005	0.500	Historic Capability	ME	015	ME	BHI
2283	EUSTIS HYDRO	2283	EUSTIS HYDRO	0.248	0.250	0.248	0.250	Historic Capability	ME	007	ME	BHI
2284	GARDINER HYDRO	2284	GARDINER HYDRO	1.050	1.050	1.050	1.050	Historic Capability	ME	011	ME	BHI
2285	GREENVILLE HYDRO	2285	GREENVILLE HYDRO	0.520	0.520	0.520	0.520	Historic Capability	ME	021	ME	BHI
2286	HACKETT MILLS HYDRO	2286	HACKETT MILLS HYDRO	0.159	0.500	0.159	0.500	Historic Capability	ME	001	ME	EPICO
2287	MECHANIC FALLS HYDRO	2287	MECHANIC FALLS HYDRO	0.231	1.050	0.231	1.050	Historic Capability	ME	001	ME	BHI
2288	NORWAY HYDRO	2288	NORWAY HYDRO	0.000	0.201	0.000	0.201	Historic Capability	ME	017	ME	BHI
2290	PITTSFIELD HYDRO	2290	PITTSFIELD HYDRO	0.877	1.000	0.877	1.000	Historic Capability	ME	025	ME	BHI
2292	YORK HYDRO	2292	YORK HYDRO	0.878	1.200	0.878	1.200	Historic Capability	ME	031	SME	BHI
2425	SPRINGFIELD REFUSE-NEW	2425	SPRINGFIELD REFUSE-NEW	6.000	6.000	6.000	6.000	Historic Capability	MA	013	WMA	CEM
2426	Hydro Kennebec	2426	HYDRO KENNEBEC	15.660	17.150	15.660	17.150	Historic Capability	ME	011	ME	BEMLP
2430	BELDENS-NEW	2430	BELDENS-NEW	4.580	5.700	4.580	5.700	Historic Capability	VT	001	VT	GMP
2431	DODGE FALLS-NEW	2431	DODGE FALLS-NEW	5.000	5.000	5.000	5.000	PPA	NH	009	VT	VELCO
2432	HUNTINGTON FALLS-NEW	2432	HUNTINGTON FALLS-NEW	4.990	5.760	4.990	5.760	Historic Capability	VT	001	VT	GMP
2433	RYEGATE 1-NEW	2433	RYEGATE 1-NEW	19.000	19.000	19.000	19.000	PPA	VT	005	NH	VELCO
2434	GORGE 18 HYDRO-NEW	2434	GORGE 18 HYDRO-NEW	3.300	3.300	3.300	3.300	Historic Capability	VT	007	VT	GMP
2435	VERGENNES HYDRO-NEW	2435	VERGENNES HYDRO-NEW	2.340	3.300	2.340	3.300	Historic Capability	VT	001	VT	GMP
2439	BROCKWAY MILLS U5	2439	BROCKWAY MILLS U5	0.500	0.500	0.500	0.500	Historic Capability	VT	025	VT	GMP
2462	PLAINVILLE GEN QF U5	2462	PLAINVILLE GEN QF U5	5.000	5.000	5.000	5.000	Historic Capability	MA	021	RI	MEC
2466	CHERRY 7	2466	CHERRY 7	3.200	3.200	3.200	3.200	Historic Capability	MA	017	CMA/NEMA	HLPD
2467	CHERRY 8	2467	CHERRY 8	3.600	3.600	3.600	3.600	Historic Capability	MA	017	CMA/NEMA	HLPD
2468	CHERRY 10	2468	CHERRY 10	2.200	2.200	2.200	2.200	Historic Capability	MA	017	CMA/NEMA	HLPD
2469	CHERRY 11	2469	CHERRY 11	2.200	2.200	2.200	2.200	Historic Capability	MA	017	CMA/NEMA	HLPD
2470	CHERRY 12	2470	CHERRY 12	5.600	5.600	5.600	5.600	Historic Capability	MA	017	CMA/NEMA	HLPD
10308	NECCO COGENERATION FACILITY	47822	NECCO GEN	5.820	5.820	5.000	5.000	N/A [5]	MA	025	BOSTON	NECCO
10401	CELLEY MILL U5	10401	CELLEY MILL U5	0.084	0.092	0.084	0.092	Historic Capability	NH	009	NH	PSNH
10402	PETTYBORO HYDRO U5	10402	PETTYBORO HYDRO U5	0.004	0.010	0.004	0.010	Historic Capability	NH	009	NH	PSNH
10403	EASTMAN BROOK U5	10403	EASTMAN BROOK U5	0.100	0.100	0.100	0.100	Historic Capability	NH	009	NH	PSNH
10406	LOWER VALLEY HYDRO U5	10406	LOWER VALLEY HYDRO U5	0.534	0.534	0.534	0.534	Historic Capability	NH	019	NH	GMP
10407	WOODSVILLE HYDRO U5	10407	WOODSVILLE HYDRO U5	0.241	0.241	0.241	0.241	Historic Capability	NH	019	NH	GMP
10409	SWEETWATER HYDRO U5	10409	SWEETWATER HYDRO U5	0.500	0.500	0.500	0.500	Historic Capability	NH	019	NH	GMP
10424	Great Lakes - Berlin Incremental	10424	GREAT LAKES - BERLIN	25.000	25.000	25.000	25.000	PPA	NH	007	NH	BEMLP
10615	BLUE SPRUCE FARM U5	10615	BLUE SPRUCE FARM	0.275	0.275	0.275	0.275	Historic Capability	VT	021	VT	GMP
10770	WEST SPRINGFIELD HYDRO U5	10770	WEST SPRINGFIELD HYDRO U5	1.200	1.250	1.200	1.250	Historic Capability	MA	013	WMA	LELWD
10801	COVENTRY CLEAN ENERGY	10801	COVENTRY CLEAN ENERGY	4.800	4.800	4.800	4.800	Historic Capability	VT	019	NH	VPPSA
10880	GE LYNN EXCESS REPLACEMENT	10880	GE LYNN EXCESS REPLACEMENT	2.282	14.982	2.282	14.982	Historic Capability	MA	009	BOSTON	CNE
10959	RRIG EXPANSION PHASE 2	10959	RRIG EXPANSION PHASE 2	6.000	6.000	6.000	6.024	IA	RI	007	RI	RRIG
10998	MASSINNOVATION FITCHBURG	10998	MASSINNOVATION FITCHBURG	0.003	3.027	0.003	3.027	Historic Capability	MA	027	WMA	FGE
11052	GRTR NEW BEDFORD LFG UTIL PROJ	11052	GRTR NEW BEDFORD LFG UTIL PROJ	3.300	3.300	3.300	3.300	Historic Capability	MA	005	SEMA	CRMC
11126	NORTH HARTLAND HYDRO	11126	NORTH HARTLAND HYDRO	4.460	4.460	4.460	4.460	Historic Capability	VT	027	VT	GMP
11408	HULL WIND TURBINE II	11408	HULL WIND TURBINE II	1.800	1.800	1.800	1.800	Historic Capability	MA	023	SEMA	HULL
11424	RUMFORD FALLS	11424	RUMFORD FALLS	44.100	44.100	40.000	40.000	IA	ME	017	ME	BEMLP
11842	WATERSIDE POWER	11842	WATERSIDE POWER	73.623	75.000	72.000	75.000	IA	CT	001	NOR	WATERSIDE
11925	BROCKTON BRIGHTFIELDS	11925	BROCKTON BRIGHTFIELDS	0.425	0.425	0.425	0.425	Historic Capability	MA	023	SEMA	EXGC
12108	FIEC DIESEL	12108	FIEC DIESEL	2.000	2.000	2.000	2.000	Historic Capability	ME	013	ME	VPPSA
12180	BERKSHIRE COW POWER	12180	BERKSHIRE COW POWER	0.500	0.500	0.500	0.500	Historic Capability	VT	011	VT	VEC
12274	GREEN MOUNTAIN DAIRY	12274	GREEN MOUNTAIN DAIRY	0.220	0.220	0.220	0.220	Historic Capability	VT	011	VT	GMP
12323	COVENTRY CLEAN ENERGY #4	12323	COVENTRY CLEAN ENERGY #4	2.895	2.975	2.895	2.975	Historic Capability	VT	019	NH	VPPSA
12500	Thomas A. Watson	15484	THOMAS A. WATSON UNIT #1	114.800	114.800	105.200	114.800	IA	MA	021	SEMA	BELD
		15485	THOMAS A. WATSON UNIT #2									
12504	Devon 15-18	12504	DEVON 15	196.800	196.800	187.600	195.600	PPA	CT	009	SWCT	GCE
		17044	DEVON 16									
		17045	DEVON 17									
		17046	DEVON 18									

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW) Summer (50^{0}F)	NRC (MW) Winter (0^{0}F)	CNRC (MW) Summer (90^{0}F)	CNRC (MW) Winter (20^{0}F)	Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
12505	Middletown 12-15	12505	MIDDLETOWN 12	196.800	196.800	187.600	193.600	IA	CT	007	CT	GCE
		37366	MIDDLETOWN 13									
		37367	MIDDLETOWN 14									
		37368	MIDDLETOWN 15									
12509	UNH Power Plant	12509	UNH POWER PLANT	2.000	2.000	2.000	2.000	Historic Capability	NH	017	NH	PSNH
12510	Swanton Gas Turbine 1	12510	SWANTON GT-1	23.500	27.100	19.440	24.980	PPA	VT	011	VT	VPPSA
12511	Swanton Gas Turbine 2	12511	SWANTON GT-2	23.500	27.100	19.723	25.344	PPA	VT	011	VT	VPPSA
12521	Lowell Power Reactivation	461	LENERGIA ENERGY CENTER	76.300	76.950	74.000	76.000	PPA	MA	017	CMA/NEMA	EDFT
12524	Cos Cob 13&14	14157	COS COB 13	42.200	46.000	36.000	46.000	PPA	CT	001	NOR	NRGPM
		14158	COS COB 14									
12526	Pierce	13515	PIERCE STATION	86.000	100.000	77.500	97.000	PPA	CT	009	SWCT	CMEEC
12530	Sheffield Wind Farm	12530	SHEFFIELD WIND PLANT	39.200	39.200	10.000	17.000	PPA	VT	005	VT	VTWIND
12551	Kibby Wind Power	12551	KIBBY WIND POWER	132.000	132.000	20.400	47.300	IA	ME	007	ME	TCPM
12553	Covanta Haverhill Landfill Gas Engine	14707	COVANTA HAVERHILL - LF GAS	1.600	1.600	1.600	1.600	IA	MA	009	BOSTON	CHA
12564	Waterbury Generation Facility	12564	WATERBURY GENERATION FACILITY	103.600	103.600	97.911	99.454	IA	CT	009	SWCT	WATERBURY
13669	Manchester Methane LLC East Windsor Facility	13669	EAST WINDSOR NORCAP LFG PLANT	1.430	1.430	1.430	1.430	Historic Capability	CT	003	CT	MMLLC
13673	MATEP (DIESEL)	13673	MATEP (DIESEL)	20.250	20.250	19.350	19.350	IA	MA	025	BOSTON	MATEP
13675	MATEP (COMBINED CYCLE)	13675	MATEP (COMBINED CYCLE)	60.400	66.000	43.250	49.250	IA	MA	025	BOSTON	MATEP
13703	Verso VCG1	13703	VERSO COGEN 1	55.000	61.000	47.223	58.377	IA	ME	007	ME	VERSO
13704	Verso VCG2	13704	VERSO COGEN 2	55.000	61.000	45.167	56.321	IA	ME	007	ME	VERSO
13705	Verso VCG3	13705	VERSO COGEN 3	55.000	61.000	44.097	55.251	IA	ME	007	ME	VERSO
13975	Corriveau Hydroelectric LLC	13975	CORRIVEAU HYDROELECTRIC LLC	0.073	0.350	0.073	0.350	Historic Capability	ME	017	ME	UNION
14087	MAT3	14087	MAT3	19.350	19.350	19.350	19.350	IA	MA	025	BOSTON	MATEP
14134	MONTAGNE FARM	14134	MONTAGNE FARM	0.300	0.300	0.300	0.300	Historic Capability	VT	011	VT	GMP
14217	NORTHFIELD MOUNTAIN 1	14217	NORTHFIELD MOUNTAIN 1	295.000	295.000	292.000	292.000	IA	MA	011	WMA	NEL1
14218	NORTHFIELD MOUNTAIN 2	14218	NORTHFIELD MOUNTAIN 2	295.000	295.000	292.000	292.000	IA	MA	011	WMA	NEL1
14219	NORTHFIELD MOUNTAIN 3	14219	NORTHFIELD MOUNTAIN 3	295.000	295.000	292.000	292.000	IA	MA	011	WMA	NEL1
14220	NORTHFIELD MOUNTAIN 4	14220	NORTHFIELD MOUNTAIN 4	295.000	295.000	292.000	292.000	IA	MA	011	WMA	NEL1
14271	Ameresco Northampton	14271	AMERESCO NORTHAMPTON	0.800	0.800	0.800	0.800	Historic Capability	MA	015	WMA	EXGC
14595	Granite Reliable Power	14595	GRANITE RELIABLE POWER, LLC	94.500	94.500	29.900	42.900	IA	NH	007	NH	GRP
14599	Rhode Island LFG Genco, LLC - ST	40054	JOHNSTON LFG TURBINE PLANT	32.629	36.785	26.000	28.000	IA	RI	007	RI	RRIG
14610	Princeton Wind Farm Project	14610	PRINCETON WIND FARM PROJECT	0.667	1.257	0.667	1.257	Historic Capability	MA	027	WMA	PMLD
14614	Kleen Energy	14614	KLEEN ENERGY	620.000	620.000	620.000	620.000	PPA	CT	007	CT	EXGC
14623	Valley Hydro (Station No. 5)	14623	VALLEY HYDRO (STATION NO. 5)	0.790	0.790	0.790	0.790	Historic Capability	MA	013	WMA	HGE
14652	Templeton Wind Turbine	14652	TEMPLETON WIND TURBINE	1.500	1.500	0.278	0.441	Cleared Capacity	MA	027	WMA	MMWEC
14660	Lempster Wind	15115	LEMPSTER WIND	24.000	24.000	4.425	10.024	PPA	NH	011	NH	PSNH
14661	Berkshire Wind Power Project	16614	BERKSHIRE WIND POWER PROJECT	15.000	15.000	2.576	6.988	IA	MA	003	WMA	MMWEC
14663	WMRE Crossroads	15998	CROSSROADS LANDFILL	3.000	3.000	3.000	3.000	Historic Capability	ME	025	ME	WMRE
14665	Record Hill Wind	14665	RECORD HILL WIND	50.600	50.600	13.600	16.700	IA	ME	017	ME	RHW
14695	Orono Hydro Station	14695	ORONO	0.000	0.000	0.000	0.000	N/A [5]	ME	019	BHE	BBHP
14706	Kimberly-Clark Corp Energy Independence Project	15097	KIMB ROCKY RIVER PH2	14.000	19.700	14.000	19.700	IA	CT	005	SWCT	KCC
15415	Dartmouth Power Expansion	15940	DARTMOUTH CT GENERATOR 3	22.800	23.500	21.300	23.500	IA	MA	005	SEMA	EPLU-I
15477	New Haven Harbor Units 2, 3, & 4	15477	NEW HAVEN HARBOR UNIT 2	147.900	147.900	129.600	145.000	IA	CT	009	CT	PSEG-NH
		40052	NEW HAVEN HARBOR UNIT 3									
		40053	NEW HAVEN HARBOR UNIT 4									
15509	Plainfield Renewable Energy	15509	PLAINFIELD RENEWABLE ENERGY	38.500	38.500	37.500	37.500	IA	CT	015	CT	PRE
16296	Milford Hydro	16296	MILFORD HYDRO	8.900	8.900	6.422	6.643	IA	ME	019	BHE	BBHP
16523	Stillwater	16523	STILLWATER	1.898	1.964	1.898	1.964	Historic Capability	ME	019	BHE	BBHP
16525	Medway	16525	MEDWAY	4.003	4.003	3.443	2.869	IA	ME	019	BHE	BBHP
16631	Victory Road Dorchester PV	16631	VICTORY ROAD DORCHESTER PV	1.000	1.000	0.316	0.000	Cleared Capacity	MA	025	BOSTON	MEC
16640	Hilldale Ave Haverhill PV	16640	HILLDALE AVE HAVERHILL PV	1.000	1.000	0.270	0.000	Cleared Capacity	MA	009	BOSTON	MEC
16642	Railroad Street Revere PV	16642	RAILROAD AVENUE REVERE PV	1.000	1.000	0.245	0.000	Cleared Capacity	MA	025	BOSTON	MEC
16643	Rover Street Everett PV	16643	ROVER STREET EVERETT PV	0.500	0.500	0.168	0.000	Cleared Capacity	MA	017	BOSTON	MEC
16644	Main Street Whitinsville PV	16644	MAIN STREET WHITINSVILLE PV	1.000	1.000	0.280	0.000	Cleared Capacity	MA	027	RI	MEC
16653	Berlin Biopower	16653	BURGESS BIOPOWER	67.500	67.500	65.380	65.380	IA	NH	007	NH	PSNH
16659	Ipswich Wind Farm 1	16659	IPSWICH WIND FARM 1	1.500	1.500	0.187	0.342	Cleared Capacity	MA	009	BOSTON	IMLD

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW) Summer (50°F)	NRC (MW) Winter (0°F)	CNRC (MW) Summer (90°F)	CNRC (MW) Winter (20°F)	Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
16675	Fox Island Wind	16675	FOX ISLAND WIND	4.500	4.500	0.000	0.444	Cleared Capacity	ME	013	ME	VPPSA
16688	Nor1	14816	NORDEN 1	1.958	1.958	1.958	1.958	Cleared Capacity	CT	001	NOR	CMEEC
16737	DFC-ERG Hybrid Fuel Cell (3)	16737	UDR GLASTONBURY	2.800	3.400	2.500	2.500	Cleared Capacity	CT	003	CT	UIL
16738	BFCP Fuel Cell	16738	DOMINION BRIDGEPORT FUEL CELL	14.990	15.390	13.054	13.259	Cleared Capacity	CT	001	SWCT	DEM
16750	Norden #2	14817	NORDEN 2	1.942	1.942	1.948	1.948	Cleared Capacity	CT	001	NOR	CMEEC
16752	Norden #3	14818	NORDEN 3	1.942	1.942	1.942	1.942	Cleared Capacity	CT	001	NOR	CMEEC
17359	Sugar River 2	17223	SUGAR RIVER 2	0.199	0.199	0.026	0.155	Cleared Capacity	NH	019	NH	PSNH
35442	Seaman Energy	17259	SEAMAN ENERGY LLC	0.484	0.483	0.484	0.483	Cleared Capacity	MA	027	CMA/NEMA	TTMLP
35485	Fitchburg-FCA-5	14098	FITCHBURG LANDFILL	4.581	4.581	4.500	4.500	Cleared Capacity	MA	027	WMA	VPPSA
35555	GMCW	35555	GMCW	9.900	9.900	2.380	3.540	IA	VT	007	VT	BED
35593	Fiske Hydro	15201	FISKE HYDRO	0.810	0.810	0.077	0.113	Cleared Capacity	NH	005	VT	PSNH
35594	Spaulding Pond Hydro	35379	SPAULDING POND HYDRO	0.265	0.265	0.074	0.172	Cleared Capacity	NH	017	NH	PSNH
35656	Rainbow_2	17234	RAINBOW UNIT 2	4.100	4.100	4.100	4.100	IA	CT	003	CT	CLP
35657	Shrewsbury Diesels	568	SHREWSBURY DIESELS	13.750	13.750	13.750	13.750	Historic Capability	MA	027	CMA/NEMA	SELP
35658	Rainbow_1	17233	RAINBOW UNIT 1	4.100	4.100	4.100	4.100	IA	CT	003	CT	CLP
35693	Spruce Mountain Wind	35693	SPRUCE MOUNTAIN WIND	20.000	20.000	4.500	9.000	Cleared Capacity	ME	017	ME	SPRUCE
35728	Moretown LG	15617	MORETOWN LFGTE	3.000	3.000	3.200	3.200	Cleared Capacity	VT	023	VT	GMP
35979	Kingdom Community Wind	35979	KINGDOM COMMUNITY WIND	64.575	64.575	12.000	21.673	IA	VT	019	VT	GMP
37040	KENDALL STEAM	10347	KENDALL STEAM 1	62.600	62.600	27.750	27.750	IA	MA	017	BOSTON	KENDALL
		10348	KENDALL STEAM 2									
		10349	KENDALL STEAM 3									
37050	Groton Wind Project	37050	GROTON WIND	48.000	48.000	9.751	19.771	IA	NH	009	NH	PPMI
37051	Silver lake PV	37722	SILVER LAKE SOLAR PV FACILITY	1.500	1.500	0.458	0.000	Cleared Capacity	MA	003	WMA	WMECO
37072	Beaver_Ridge_Wind	15706	BEAVER RIDGE WIND	1.800	1.800	0.474	1.344	Cleared Capacity	ME	027	ME	NHEC
37077	Woronoco Hydro LLC	15787	WORONOCO HYDRO LLC	2.700	2.700	1.181	1.611	IA	MA	013	WMA	PSS
37079	Indian River Power Supply LLC	37823	INDIAN RIVER POWER SUPPLY LLC	1.300	1.300	0.314	0.941	IA	MA	013	WMA	PSS
37105	BLUE SKY WEST	37105	BINGHAM WIND	184.800	184.800	42.270	87.300	IA	ME	025	ME	BSWL
37120	Thundermist Hydropower	16926	THUNDERMIST HYDRO QF	1.253	1.253	0.000	0.941	Cleared Capacity	RI	007	RI	NEC
38078	NFM Solar Power, LLC	40176	NFM SOLAR POWER, LLC	1.700	1.700	0.507	0.000	Cleared Capacity	MA	011	WMA	NEL1
38081	Indian Orchard Solar PV	40015	INDIAN ORCHARD SOLAR FACILITY	1.500	1.500	0.595	0.000	Cleared Capacity	MA	013	WMA	WMECO
38083	Orono "B" Hydro	38083	ORONO B HYDRO	4.000	4.000	0.000	0.000	N/A [5]	ME	019	BHE	BBHP
38084	Stillwater "B" Hydro	38084	STILLWATER B HYDRO	2.400	2.400	0.000	0.000	N/A [5]	ME	019	BHE	BBHP
38114	East Bridgewater Solar Energy Project	43623	E BRIDGEWATER-02333PV2000NM	2.000	2.000	0.850	0.000	Cleared Capacity	MA	023	SEMA	MEC
38115	HARRINGTON STREET PV PROJECT	38115	HARRINGTON STREET PV	9.750	9.750	1.430	0.000	IA	MA	027	WMA	HCG
38173	Saddleback Ridge Wind	38173	SADDLEBACK RIDGE WIND	34.200	34.200	3.750	10.230	IA	ME	007	ME	SPRUCE
38178	Southbridge Landfill Gas to Energy 17-18	37073	SOUTHBRIDGE LANDFILL	1.541	1.541	1.400	1.400	Cleared Capacity	MA	027	WMA	FPLP
38181	Westford Solar	41879	WESTFORD SOLAR 1- PV	4.000	4.000	1.800	0.000	Cleared Capacity	MA	017	CMA/NEMA	MEC
		41880	WESTFORD SOLAR 2- PV									
		42203	WESTFORD SOLAR 3 - PV									
		42497	WESTFORD SOLAR 4- PV									
38287	WMA Chester Solar 1	38287	WMA CHESTER SOLAR 1	4.800	4.800	1.904	0.000	Cleared Capacity	MA	013	WMA	VPPSA
38302	Fisher Road Solar I	38302	TOWN_OF_CARVER_PV_1763	4.560	4.560	1.920	0.000	N/A [5]	MA	005	SEMA	NSTAR
38372	Dartmouth Solar	38372	BLUEWAVE - CC COMM COLL 2209	3.500	3.500	0.000	0.000	Cleared Capacity	MA	005	SEMA	NSTAR
38373	Holliston	38373	BLUEWAVE BOURNE-HOLLISTON 2262	3.000	3.000	0.000	0.000	Cleared Capacity	MA	017	RI	NSTAR
38374	Plymouth	47374	NEW BEDFORD RED AUTH #2283	4.260	4.260	0.000	0.000	Cleared Capacity	MA	023	SEMA	NSTAR
38375	Uxbridge	38375	BWC FIVEMILE-01569PV3000NM	3.000	3.000	0.000	0.000	Cleared Capacity	MA	027	RI	MEC
38376	Landcraft	48705	SUN E. BRDGEWTR-02324PV3000NM	3.000	3.000	0.000	0.000	Cleared Capacity	MA	023	SEMA	MEC
38378	LSRHS	47424	SUN EDISON - SUDBURY 2417	0.980	0.980	0.000	0.000	Cleared Capacity	MA	017	BOSTON	NSTAR
38380	Treasure Valley- SE	46664	NEXAMP CAPITAL-01543PV4999NM	4.999	4.999	0.670	0.000	N/A [5]	MA	027	WMA	MEC
38381	Belchertown SEd	46645	NEXAMP CAPITAL-01007PV1300NM	1.300	1.300	0.530	0.000	N/A [5]	MA	015	WMA	MEC
38421	Jericho Power	43580	JERICHO WIND	12.050	12.050	2.500	3.900	IA	NH	007	NH	JERICHO
38437	Ipswich Wind II	42424	IPSWICH WIND II	2.000	2.000	0.000	0.000	Cleared Capacity	MA	009	BOSTON	IMLD
38440	Cottage St PV	46267	COTTAGE STREET SOLAR FACILITY	3.894	3.894	1.635	0.000	N/A [5]	MA	019	WMA	WMECO
38441	UI RCP BGPT FC	38441	UI RCP BGPT FC	2.800	2.800	2.520	2.520	N/A [5]	CT	001	SWCT	UI
38442	UI RCP NH FC	38442	UI RCP NH FC	2.800	2.800	2.520	2.520	N/A [5]	CT	009	CT	UI
38475	Hoosac Wind Project	12529	HOOSAC WIND	28.500	28.500	3.942	10.412	IA	MA	003	WMA	PPMI

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW) Summer (50°F)	NRC (MW) Winter (0°F)	CNRC (MW) Summer (90°F)	CNRC (MW) Winter (20°F)	Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
38480	Hubbardston SE	46918	TOWN OF WESTFORD-01452PV2800NM	2.800	2.800	0.000	0.000	Cleared Capacity	MA	027	CMA/NEMA	MEC
38494	24 Boutilier Rd Leicester PV	48728	MECO.LCSTR-01524PV684QF	0.684	0.684	0.000	0.000	Cleared Capacity	MA	027	WMA	MEC
38495	DEEPWATER WIND BLOCK ISLAND	38495	BLOCK ISLAND WIND FARM	29.000	29.000	0.000	0.000	Cleared Capacity	RI	009	RI	DWBI
38500	Mass Mid-State Solar	44030	WARREN PV	14.000	14.000	7.110	0.000	N/A [5]	MA	027	WMA	MS1
38510	City of Gardner - Mill St. Solar	46568	GLC-MA SOLAR-01440PV1000NM	1.000	1.000	0.392	0.000	N/A [5]	MA	027	WMA	MEC
38527	Grafton WD	43729	GRAFTON WATER-01519PV1500NM	1.500	1.500	0.715	0.000	N/A [5]	MA	027	CMA/NEMA	MEC
38528	29 Oxford Rd Charlton PV	47996	NAT GRID CHARLTON-01507PV684QF	0.684	0.684	0.000	0.000	Cleared Capacity	MA	027	WMA	MEC
38530	Mattapoisett 2	47378	BLUEWAVE - MATTAPOISETT 2261	0.750	0.750	0.000	0.000	Cleared Capacity	MA	023	SEMA	NSTAR
38532	Leominster- South St.	43948	SUNGEN 1-01810PV950NM	2.850	2.850	1.409	0.000	N/A [5]	MA	017	BOSTON	MEC
		43949	SUNGEN 2-01810PV950NM									
		43950	SUNGEN 3-01810PV950NM									
38533	Berlin 1	46984	FIVEMILE RIVER1-01503PV750NM	0.750	0.750	0.347	0.000	N/A [5]	MA	027	CMA/NEMA	MEC
38534	Millbury Solar	44007	MILLBURY SOLAR-01527PV3000NM	3.000	3.000	1.638	0.000	N/A [5]	MA	027	CMA/NEMA	MEC
38538	Groton Road Shirley PV	47995	NATL GRID SHIRLEY-01464PV996QF	0.996	0.996	0.000	0.000	Cleared Capacity	MA	017	CMA/NEMA	MEC
38539	40 Auburn Rd Millbury PV	48314	NAT GRID MILLBURY-01527PV684QF	0.684	0.684	0.000	0.000	Cleared Capacity	MA	027	WMA	MEC
38544	17 Kelly Rd Sturbridge PV	48727	510PVDEVKELLY1-01566PV996QF	0.996	0.996	0.000	0.000	Cleared Capacity	MA	027	WMA	MEC
38545	90 River Rd Sturbridge PV	48726	510PV DEV. 2-01566PV996QF	0.996	0.996	0.000	0.000	Cleared Capacity	MA	027	WMA	MEC
38548	Fall River- Commerce	43951	SUNGEN-02720PV950NM	0.950	0.950	0.535	0.000	N/A [5]	MA	005	SEMA	MEC
38551	Fasll River - Innovation	43903	SUNGEN-02720PV2850NM	2.850	2.850	1.748	0.000	N/A [5]	MA	005	SEMA	MEC
38555	Berlin 2	46985	FIVEMILE RIVER2-01503PV750NM	0.750	0.750	0.339	0.000	N/A [5]	MA	027	CMA/NEMA	MEC
38556	Berlin 3	46986	FIVEMILE RIVER3-01503PV750NM	0.750	0.750	0.331	0.000	N/A [5]	MA	027	CMA/NEMA	MEC
38558	Fall River- Uxbridge	43643	SUNGEN UXBRIDGE1-01569PV950NM	2.850	2.850	1.474	0.000	N/A [5]	MA	027	RI	MEC
		43644	SUNGEN UXBRIDGE2-01569PV950NM									
		43645	SUNGEN UXBRIDGE3-01569PV950NM									
38559	Berlin 4	46987	FIVEMILE RIVER4-01503PV750NM	0.750	0.750	0.347	0.000	N/A [5]	MA	027	CMA/NEMA	MEC
38560	Grafton	47446	BWC 5 MILE RIVER-01519PV2000NM	2.000	2.000	0.000	0.000	Cleared Capacity	MA	027	CMA/NEMA	MEC
38561	True North	42193	TRUE NORTH ENERGY A	4.750	4.750	2.585	0.000	N/A [5]	MA	009	BOSTON	MEC
		42194	TRUE NORTH ENERGY B									
		42195	TRUE NORTH ENERGY C									
		42196	TRUE NORTH ENERGY D									
		42197	TRUE NORTH ENERGY E									
38562	Franklin 1	43952	KEARSARGE SOLAR-02038PV3000NM	3.000	3.000	1.499	0.000	N/A [5]	MA	013	RI	MEC
38565	Franklin 2	43953	KEARSARGE SOLAR-02038PV4000NM	4.000	4.000	2.146	0.000	N/A [5]	MA	013	RI	MEC
38567	Billerica	46731	BILLERICA-01821PV4999NM	4.999	4.999	0.967	0.000	N/A [5]	MA	017	CMA/NEMA	MEC
38574	Route 57	43887	NM-TOWN OF AGAWAM SOLAR	1.500	1.500	0.739	0.000	N/A [5]	MA	013	WMA	WMECO
38575	Agawam Solar	43885	NM-HP HOOD AND SONS	1.500	1.500	0.702	0.000	N/A [5]	MA	013	WMA	WMECO
38576	Whately	43886	NM-FRANKLIN COUNTY SHERIFF	1.500	1.500	0.617	0.000	N/A [5]	MA	011	WMA	WMECO
38579	Rehoboth	43915	CITIZENS-02769PV2000NM	2.000	2.000	1.093	0.000	N/A [5]	MA	005	RI	MEC
38580	AMESBURY	38580	HUNTRDSOLARLLC-01913PV4500NM	4.500	4.500	0.000	0.000	Cleared Capacity	MA	009	BOSTON	MEC
38581	TYNGSBOROUGH	38581	TYNGS.LANDFILL#1-01879PV1692NM	1.656	1.656	0.000	0.000	Cleared Capacity	MA	017	CMA/NEMA	MEC
38582	NORTON MA	49365	NORTONLANDFILL-02766PV1500NM	1.500	1.500	0.000	0.000	Cleared Capacity	MA	005	SEMA	MEC
38638	PASSADUMKEAG WIND PROJECT	38417	PASSADUMKEAG WIND PROJECT	39.975	39.975	0.000	0.000	N/A [5]	ME	019	BHE	EDFS
38669	FUTURE GEN WIND	47741	FUTURE GEN WIND	7.861	7.861	2.700	2.800	N/A [5]	MA	023	SEMA	CEEI
38701	Onset East	48714	ONSET EAST	1.000	1.000	0.000	0.000	Cleared Capacity	MA	023	SEMA	NSTAR
38702	Onset West	48715	ONSET WEST	1.000	1.000	0.000	0.000	Cleared Capacity	MA	023	SEMA	NSTAR
38704	Richardson Ave Attleboro PV 2	47994	NAT GRID ATTLEBORO02703PV996QF	0.996	0.996	0.000	0.000	Cleared Capacity	MA	005	RI	MEC
38760	NORWICH WWT	14823	NORWICH WWTP	2.000	2.000	2.000	2.000	N/A [5]	CT	011	CT	CMEEC
	No Resource [3]	973	CONCORD STEAM	1.300	1.300	N/A	N/A	N/A [5]	NH	013	NH	UNITIL-ES
	No Resource [3]	11827	PORTSMOUTH ABBEY WIND QF	0.445	0.660	N/A	N/A	N/A [5]	RI	005	SEMA	NEC
	No Resource [3]	11889	IBEW LOCAL 99 SOLAR QF	0.029	0.050	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	13933	JIMINY PEAK WIND QF	1.500	1.500	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	14767	PINE TREE LFGTE	2.893	2.893	N/A	N/A	N/A [5]	ME	019	BHE	FPLP
	No Resource [3]	14925	ICE HOUSE PARTNERS INC.	0.221	0.221	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	LELWD
	No Resource [3]	15462	HOLY NAME CC JR SR HIGH SCHOOL	0.600	0.600	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	15464	STETSON WIND FARM	59.710	59.710	N/A	N/A	IA	ME	029	BHE	STETSON
	No Resource [3]	16089	TURNERS FALLS HYDRO LLC	0.937	0.937	N/A	N/A	IA	MA	011	WMA	PSS

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
	No Resource [3]	16183	RICHEYWOODWORKINGWIND&PVQF	0.976	0.976	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	16188	WILSON HOLDINGS LLC - PV QF	0.135	0.135	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	16233	CITY OF MEDFORD WIND QF	0.100	0.100	N/A	N/A	N/A [5]	MA	017	BOSTON	MEC
	No Resource [3]	16234	CONSTELLATION-MAJILITE PV QF	0.375	0.375	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	16331	QUARRY ENERGY PROJECT	0.571	0.571	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	16386	NATURE'SCLASSROOM-01507WT185NM	0.185	0.185	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	16612	STETSON II WIND FARM	26.000	26.000	N/A	N/A	IA	ME	029	BHE	STET2
	No Resource [3]	17023	NE ENGRS MIDDLETOWN RI WIND QF	0.100	0.100	N/A	N/A	N/A [5]	RI	005	SEMA	NEC
	No Resource [3]	17085	AMERESCO-NEWBURYPORT DPW PV QF	0.095	0.095	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	17128	OTIS_AF_WIND_TURBINE	1.500	1.500	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	17194	TOWN_OF_FALMOUTH_WIND_TURBINE	1.000	1.000	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	17229	MOUNT ST MARY-WRENTHAM MA WIND	0.100	0.100	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	36882	NOTUS WIND I	1.500	1.500	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	37175	ROLLINS WIND PLANT	61.200	61.200	N/A	N/A	IA	ME	019	BHE	EWP3
	No Resource [3]	37224	PATRIOT PL. D FOXBORO MA PV	0.100	0.100	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	37225	PATRIOT PL. E FOXBORO MA PV	0.075	0.075	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	37226	PATRIOT PL. F FOXBORO MA PV	0.100	0.100	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	37227	PATRIOT PL. H FOXBORO MA PV	0.075	0.075	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	37228	PATRIOT PL. J FOXBORO MA PV	0.100	0.100	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	37229	PATRIOT PL. K FOXBORO MA PV	0.100	0.100	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	37230	UNITED NAT. FOODS PROV. RI PV	0.075	0.075	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	37266	CARLSON ORCH HARVARD MA PV	0.200	0.200	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	37267	SPRUCE ENV HAVERHILL MA PV	0.082	0.082	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	37721	ROYAL MILLS WARWICK RI HYDRO	0.179	0.179	N/A	N/A	N/A [5]	RI	003	RI	NEC
	No Resource [3]	37751	NM-UNISTRESS	0.097	0.097	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	37752	NM-COUNTRY	0.127	0.127	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	37753	NM-HANCOCK	0.082	0.082	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	37754	NM-QUALITY	0.130	0.130	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	37755	NM-WOOD	0.097	0.097	N/A	N/A	N/A [5]	MA	011	WMA	WMECO
	No Resource [3]	37756	NM-FOURSTAR	0.067	0.067	N/A	N/A	N/A [5]	MA	011	WMA	WMECO
	No Resource [3]	37757	NM-ASTRO	0.097	0.097	N/A	N/A	N/A [5]	MA	013	WMA	WMECO
	No Resource [3]	37758	NM-MARLEY	0.085	0.085	N/A	N/A	N/A [5]	MA	015	WMA	WMECO
	No Resource [3]	37759	NM-STONE	0.615	0.615	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	37760	NM-RIVERVIEW	0.170	0.170	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	37761	NM-PETRICCA	0.086	0.086	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	37955	TRANS MED TYNGSBORO MA PV	0.096	0.096	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	37956	PH HENBIL BILLERICA MA PV	0.075	0.075	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	37957	CHELM WTR N CHELMSFORD MA PV	0.500	0.500	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	37958	PETER W ELEM LOWELL MA PV	0.138	0.138	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	37959	CIRCLE FIN NEWBURYPORT MA PV	0.120	0.120	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	37965	BIO-DETEK PAWTUCKET RI PV	0.165	0.165	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	37966	LTI HARVARD AP HARVARD MA PV	0.085	0.085	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	37967	HILLSIDE MARLBOROUGH MA PV	0.125	0.125	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	37968	LOW MEM AUD LOWELL MA PV	0.075	0.075	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	37972	DARTMOUTHBUSPARK_PV_ID1592	1.600	1.600	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	37973	GENERAL MILLS METHUEN MA PV	0.096	0.096	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	38757	UI RCP WOODBRIDGE FC	2.200	2.200	N/A	N/A	N/A [5]	CT	009	SWCT	UI
	No Resource [3]	39663	BARNSTABLE_DPW_ID1545	0.200	0.200	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	39664	DART_BLDG_SUPPLY_ID1470	0.200	0.200	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	39665	YARMOUTH_DPW_ID1740	0.265	0.265	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	39675	TURKEY HILL	0.100	0.100	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	39717	HI-GEAR	0.300	0.300	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	39722	GTR_BOSTON_FOODBANKS_ID1628	0.177	0.177	N/A	N/A	N/A [5]	MA	025	BOSTON	NSTAR
	No Resource [3]	39724	EASTERN_AVE_HOLDINGS_PV_ID1652	0.160	0.160	N/A	N/A	N/A [5]	MA	025	BOSTON	NSTAR
	No Resource [3]	39738	MWRA_LORING_RD_ID1400	0.189	0.189	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	40050	EXETER AGRI ENERGY	0.980	0.980	N/A	N/A	N/A [5]	ME	019	BHE	VPPSA

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
	No Resource [3]	40066	OLDBARNST_RD_MASHPEE_PV_ID1798	0.312	0.312	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	40067	MARION_DR_KINGSTON_WT_ID1656	6.000	6.000	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	40085	QUABBIN 1_ORANGE MA PV NET	0.095	0.095	N/A	N/A	N/A [5]	MA	011	WMA	MEC
	No Resource [3]	40116	DELAWARE VALLEY CORP PV	0.095	0.095	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	40137	BERKSHIRE EAST WIND	0.900	0.900	N/A	N/A	N/A [5]	MA	011	WMA	MEC
	No Resource [3]	40194	MICRON	0.096	0.096	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	40225	MILLIPORE PV - BILLERICA	0.143	0.143	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	40242	TANTASQUA JR HIGH_PV	0.300	0.300	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	40243	SOLAR SHOP LLC BLDG 14_PV	0.256	0.256	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	40244	SOLAR SHOP LLC BLDG 10_PV	0.120	0.120	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	40246	HODGES BADGE CO_WIND	0.225	0.225	N/A	N/A	N/A [5]	RI	005	SEMA	NEC
	No Resource [3]	40247	QUABBIN BARRE - WIND	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	40248	JJ CARROLL WW PLANT_PV	0.300	0.300	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	40249	WESTBORO SUITES	0.266	0.266	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	40250	SHAWS SUPER MARKET	0.250	0.250	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	40251	VETERAN HOMESTEAD PV	0.323	0.323	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	40259	COMMERCE_PK_RD_PV_ID1871	0.350	0.350	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	40263	MATOUK TEXTILE WORKS	0.084	0.084	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	40270	TECTA AMERICA	0.130	0.130	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	40343	BULL HILL WIND	34.485	34.485	N/A	N/A	IA	ME	009	BHE	BSE
	No Resource [3]	40365	EAST ISLAND COMMUNITY - PV	0.100	0.100	N/A	N/A	N/A [5]	MA	009	CMA/NEMA	MEC
	No Resource [3]	40482	DURFEE UNION MILLS BLDG 9 - PV	0.120	0.120	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	40483	TYNGSBOROUGH SPORTS PV	0.100	0.100	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	40484	BANCROFT SCHOOL PV	0.120	0.120	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	40485	LITCHFIELD LEOMINSTER PV	0.062	0.062	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	40520	MANCHESTER-BOSTON REGIONAL PV	0.500	0.500	N/A	N/A	N/A [5]	NH	011	NH	PSNH
	No Resource [3]	40524	MOUNT WACHUSSETT CC WIND	3.300	3.300	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	40555	BLACKCOMB WORC MA PV	0.430	0.430	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	41782	PAWTUCKET MEMORIAL ELEM SCH	0.100	0.100	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	41783	PHOENIX FINANCE LLC	0.190	0.190	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	41784	NANTUCKET HIGH SCHOOL	0.100	0.100	N/A	N/A	N/A [5]	MA	019	SEMA	MEC
	No Resource [3]	41806	NM-PROPEL	0.260	0.260	N/A	N/A	N/A [5]	MA	011	WMA	WMECO
	No Resource [3]	41807	NM-PITTSFIELD WWTP	1.500	1.500	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	41808	NM-MASS DEP	0.120	0.120	N/A	N/A	N/A [5]	MA	013	WMA	WMECO
	No Resource [3]	41810	NM-FULL BLOOM MARKET	0.100	0.100	N/A	N/A	N/A [5]	MA	011	WMA	WMECO
	No Resource [3]	41811	NM-BERKSHIRE CC	0.386	0.386	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	41816	QUABOAG REGIONAL ELEM - PV	0.100	0.100	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	41819	US PACK - PV	0.200	0.200	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	41820	EDMUND TALBOT MS - PV	0.200	0.200	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	41821	NEW ENGLAND TECH WIND	1.000	1.000	N/A	N/A	N/A [5]	RI	003	RI	NEC
	No Resource [3]	41822	SOLTAS CBIS INC - PV	0.300	0.300	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	41827	TOWN_OF_FAIRHAVEN_WT_ID1663	0.350	0.350	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	41828	TOWN_OF_FAIRHAVEN_WT_ID1664	0.350	0.350	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	41829	MWRA_ALFORD_ST_WT_ID1638	1.500	1.500	N/A	N/A	N/A [5]	MA	025	BOSTON	NSTAR
	No Resource [3]	41830	TOWN_OF_KINGSTON_WT_ID1833	2.000	2.000	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	41833	JEM ELECTRONIS PV	0.214	0.214	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	41834	CLARKE DISTRIBUTION PV	0.375	0.375	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	41838	WEST BROOKFIELD ELEM - PV	0.096	0.096	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	41839	ARPIN ASSOCIATES - PV	0.150	0.150	N/A	N/A	N/A [5]	RI	003	RI	NEC
	No Resource [3]	41840	AERO MANUFACTURING	0.096	0.096	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	41841	EXAJOULE FRANKLIN PV	0.260	0.260	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	41842	KB SOLAR LLC - PV	0.250	0.250	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	41843	NORTHEAST TREATERS	0.224	0.224	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	41844	LOWELL TRANSIT MGMT PV	0.500	0.500	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	41845	TRADER JOES SAUGUS PV	0.225	0.225	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	41846	KOLLMORGEN PV	0.210	0.210	N/A	N/A	N/A [5]	MA	015	WMA	MEC

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
	No Resource [3]	41847	FISHERMENS MEMORIAL PARK- WIND	0.100	0.100	N/A	N/A	N/A [5]	RI	009	RI	NEC
	No Resource [3]	41848	SOLAR SHOP WHITINSVILLE - PV	0.500	0.500	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	41856	MASSASOIT COMMUNITY COLLEGE	0.370	0.370	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	41857	HI- GEAR (QF)	0.675	0.675	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	41863	THE WHEELER SCHOOL	0.100	0.100	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	41864	NM-EHAMPTON MA LANDFILL	2.000	2.000	N/A	N/A	N/A [5]	MA	015	WMA	WMECO
	No Resource [3]	41866	LOWES HOME CENTER QUINCY - PV	0.340	0.340	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	41867	SCITUATE TOWN OF WIND	1.500	1.500	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	41868	AGREEN ENERGY (JORDAN DAIRY)	0.600	0.600	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	41870	EXAJOULE RENEWABLES PV	0.360	0.360	N/A	N/A	N/A [5]	MA	017	BOSTON	MEC
	No Resource [3]	41871	QUABBIN SOLAR - PV	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	41881	TOWN OF SWAMPSCOTT HS - PV	0.350	0.350	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	41882	NEXAMP CAP-NASHOBA VALLEY THS	0.096	0.096	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	41921	M&I REALTY JAMES ST - PV	0.200	0.200	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	41922	LIGHTOLIER - WIND	2.000	2.000	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	41923	BLACKCOMB SOLAR III-PV	1.000	1.000	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	41924	COREMARK-PV	1.000	1.000	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	42041	D.D. BEAN	0.027	0.027	N/A	N/A	N/A [5]	NH	005	VT	CNE
	No Resource [3]	42043	SWANSEA WATER DISTRICT	0.080	0.080	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	42045	NM-GREENFIELD MA LANDFILL	2.000	2.000	N/A	N/A	N/A [5]	MA	011	WMA	WMECO
	No Resource [3]	42046	ST. MARYS HIGH SCHOOL	0.155	0.155	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42048	TANTASQUA HIGH- PV	0.586	0.586	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	42050	PETE'S TIRE BARN	0.155	0.155	N/A	N/A	N/A [5]	MA	011	WMA	MEC
	No Resource [3]	42083	CANTON_LANDFILL_PV_ID1726	3.000	3.000	N/A	N/A	N/A [5]	MA	021	SEMA	NSTAR
	No Resource [3]	42091	QUABOAG REGIONAL HS - PV	0.096	0.096	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	42092	TOWN OF SUTTON MA PV	0.175	0.175	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	42104	HYDEPARKSTORPV_ID1919	0.190	0.190	N/A	N/A	N/A [5]	MA	025	BOSTON	NSTAR
	No Resource [3]	42105	MILLST_NATICKPV_ID1818	0.202	0.202	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	42106	SUBURBANATHLETIC2_ID1637	0.110	0.110	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	42107	4M_ALDRINRDPV_ID1856	0.200	0.200	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	42108	BROADWAY_RENEWABLE_ID1772	0.907	0.907	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	42109	COCHITUATERD_FRAMPV_ID1873	0.204	0.204	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	42110	DOUGLAS_SCHOOLPV_ID1464	0.095	0.095	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	42111	HYANNIS_SELF_STOR_ID1946	0.475	0.475	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	42112	POND_ST_ASHLAND_ID1736	0.500	0.500	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	42115	GLC_ACUSHNETLLC_ID1821_1824	3.500	3.500	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	42116	DSD_REALTY_TRUST_ID1672	1.720	1.720	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	42117	CONST_SOLAR_NORFOLK_ID1846	1.600	1.600	N/A	N/A	N/A [5]	MA	021	RI	NSTAR
	No Resource [3]	42118	CONED_HIXVILLERD_ID1862	2.000	2.000	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	42135	18 PHOENIX PARK BLDG DEAST & F	0.100	0.100	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	42136	18 PHOENIX PARK BLDG DEAST & J	0.100	0.100	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	42137	18 PHOENIX PARK BLDG DWEST	0.100	0.100	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	42149	FAVORITE FOODS PV	0.045	0.045	N/A	N/A	N/A [5]	NH	017	NH	PSNH
	No Resource [3]	42155	LEICESTER HS - BWAY RENEWABLE	0.175	0.175	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	42156	UMASS LOWELL LEITCH HALL	0.120	0.120	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	42158	MOHAWK DRIVE CORPORATION	0.113	0.113	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	42201	MATTHEW KUSS MS	0.135	0.135	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	42202	DR AMP 100 AMES POND - PV	0.082	0.082	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	42204	BPV LOWELL	0.190	0.190	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	42205	SALEM STATE UNIVERSITY	0.164	0.164	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42212	DR AMP 200 AMES POND - PV	0.095	0.095	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	42213	CUMMINGS PROPERTY E GAR	0.190	0.190	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42214	ORCHARD MADE PRODUCTS	0.190	0.190	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42344	CAMELOT_WIND_ID1240	1.500	1.500	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	42346	3 RIVERS PALMER-SPRINGFLD-PV	0.582	0.582	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	42347	CONSTELLATION SOLAR-UXBRG-PV	2.000	2.000	N/A	N/A	N/A [5]	MA	027	RI	MEC

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW) Summer (50^{0}F)	NRC (MW) Winter (0^{0}F)	CNRC (MW) Summer (90^{0}F)	CNRC (MW) Winter (20^{0}F)	Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
	No Resource [3]	42349	15 UNION SOLAR LLC-LAWRENCE-PV	0.490	0.490	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42350	BARRETT-FRANKLIN-SOLAR	0.500	0.500	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	42351	OMA GROUP-CHARLTON-PV	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	42352	OSG SOLAR 1-ORANGE-PV	1.000	1.000	N/A	N/A	N/A [5]	MA	011	WMA	MEC
	No Resource [3]	42353	OSG SOLAR 2-ORANGE-PV	1.000	1.000	N/A	N/A	N/A [5]	MA	011	WMA	MEC
	No Resource [3]	42354	OSG SOLAR 3-ORANGE-PV	0.750	0.750	N/A	N/A	N/A [5]	MA	011	WMA	MEC
	No Resource [3]	42355	CIL CEDAR-MARLBORO-PV	0.433	0.433	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	42356	LEEWOOD SWIX-HAVERHILL-PV	0.496	0.496	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42357	UP BLACKSTONE WWTP-MILLBURY-PV	0.300	0.300	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	42359	FOREKICKS-MARLBORO-PV	0.270	0.270	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	42360	35 LYMAN LLC-NORTHBORO-PV	0.285	0.285	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	42364	CAPITAL GROUP-SOUTHBORO-PV	1.000	1.000	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	42365	LOFT 27-LOWELL-PV	0.275	0.275	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	42366	SOLTAS SPECTOR-LAWRENCE-PV	0.300	0.300	N/A	N/A	N/A [5]	MA	009	CMA/NEMA	MEC
	No Resource [3]	42385	CORNER BROOK-MILFORD-PV	0.155	0.155	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	42394	WINDENERGYDEV-NKINGSTOWN-WIND	1.500	1.500	N/A	N/A	N/A [5]	RI	009	RI	NEC
	No Resource [3]	42411	EXTRA SPACE-PLAINVILLE-PV	0.143	0.143	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	42412	EXTRA SPACE-SAUGUS-PV	0.162	0.162	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42413	35 LYMAN LLC - ACTIVE	0.190	0.190	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	42414	NE ELECTRO-FALL RIVER-PV	0.190	0.190	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	42431	SOLECT PLUMBING-NORWELL-PV	0.200	0.200	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	42432	VAUGHN CORP-SALISBURY-PV	0.190	0.190	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42433	BETHANY CHURCH-MENDON-PV	0.150	0.150	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	42438	EXTRA SPACE-NORTHBORO-PV	0.155	0.155	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	42439	CITY OF BROCKTON-SWANSEA-PV1	1.000	1.000	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	42440	CITY OF BROCKTON-SWANSEA-PV2	1.000	1.000	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	42443	WAL-MART LUN (PV)	0.300	0.300	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	42444	MRTA (PV)	0.135	0.135	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	42448	CITY OF GLOUCESTER 1 - WIND	2.000	2.000	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42449	CITY OF GLOUCESTER 2 - WIND	2.000	2.000	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42482	CITY_OF_WALTHAM_PV_ID1805	0.193	0.193	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	42483	FIRST_HIGHLAND_PV_ID2021	0.975	0.975	N/A	N/A	N/A [5]	MA	025	BOSTON	NSTAR
	No Resource [3]	42484	UNITEDSALVAGE_PV_ID1966	0.808	0.808	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	42485	SOLCHEMY_PV_ID1969	0.293	0.293	N/A	N/A	N/A [5]	MA	007	SEMA	NSTAR
	No Resource [3]	42486	AIRPORT_WAY_PV_ID1875	1.238	1.238	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	42487	BILL_BENNETT_PV_ID1967	0.593	0.593	N/A	N/A	N/A [5]	MA	007	SEMA	NSTAR
	No Resource [3]	42495	VARIANSEMICON-GLOUCESTER-WT	2.500	2.500	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42496	HANOVER SOLAR-LEICESTER-PV	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	42504	BERKSHIRE SREG-GT BARRGTN-PV	0.082	0.082	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	42505	CUMMINGS 1000-BEVERLY-PV	0.190	0.190	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42597	GPT JACLEN-BEVERLY-CHP	0.075	0.075	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42599	MAPREMCT-97GREEN-02035-PV	0.300	0.300	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	42600	HOOSACVALREG-0ORCHARD-01225-PV	0.450	0.450	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	42601	CARLSTROMPM-65FISHER-0158-PV	0.600	0.600	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	42602	KEYPOLYMER-1 JACOB-01843-PV	0.600	0.600	N/A	N/A	N/A [5]	MA	009	CMA/NEMA	MEC
	No Resource [3]	42603	BARRE1-750BARRE-01005-PV	0.800	0.800	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	42611	AUBUCHON-95AUBUCHON-01473-PV	0.500	0.500	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	42612	NPPDEVELOP-370PATRIOT-02035-PV	0.495	0.495	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	42613	AMERICOLD-0PEW-01930-PV	0.450	0.450	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42631	CABRAL-247BAKER-02777-PV	0.500	0.500	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	42632	ALPHA GRAINGER-02038PV250NM	0.250	0.250	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	42633	NORTHBORSPORTS-01532PV300NM	0.300	0.300	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	42641	NATICKMEMORIALSCHOOL_PV_ID1892	0.140	0.140	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	42812	PEGASUS_PV_ID1809	1.000	1.000	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	42813	BIG Y FOODS-02038PV250NM	0.250	0.250	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	42814	SWANSEA REALTY-02777PV315NM	0.315	0.315	N/A	N/A	N/A [5]	MA	005	RI	MEC

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
	No Resource [3]	42815	WILLETTE REALTY-02762PV225NM	0.225	0.225	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	42816	JAY CASHMAN-02169PV155NM	0.155	0.155	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	42817	IKEA 158-0223PV520NM	0.520	0.520	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	42819	CUMMINGS PROP 1-0195PV224NM	0.224	0.224	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42820	CUMMINGS PROP 2-01915PV224NM	0.224	0.224	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	42821	GLC-MA ACUSHNET_PV_ID2109	0.649	0.649	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	42822	CARDINAL SHOE-01840PV250NM	0.250	0.250	N/A	N/A	N/A [5]	MA	009	CMA/NEMA	MEC
	No Resource [3]	42823	WALDEN LIBERTY-02038PV231NM	0.231	0.231	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	42893	BISCO FALLS HYDRO	0.093	0.093	N/A	N/A	N/A [5]	ME	017	ME	UNION
	No Resource [3]	43256	SANDYWOODS-02878WT275NM	0.275	0.275	N/A	N/A	N/A [5]	RI	005	SEMA	NEC
	No Resource [3]	43257	LEICESTER MS C-01524PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43262	BERKSHIRE SCHL-01257PV1750NM	1.760	1.760	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	43263	JF WHITE-02702PV86NM	0.086	0.086	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	43267	PLANET SUBARU-02339PV75NM	0.075	0.075	N/A	N/A	N/A [5]	MA	023	RI	MEC
	No Resource [3]	43269	SIGN DESIGN-02301PV95NM	0.095	0.095	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	43270	LEICESTER MS A-01524PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43409	GLC-MA ACUSHNET_PV_ID1827	1.304	1.304	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	43411	S BARRE-01005PV800NM	0.800	0.800	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43416	MIG ACTON-01581PV260NM	0.260	0.260	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43417	WORCESTER SCHL-01602PV135NM	0.135	0.135	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43418	FALLON AMB-02169PV116NM	0.116	0.116	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	43420	BANNER MOLD-01453PV111NM	0.111	0.111	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43422	EPG SOLAR 1 - 01550PV1500NM	1.500	1.500	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43423	EPG SOLAR 2 - 01550PV1500NM	1.500	1.500	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43424	PINGREE SCHL - 01982PV200NM	0.200	0.200	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	43425	NPP DEV - 02035PV125NM	0.125	0.125	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	43426	ABBOTT MILL - 01886PV235NM	0.235	0.235	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	43489	BOST SCIENT-02171PV1100NM	1.100	1.100	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	43491	146 CAMPANELLI-02072PV332NM	0.332	0.332	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	43492	NARR BAY - 02903WT4500NM	4.500	4.500	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	43509	DOUGLAS SOLAR-01516PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	43510	SANDF MGMNT-02725PV623NM	0.623	0.623	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	43512	WEST GREENWICH - 02817PV2000DG	2.000	2.000	N/A	N/A	N/A [5]	RI	003	RI	NEC
	No Resource [3]	43527	STUART THOMAS - 02842PV500DG	0.500	0.500	N/A	N/A	N/A [5]	RI	005	SEMA	NEC
	No Resource [3]	43528	EXTRA SPC MGMT-02035PV102NM	0.102	0.102	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	43529	CREEDON AND CO-01604PV110NM	0.110	0.110	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43531	28 HASTINGS - 01756PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	43556	CALLAHAN - 02324PV110NM	0.110	0.110	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	43557	BRDGWTR RECYCLE-02324PV96NM	0.096	0.096	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	43558	COMMERCE GRN-02339PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	43572	JDH_SOLAR_SYSTEMS_PV_2221	0.650	0.650	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	43573	NEW_ENGLAND_RESINS_PV_2309	0.060	0.060	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	43574	TOWN_OF_FAIRHAVEN_LF_PV_1714	0.500	0.500	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	43575	NE_ELEMENTARY_WALTHAM_PV_1872	0.259	0.259	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	43576	GLC_ACUSHNET_PV_1888	0.917	0.917	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	43577	GLC_ACUSHNET_PV_1889	0.917	0.917	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	43578	GLC_ACUSHNET_PV_1890	0.917	0.917	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	43579	GOIS_SOLAR_ONE_PV_2040	0.822	0.822	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	43586	COMTRAN CABLE-02864PV400DG	0.400	0.400	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	43587	TRAVIS_HOSPITALITY_PV_2239	0.145	0.145	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	43603	WORC GEAR AND RACK-01537PV95NM	0.095	0.095	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43604	METRO WST PROVIS-01747PV95NM	0.095	0.095	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	43605	PRECISE PACK-02720PV95NM	0.095	0.095	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	43606	CITY NORTHAMPTON-02721PV95NM	0.095	0.095	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	43607	COX PRTSMTH-02871PV500DG	0.500	0.500	N/A	N/A	N/A [5]	RI	005	RI	NEC
	No Resource [3]	43608	35 LYMAN LLC-01532PV95NM	0.095	0.095	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
	No Resource [3]	43609	MA CORRECTIONAL-01440WT3300NM	3.300	3.300	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43624	TJ MAXX - 02061PV260NM	0.260	0.260	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	43652	TWN W BRDGEWTR-02379PV1500NM	1.500	1.500	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	43653	40 WASHINGTON LTD-01581PV750NM	0.750	0.750	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43654	3 COUNTY FAIR ASN-01060PV250NM	0.250	0.250	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	43655	SPRING HILL FARM-01835PV229NM	0.229	0.229	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	43656	SVC TIRE TRUCK - 01527PV300NM	0.300	0.300	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43657	RIPTA - 02907PV300NM	0.300	0.300	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	43658	TWN LANCASTER-01523PV500QF	0.500	0.500	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43659	TWN OF SCITUATE2-02066PV1500NM	1.500	1.500	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	43678	DISCOVER MARBLE - 01527PV142NM	0.142	0.142	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43682	NEXTSUN ENERGY-01516PV3000NM	3.000	3.000	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	43683	TWN OF SCITUATE1-02066PV1500NM	1.500	1.500	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	43684	KEY BOSTON-02038PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	43685	CONANICUT MARINE-02835PV120DG	0.120	0.120	N/A	N/A	N/A [5]	RI	005	SEMA	NEC
	No Resource [3]	43686	SHEA CONCRETE-01913PV300NM	0.300	0.300	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	43687	SUNGEN ORANGE1-01364PV1500NM	1.500	1.500	N/A	N/A	N/A [5]	MA	011	WMA	MEC
	No Resource [3]	43688	SUNGEN ORANGE2-01364PV1500NM	0.500	0.500	N/A	N/A	N/A [5]	MA	011	WMA	MEC
	No Resource [3]	43689	BOSTON NORTH TECH-01913PV300NM	0.300	0.300	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	43690	OXFORD REALTY-01604PV145NM	0.145	0.145	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43691	CRAFT INC-02703PV285NM	0.285	0.285	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	43695	KOHLS-01906PV252NM	0.252	0.252	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	43696	STOP AND SHOP-02155PV200NM	0.200	0.200	N/A	N/A	N/A [5]	MA	017	BOSTON	MEC
	No Resource [3]	43698	NTHBRDGE SOLAR-01560PV1910NM	1.910	1.910	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	43706	CITY OF LOWELL1-01364PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	011	WMA	MEC
	No Resource [3]	43707	CITY OF LOWELL2-01364PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	011	WMA	MEC
	No Resource [3]	43708	HANNAFORD-02061PV135NM	0.135	0.135	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	43709	CITY OF LOWELL 1-01331PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43710	CITY OF LOWELL 2-01331PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43711	CITY OF LOWELL 3-01331PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43712	PHOENIX FIN5-01464PV95NM	0.095	0.095	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	43713	CUMMINGS PROP-01915PV110NM	0.110	0.110	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	43714	EXTRA SPC STOR-02189PV95NM	0.095	0.095	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	43715	MILFORD IND-01757PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	43716	NEXAMP-02852PV2000DG	2.000	2.000	N/A	N/A	N/A [5]	RI	009	RI	NEC
	No Resource [3]	43717	ASSUMPTION-01562PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43731	JEFFERSON-02720PV95NM	0.095	0.095	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	43734	TOWN EASTON-02375PV1500NM	1.500	1.500	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	43735	28 HASTINGS-01756PV95NM	0.095	0.095	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	43736	SMITH COLLEGE-01060NG3500QF	3.500	3.500	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	43747	PARSONS GRP-01581PV95NM	0.095	0.095	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43748	ACUMEN-01752PV85NM	0.085	0.085	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	43749	WILVECO-01821PV82NM	0.082	0.082	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	43750	CANTON HIGH SCHOOL 2009	0.500	0.500	N/A	N/A	N/A [5]	MA	021	SEMA	NSTAR
	No Resource [3]	43751	EAGLE LEASE-01540PV95NM	0.094	0.094	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43752	EXTRA SPACE-01607PV91.2NM	0.091	0.091	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43762	FORBES STREET 1-02914PV3000DG	3.000	3.000	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	43766	EXTRA SPACE-02149PV237NM	0.237	0.237	N/A	N/A	N/A [5]	MA	017	BOSTON	MEC
	No Resource [3]	43840	SOLVENTERRA-01069PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	43841	FLAIR ONE-01507PV950NM	0.950	0.950	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43842	FORRESTALL-01507PV950NM	0.950	0.950	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43869	FRPV WEST-02720PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	43870	FRPV EAST-02720PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	43871	SYNAGRO-02895CHP2000QF	2.000	2.000	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	43874	MASS MOCA1-01247PV225NM	0.225	0.225	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	43875	CUMMINGS PROP-01915PV230NM	0.230	0.230	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50^{0}F)	Winter (0^{0}F)	Summer (90^{0}F)	Winter (20^{0}F)					
	No Resource [3]	43876	KENNEDY CARPET-02189PV95NM	0.095	0.095	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	43878	MCI WORLD COMM-01821PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	43884	MASS MOCA3 01247PV177NM	0.177	0.177	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	43892	SYNCARPHA SOLAR-01740PV4950NM	4.950	4.950	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43893	HUBBARDSTON-01452PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43904	CITY OF METHUEN-01523PV3000NM	3.000	3.000	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	43907	PALMER SOLAR-01069PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	43908	NEXTSUN ENERGY-02370PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	43916	TOWN OF ADAMS-01220PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	43917	CHEER PACK-02397PV1750NM	1.750	1.750	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	43918	CITY OF LOWELL-01851PV1333NM	1.333	1.333	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	43919	SOLVENTERRA 1-01535PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43920	SOLVENTERRA 2-01535PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43921	COXCOM-02893PV135DG	0.135	0.135	N/A	N/A	N/A [5]	RI	003	RI	NEC
	No Resource [3]	43922	SOLVENTERRA 4-01083PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43923	PLYMOUTH PUBLIC SCHOOLS-#2062	4.000	4.000	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	43924	TOWN OF DARTMOUTH #1777	1.250	1.250	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	43927	SOUTHERN SKY-CARVER #1 (1997)	1.000	1.000	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	43928	SOUTHERN SKY-CARVER #2 (1998)	1.000	1.000	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	43929	SOUTHERN SKY-CARVER #4 (2000)	1.000	1.000	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	43930	SOUTHERN SKY-CARVER #5 (2001)	1.000	1.000	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	43932	SOUTHERN SKY-CARVER #3 (1999)	1.000	1.000	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	43936	SOLVENTERRA 1-01083PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43937	SOLVENTERRA 2-01083PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43938	SOLVENTERRA 3-01083PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43954	NM-LUDLOW LANDFILL	2.000	2.000	N/A	N/A	N/A [5]	MA	013	WMA	WMECO
	No Resource [3]	43955	CITY OF METHUEN-01844PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	43956	MILLWORK-02920PV495NM	0.495	0.495	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	43991	PROFETTY-02379PV300NM	0.300	0.300	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	43992	CITY OF WORCESTER-01603PV135NM	0.466	0.466	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	43993	CITY OF MELROSE-02176PV260NM	0.260	0.260	N/A	N/A	N/A [5]	MA	017	BOSTON	MEC
	No Resource [3]	43994	NORMANDY GATOR-01752PV110NM	0.110	0.110	N/A	N/A	N/A [5]	MA	005	CMA/NEMA	MEC
	No Resource [3]	43995	NORMANDY GATOR-01752PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	005	CMA/NEMA	MEC
	No Resource [3]	44003	ALTUS-02907PV1225DG	1.225	1.225	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	44004	ALTUS-02907PV300DG	0.300	0.300	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	44005	ALTUS 1-02864PV450DG	0.450	0.450	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	44006	ALTUS 2-02864PV450DG	0.450	0.450	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	44008	PWRR-01610PV130NM	0.130	0.130	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	44010	GOLDEN-02920PV300DG	0.300	0.300	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	44011	ENDICOTT-01915PV800NM	0.800	0.800	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	44023	WRTA-01608PV75QF	0.075	0.075	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	44026	STONEHILL-02356PV84NM	0.084	0.084	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	44027	SCITUTATE TENNIS-02066PV281NM	0.281	0.281	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	44028	TEAMWORK LABOR-02375PV75NM	0.075	0.075	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	44029	C&R TIRE-01606PV81NM	0.081	0.081	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	44035	TOWER SOLAR-02723PV485NM	0.485	0.485	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	46210	NEXAMP-01475PV1900NM	1.900	1.900	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	46211	GIGUERE-01524PV75NM	0.075	0.075	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	46212	BODWELL REALTY-02322PV75NM	0.075	0.075	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	46213	PINGREE SCHOOL-01982PV85NM	0.085	0.085	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	46220	BERKELEY-01844PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	46221	JP SULLIVAN-01432PV90NM	0.090	0.090	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	46268	OLD TIME SPORTS-01952PV150NM	0.150	0.150	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	46294	LAWRENCE 1-01840PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	009	CMA/NEMA	MEC
	No Resource [3]	46295	LAWRENCE 2-01840PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	009	CMA/NEMA	MEC
	No Resource [3]	46479	CANTON_MIDDLE_SCHOOL_2013	0.225	0.225	N/A	N/A	N/A [5]	MA	021	SEMA	NSTAR

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
	No Resource [3]	46480	CEDAR_SOLAR1_2411	0.085	0.085	N/A	N/A	N/A [5]	MA	025	BOSTON	NSTAR
	No Resource [3]	46481	TOWN_OF_MARSHFIELD_1865	3.000	3.000	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	46482	NEWBEDFORD_DPI_1843_1844	3.500	3.500	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	46483	MILFORD INDUSTRIAL-0175PV82NM	0.082	0.082	N/A	N/A	N/A [5]	MA	009	RI	MEC
	No Resource [3]	46484	WORCESTER SCHL-01602PV75NM	0.075	0.075	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	46485	NPP DEVELOPMENT-02035PV75NM	0.075	0.075	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	46486	WB HUNT-02176PV75NM	0.075	0.075	N/A	N/A	N/A [5]	MA	017	BOSTON	MEC
	No Resource [3]	46487	CIDER HILL-01913PV78NM	0.078	0.078	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	46537	CUMMINGS-0191PV82NM	0.082	0.082	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	46538	SILVIA-02720PV75NM	0.075	0.075	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	46539	BCC SEA QALIBC-01854PV66NM	0.066	0.066	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	46540	NPP DEVELOPMENT-02035PV62NM	0.062	0.062	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	46541	TEKNOR APEX-02703PV75NM	0.075	0.075	N/A	N/A	N/A [5]	MA	023	RI	MEC
	No Resource [3]	46564	EPG SOLAR-01005PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	46565	CABOT BEVERLY-01915PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	46566	PRECISE PACKAGING-02720PV250NM	0.250	0.250	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	46567	NORTH BROOKFIELD-01535PV3000NM	3.000	3.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	46569	NUGEN NCMC (PV)	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	46570	NUGEN LUN (PV)	2.500	2.500	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	46607	HARVARD SOLAR-01451PV460NM	0.460	0.460	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	46636	GOOSE RIVER HYDRO, INC.	0.375	0.375	N/A	N/A	N/A [5]	ME	027	ME	GOOSE
	No Resource [3]	46641	205 STURBRIDGE-01010PV3000NM	3.000	3.000	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	46643	EPG SOLAR-01005PV1500NM	1.500	1.500	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	46644	UGT RENEW ENERGY-01540PV2750NM	2.750	2.750	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	46646	SOLTAS ENERGY-01010PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	46647	BLUEWAVE CAPITAL-02769PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	46653	WESTBORO SOLAR-01581PV1820NM	1.820	1.820	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	46657	INDIAN HILL-01069PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	46659	BROWN SOLAR-01069PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	46660	STATE SOLAR-01069PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	46662	DISTRIBUTOR CORP-02148PV300NM	0.300	0.300	N/A	N/A	N/A [5]	MA	017	BOSTON	MEC
	No Resource [3]	46663	CITY OF LAWRENCE-01841PV300NM	0.300	0.300	N/A	N/A	N/A [5]	MA	009	CMA/NEMA	MEC
	No Resource [3]	46665	SX INDUSTRIES-02072PV170NM	0.170	0.170	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	46666	CUMMINGS-01915PV224NM	0.224	0.224	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	46667	E NAZARENE-02170PV85NM	0.085	0.085	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	46691	CORNERSTONE-01057PV3000NM	3.000	3.000	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	46717	EAST BAY-02915PV70NM	0.070	0.070	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	46718	EXTRA SPACE-02151PV144.3NM	0.144	0.144	N/A	N/A	N/A [5]	MA	025	BOSTON	MEC
	No Resource [3]	46719	STONEHILL COLL-02356PV2225QF	2.225	2.225	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	46721	ALL AMERICAN-02852PV250DG	0.250	0.250	N/A	N/A	N/A [5]	RI	009	RI	NEC
	No Resource [3]	46732	PIONEER SOLAR-01453PV495NM	0.495	0.495	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	46733	TKS SOLAR-02301PV180NM	0.180	0.180	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	46911	NEXTSUN ENERGY-02896PV850DG	0.850	0.850	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	46913	WOONSOCKET-02895PV190DG	0.190	0.190	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	46914	BILLERICA-01523PV2499NM	2.499	2.499	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	46915	NEXAMP-01844PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	46916	PHILLIPS-01810PV495NM	0.495	0.495	N/A	N/A	N/A [5]	MA	009	CMA/NEMA	MEC
	No Resource [3]	46917	NEWPORT VINEYARDS-02882PV50DG	0.050	0.050	N/A	N/A	N/A [5]	RI	005	SEMA	NEC
	No Resource [3]	46924	BILLERICA-01523PV2500NM	2.500	2.500	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	46925	GLC-MA SOLAR-01440PV1980NM	1.980	1.980	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	46926	STILLWATER-02917PV56DG	0.056	0.056	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	46947	AMERIPRIDE-01607PV225NM	0.225	0.225	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	46948	MILFORD IND-01757PV170NM	0.170	0.170	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	46949	NEW SALEM-01452PV675NM	0.675	0.675	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	46951	OAKFIELD WIND	135.500	135.500	N/A	N/A	N/A [5]	ME	003	BHE	EWP2
	No Resource [3]	46952	TOWN OF WENDELL-01876PV260NM	0.260	0.260	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW) Summer (50°F)	NRC (MW) Winter (0°F)	CNRC (MW) Summer (90°F)	CNRC (MW) Winter (20°F)	Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
	No Resource [3]	46953	MACHINE INC-02072PV75NM	0.075	0.075	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	46954	PROTECTOWIRE-02359PV70NM	0.070	0.070	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	46955	MASS FISHERIES-01581PV251NM	0.251	0.251	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	46982	GLOBAL LIQUORS-02720PV85NM	0.085	0.085	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	46992	RIN LOGISTICS-02720PV1500NM	1.500	1.500	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	46993	PARAGON HOLDINGS-01740PV995NM	0.995	0.995	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	46997	BOLTONVILLE HYDRO	1.318	1.318	N/A	N/A	N/A [5]	VT	017	VT	GMP
	No Resource [3]	46998	STEERE ELECTRIC-02814PV72DG	0.072	0.072	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	47002	ONE KENWOOD-02038PV266NM	0.266	0.266	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	47003	S SHORE MILLWORK-02766PV648NM	0.648	0.648	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	47004	IRON MOUNTAIN-01532PV760NM	0.760	0.760	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	47007	FRANKLIN FORD-02038PV140NM	0.140	0.140	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	47008	MCGEE TOYOTA-02339PV85NM	0.085	0.085	N/A	N/A	N/A [5]	MA	023	RI	MEC
	No Resource [3]	47020	NEXAMP-02898PV499DG	0.499	0.499	N/A	N/A	N/A [5]	RI	009	RI	NEC
	No Resource [3]	47032	ABINGTON TARGET-02351PV418NM	0.418	0.418	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	47033	HANOVER TARGET-02339PV441NM	0.441	0.441	N/A	N/A	N/A [5]	MA	023	RI	MEC
	No Resource [3]	47034	MARLBORO TARGET-01752PV441NM	0.441	0.441	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47035	MILFORD TARGET-01757PV302NM	0.302	0.302	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	47036	NORTHBORO WALMART-01532PV368NM	0.368	0.368	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	47037	LYNN WALMART-01905PV232NM	0.232	0.232	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	47046	BOOTHBAY ENERGY STORAGE	0.500	0.500	N/A	N/A	N/A [5]	ME	015	ME	CONV
	No Resource [3]	47060	HANNAFORD FOOD-01535PV120NM	0.120	0.120	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	47061	WHITTIER FARMS-01590PV114NM	0.114	0.114	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	47062	EASTERN BANK-01901PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	47063	SWISS TURN-01540PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	47064	1ST CONGREGATION-02176PV90NM	0.090	0.090	N/A	N/A	N/A [5]	MA	017	BOSTON	MEC
	No Resource [3]	47065	210 UPHAM (PV)	0.072	0.072	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	47066	S.D. WARREN SACCARAPPA HYDRO	1.350	1.350	N/A	N/A	N/A [5]	ME	005	SME	FPLP
	No Resource [3]	47092	3 VENUS WAY-02703PV750NM	0.750	0.750	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	47093	SWANSEA MALL-02777PV499NM	0.499	0.499	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	47094	MACY'S SAUGUS-01906PV278NM	0.278	0.278	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	47095	MILFORD IND PLAZA-01757PV170NM	0.170	0.170	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	47096	JENIKE AND JO-01879PV150NM	0.150	0.150	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47097	PREFERRED FREEZER-02322PV990NM	0.990	0.990	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	47125	BOW STREET HYDRO	0.236	0.236	N/A	N/A	N/A [5]	NH	013	NH	MMWEC
	No Resource [3]	47126	CITY OF QUINCY-02171PV132NM	0.132	0.132	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	47127	CITY OF QUINCY-02169PV144NM	0.144	0.144	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	47128	CITY OF QUINCY-02170PV195NM	0.195	0.195	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	47129	CITY OF QUINCY-02169PV129NM	0.129	0.129	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	47210	LEICESTER ONE-01524PV4883NM	4.883	4.883	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	47211	SYNCARPHA-01453PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	47263	WARILA-01523PV150NM	0.150	0.150	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	47264	MERRIMACK REALITY-01830PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	47265	LMP FRANKLIN-02038PV490NM	0.490	0.490	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	47266	EAST COASTWELDING-01950PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	47267	BLACKMARBLEMOTOR-02151PV241NM	0.241	0.241	N/A	N/A	N/A [5]	MA	025	BOSTON	MEC
	No Resource [3]	47281	SWANSEA MALL-02777PV260QF	0.260	0.260	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	47282	CITY OF QUINCY-02171PV225NM	0.225	0.225	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	47283	NATIONAL MARKER-02896PV186NM	0.186	0.186	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	47284	LARRY LUNDIN-02333PV180NM	0.180	0.180	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	47285	LARSON TOOL-02703PV131NM	0.131	0.131	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	47311	PETERBOROUGH WWTF PV	0.750	0.750	N/A	N/A	N/A [5]	NH	011	NH	PSNH
	No Resource [3]	47312	SKATE 3-01879PV491NM	0.491	0.491	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47313	MACYS MARLBORO-01752PV371NM	0.371	0.371	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47357	JOHNSTON SOLAR-02919PV1375DG	1.375	1.375	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	47364	HA MA SOLAR-01222PV999NM	0.999	0.999	N/A	N/A	N/A [5]	MA	003	WMA	MEC

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
	No Resource [3]	47365	WILLIAMS COLLEGE-01267PV414NM	0.414	0.414	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	47377	BLUEWAVE - MATTAPOISETT 2260	0.750	0.750	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	47379	GARDNER WALMART-01440PV278NM	0.278	0.278	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	47391	CHELMSFORD DPW-01824PV335NM	0.335	0.335	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47392	MCCARTHY SCHOOL-01824PV300NM	0.300	0.300	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47393	HARRINGTON SCHOOL-01824PV295NM	0.295	0.295	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47397	NM-ALNASCO	0.300	0.300	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	47398	NM-BGREEN ENERGY	0.300	0.300	N/A	N/A	N/A [5]	MA	015	WMA	WMECO
	No Resource [3]	47399	NM-BWC ORIGINATION	0.833	0.833	N/A	N/A	N/A [5]	MA	015	WMA	WMECO
	No Resource [3]	47400	NM-CENTER FOR ECOLOGICAL TECH	0.142	0.142	N/A	N/A	N/A [5]	MA	013	WMA	WMECO
	No Resource [3]	47401	NM-C F FARMS	0.175	0.175	N/A	N/A	N/A [5]	MA	015	WMA	WMECO
	No Resource [3]	47402	NM-CLARKS COVAIR PARTS	0.082	0.082	N/A	N/A	N/A [5]	MA	011	WMA	WMECO
	No Resource [3]	47403	NM-COWLS BUILDING SUPPLY	0.100	0.100	N/A	N/A	N/A [5]	MA	015	WMA	WMECO
	No Resource [3]	47404	NM-FRANKLIN REGIONAL	0.100	0.100	N/A	N/A	N/A [5]	MA	011	WMA	WMECO
	No Resource [3]	47405	NM-FW WEBB	0.266	0.266	N/A	N/A	N/A [5]	MA	013	WMA	WMECO
	No Resource [3]	47406	NM-GUIDO QUALITY FOODS	0.168	0.168	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	47407	NM-LYNN EDWARDS	0.095	0.095	N/A	N/A	N/A [5]	MA	015	WMA	WMECO
	No Resource [3]	47408	NM-LYON AVIATION	0.100	0.100	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	47409	NM-PITTSFIELD RYE	0.499	0.499	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	47410	CHELMSFORD HIGH-01824PV225NM	0.225	0.225	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47411	PARKER SCHOOL-01824PV225NM	0.225	0.225	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47412	BYAM SCHOOL-01824-PV225NM	0.225	0.225	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47413	SOUTH ROW SCHOOL-01824PV150NM	0.150	0.150	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47414	WESTLAND SCHOOL-01824PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47415	CENTER SCHOOL-01824PV75NM	0.750	0.750	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47419	NM-TOWN OF WEST SPRINGFIELD	3.300	3.300	N/A	N/A	N/A [5]	MA	013	WMA	WMECO
	No Resource [3]	47420	NM-TOWN OF LONGMEADOW	3.340	3.340	N/A	N/A	N/A [5]	MA	013	WMA	WMECO
	No Resource [3]	47421	NM-TOWN OF ASHFIELD	2.500	2.500	N/A	N/A	N/A [5]	MA	015	WMA	WMECO
	No Resource [3]	47422	NM-UMASS AMHERST	2.000	2.000	N/A	N/A	N/A [5]	MA	011	WMA	WMECO
	No Resource [3]	47423	BRISTOLCOMMCOLL-02720PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	47443	HA MA SOLAR-01036PV3500NM	3.500	3.500	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	47444	SUN EDISON ORIG3-02769PV3334NM	3.334	3.334	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	47445	NORTH ADAMS-01247PV2250NM	2.250	2.250	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	47447	BWC 5 MILE RIVER-01031PV1890NM	1.890	1.890	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	47448	BWC 5 MILE RIVER-01031PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	47455	BROCKTON WALMART-02301PV252QF	0.252	0.252	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	47477	TOWN OF WAREHAM 2155	4.750	4.750	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	47484	TOWN OF DARTMOUTH 1924	2.750	2.750	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	47485	TOWN OF DARTMOUTH 1925	4.000	4.000	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	47486	PLAINVILLE GAMING-02762PV615QF	0.615	0.615	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	47487	N KINGSTOWN SOLAR-02852PV495DG	0.495	0.495	N/A	N/A	N/A [5]	RI	009	RI	NEC
	No Resource [3]	47504	CVEC EDGARTOWN - 1886	1.083	1.083	N/A	N/A	N/A [5]	MA	007	SEMA	NSTAR
	No Resource [3]	47505	CVEC EDGARTOWN - 1887	1.083	1.083	N/A	N/A	N/A [5]	MA	007	SEMA	NSTAR
	No Resource [3]	47506	CVEC HARWICH - 1913	4.000	4.000	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	47530	SEEKONK WALMART-02771PV230QF	0.230	0.230	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	47559	HANNAFORD LUN PV	0.170	0.170	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	47699	H&V-01472ST3519QF	3.519	3.519	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	47703	WEST ST NOMINEE-01747PV490NM	0.490	0.490	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	47704	ERVING PAPER-01344ST3519QF	2.583	3.519	N/A	N/A	N/A [5]	MA	011	WMA	MEC
	No Resource [3]	47731	245 RIVER STREET PLACE LLC	0.400	0.400	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	47749	UI RCP BGPT PV	2.200	2.200	N/A	N/A	N/A [5]	CT	001	SWCT	UI
	No Resource [3]	47751	WED COVENTRY 1-6	15.000	15.000	N/A	N/A	N/A [5]	RI	003	RI	GRDV
	No Resource [3]	47752	AMPERSAND BROOKLYN DAM HYDRO	0.600	0.600	N/A	N/A	N/A [5]	NH	007	NH	PSNH
	No Resource [3]	47836	QUABBIN WIRE-01082PV70NM	0.070	0.070	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	47837	QUABBIN WIRE-01082PV224NM	0.224	0.224	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	47838	GOODING FAMILY-02302PV250NM	0.250	0.250	N/A	N/A	N/A [5]	MA	023	SEMA	MEC

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
	No Resource [3]	47926	NM AMHERST DEVELOPMENT ASSOC	0.095	0.095	N/A	N/A	N/A [5]	MA	015	WMA	WMECO
	No Resource [3]	47927	NM EASTHAMPTON HS	0.083	0.083	N/A	N/A	N/A [5]	MA	015	WMA	WMECO
	No Resource [3]	47928	NM BIG Y LEE MA	0.295	0.295	N/A	N/A	N/A [5]	MA	003	WMA	WMECO
	No Resource [3]	47929	NM BIG Y SPRINGFIELD MA	0.500	0.500	N/A	N/A	N/A [5]	MA	013	WMA	WMECO
	No Resource [3]	47930	NM-HONORE LLC	0.095	0.095	N/A	N/A	N/A [5]	MA	013	WMA	WMECO
	No Resource [3]	47931	NM-BETA FOG NOZZLE	0.135	0.135	N/A	N/A	N/A [5]	MA	011	WMA	WMECO
	No Resource [3]	47932	NM GIRARD LIMITED	0.080	0.080	N/A	N/A	N/A [5]	MA	013	WMA	WMECO
	No Resource [3]	47933	NM WALMART SPRINGFIELD MA	0.333	0.333	N/A	N/A	N/A [5]	MA	013	WMA	WMECO
	No Resource [3]	47934	NM WINTON CORP	0.110	0.110	N/A	N/A	N/A [5]	MA	013	WMA	WMECO
	No Resource [3]	47950	NATIONAL GRID 1-01005PV480NM	0.480	0.480	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	47951	NATIONAL GRID 2-01005PV480NM	0.480	0.480	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	47952	NATIONAL GRID 3-01005PV480NM	0.480	0.480	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	47953	NATIONAL GRID 4-01005PV480NM	0.480	0.480	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	47954	WINN SOLAR THREE-01841PV115NM	0.115	0.115	N/A	N/A	N/A [5]	MA	009	CMA/NEMA	MEC
	No Resource [3]	47955	BELLINGHAM PLAZA-02019PV198QF	0.198	0.198	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	47956	ANDOVER COMPANIES-01810PV494NM	0.494	0.494	N/A	N/A	N/A [5]	MA	009	CMA/NEMA	MEC
	No Resource [3]	47959	ZORENA-01590PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	47983	JLS MAILING SVS-01876PV490NM	0.490	0.490	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	47984	BJ'S WHOLESALE-01532PV460NM	0.460	0.460	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	47985	DENNISON LUBRICANT01607PV308QF	0.308	0.308	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	47986	TARGET LEOMINSTER-01453PV184QF	0.184	0.184	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	47987	LAMOUREUX FORD-01515PV100NMNM	0.100	0.100	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	47991	SOLTERRA LLC SOLAR PROJECT	16.530	16.530	N/A	N/A	N/A [5]	MA	027	WMA	NRGPM
	No Resource [3]	47992	BREAKAWAY ICE-01876PV120NM	0.120	0.120	N/A	N/A	N/A [5]	MA	017	BOSTON	MEC
	No Resource [3]	47993	217 EAST RD SOLAR-01220PV996NM	0.996	0.996	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	48022	WINN SOLAR THREE-01852PV120NM	0.120	0.120	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48075	STONY HILL SOLAR-01036PV499NM	0.499	0.499	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	48081	APOLLO SOLAR-01876PV268NM	0.268	0.268	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48082	HANCOCK WIND	51.000	51.000	N/A	N/A	N/A [5]	ME	009	BHE	HCWL
	No Resource [3]	48083	FRENCH RIVER	12.350	12.350	N/A	N/A	N/A [5]	MA	027	WMA	EMMT-I
	No Resource [3]	48166	MAYBURY ASSOC-01028PV250QF	0.250	0.250	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	48167	RANDOLP & BALDWIN-01432PV80QF	0.080	0.080	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48170	SYNCARPHA PALMER-01069PV4995NM	4.995	4.995	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	48171	HALIFAX SOLAR NG-02338PV2500NM	2.500	2.500	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	48172	BLUEWAVE CAPITAL-02769PV1670NM	1.670	1.670	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	48177	PARKRIDGE-01835PV92.4QF	0.092	0.092	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	48178	PLAINVILLE TARGET-02762PV414QF	0.414	0.414	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	48205	GENERAL WOODWKNG2-01851PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48206	GENERAL WOODWKNG1-01851PV224NM	0.224	0.224	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48221	146 SUPPLY CTR-01527PV98NM	0.098	0.098	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48225	SWANSEA TARGET-02777PV483QF	0.483	0.483	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	48226	UXBRIDGE PRO STGE-01569PV265QF	0.265	0.265	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	48232	TOWN OF WENDELL-01473PV600NM	0.600	0.600	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48239	CYN OIL CORP-02072PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	48249	WORC BURNCOAT-01606PV252QF	0.252	0.252	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48250	WORC FOREST GROVE-01605PV87QF	0.087	0.087	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48321	WORC CHANDLER-01602PV100QF	0.100	0.100	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48400	SOMERSET SCHOOL-02726PV240NM	0.240	0.240	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	48401	EVERSOURCE PV N2123	0.121	0.121	N/A	N/A	N/A [5]	NH	011	NH	PSNH
	No Resource [3]	48402	MERCURY WIRE-01562PV224NM	0.224	0.224	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48403	FACILITY MGT CORP-01747PV200NM	0.200	0.200	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	48406	HERRICKS INC-01364PV112NM	0.112	0.112	N/A	N/A	N/A [5]	MA	011	WMA	MEC
	No Resource [3]	48407	ENRIGHT LLC-01879PV300NM	0.300	0.300	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48426	19 POND RD LLC-01930PV200NM	0.200	0.200	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	48583	HYDE TOOLS INC-01550PV263NM	0.263	0.263	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48584	LAND OF THE SKY1-01550PV480NM	0.480	0.480	N/A	N/A	N/A [5]	MA	027	WMA	MEC

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
	No Resource [3]	48585	LAND OF THE SKY2-01550PV480NM	0.480	0.480	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48586	LAND OF THE SKY3-01550PV480NM	0.480	0.480	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48587	LAND OF THE SKY4-01550PV480NM	0.480	0.480	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48588	SOLARCITY CORP-01096PV2266NM	2.266	2.266	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	48643	DURHAM PV N3524	0.504	0.504	N/A	N/A	N/A [5]	NH	017	NH	PSNH
	No Resource [3]	48645	PISGAH MOUNTAIN WIND	9.075	9.075	N/A	N/A	N/A [5]	ME	019	BHE	SWEB
	No Resource [3]	48649	ALPHA RHO	0.200	0.200	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	48650	LONG SUBARU-01570PV75NM	0.075	0.075	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48651	TRINITY EMS-01853PV64.8QF	0.065	0.065	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48659	MILTON PV N3084	0.750	0.750	N/A	N/A	N/A [5]	NH	017	NH	PSNH
	No Resource [3]	48664	S COUNTY-02822PV878DG	0.878	0.878	N/A	N/A	N/A [5]	RI	009	RI	NEC
	No Resource [3]	48665	IMPERIAL DELTAH-02914PV264NM	0.264	0.264	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	48672	THEDODGECO-01821PV172NM	0.172	0.172	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48674	RES.RD.HOLDINGS-02136PV2500NM	2.500	2.500	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	48675	HARBOR SOLAR LLC-02324PV989NM	0.989	0.989	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	48676	HARBOR SOLAR 2-02324PV1978NM	1.978	1.978	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	48694	MERCURY (198)-01543PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48697	MCI TELECOM-01507PV772.8QF	0.772	0.772	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48698	STORZ 2101B-01507PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48713	STORZ 2101A-01507PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48718	BRODIE MT RD-01237PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	48719	HOUSATONIC-WARE-01092PV960NM	0.960	0.960	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48720	WESTBROOKFIELD-01585PV1400NM	1.400	1.400	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48721	HOUSATONIC SPRING-01092PV952NM	0.952	0.952	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48722	BURTON VILLAGE-01452PV96QF	0.096	0.096	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48723	INDEPENDENCE2575-02072PV1725NM	1.725	1.725	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	48724	CASCO BAY ENERGY STORAGE	16.200	16.200	N/A	N/A	N/A [5]	ME	005	SME	FPLP
	No Resource [3]	48741	CECSOLAR#1050-01569PV950NM	0.950	0.950	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	48742	HOUSATONIC 1734-01236PV2100NM	2.100	2.100	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	48743	ECASOLAR39TOZERRD-01915PV840NM	0.840	0.840	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	48747	BRAUNSEXPRESS-01747PV164NM	0.164	0.164	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	48748	RANDOLPH&BALDWIN-01432PV79.2NM	0.079	0.079	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48749	ARSENAULT2103-01585PV800NM	0.800	0.800	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48750	BLUEWAVE 8861-01540PV1500NM	1.500	1.500	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48751	BLUEWAVE5149-02766PV750NM	0.750	0.750	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	48752	BLUEWAVE 5161-02766PV750NM	0.750	0.750	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	48753	CEREBRAL PALSY-02072PV112QF	0.112	0.112	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	48756	QUINCYSCHOOLS4785-02169PV135NM	0.135	0.135	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	48757	SAFEHARBOROTIS-01581PV741NM	0.741	0.741	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48758	CEDEV.MEETINGST-02905PV75NM	0.075	0.075	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	48764	QUINCYPALMERST-02169PV120NM	0.120	0.120	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	48765	QUINCYQPSOFFICE-02169PV96NM	0.096	0.096	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	48766	CECSOLAR#1045-01569PV728NM	0.728	0.728	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	48767	510PVDEVNASHUARD-01463PV990NM	0.990	0.990	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48768	QUINCY_BILLINGS-02171PV63NM	0.063	0.063	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	48774	FOSTER-SOLAR-02857PV1170RIDG	1.170	1.170	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	48778	CECSOLAR#1051-01569PV450NM	0.450	0.450	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	48787	KNIGHT FARM-02828PV70NM	0.070	0.070	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	48788	HOWLANDASS.-02865PV136NM	0.136	0.136	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	48801	BELLAENERGY5140-02715PV499NM	0.499	0.499	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	48810	510PVDEV.ELLIS RD-01473PV480NM	0.480	0.480	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48811	ALVES238E.MAINRD-02842PV86.4NM	0.086	0.086	N/A	N/A	N/A [5]	RI	005	RI	NEC
	No Resource [3]	48812	PRINTGUARD-01527PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48813	WINDSORWOOD-02148PV140NM	0.140	0.140	N/A	N/A	N/A [5]	MA	017	BOSTON	MEC
	No Resource [3]	48814	PALMERFOUNDRY-01069PV252NM	0.252	0.252	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	48815	NEXTSUNWALKERRD-01464PV2000NM	2.000	2.000	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
	No Resource [3]	48816	510PVDEVBARRE-01005PV480NM	0.480	0.480	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48817	TARGET#T2430-02886PV112NM	0.112	0.112	N/A	N/A	N/A [5]	RI	003	RI	NEC
	No Resource [3]	48818	510PV_NBROOKFIELD-01535PV480NM	0.480	0.480	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48819	BLUEWAVE7629-02766PV500NM	0.750	0.750	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	48820	WNEWBURYMAINSTLLC-01985PV354NM	0.354	0.354	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	48821	EJRREALESTATE-01752PV300NM	0.300	0.300	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48823	LONG SUB.3685-01570PV140NM	0.140	0.140	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48824	KJA PROPERTIES-02842PV63NM	0.063	0.063	N/A	N/A	N/A [5]	RI	005	SEMA	NEC
	No Resource [3]	48825	MOTOMANCHESTER-02035PV255NM	0.255	0.255	N/A	N/A	N/A [5]	MA	021	RI	MEC
	No Resource [3]	48826	BROOKFIELDWIRECO-01585PV1414NM	1.414	1.414	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48827	UNIONSQUARERLTY-01453PV260NM	0.260	0.260	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48828	WINNSOLARWATERST-01604PV75.6NM	0.076	0.076	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48840	JPSULLIVAN-01434PV230NM	0.230	0.230	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48841	EXTRASPACEMAN.INC-01862PV76NM	0.076	0.076	N/A	N/A	N/A [5]	MA	017	BOSTON	MEC
	No Resource [3]	48847	EXTRASPACEBROCKTON-02301PV92NM	0.092	0.092	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	48848	DANAWALLSUPPLY-01879PV68.4NM	0.068	0.068	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	48849	RUTLANDPLAZALLC-01543PV70NM	0.070	0.070	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48850	AIRTIGHTHOLDERS-01257PV250NM	0.250	0.250	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	48856	JIMARYLANDTRUST-01930PV108NM	0.108	0.108	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	48857	E.CALIGARI&SONS-01240PV112NM	0.112	0.112	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	48858	530MAINSTR.E.LLC-01510PV183NM	0.183	0.183	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48859	BROOKFIELDWASTE-01506PV333NM	0.333	0.333	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48860	DUVAL'SPHARMACY-02382PV70NM	0.070	0.070	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	48861	WILLIAMSTOWNYOUTH-01267PV80NM	0.080	0.080	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	48862	R.E.DEV.WILBRAHAM-01095PV750NM	0.750	0.750	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	48863	WESTBOROTENNIS-01510PV72NM	0.072	0.072	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48872	PLUMBERSSUPPLY-01453PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48874	CLARKUNIVERSITY-01610PV140NM	0.140	0.140	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48876	CVEC_CHATHAM_ID1911	1.500	1.500	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	48877	CVEC_BREWSTER_ID1912	1.083	1.083	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	48878	ATHENS ENERGY LLC	0.000	0.000	N/A	N/A	N/A [5]	ME	025	ME	AELC
	No Resource [3]	48879	WAREHAM_MA1_LLC_ID1972361	2.000	2.000	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	48880	TOWN_OF_MASHPEE_ID2049	1.500	1.500	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	48881	CITY_OF_NEWBEDFORD_ID1939	1.500	1.500	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	48882	CVEC_MARSTON_MILLS_ID1965	1.416	1.416	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	48883	TOWN_OF_DENNIS_ID1712	1.250	1.250	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	48884	CVEC_HYANNIS_ID2181	4.500	4.500	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	48885	UMASS_DARTMOUTH_ID1849	4.200	4.200	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	48886	TOWN_OF_SANDWICH_ID2043	3.500	3.500	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	48887	PLYMOUTH_PUB_SCHS_ID1895	2.900	2.900	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	48888	TOWN_OF_DENNIS_ID2115	2.500	2.500	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	48889	CVEC_MARSTON_MILLS_ID1964	2.000	2.000	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	48895	COSTAPROPMGMTLLC-02724PV150NM	0.150	0.150	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	48896	SHAHEENBROSLLC-01913PV300NM	0.300	0.300	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	48899	BRANDYWICKLLC-02896PV1000RIDG	1.000	1.000	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	48913	VALLEYST.MILL-02909PV98NM	0.098	0.098	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	48914	DRACUTHOUS.AUTH-01507PV1980NM	1.980	1.980	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48915	510PVMOSSBERG-02703PV684QF	0.684	0.684	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	48916	BEVOVATIONSLLC-01453PV252NM	0.252	0.252	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48949	77LEICESTERLLC-01540PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	48955	PATEL-REALTY-02721PV72NM	0.072	0.072	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	48960	ATHENS ENERGY LLC_1	7.100	7.100	N/A	N/A	N/A [5]	ME	025	ME	AELC
	No Resource [3]	48963	BROOKSSTDEV-01606PV476NM	0.476	0.476	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	48975	FISHER ROAD PV	0.540	0.540	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	49000	AQUILACURTISHILL-01507PV1980NM	1.980	1.980	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	49001	NEXAMPFACTORYST-02893PV384NM	0.384	0.384	N/A	N/A	N/A [5]	RI	003	RI	NEC

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW)		CNRC (MW)		Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
				Summer (50°F)	Winter (0°F)	Summer (90°F)	Winter (20°F)					
	No Resource [3]	49002	SOMERSETELEM.-02726PV270NM	0.270	0.270	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	49003	APE.VINEYARDRD-02771PV150NM	0.150	0.150	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	49010	ROCHESTER PV N3365	0.500	0.500	N/A	N/A	N/A [5]	NH	017	NH	PSNH
	No Resource [3]	49011	BEDFORD PV N3787	0.364	0.364	N/A	N/A	N/A [5]	NH	011	NH	PSNH
	No Resource [3]	49012	NASHUA PV N3791	0.364	0.364	N/A	N/A	N/A [5]	NH	011	VT	PSNH
	No Resource [3]	49013	KEENE PV N3792	0.364	0.364	N/A	N/A	N/A [5]	NH	005	VT	PSNH
	No Resource [3]	49014	GREENLAND PV N3788	0.364	0.364	N/A	N/A	N/A [5]	NH	015	NH	PSNH
	No Resource [3]	49017	AMERICANATHLETIC-01082PV75NM	0.075	0.075	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	49031	C.H.YATESRUBBER-02720PV972NM	0.972	0.972	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	49055	TOWN_OF_SUDBURY_ID2176	1.333	1.333	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	49063	TOWN_OF_MEDWAY_ID1972386	4.500	4.500	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	49064	TOWN_OF_WESTON_ID2055868	1.795	1.795	N/A	N/A	N/A [5]	MA	017	BOSTON	NSTAR
	No Resource [3]	49065	DOVER PV N3015	0.267	0.267	N/A	N/A	N/A [5]	NH	017	NH	PSNH
	No Resource [3]	49070	TOWN_OF_NEEDHAM_ID1989732	3.120	3.120	N/A	N/A	N/A [5]	MA	021	BOSTON	NSTAR
	No Resource [3]	49071	CVEC_INC_VINEYARDHAVEN_ID1923	1.083	1.083	N/A	N/A	N/A [5]	MA	007	SEMA	NSTAR
	No Resource [3]	49072	TOWN_OF_ACTON_ID2056	1.500	1.500	N/A	N/A	N/A [5]	MA	017	Boston	NSTAR
	No Resource [3]	49073	CES_TIHONET_SOLAR_ID2350	1.000	1.000	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	49074	WAREHAM_FIRE_DISTRICT_ID2128	0.583	0.583	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	49075	TOPEKA_SOLAR1_ID2191	1.000	1.000	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	49076	MASSDOT_ID1977739	0.500	0.500	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	49077	IGS_SOLARLLC_ID2094068	0.300	0.300	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	49078	BWC_ORIGIN_FAIRHAVEN_ID1964211	0.750	0.750	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	49081	TOWN_OF_DUXBURY_ID2143	0.500	0.500	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	49082	GLC_ACUSHNET_ID1819	1.000	1.000	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	49083	TOWN_OF_CHILMARK_ID1981127	0.173	0.173	N/A	N/A	N/A [5]	MA	007	SEMA	NSTAR
	No Resource [3]	49084	CVEC_INC_WESTTISBURY_ID2189	0.600	0.600	N/A	N/A	N/A [5]	MA	007	SEMA	NSTAR
	No Resource [3]	49085	MARGUERITE_SMALL_SCHOOL_ID2168	0.750	0.750	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	49086	BRALEY_ROAD_SOLAR4_ID1896	1.000	1.000	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	49087	SIPPICAN_COMM_SOLAR_ID2029145	0.783	0.783	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	49088	CVEC_INC_ORLEANS_ID2217	0.500	0.500	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	49089	CANAM (PV)	0.084	0.084	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	49093	S&E (PV)	0.239	0.239	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	49094	FRIENDS_ACADEMY_ID2326	0.134	0.134	N/A	N/A	N/A [5]	MA	005	SEMA	NSTAR
	No Resource [3]	49095	DY_HIGH_SCHOOL_ID2173	0.500	0.500	N/A	N/A	N/A [5]	MA	001	SEMA	NSTAR
	No Resource [3]	49096	MCCARTHY_PROPERTIES_ID2077939	0.200	0.200	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	49097	815_MAIN_ST_SOLARLLC_ID2077567	0.130	0.130	N/A	N/A	N/A [5]	MA	023	SEMA	NSTAR
	No Resource [3]	49197	SHREDKING-02343PV180NM	0.180	0.180	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	49198	HOLYNAMESCHOOL-02720PV144NM	0.144	0.144	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	49202	WORC.ROOSEVELT-01604PV100NM	0.100	0.100	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	49203	WORC.BELMONTST-01605PV200NM	0.200	0.200	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	49213	JUDSONHOUSE-01830PV82NM	0.082	0.082	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	49214	APE.1788GARHWY-02777PV476NM	0.476	0.476	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	49215	REINGOLD SCHOOL (PV)	0.195	0.195	N/A	N/A	N/A [5]	MA	027	WMA	FGE
	No Resource [3]	49216	MISCOHILLELEM-01756PV386NM	0.386	0.386	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	49217	NOHOARTSTRUST-01060PV176NM	0.176	0.176	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	49222	NEXAMP-LOGEE-02895PV153RE	0.153	0.153	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	49240	QUINCYCODDINGTON-02169PV183NM	0.183	0.183	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	49241	DINO'SPARK&SHOP-02814PV196RE	0.196	0.196	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	49242	WORCESTERNORTHHS-01604PV101NM	0.101	0.101	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	49243	510PVDEVDIGHTON-01851PV996QF	0.996	0.996	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	49244	510PVDEVGRAFTON-01519PV672QF	0.672	0.672	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	49245	510PVDEVAYER-01432PV996QF	0.996	0.996	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	49247	510PVDEVABINGTON-02351PV996QF	0.996	0.996	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	49248	GE.TINKHAMRD-01095PV496NM	0.496	0.496	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	49249	SHAFIIREALESTATE-01028PV468NM	0.468	0.468	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	49250	ORANGEINNOVATION-01364PV80NM	0.080	0.080	N/A	N/A	N/A [5]	MA	011	WMA	MEC

Resource ID	Resource Name	Asset ID	Asset Name	NRC (MW) Summer (50°F)	NRC (MW) Winter (0°F)	CNRC (MW) Summer (90°F)	CNRC (MW) Winter (20°F)	Instrument Used to Identify Capability[4]	State	County	RSP Area	Lead Participant
	No Resource [3]	49251	SUTTONSOLARLLC-01590PV1950NM	1.950	1.950	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	49252	BUXTONRDSOLARLLC-01569PV1000NM	1.000	1.000	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	49253	VIRGINIOSARDINIA-01757PV236QF	0.236	0.236	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	49254	TANGLEWOODFARM-02814PV196RE	0.196	0.196	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	49255	CONWELLSEMINARY-01982PV187QF	0.187	0.187	N/A	N/A	N/A [5]	MA	009	BOSTON	MEC
	No Resource [3]	49256	RICARBIDETOOLCO-02917PV196RE	0.196	0.196	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	49260	USFLUIDS-01028PV110QF	0.110	0.110	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	49276	ROCKY'SELONGMEADOW-01028PV86QF	0.086	0.086	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	49277	KEARSARGE188EAST-01033PV450NM	0.450	0.450	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	49278	KEARSARGE190EAST-01033PV450NM	0.450	0.450	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	49279	PEGASUSSOLAR-01752PV300NM	0.300	0.300	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	49280	KEARSARGE229REAST-01033PV450NM	0.450	0.450	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	49282	KEARSARGE914WEST-01056PV450NM	0.450	0.450	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	49283	KEARSARGE220REAST-01033PV450NM	0.450	0.450	N/A	N/A	N/A [5]	MA	015	WMA	MEC
	No Resource [3]	49288	BLUEWAVEWEBSTER-01570PV1380NM	1.380	1.380	N/A	N/A	N/A [5]	MA	027	WMA	MEC
	No Resource [3]	49289	FUREYROOFINGCO-02888PV29NM	0.029	0.029	N/A	N/A	N/A [5]	RI	003	RI	NEC
	No Resource [3]	49290	CRISSEYFARMS-01230PV113NM	0.113	0.113	N/A	N/A	N/A [5]	MA	003	WMA	MEC
	No Resource [3]	49291	NANTUCKETICE-02554PV284NM	0.284	0.284	N/A	N/A	N/A [5]	MA	019	SEMA	MEC
	No Resource [3]	49292	NATCOPRODUCTS-02893PV375NM	0.375	0.375	N/A	N/A	N/A [5]	RI	003	RI	NEC
	No Resource [3]	49306	SAFEHARBORSOLAR-01581PV886NM	0.886	0.886	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	49327	NANTUCKETPAVERS-02771PV240NM	0.240	0.240	N/A	N/A	N/A [5]	MA	005	RI	MEC
	No Resource [3]	49328	MILLREALTYTRUST-02370PV86QF	0.086	0.086	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	49331	SHALOMHOUSING-02886WT100NM	0.100	0.100	N/A	N/A	N/A [5]	RI	003	RI	NEC
	No Resource [3]	49335	WESTBOROWWTP-01581PV660NM	0.660	0.660	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	49354	SEAVIEWINNLLC-02842PV180NM	0.180	0.180	N/A	N/A	N/A [5]	RI	005	SEMA	NEC
	No Resource [3]	49359	MILFORDGERIATRIC-01757PV225QF	0.225	0.225	N/A	N/A	N/A [5]	MA	027	RI	MEC
	No Resource [3]	49360	TYNGS.LANDFILL#2-01879PV900NM	0.900	0.900	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	49361	CROMWELLVENTURES-02907PV69NM	0.069	0.069	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	49366	RUTLANDSOLAR-01543PV990NM	0.990	0.990	N/A	N/A	N/A [5]	MA	021	WMA	MEC
	No Resource [3]	49369	PLYMOUTHREALTY-02333PV143NM	0.143	0.143	N/A	N/A	N/A [5]	MA	023	SEMA	MEC
	No Resource [3]	49371	ECASOLARAFF.INT.-01453PV2800QF	2.800	2.800	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	49374	BLUEWAVE CAPITAL-01069PV3800NM	3.800	3.800	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	49376	SYNC.STILLRIVER-01740PV1980NM	1.980	1.980	N/A	N/A	N/A [5]	MA	027	CMA/NEMA	MEC
	No Resource [3]	49383	EASTONHS-02356PV370NM	0.370	0.370	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	49393	IBCCORPORATION-02375PV240QF	0.240	0.240	N/A	N/A	N/A [5]	MA	005	SEMA	MEC
	No Resource [3]	49394	STRAFELLOINC-02322PV266NM	0.266	0.266	N/A	N/A	N/A [5]	MA	017	SEMA	MEC
	No Resource [3]	49396	ELITEENVELOPE-02368PV105NM	0.105	0.105	N/A	N/A	N/A [5]	MA	021	SEMA	MEC
	No Resource [3]	49397	NEXTSUNSHIRLEY-01464PV920NM	0.920	0.920	N/A	N/A	N/A [5]	MA	017	CMA/NEMA	MEC
	No Resource [3]	49398	MADBURY PV N5466	0.222	0.222	N/A	N/A	N/A [5]	NH	017	NH	PSNH
	No Resource [3]	49399	PORTSMOUTH PV N5465A	0.108	0.108	N/A	N/A	N/A [5]	NH	015	NH	PSNH
	No Resource [3]	49400	PORTSMOUTH PV N5465	0.144	0.144	N/A	N/A	N/A [5]	NH	015	NH	PSNH
	No Resource [3]	49401	ROCHESTER PV N5486	0.200	0.200	N/A	N/A	N/A [5]	NH	017	NH	PSNH
	No Resource [3]	49402	NASHUA PV N5606	0.833	0.833	N/A	N/A	N/A [5]	NH	011	VT	PSNH
	No Resource [3]	49404	PKPROPERTIES-02914PV120NM	0.120	0.120	N/A	N/A	N/A [5]	RI	007	RI	NEC
	No Resource [3]	49408	CAVALLO-INC.-01069PV499NM	0.499	0.499	N/A	N/A	N/A [5]	MA	013	WMA	MEC
	No Resource [3]	49409	GMHMIL.HOUSING-02842PV612NM	0.612	0.612	N/A	N/A	N/A [5]	RI	005	SEMA	NEC

FOOTNOTES:

(1) The NRC & CNRC values stated in this CELT Report reflect the results of historical resource testing and, where applicable, are limited by the output value for which the resource has received approval under the ISO-NE Tariff, i.e. the output value approved under the interconnection procedures or under Section I.3.9 of the ISO New England Tariff, or predecessor provisions, such as Section 18.4 of the Restated NEPOOL Agreement. Where applicable, resources may submit additional documentation to the ISO in order to demonstrate that a given resource has been approved under the ISO Tariff review process for a higher output level.

(2) The CNRC values are effective June 1, 2017, as of March 18, 2017. It will be the case that the CNRC will be different in later Capacity Commitment Periods for certain resources that have obtained Capacity Supply Obligations in later Capacity Commitment Periods.

(3) This is an existing Asset that has no associated Resource in the 2017-2018 Capacity Commitment Period.

(4) In accordance with Section 5.2 of Schedule 22 (Large Generator Interconnection Procedures) of Section II of the ISO Tariff or Section 1.6.4 of Schedule 23 (Small Generator Interconnection Procedures) of Section II of the ISO Tariff, as applicable, the instrument used to identify the capability of the resource is either the Interconnection Agreement (IA), the Section I.3.9 (or its predecessor provisions) Proposed Plan Approval (PPA) or the historic capability of the resource.

(5) The NRC values for this Resource are captured in the Customer Asset Management System (CAMS), as reported by the Lead Participant.

5.2 Summary of Demand Resource Capacity (MW) Used in System Planning Studies [(1)(2)(3)(4)(5)(6)]

Consists of Qualified Capacity (QC) of Existing Resources + FCA Cleared Capacity of New Resources

			Capacity Commitment Period							
			2017-18		2018-19		2019-20		2020-21	
Load Zone	Resource Type	Resource Sub Type	Summer	Winter	Summer	Winter	Summer	Winter	Summer	Winter
CT	ACTIVE DR	REAL TIME DR	279.795	250.571	77.319	75.486	59.896	58.666	91.897	91.192
		REAL-TIME EG	138.338	137.824	52.941	52.427	59.097	58.151	52.941	52.427
		TOTAL ACTIVE	418.133	388.395	130.260	127.913	118.993	116.817	144.838	143.619
	PASSIVE DR	ON-PEAK	81.432	60.877	76.632	58.399	75.453	56.637	92.015	65.407
		SEASONAL PEAK	339.454	208.936	382.736	364.241	457.899	438.469	550.542	568.114
		TOTAL PASSIVE	420.886	269.813	459.368	422.640	533.352	495.106	642.557	633.521
CT DR Total			**839.019**	**658.208**	**589.628**	**550.553**	**652.345**	**611.923**	**787.395**	**777.140**
ME	ACTIVE DR	REAL TIME DR	213.168	231.063	152.030	169.925	136.537	154.432	138.682	156.578
		REAL-TIME EG	11.802	9.299	7.482	5.198	6.402	4.550	6.402	4.550
		TOTAL ACTIVE	224.970	240.362	159.512	175.123	142.939	158.982	145.084	161.128
	PASSIVE DR	ON-PEAK	184.180	170.727	180.936	194.393	183.052	183.052	154.683	139.101
		SEASONAL PEAK	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
		TOTAL PASSIVE	184.180	170.727	180.936	194.393	183.052	183.052	154.683	139.101
ME DR Total			**409.150**	**411.089**	**340.448**	**369.516**	**325.991**	**342.034**	**299.767**	**300.229**
NEMA	ACTIVE DR	REAL TIME DR	95.997	92.519	73.529	72.751	62.097	62.097	70.899	70.899
		REAL-TIME EG	26.196	25.968	10.439	10.211	9.429	9.201	6.190	5.962
		TOTAL ACTIVE	122.193	118.487	83.968	82.962	71.526	71.298	77.089	76.861
	PASSIVE DR	ON-PEAK	497.036	468.504	569.011	544.134	635.798	594.300	782.988	754.142
		SEASONAL PEAK	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
		TOTAL PASSIVE	497.036	468.504	569.011	544.134	635.798	594.300	782.988	754.142
NEMA DR Total			**619.229**	**586.991**	**652.979**	**627.096**	**707.324**	**665.598**	**860.077**	**831.003**
NH	ACTIVE DR	REAL TIME DR	28.112	27.392	16.038	15.318	10.067	9.347	17.209	16.489
		REAL-TIME EG	14.022	12.045	14.022	12.045	13.914	11.937	12.300	11.937
		TOTAL ACTIVE	42.134	39.437	30.060	27.363	23.981	21.284	29.509	28.426
	PASSIVE DR	ON-PEAK	96.665	79.227	102.489	83.038	109.452	88.882	126.531	102.207
		SEASONAL PEAK	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
		TOTAL PASSIVE	96.665	79.227	102.489	83.038	109.452	88.882	126.531	102.207
NH DR Total			**138.799**	**118.664**	**132.549**	**110.401**	**133.433**	**110.166**	**156.040**	**130.633**
RI	ACTIVE DR	REAL TIME DR	57.595	54.064	60.362	56.831	42.214	38.683	40.024	36.523
		REAL-TIME EG	33.540	29.149	15.720	11.329	15.720	11.329	14.640	10.249
		TOTAL ACTIVE	91.135	83.213	76.082	68.160	57.934	50.012	54.664	46.772
	PASSIVE DR	ON-PEAK	178.968	175.377	203.670	197.823	226.850	217.992	266.873	268.448
		SEASONAL PEAK	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
		TOTAL PASSIVE	178.968	175.377	203.670	197.823	226.850	217.992	266.873	268.448
RI DR Total			**270.103**	**258.590**	**279.752**	**265.983**	**284.784**	**268.004**	**321.537**	**315.220**

			Capacity Commitment Period							
			2017-18		2018-19		2019-20		2020-21	
Load Zone	Resource Type	Resource Sub Type	Summer	Winter	Summer	Winter	Summer	Winter	Summer	Winter
SEMA	ACTIVE DR	REAL TIME DR	61.073	55.309	51.987	50.113	46.340	44.465	45.682	43.807
		REAL-TIME EG	15.962	15.962	12.722	12.722	12.722	12.722	12.182	12.182
		TOTAL ACTIVE	77.035	71.271	64.709	62.835	59.062	57.187	57.864	55.989
	PASSIVE DR	ON-PEAK	259.231	240.241	306.922	285.606	338.597	305.718	382.321	373.484
		SEASONAL PEAK	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
		TOTAL PASSIVE	259.231	240.241	306.922	285.606	338.597	305.718	382.321	373.484
SEMA DR Total			**336.266**	**311.512**	**371.631**	**348.441**	**397.659**	**362.905**	**440.185**	**429.473**
VT	ACTIVE DR	REAL TIME DR	43.293	51.226	31.900	39.833	31.900	39.833	34.079	39.685
		REAL-TIME EG	2.866	2.866	4.918	4.356	5.458	4.789	4.200	4.357
		TOTAL ACTIVE	46.159	54.092	36.818	44.189	37.358	44.622	38.279	44.042
	PASSIVE DR	ON-PEAK	131.825	130.877	126.176	119.195	120.383	114.067	97.751	97.672
		SEASONAL PEAK	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
		TOTAL PASSIVE	131.825	130.877	126.176	119.195	120.383	114.067	97.751	97.672
VT DR Total			**177.984**	**184.969**	**162.994**	**163.384**	**157.741**	**158.689**	**136.030**	**141.714**
WCMA	ACTIVE DR	REAL TIME DR	98.329	91.205	59.586	54.728	49.595	45.940	71.146	67.491
		REAL-TIME EG	27.798	27.244	25.098	24.544	25.530	24.976	23.694	23.140
		TOTAL ACTIVE	126.127	118.449	84.684	79.272	75.125	70.916	94.840	90.631
	PASSIVE DR	ON-PEAK	265.876	248.388	304.052	282.812	363.681	337.721	394.181	392.998
		SEASONAL PEAK	54.798	49.016	52.968	40.916	49.645	33.939	45.251	25.964
		TOTAL PASSIVE	320.674	297.404	357.020	323.728	413.326	371.660	439.432	418.962
WCMA DR Total			**446.801**	**415.853**	**441.704**	**403.000**	**488.451**	**442.576**	**534.272**	**509.593**
ISO NEW ENGLAND Total	ACTIVE DR	REAL TIME DR	877.362	853.349	522.751	534.985	438.646	453.463	509.618	522.664
		REAL-TIME EG	270.524	260.357	143.342	132.832	148.272	137.655	132.549	124.804
		TOTAL ACTIVE	1147.886	1113.706	666.093	667.817	586.918	591.118	642.167	647.468
	PASSIVE DR	ON-PEAK	1695.213	1574.218	1869.888	1765.400	2053.266	1898.369	2297.343	2193.459
		SEASONAL PEAK	394.252	257.952	435.704	405.157	507.544	472.408	595.793	594.078
		TOTAL PASSIVE	2089.465	1832.170	2305.592	2170.557	2560.810	2370.777	2893.136	2787.537
ISO-NE DR Total			**3237.351**	**2945.876**	**2971.685**	**2838.374**	**3147.728**	**2961.895**	**3535.303**	**3435.005**

FOOTNOTES:

(1) Capacity values are based on Qualified Capacity (QC) of Existing Capacity Resources and FCA cleared auction results of New Capacity Resources for each Capacity Commitment Period (see http://www.iso-ne.com/markets-operations/markets/forward-capacity-market).

(2) The 600 MW cap on RTEG has not been applied.

(3) Not all types of DR are reflected in all System Planning studies. The use of DR varies by the type of study, type of DR, and load level being evaluated. See the Transmission Planning Technical Guide, Appendix C, Guidelines for Treatment of Demand Resources in System Planning Analysis, http://www.iso-ne.com/static-assets/documents/committees/comm_wkgrps/prtcpnts_comm/pac/plan_guides/plan_tech_guide/technical_planning_guide_appendix_c_guidelines_for_treatment_of_demand_resources_in_system_planning_analysis.pdf

(4) Qualified Capacity does reflect reductions for Permanent De-List Bids and accepted Non-Price Retirements for all applicable Capacity Commitment Periods.

(5) Dynamic and Static De-List Bids are not reflected.

(6) These values have been scaled up to include the 8% transmission and distribution loss adjustment.

Section 6
Transmission Information

6.1 Links

The ISO New England Regional Transmission Project Lists are currently published three times a year, which has typically been every March, June, and October. However, these publication times are subject to change. The transmission project lists can be found at:

http://www.iso-ne.com/system-planning/system-plans-studies/rsp

The 'RSP 17 Project List - March 2017 - Final' contains the prospective ISO New England Transmission System that shall be considered part of the 2017 CELT Report.

The new and modified interconnection requests may be found at:

http://www.iso-ne.com/system-planning/transmission-planning/interconnection-request-queue

Appendix A.1 Definitions

Section 1 - Summaries

The summary pages of this report contain terms used to describe how the ISO-NE Reliability Coordinator area forecast is adjusted. The definitions for those terms are as follows:

Load

The ten-year forecast of the ISO New England Reliability Coordinator (RC) area energy and seasonal peak demand is based on econometric models of energy and seasonal peaks for the ISO-NE RC area and the six New England states. The peak forecast has been adjusted to include the current MW reductions achieved by the Passive Demand Resources, as they are treated as resources in the Installed Capacity Requirement (ICR) calculations. The ten-year forecast for New England includes the load forecast for Northern Maine, as provided by the Maine Public Service Company.

Reserves

Installed Reserves in megawatts (MW) are calculated by taking the total Capabilities (including demand resources and imports) for the ISO-NE RC area, less the Reference Load forecast for the ISO-NE RC area. The Installed Reserves as a percentage of Load are calculated by taking the total Installed Reserves and dividing them by the total Reference Load.

Capabilities

Section 1 of the CELT Report takes into account the Capacity Supply Obligations (CSO) for the Forward Capacity Market's (FCM) 2016-2017, 2017-2018, 2018-2019, 2019-2020 and 2020-2021 Capacity Commitment Periods. These include new and existing generating resources, demand resources, and imports. The CELT Capacity Based on FCM CSOs in the Section 1 totals is consistent with the most recent Forward Capacity Market CSOs. The CSOs for the 2020-2021 Capacity Commitment Period are carried through the remainder of the CELT reporting period. Values represent Resource CSOs for the Capacity Commitment Period as of March 18, 2017, and take into account any adjustments to FCM CSOs that have occurred up to that point, including proration, Annual Reconfiguration Auctions, and bilaterals.

An energy efficiency forecast that is based on a forecasting methodology developed by ISO-NE and the Energy Efficiency Working Group, is included in the Passive DR Used in System Planning line, beginning in 2020-21. See http://www.iso-ne.com/committees/comm_wkgrps/othr/enrgy_effncy_frcst/index.html for details.

Section 2 - ISO-NE Reliability Coordinator Area Capability

ISO-NE Reliability Coordinator Area Capability Values as of January 1, 2017, and as of the 2016/17 Winter and 2017 Summer Peaks (Section 2.1)

Section 2.1 lists generating assets claimed toward capability. The generating asset information, including the Lead Market Participant, is listed as it existed as of January 1, 2017 in the ISO-NE Market System. The facilities may or may not be owned, managed, or operated by the Lead Market Participant. Lead Participant updates to generating assets since January 1 are listed at the end of Section 2.1 on the endnotes page.

Seasonal Claimed Capability (SCC) values are the maximum dependable load carrying ability of a generating unit or units, excluding capacity required for station service use. The rating is based on the SCC Audits conducted according to Market Rule 1, and ISO New England Manual for Registration and Performance Auditing M-RPA. For additional information, please visit ISO-NE's website at: http://www.iso-ne.com/rules_proceds/isone_mnls/index.html.

The generator capabilities in Section 2.1 are based on SCC and not on FCM CSOs. Summer and winter capabilities are as of January 1, 2017. In addition, the winter capabilities as of the actual winter peak for 2017/18, which occurred on December 15, 2016, and the summer capabilities for the forecasted summer peak of July 1, 2017 are provided.

This section of the CELT Report was tabulated from data provided by ISO-NE Market Participants. Although every effort has been made to verify its content, ISO New England does not assume responsibility for the accuracy of the data presented.

Appendix A.1 Definitions

Net of Firm Imports and Exports Outside of ISO-NE Reliability Coordinator Area (Section 2.2):

Section 2.2 is based on the Import CSOs and Administrative Export Delists as of the 2016/17 winter peak and the 2017 summer.

Section 3 - Forecast of Solar Photovoltaic (PV) Resources by State

Section 3 is a forecast of solar photovoltaic (PV) resources by state for the years 2017 through 2026. The forecast represents discounted values that were developed to reflect a degree of uncertainty in the achievement of public policies supporting PV development, as well as the estimated summer Seasonal Claimed Capability (SCC). The forecast methodology and assumptions are available athttp://www.iso-ne.com/system-planning/system-forecasting/distributed-generation-forecast.

Section 4 - Summary of Capacity Supply Obligations

Section 4 summarizes the Forward Capacity Market CSOs as of March 18, 2017. The Demand Resources are broken down into On-Peak Demand Resource, Real-Time Demand Response Resource, Real-Time Emergency Generation Resource, and Seasonal Peak Demand Resource categories. Generation is broken down into Intermittent and Non-Intermittent categories.

Renewable Technology Resources

To participate in the Forward Capacity Market as a Renewable Technology Resource, a Generating Capacity Resource or an On-Peak Demand Resource (including every asset that is part of the On-Peak Demand Resource) must satisfy the following requirements:
(a) receive an out-of-market revenue source supported by a state- or federally-regulated rate, charge or other regulated cost recovery mechanism;
(b) qualify as a renewable or alternative energy generating resource under any New England state's mandated (either by statute or regulation) renewable or alternative energy portfolio standards as in effect on January 1, 2014, or, in states without a standard, qualify under that state's renewable energy goals as a renewable resource (either by statute or regulation) as in effect on January 1, 2014. The resource must qualify as a renewable or alternative energy generating resource in the state in which it is geographically located;
(c) participate in a Forward Capacity Auction for a Capacity Commitment Period beginning on or after June 1, 2018 as a New Generating Capacity Resource or New Demand Resource pursuant to Section III.13.1.1, and;
(d) has been designated for treatment as a Renewable Technology Resource pursuant to Section III.13.1.1.2.9.

Section 5 – Forward Capacity Market Resource Capabilities

The October 31, 2008 Forward Capacity Market (FCM)/Queue Amendments filing (FERC Docket ER09237 http://www.iso-ne.com/regulatory/ferc/filings/2008/oct/er09-237-000_10-8-31_fcm_queue.pdf) established the Capacity Network Resource Capability (CNRC) values for each generating resource. Those CNRC values are listed in Section 5.1.

Capacity Network Resource Capability ("CNR Capability"):

The CNR Capability shall mean: (i) in the case of a Generating Facility that is a New Generating Capacity Resource pursuant to Section III.13.1 of the Tariff or an Existing Generating Capacity Resource that is increasing its capability pursuant to Section III.13.1.2.2.5 of the Tariff, the highest megawatt amount of the Capacity Supply Obligation obtained by the Generating Facility in accordance with Section III.13 of the Tariff, and, if applicable, as specified in a filing by the System Operator with the Commission in accordance with Section III.13.8.2 of the Tariff, or (ii) in the case of a Generating Facility that meets the criteria under Section 5.2.3 of this LGIP, the total megawatt amount reflected in an existing Interconnection Agreement, whether executed or filed in unexecuted form with the Commission, an application pursuant to Section I.3.9 of the Tariff (or its predecessor provision, if any), or as determined by the System Operator based on documented historic capability of the Generating Facility. The CNR Capability shall not exceed the maximum net megawatt electrical output of the Generating Facility at an ambient temperature at or above 90 degrees F for Summer and at or above 20 degrees F for Winter. Where the Generating Facility includes multiple production devices, the CNR Capability shall not exceed the aggregate maximum net megawatt electrical output of the Generating Facility at an ambient temperature at or above 90 degrees F for Summer and at or above 20 degrees F for Winter.

Appendix A.1 Definitions

Network Resource Capability ("NR Capability")

The NR Capability shall mean the maximum gross and net megawatt electrical output of the Generating Facility at an ambient temperature at or above 50 degrees F. for Summer and at or above 0 degrees F for Winter. Where the Generating Facility includes multiple energy production devices, the NR Capability shall be the aggregate maximum gross and net megawatt electrical output of the Generating Facility at an ambient temperature at or above 50 degrees F for Summer and at or above 0 degrees F for Winter. The NR Capability shall be equal to or greater than the CNR Capability.

System Planning DR Assumptions

Section 5.2 is the "Summary of Demand Resource Capacity (MW) Used in System Planning Studies". The capacity values in that table are based on Qualified Capacity (QC) of Existing Capacity Resources and FCA cleared auction results of New Capacity Resources for each Capacity Commitment Period (see http://www.iso-ne.com/markets/othrmkts_data/fcm/cal_results/index.html). The need for this data by ISO-NE Transmission Planning is described in the Load Modeling Guide for ISO New England Network Model (see http://www.iso-ne.com/rules_proceds/isone_plan/othr_docs/index.html).

Section 6 - Transmission

Information on the ISO New England Regional Transmission Projects is periodically published and can be found at: http://www.iso-ne.com/committees/comm_wkgrps/prtcpnts_comm/pac/projects/index.html. The project lists are currently published every March, June, and October and are referred to as the March, June, and October Regional System Plan (RSP) Update, respectively.

The 'RSP 17 Project List - March 2017 - Final' will contain the prospective ISO New England Transmission System projects that shall be considered part of the 2017 CELT Report.

A.2 Company Abbreviations

Sections 2 and 5 of the CELT Report include company abbreviations. Below are the abbreviations used in this report along with their corresponding name.

LP Acronym	Lead Participant
AESR	Algonquin Energy Services Inc.
APNM	American PowerNet Management, LP
AMP	Ampersand Energy Partners LLC
AELC	Athens Energy LLC
PPMI	Avangrid Renewables, LLC
BSP	Bear Swamp Power Company LLC
BBHP	Black Bear Hydro Partners, LLC
BHI	Blackstone Hydro, Inc.
BSE	Blue Sky East, LLC
BSWL	Blue Sky West, LLC
EMMT-I	Boston Energy Trading and Marketing LLC
BELD	Braintree Electric Light Department, Town of
BPE	Brayton Point Energy, LLC
BPCLP	Bridgewater Power Company, L.P.
BEMLP	Brookfield Energy Marketing, LP
FPLEMH	Brookfield White Pine Hydro LLC
BKSG	Bucksport Generation LLC
BED	Burlington Electric Department
CALP	Calpine Energy Services, LP
CHIPM	CHI Power Marketing, Inc.
CMLP	Chicopee Municipal Lighting Plant
CMA	Christopher M. Anthony
CRMC	Commonwealth Resource Management Corporation
CESLLC	Competitive Energy Services, LLC
CLP	Connecticut Light and Power Company, The
CMEEC	Connecticut Municipal Electric Energy Cooperative
CEEI	Consolidated Edison Energy, Inc
CNE	Constellation NewEnergy, Inc.
CONV	Convergent Energy and Power LLC

LP Acronym	Lead Participant
CEM	Covanta Energy Marketing, LLC
CHA	Covanta Haverhill Associates
CPW	Covanta Projects of Wallingford, L.P.
DWBI	Deepwater Wind Block Island, LLC
DEM	Dominion Energy Marketing, Inc.
DMT1	Dynegy Marketing and Trade, LLC
EDFS	EDF Energy Services, LLC
EDFT	EDF Trading North America, LLC
EES5	Emera Energy Services Subsidiary No. 5 LLC
EES6	Emera Energy Services Subsidiary No. 6 LLC
EES7	Emera Energy Services Subsidiary No. 7 LLC
ECLP	EmpireCo Limited Partnership
ENE	Energy New England LLC
SUEZ	Engie Energy Marketing NA, Inc
ENPM	Entergy Nuclear Power Marketing LLC
EPICO	Epico USA, Inc.
NAEA-EM	Essential Power Massachusetts, LLC
EPN	Essential Power Newington, LLC
EWP2	Evergreen Wind Power II, LLC
EWP3	Evergreen Wind Power III, LLC
EXGC	Exelon Generation Company, LLC
NEL1	FirstLight Power Resource Management, LLC
FGE	Fitchburg Gas & Electric Light Company
GCE	GenConn Energy LLC
MET	Genon Energy Management, LLC
GOOSE	Goose River Hydro, Inc.
GRP	Granite Reliable Power, LLC
GRRN	Gravity Renewables, Inc
GRDV	Green Development, LLC
GMP	Green Mountain Power Corporation
HCG	Hampshire Council of Governments
HCWL	Hancock Wind, LLC
HGE	Holyoke Gas & Electric Department
HLPD	Hudson Light & Power Department

LP Acronym	Lead Participant
HULL	Hull Municipal Lighting Plant
IEA	Indeck Energy-Alexandria, L.L.C.
IPSC	Industrial Power Services Corp
IMLD	Ipswich Municipal Light Department
JERICHO	Jericho Power LLC
KENDALL	Kendall Green Energy, LLC
KCC	Kimberly-Clark Corporation
LELWD	Littleton Electric Light & Water Department
MMLLC	Manchester Methane, LLC
MMLD	Marblehead Municipal Light Department
MS1	Mass Solar 1, LLC
MBTA	Massachusetts Bay Transportation Authority
MEC	Massachusetts Electric Company
MMWEC	Massachusetts Municipal Wholesale Electric Company
MATEP	MATEP, LLC
MESSA	Messalonskee Stream Hydro, LLC
MMELD	Middleton Municipal Light Department
NBPGC	New Brunswick Energy Marketing Corporation
NECCO	New England Confectionery Company, Inc
NEP	New England Power Company
NHEC	New Hampshire Electric Cooperative, Inc.
FPLP	NextEra Energy Power Marketing, LLC
NRGPM	NRG Power Marketing LLC
NSTAR	NSTAR Electric Company
PPH	Pawtucket Power Holding Company LLC
PHE	Pioneer Hydro Electric Co., Inc.
PRE	Plainfield Renewable Energy, LLC
PSS	Power Supply Services, LLC
PMLD	Princeton Municipal Light Department
PSEG	PSEG Energy Resources & Trade LLC
PSEG-NH	PSEG New Haven, LLC
PSNH	Public Service Company of New Hampshire
PUTNAM	Putnam Hydropower, Inc.
RHW	Record Hill Wind, LLC

LP Acronym	Lead Participant
REESTR	ReEnergy Stratton LLC
RRIG	Rhode Island Engine Genco, LLC
RISE	Rhode Island State Energy Center, LP
RGC	Rocky Gorge Corporation
SENA	Shell Energy North America (US), L.P.
SELP	Shrewsbury Electric & Cable Operations
SPRING	Springfield Power, LLC
SPRUCE	Spruce Mountain Wind, LLC
SMED	Sterling Municipal Electric Light Department
STETSON	Stetson Holdings, LLC
STET2	Stetson Wind II, LLC.
IESI-I	Stored Solar J&WE, LLC

A.3 Column Abbreviations

Code	**Prime Mover** (Consistent with the DOE EIA-411 Instructions except where noted)
BA	Energy Storage, Battery
CC	Combined Cycle Total Unit Includes generators defined by EIA as Combined Cycle Steam Part (CA); Combined Cycle Single Shaft (CS - combustion turbine and steam turbine share a single generator); Combined Cycle Combustion Turbine Part (CT)
CE	Compressed Air Energy Storage
FC	Fuel Cell - Electrochemical
GT	Combustion (Gas) Turbine – Simple Cycle (includes jet engine design)
HL	Hydraulic Turbine
HDR	Hydraulic Turbine – Conventional -- Daily -- Run of River (includes turbines associated with delivery of water)
HDP	Hydraulic Turbine – Conventional -- Daily -- Pondage (includes turbines associated with delivery of water)
HTO	Hydraulic Turbine - Other (includes hydrokinetic tidal power technology)
HW	Hydraulic Turbine -- Conventional – Weekly -- Pondage (includes turbines associated with delivery of water)
IC	Internal Combustion Engine (diesel, piston, reciprocating)
IG	Integrated Coal Gasification Combined Cycle
OT	Other
PB	Pressurized Fluidized Bed Combustion
PS	Hydraulic Turbine – Reversible (pumped storage)
PV	Photovoltaic
ST	Steam Turbine, including nuclear, geothermal and solar steam (does not include combined cycle)
WT	Wind Turbine

A.4 Column Abbreviations

Code	**Energy Source** (Description of Fuel Used)
AB	Agricultural Crop Byproducts/Straw/Energy Crops
BFG	Blast Furnace Gas
BIT	Anthracite Coal and Bituminous Coal
BLQ	Black Liquor
DFO	Distillate Fuel Oil - including Diesel, No. 1, 2, and 4
JF	Jet Fuel
KER	Kerosene
LFG	Landfill Gas
LIG	Lignite Coal
MSW	Municipal Solid Waste
MWH	Electricity Used for Energy Storage
NG	Natural Gas
NUC	Nuclear Uranium, Plutonium, Thorium
OBG	Other Biomass Gas - includes digester gas, methane, and other biomass gasses
OBL	Other Biomass Liquids
OBS	Other Biomass Solids
OG	Other Gas
PC	Petroleum Coke
PG	Gaseous Propane
PUR	Purchased Steam
RFO	Residual Fuel Oil Includes: Bunker C, No. 5, and No. 6 (020, 030, 070, and 100)
SC	Coal Synfuel - Coal-based solid fuel - processed by a coal synfuel plant; and coal-based fuels such as briquettes, pellets, or extrusions, which are formed from fresh or recycled coal and binding materials
SLW	Sludge Waste
SUB	Subbituminous Coal
SUN	Solar
TDF	Tire-derived Fuels
WAT	Water at a Conventional Hydroelectric Turbine
WC	Waste/Other Coal - including anthracite culm, bituminous gob, fine coal, lignite waste, waste coal

A.4 Column Abbreviations

Code	**Energy Source** (Description of Fuel Used)
WDL	Wood Waste Liquids excluding Black Liquor - includes red liquor, sludge wood, spent sulfite liquor, and other wood-based liquids
WDS	Wood/Wood Waste Solids - including paper pellets, railroad ties, utility poles, wood chips, bark, and wood waste solids
WND	Wind
WO	Waste/Other Oil - including Crude Oil, Liquid Butane, Liquid Propane, Oil Waste, Re-Refined Motor Oil, Sludge Oil, Tar Oil, or other petroleum-based liquid wastes

B.1 Federal Information Processing Standard (FIPS) Codes

FIPS Code	County Name	FIPS Code	County Name (Cont'd)	FIPS Code	County Name (Cont'd)	FIPS Code	County Name (Cont'd)
State of Connecticut							
1	Fairfield	5	Litchfield	9	New Haven	13	Tolland
3	Hartford	7	Middlesex	11	New London	15	Windham
State of Maine							
1	Androscoggin	9	Hancock	17	Oxford	25	Somerset
3	Aroostook	11	Kennebec	19	Penobscot	27	Waldo
5	Cumberland	13	Knox	21	Piscataquis	29	Washington
7	Franklin	15	Lincoln	23	Sagadahoc	31	York
State of Massachusetts							
1	Barnstable	9	Essex	17	Middlesex	25	Suffolk
3	Berkshire	11	Franklin	19	Nantucket	27	Worcester
5	Bristol	13	Hampden	21	Norfolk		
7	Dukes	15	Hampshire	23	Plymouth		
State of New Hampshire							
1	Belknap	7	Coös	13	Merrimack	19	Sullivan
3	Carroll	9	Grafton	15	Rockingham		
5	Cheshire	11	Hillsborough (Hillsboro)	17	Strafford		
State of Rhode Island							
1	Bristol	5	Newport	9	Washington		
3	Kent	7	Providence				
State of Vermont							
1	Addison	9	Essex	17	Orange	25	Windham
3	Bennington	11	Franklin	19	Orleans	27	Windsor
5	Caledonia	13	Grand Isle	21	Rutland		
7	Chittenden	15	Lamoille	23	Washington		

B.2 Regional System Plan (RSP) Subarea & Load Zone Descriptions

Subarea or Control Area Designation	Region or State
BHE	Northeastern Maine
ME	Western and central Maine/Saco Valley, New Hampshire
SME	Southeastern Maine
NH	Northern, eastern, and central New Hampshire/eastern Vermont and southwestern Maine
VT	Vermont/southwestern New Hampshire
Boston	Greater Boston, including the North Shore
CMA/NEMA	Central Massachusetts/ northeastern Massachusetts
WMA	Western Massachusetts
SEMA	Southeastern Massachusetts/Newport, Rhode Island
RI	Rhode Island/bordering MA
CT	Northern and eastern Connecticut
SWCT	Southwestern Connecticut
NOR	Norwalk/Stamford, Connecticut
M, NY, and HQ	Maritimes, New York, and Hydro-Québec external Reliability Coordinator areas

Load Zone*	Region or State
CT	Connecticut
ME	Maine
NH	New Hampshire
RI	Rhode Island
VT	Vermont
NEMA	Northeastern Massachusetts
SEMA	Southeastern Massachusetts
WCMA	Western and Central Massachusetts

* The boundaries for the CT, ME, NH, RI, and VT load zones are the same as the state boundaries.