

1 Q. Please state your full name and business address.

2 A. Renee Codega, Vanasse Hangen Brustlin, Inc. (“VHB”), 1 Cedar Street, Suite 400,
3 Providence, Rhode Island.

4 Q. By whom are you employed and in what position?

5 A. I am employed by VHB as a licensed professional engineer and specifically as a Senior
6 Project Engineer and Chief Reviewer for the Providence office.

7 Q. What are your responsibilities as Senior Project Engineer and Chief Reviewer?

8 A. As a Senior Project Engineer my design responsibilities include civil/site design, utility
9 design, and stormwater design. Applying for and securing various permits for the
10 projects are also within my scope of responsibilities. As Chief Reviewer, my
11 responsibilities include providing quality assurance reviews for VHB land development
12 projects designed by other VHB staff members.

13 Q. Please describe your education, training and experience.

14 A. I received a Bachelor of Science Degree in Civil Engineering from the University of
15 Rhode Island. I am a Registered Professional Engineer in Rhode Island and
16 Massachusetts. I have been a Professional Mentor for the University of Rhode Island
17 Senior Capstone Projects and am a member of the Rhode Island Healthcare Engineers
18 Society.

19 I have over 30 years of experience in civil and environmental engineering working for
20 private and public clients. Some of my past projects include National Grid substations,
21 Fidelity Regional Campus, various projects for Lifespan and Care New England,
22 Navigant Credit Union, and various Rhode Island College projects. These projects have

1 included stormwater design components complying with the Rhode Island Stormwater
2 Design and Installations Standards Manual (“RISDISM”). I have also provided on-call
3 engineering services for the Town of Portsmouth as a peer reviewer for projects subject
4 to various Town regulations and ordinances, providing compliance reviews and
5 testimonies at the Planning Board’s public hearings. A copy of my vitae is attached as
6 Attachment RC-1.

7 Q. Are you familiar with National Grid’s Aquidneck Island Reliability Project (the
8 “Project”)?

9 A. Yes, I have prepared the stormwater analysis and stormwater management design for its
10 proposed new Jepson Substation and presented the design on behalf of National Grid in
11 proceedings before the Town of Middletown.

12 Q. What is the scope of your testimony in this proceeding?

13 A. In my testimony, I will respond to the prefiled testimony of Steven M. Cabral that was
14 filed on behalf of the Town of Middletown.

15 Q. In his prefiled testimony, Mr. Cabral refers to the RISDISM on page 5 Line 141 and the
16 Town of Middletown Section 153 - Stormwater Management on page 8 line 312 through
17 313, are you familiar with these documents?

18 A. Yes.

19 Q. What are the differences between the RISDISM and the Town of Middletown Section
20 153 - Stormwater Management?

21 A. From a stormwater design perspective, the Town’s Code requires a project’s stormwater
22 analysis to include the evaluation and mitigation of the 2-year and 25-year 24-hour storm

1 events, where the RISDISM requires the evaluation and mitigation of the 1-year, 10-year
2 and 100-year, 24-hour storm events.

3 Q. Are any of these differences relevant to the proposed Project?

4 A. Yes. The Project's stormwater analysis includes the additional evaluation and mitigation
5 required by the local ordinance.

6 Q. Are you familiar with Mr. Cabral's statement that the "compacted gravel", as defined in
7 RISDISM, is considered impervious?

8 A. Yes.

9 Q. Is the proposed fill for the substation "compacted gravel" as defined in RISDISM?

10 A. No. In the Glossary of Terms Section of the RISDISM, impervious cover is defined as
11 follows: IMPERVIOUS COVER (I) - Those surfaces that cannot effectively infiltrate
12 rainfall consisting of surfaces such as building rooftops, pavement, sidewalks, driveways,
13 compacted gravel (e.g., driveways and parking lots).

14 Q. Please explain the difference.

15 A. Within the upper 24-inches of gravel of the substation yard, electrical conduits and
16 grounding grid are installed. Due to these conduits, grounding grid and the overhead
17 conductors throughout the substation yard, vehicle travel is limited to the paved
18 driveways. Therefore, the gravel within the substation yard is not subject to the
19 consolidation from constant wheel loading that can affect permeability of gravel
20 driveways. Additionally, the lower gravel fill material, compacted to 95% will have a
21 hydraulic conductivity of 2 inches per hour, a rate that allows for filtering of rainfall. In
22 fact, the RIDEM's specifications for the various media within a pervious pavement

1 section requires compaction to 95% for those materials. Testing during construction will
2 ensure conformance with the required specification.

3 Q. Is Mr. Cabral correct in stating that National Grid is seeking waivers from the RISDISM?

4 A. No. The Project is providing technical justifications for using a different method of
5 achieving water quality treatment. This is not considered a waiver.

6 Q. Do you agree with Mr. Cabral's statement on page 5 lines 175 through 177 that the
7 proposed underdrain will prevent the recharge of groundwater?

8 A. No. There are several underdrains within the substation yard. There are three in the
9 upper area of the yard that intercepts the groundwater in this area and provides a
10 separation to groundwater from the yard development during seasonal high groundwater
11 conditions. The lower half of the yard also has one underdrain at the base of the wall to
12 provide discharge of the stormwater runoff that drains through the substation yard. This
13 is common practice in the structural design of retaining walls. This underdrain is
14 elevated slightly from the bottom of the yard fill and the outlet pipe is sized to meter the
15 flow, thereby allowing for recharge of the required recharge volume

16 Q. Are you familiar with the Soil Erosion and Sediment Control Plan ("SESC") for the
17 proposed substation?

18 A. Yes.

19 Q. Was this plan submitted to the Town of Middletown?

20 A. Yes. The original draft of the plan was submitted to the Town of Middletown on
21 November 8, 2016 in connection with applications to the Planning Board and Zoning
22 Board of Review.

1 Q. Does National Grid propose to use sediment controls during the construction phase of the
2 Project?

3 A. Yes.

4 Q. Were these controls described in the plan submitted to the Town of Middletown?

5 A. Yes.

6 Q. What is the status of the plan?

7 A. The SESC Plan was submitted and has been reviewed by the RIDEM. Their comment
8 letter requires the use of temporary sediment traps on the site in addition to the compost
9 filter socks, erosion control blankets, and stabilized construction exit that were part of the
10 original plan. The SESC Plan will be modified and resubmitted to the RIDEM and will
11 include the use of temporary sediment traps during construction.

12 Q. Do you agree with Mr. Cabral's statement on page 6 line 189 through 194 of his prefiled
13 testimony that there would be a net loss of water recharge from the use of 16 feet of
14 highly compacted gravel?

15 A. No. Section 153.25C. of the Town's Stormwater Ordinance requires "all receiving
16 waters will be recharged in a manner closely resembling predevelopment conditions."

17 Q. Please explain.

18 A. First, Mr. Cabral's use of the term highly compacted gravel is inaccurate. As discussed
19 previously, the fill will be compacted, but will have a hydraulic conductivity of 2 inches
20 per hour. Second, the lodgement till soils present on the site function poorly in terms of
21 deep infiltration and groundwater recharge. For example, the Newport Series that is
22 mapped in the well-drained position at the proposed substation has a reported saturated

1 permeability of 10.25 um/sec (1.5 inch per hour) in the upper two feet of the solum, the
2 upper layers of the soil profile, and only 0.71 um/sec (0.1 inch per hour) in the dense till
3 substratum which is typically encountered within three feet of the surface. This
4 difference in permeability rates creates a situation where a seasonal “perched” water table
5 forms above the dense till layer. In response to the gravitational gradient (slope) of the
6 till deposit, saturated flow occurs within the lower part of the solum. This lateral flow
7 above a confining layer is termed “through-flow” by soil scientists. In landscapes
8 underlain by dense till, such as the substation site, this through-flow is transpired or
9 eventually re-emerges at the ground surface as seeps at slope breaks. Once on the surface
10 of the ground this seepage is termed “reflow”. This existing hydrologic setting will be
11 mimicked by the constructed substation where water can travel through the thick
12 compacted fill layer at rates greater than the compacted underlying substratum. Reflow
13 will leak from the toe of the fill slope and provide hydrologic support to wetlands in the
14 head waters of Mother of Hope Brook.

15 Q. Does this complete your testimony?

16 A. Yes.

The Narragansett Electric Company
d/b/a National Grid
Aquidneck Island Reliability Project
EFSB Docket No. SB-2016-01
Witness: Renee L. Codega, P.E.

ATTACHMENT

RC-1 Curriculum Vitae of Renee L. Codega, P.E.