

**STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS  
PUBLIC UTILITIES COMMISSION**

The Narragansett Electric Company d/b/a )  
National Grid (Rhode Island Reliability Project) ) RIPUC Docket No. 4029

**PREFILED TESTIMONY OF  
FRANK MEZZANOTTE**

**ON BEHALF OF  
ISO NEW ENGLAND INC.**

March 13, 2009

Mr. Mezzanotte is a Manager of Area Transmission Planning at ISO New England Inc. with the responsibility for the Southern New England studies. His testimony describes the responsibilities of ISO New England, including its function as the regional transmission planner for the New England bulk power grid, discusses electric system reliability concerns in Rhode Island, and supports the Rhode Island Reliability Project as a solution to such reliability concerns.

## TABLE OF CONTENTS

1. ....	
<b>Introduction</b> .....	1
2. ....	
<b>Summary of Testimony</b> .....	2
3. ....	
<b>ISO'S Mission and Responsibilities</b> .....	4
4. ....	
<b>Reliability Standards</b> .....	8
5. ....	
<b>The Reliability of the Transmission System in Rhode Island</b> .....	10
6. ....	
<b>Benefits of The Rhode Island Reliability Project</b> .....	14
<b>LIST OF ATTACHMENTS</b> .....	16

1    **1.    Introduction**

2    *Q1.    Please state your name, position, and business address.*

3    A1.    I am Frank Mezzanotte, Manager – Area Transmission Planning at ISO New  
4            England Inc. (the “ISO”). My business address is ISO New England Inc., One  
5            Sullivan Road, Holyoke, Massachusetts 01040.

6    *Q2.    Please state your educational background and work experience.*

7    A2.    I have a Masters in Power Engineering & Engineering Management from the  
8            George Washington University. I began my career with the Long Island Lighting  
9            Company where I worked for nineteen years in various planning and engineering  
10           positions. After that, I served as the Manager of System Engineering & Planning  
11           at Northern Virginia Electric Cooperative.

12           I joined Transmission Planning at the ISO as a Lead Engineer in June, 2001, was  
13           promoted to Supervisor in 2004, and achieved the title of Manager in 2008. My  
14           main responsibility has been to lead, coordinate and review studies in the three  
15           southern New England states of Rhode Island, Massachusetts and Connecticut. I  
16           have been directly involved in the development of all of the Regional  
17           Transmission Expansion Plan and Regional System Plan reports since joining the  
18           ISO in 2001.

19           I am a licensed Professional Engineer in the states of Massachusetts, New York  
20           and Virginia.

21

1 Q3. *Have you previously testified before the Rhode Island Public Utilities*  
2 *Commission?*

3 A3. Yes. I testified in the Southern Rhode Island Transmission Project proceeding in  
4 Docket No. 3732.

5 2. **Summary of Testimony**

6 Q4. *What is the purpose of your testimony in this proceeding?*

7 A4. In my testimony, I describe generally the ISO's mission and responsibilities. I  
8 also describe the ISO's planning criteria and how they relate to the Federal  
9 Energy Regulatory Commission ("FERC"), the North American Electric  
10 Reliability Corporation ("NERC") and the Northeast Power Coordinating  
11 Council, Inc. ("NPCC") standards and requirements for the Nation's bulk power  
12 transmission system. My testimony supports the need for the Rhode Island  
13 Reliability Project to address identified reliability concerns in Rhode Island.

14 Q5. *Please summarize your testimony.*

15 A5. Based on studies to date and applicable regional reliability standards, the ISO is  
16 concerned about the reliability of the existing electricity delivery system in Rhode  
17 Island. In an effort to evaluate the ability of the transmission system in southern  
18 New England to continue to perform reliably, a working group, consisting of  
19 planners from the ISO, National Grid and Northeast Utilities was formed. Under  
20 my direction and supervision, this working group undertook a comprehensive  
21 forward looking transmission planning study, known as the Southern New  
22 England Transmission Reliability analysis. This analysis is documented in the

1 Southern New England Transmission Reliability Report, Needs Assessment

2 (“Needs Assessment”)<sup>1</sup>.

3 Transmission reliability and dependence on local generation are major concerns  
4 for the Rhode Island system. Section 3.3.2 of the Needs Assessment identifies  
5 critical weaknesses in Rhode Island where, without transmission improvements,  
6 the system may fail to provide reliable service.

7 After establishing the existence, nature and location of the reliability concerns, the  
8 working group identified possible transmission solutions and evaluated each  
9 solution. This step involved determining the advantages and disadvantages of  
10 each possible transmission solution: what new infrastructure, configurations and  
11 operational changes could best cure the identified problems. The working group  
12 detailed this analysis in the New England East-West Options Analysis (“Options  
13 Report”)<sup>2</sup>, including the selection of the Rhode Island Reliability Project (the  
14 “Project”) in conjunction with the Interstate Reliability Project as the  
15 recommended solutions for the identified reliability concerns in Rhode Island.

16 The Project consists of a new 345 kV transmission line, and the relocation of two  
17 existing 115 kV transmission lines on an existing 21.4 mile right-of-way from the  
18 West Farnum Substation in North Smithfield to the Kent County Substation in  
19 Warwick. The major component of the Project is the construction of a second  
20 345 kV transmission line to National Grid’s existing Kent County Substation. In

---

<sup>1</sup> Included as Appendix D to the Petitioner’s Environmental Report.

<sup>2</sup> Included as Appendix E to the Petitioner’s Environmental Report.

1 order to accomplish this, it is necessary to relocate two existing 115 kV lines on  
2 the right-of-way and relocate short segments of other 115 kV lines. To accept the  
3 new 345 kV transmission line, the existing West Farnum and Kent County  
4 Substations will be expanded and modified.

5 In September 2008, Narragansett Electric Company (“National Grid”) filed with  
6 the Rhode Island Energy Facility Siting Board an application to construct the  
7 Rhode Island Reliability Project. I support the Project as needed to address the  
8 reliability concerns identified in the Needs Assessment and to ensure the  
9 continuation of reliable electric service to customers in Rhode Island.

10 **3. The ISO Mission and Responsibilities**

11  
12 *Q6. Why was the ISO established?*

13 A6. The “Independent System Operator” concept was developed by FERC as part of  
14 the framework to support competitive electricity markets. In 1996, FERC stated  
15 its principles for the ISO operation and governance in FERC Order 888.<sup>3</sup> FERC  
16 identified Independent System Operator principles as: providing independent,  
17 open and fair access to the region’s transmission system; establishing a non-  
18 discriminatory governance structure; facilitating market based wholesale  
19 electricity rates; and ensuring the efficient management and reliable operation of  
20 the regional bulk power system.

---

<sup>3</sup> Promoting Wholesale Competition Through Open Access, Non-Discriminatory Transmission Services by Public Utilities; Recovery of Stranded Costs by Public Utilities and Transmitting Utilities, Order No. 888, 75 FERC ¶ 31,036 (1996)(establishing principles for ISO's operation and governance).

1 The ISO was established to be the Independent System Operator of the New  
2 England bulk power grid on July 1, 1997,<sup>4</sup> and it assumed certain operating and  
3 transmission reservation responsibilities which had previously been carried out by  
4 NEPOOL, which transferred staff and assets to the ISO.

5 Q7. *Does the ISO make any profit from its role as the Independent System Operator?*

6 A7. No. As the Independent System Operator, the ISO complies with FERC Order  
7 No. 889.<sup>5</sup> In this regard, the ISO is an independent, private, non-profit, non-  
8 stock, company. The ISO therefore has no shareholders, and its Board of  
9 Directors and employees are barred from being employed by or owning shares in  
10 NEPOOL Market Participants. Its budget is reviewed and approved annually by  
11 FERC, and the ISO only recoups its annual expenses. As a result, market activity  
12 covers the ISO's expenses in monitoring and administering the system.

13 Q8. *What are the ISO's mission and responsibilities?*

14 A8. The ISO manages the New England region's bulk electric power system, operates  
15 the wholesale electricity market, administers the region's Open Access  
16 Transmission Tariff, and conducts regional transmission planning. More  
17 specifically, the ISO's responsibilities include independently operating and  
18 maintaining a highly reliable bulk transmission system, promoting efficient  
19 wholesale electricity markets, and working collaboratively and proactively with

---

<sup>4</sup> New England Power Pool, Order Conditionally Authorizing Establishment of an Independent System Operator and Disposition of Control Over Jurisdictional Facilities, 79 FERC ¶ 61,374 (1997) (authorizing formation of ISO).

<sup>5</sup> Open Access Same-Time Information System Conduct, Order No. 889, 75 FERC ¶ 61,078 (1996) (rules establishing and governing Open Access Same-Time Information System).

1 state and federal regulators, NEPOOL Participants, and other stakeholders in  
2 pursuit of these goals.

3 As pertinent to this proceeding, FERC has conferred upon the ISO responsibility  
4 for conducting long-term system planning for New England.<sup>6</sup> As such, the ISO  
5 must maintain a level of system reliability that meets criteria established by  
6 NERC, NPCC, and the ISO's own planning standards. Applicable reliability  
7 standards are discussed more fully below.

8 It is appropriate to add that the massive outage that struck the North American  
9 electric power system on August 14, 2003, causing the loss of approximately  
10 2,500 megawatts ("MW") of load in New England, has underscored the  
11 significance of the ISO's mission and responsibilities. The event demonstrated the  
12 need for appropriate reliability standards, effective monitoring of compliance,  
13 and, most importantly, a reliable bulk power transmission system. A well  
14 coordinated regional system plan and additional power system infrastructure are  
15 more essential than ever to ensure reliability of service to load, because without a  
16 well-planned system, there may not be operating options available to maintain  
17 reliable service.

18  
19  

---

<sup>6</sup> ISO New England Inc. and New England Power Pool, Order on Reh'g, 95 FERC ¶ 61,384 (2001) (authorizing ISO to oversee regional transmission planning); ISO New England Inc and New England Power Pool, 103 FERC ¶ 61,304 (2003) (finding that "[w]e are persuaded by ISO-NE's arguments it is the appropriate authority to approve planning for transmission upgrades..."); Order Accepting Compliance Filing, As Modified, 123 FERC ¶ 61,113 (2008) (accepting ISO Tariff provisions regarding transmission planning).



1 Q9. *What is the ISO's role in conducting regional transmission planning?*

2 A9. The ISO is responsible for conducting long-term regional transmission planning  
3 for the New England region. The ISO annually prepares a comprehensive  
4 Regional System Plan ("RSP") for the six New England states that includes  
5 forecasts of future load and how the electrical transmission system as planned can  
6 meet the growing demand by adding generating resources, energy efficiency or  
7 other demand-side resources, and transmission. Transmission upgrades are  
8 planned and required throughout New England to maintain system reliability,  
9 improve the efficiency of system operations, increase system transfer capability,  
10 serve major load pockets, and reduce locational dependence on generating units.  
11 The RSP identifies additional work required to fully develop a highly coordinated  
12 regional plan to meet the reliability requirements of New England. The regional  
13 transmission plan is developed through an open process and through participation  
14 of, and review by, interested parties, including state regulators and NEPOOL  
15 market participants. To ensure that the ISO receives the full benefit of input from  
16 all interested stakeholders, the ISO convenes multiple planning meetings over the  
17 course of the year with the Planning Advisory Committee ("PAC")—a  
18 stakeholder group that is open to any interested entity, including, but not limited  
19 to, Transmission Customers, Market Participants, and various officials of the New  
20 England states. The ISO also coordinates the regional system planning process  
21 with the Participating Transmission Owners and other asset owners in New  
22 England.

1    **4.    Reliability Standards**

2    *Q10.    What criteria does the ISO use in determining whether electricity service in New*  
3    *England, including Rhode Island, is reliable?*

4    A10.    As explained below, there are numerous criteria employed in planning a reliable  
5    transmission system. Overall, these criteria all seek to satisfy one overarching  
6    objective - to ensure an electric system that can reliably deliver electric energy to  
7    the distribution systems served by the Participating Transmission Owners.

8    Without this objective, the probability of widespread electric outages to many  
9    customers is increased significantly. In other words, the reliability objectives  
10   seek to keep the lights on in the region, generally, and in specific areas of  
11   transmission need, particularly.

12   The ISO plans the New England regional transmission system to comply with the  
13   reliability and criteria standards established by NERC, NPCC and the ISO. The  
14   ISO's implementation and compliance with NERC/NPCC Reliability Rules are  
15   codified in its Operations, Planning, and Administrative manuals and other  
16   written procedures. NERC oversees a number of regional councils, one of which  
17   is the NPCC. The NPCC covers New York, New England, and parts of Canada.

18   Under this framework, NERC has established a general set of mandatory rules  
19   and criteria applicable to all geographic areas. NPCC has established a set of  
20   rules and criteria particular to the Northeast, although they also encompass the  
21   more general NERC standards. In turn, the ISO has developed standards and

1 criteria specific to New England that coordinate with the NPCC rules. Similar  
2 standards exist throughout the nation and other portions of North America.  
3 Whether developed by NERC, NPCC, or the ISO, the standards and criteria  
4 applicable to the New England transmission system are applied in a deterministic  
5 fashion (*i.e.*, for specific disturbances or “contingencies”) in order to assess the  
6 ability for it to perform under a series of defined contingency situations.  
7 Specifically, these standards and criteria dictate a set of operating circumstances  
8 or contingencies under which the New England transmission system must perform  
9 without experiencing overloads, instability, or voltage violations. For NPCC,  
10 these performance measurements are set forth in NPCC Document A-2, “Basic  
11 Criteria for the Design and Operation of Interconnected Power Systems” (revised  
12 May 2004) attached as Attachment A. The ISO planning procedures are designed  
13 to meet the reliability standards that are specifically defined in Planning  
14 Procedure No. 3, “Reliability Standards for the New England Bulk Power Supply  
15 System” (“PP3”), attached as Attachment B. PP3 provides the published standard  
16 that provides consistent system planning criteria throughout New England.  
17 Analyses of these contingencies also include assessment of the potential for  
18 widespread cascading outages due to overloads, instability or voltage collapse.

19  
20  
21  
22

1    **5.    The Reliability of the Transmission System in Rhode Island**

2    *Q11. Does the ISO have concerns regarding the ability of the transmission system in*  
3    *Rhode Island to provide continued reliable electric service?*

4    A11. Yes. The Needs Assessment identifies and details reliability concerns with the  
5    Rhode Island electric system. The ISO presented the deficiencies of the Rhode  
6    Island electric system at PAC meetings on five different occasions: May 4, 2005;  
7    March 15, 2006; December 15, 2006; December 3, 2007; and May 19, 2008.

8    *Q12. What are the ISO's concerns regarding the ability of this transmission system to*  
9    *provide continued reliability of electricity service in Rhode Island?*

10   A12. From a reliability perspective, the ISO is concerned that the existing system in  
11   Rhode Island faces a combination of growing summer peak demand, limited  
12   transmission capacity, and limited generation that is effectively integrated to serve  
13   the load. As the Needs Assessment shows, there is a high and increasing  
14   potential exposure to being unable to withstand single and multiple element  
15   contingencies following the single loss or outage of certain critical facilities in  
16   Rhode Island as the system approaches or exceeds forecasted peak load levels.  
17   Single element contingencies refer to the loss of an individual transmission line,  
18   transformer, or generator due to any event such as a lightning strike. Multiple  
19   element contingencies refer to a single event which removes multiple pieces of  
20   generating or transmission equipment from service such as may occur following  
21   the failure of a circuit breaker or the simultaneous loss of multiple transmission  
22   circuits which are on the same tower. These contingencies can result in thermal

1 and voltage violations of the reliability and security standards established by  
2 NERC, the NPCC and the ISO.

3 Because of Rhode Island's dependence on local generation, reliability concerns  
4 are exacerbated if local generation is unavailable. If local generation is not  
5 available, the limited amount of electricity that the existing transmission system  
6 can import from other areas and transmit in Rhode Island places the area at an  
7 unacceptable risk of loss of service.

8 *Q13. What specifically are the ISO's reliability concerns in Rhode Island?*

9 A13. The ISO shares National Grid's concerns with thermal overloading of  
10 transmission lines, poor voltage performance and potential voltage collapse. As  
11 stated in the Needs Assessment, transmission system reliability and dependence  
12 on local generation are the major concerns for the Greater Rhode Island area. A  
13 number of steady-state thermal and voltage violations were observed on the  
14 transmission facilities while analyzing the conditions for the 2009 system.  
15 The reliability problems on the Rhode Island 115 kV system are caused by a  
16 number of contributing factors (both independently and in combination),  
17 including high load growth (especially in southwestern Rhode Island and the  
18 coastal communities), generation unit availability, and transmission outages  
19 (planned or unplanned). Additionally, the Rhode Island 115 kV system is  
20 constrained when one of the Greater Rhode Island 345 kV lines is out-of-service.  
21 The 345 kV transmission lines critical for serving load in the Rhode Island 115  
22 kV system are as follows:

- 1           • Line 328 (Sherman Rd – West Farnum)
- 2           • Line 332 (West Farnum – Kent County)
- 3           • Line 315 (West Farnum – Brayton Point)
- 4           • Line 303 (ANP Bellingham – Brayton Point)

5           Outage of any of these transmission lines result in limits to power transfer into  
6           Rhode Island. For line-out conditions, the next critical contingency would  
7           involve a loss of a 345/115 kV autotransformer or the loss of a second 345 kV tie.

8    *Q14. How do thermal overloads occur?*

9    A14. Thermal overloads occur when transmission lines, often as a result of a  
10           contingency event elsewhere in the system, carry current in excess of their design  
11           capacity. Overloaded lines build up heat beyond their temperature limits and may  
12           sag in an unsafe manner or fail, redirecting power to other lines, which in turn  
13           may become overloaded; a pattern that may result in a sustained loss of load,  
14           equipment damage and cascading outages that could affect areas well outside  
15           Rhode Island.

16           Transmission lines have normal and emergency current ratings. Normal ratings  
17           are the rating limits within which a line should generally operate at all times.

18           Normal line loading ratings are violated when a transmission line is used to carry  
19           current in excess of its rating for sustained planned system configurations.

20           Transmission lines can be operated at current loads that exceed the normal rating,  
21           but only for a limited period of time, such as following a sudden equipment  
22           outage. An emergency current rating is the upper operational limit of the line.

1 Consequences of operating lines between normal and emergency limits include  
2 reduced life expectancy of the transmission line and reduction in the ability to  
3 respond to subsequent outages. Exceeding the emergency ratings of transmission  
4 lines can result in line mechanical failure or sagging into public areas, such as  
5 highways; thereby compromising public safety and causing uncontrolled outages.  
6 Lines that sagged into trees in Ohio contributed to the Northeast Blackout of  
7 August 2003.

8 *Q15. Why is low voltage a concern?*

9 A15. Low voltage at the consumer level is a concern because it can damage equipment  
10 and interfere with the proper operation of appliances and machinery. At the  
11 transmission level, insufficient voltage can also cause unanticipated and  
12 undesirable protective equipment operation, voltage collapse and loss of load.

13 *Q16. How many violations of the ISO Reliability Standards may occur before a system*  
14 *is considered to be out of compliance?*

15 A16. None. A system that has only one violation of the criteria outlined in the ISO  
16 Reliability Standards is not in compliance.

17 *Q17. What consequences can an uncontrolled blackout have?*

18 A17. There are two consequences of an uncontrolled blackout. First, it is often difficult  
19 to accurately predict how large an area will be affected by blackout, and as a  
20 result, it could encompass the entire northeastern United States, as happened in  
21 1965 and again on August 14, 2003, when parts of the Midwest and Canada were  
22 also affected along with the Northeast. Second, it may result in equipment

1 damage that will hamper restoration of service, thus prolonging outages, and  
2 make efforts to remedy the system more expensive.

3 **6. Benefits of the Rhode Island Reliability Project**

4  
5 *Q18. What reliability benefits will the Rhode Island Reliability Project provide to the*  
6 *transmission system?*

7 A18. The installation of the Rhode Island Reliability Project will address the reliability  
8 issues described above by eliminating the thermal and voltage criteria violations.  
9 Moreover, the transmission upgrades will serve to ensure that Rhode Island's  
10 transmission system remains in compliance with NERC, the NPCC, and the ISO  
11 reliability standards.

12 *Q19. Are there any factors that could influence the timing of when these upgrades are*  
13 *needed?*

14 A19. Yes. The first Forward Capacity Auction ("FCA") was held in February 2008 and  
15 the second FCA was held in December 2008. The ISO's Tariff requires that the  
16 ISO "reflect proposed market responses in the regional system planning process."<sup>7</sup>

17 As required by the Tariff, the ISO has considered the impact on the need for the  
18 Rhode Island Reliability Project based on the cleared resources resulting from the  
19 FCA. Additionally, the ISO has considered the timing of need for the project  
20 based on recent load forecasts.

21 The ISO has concluded that neither the FCA resources nor the revised load  
22 forecast would affect the timing of the need for the project. A total of 76 MW of

---

<sup>7</sup> Section 4.2(a) of Attachment K to the ISO New England Transmission, Markets and Services Tariff.



1 Demand Resources in Rhode Island cleared in the second FCA. Only about half  
2 of these resources are located in the load area that would impact the need for the  
3 project. Additionally, only two New Generating Capacity Resources in Rhode  
4 Island cleared in the auctions and both of these resources are small landfill units.  
5 Finally, the recent reduced load forecast is comparable (within 1%) of the original  
6 2005 forecast in the Needs Assessment.

7 *Q20. Will these findings be presented to the PAC?*

8 A.20. Yes. The findings and analysis supporting the determination that neither the FCA  
9 resources nor the revised load forecast affect the timing of the need for the Rhode  
10 Island Reliability Project will be presented to the PAC on May 15, 2009.

11 *Q21. Does the ISO support the proposed Rhode Island Reliability Project?*

12 A21. Yes. As described above and in the Needs Assessment, the ISO is concerned  
13 about the ability of the existing transmission system to maintain reliable electric  
14 service in Rhode Island. The Rhode Island Reliability Project proposes a new  
15 345 kV line from West Farnum to Kent County, which is needed to support the  
16 southwestern Rhode Island area if the existing 345 kV line (line 332) is lost,  
17 especially if either the FPLE Rhode Island State Energy generation plant or  
18 Manchester Street generation plant is out-of- service. The Project will provide a  
19 critical reinforcement when line 332 is out-of- service and an additional key  
20 southwestern Rhode Island element is lost (an N-1-1 contingency condition).

21 *Q22. Does this conclude your testimony?*

22 A22. Yes, thank you.

## ISO ATTACHMENT LIST

---

### Frank Mezzanotte

- |              |  |
|--------------|--|
| Attachment A | NPCC Document A-2 “Basic Criteria for the Design and Operation of the Interconnected Power Systems.” |
| Attachment B | ISO Planning Procedure No. 3, “Reliability Standards for the New England Bulk Power Supply System.”  |