

#3696

RECEIVED

2006 MAR 27 PM 12: 51

New England Gas Company 

March 24, 2006

PUBLIC UTILITIES COMMISSION

Luly Massaro, Commission Clerk
Public Utilities Commission
89 Jefferson Boulevard
Warwick, Rhode Island 02888

Re: Semi-annual Btu Content Factor Update

Dear Luly:

Pursuant to Section 1, Schedule B, Sheet 1 of the Company's currently effective tariff (RIPUC NEG No. 101), the Company shall calculate the seasonal btu content at the end of October and April based upon the prior six-month experience. Such btu conversion factors shall be used to convert volumetric meter readings into therms. Based on actual gas send-out data for the six months ended October 2005, the actual weighted average system btu content was 1.023. Thus, for the period May through October 2006, the Company will convert volumetric meter readings to therms using a btu conversion factor of 1.023. For example, a meter reading of 100 ccf will equate to 102.3 therms (100×1.023). The 1.023 btu conversion factor reflects a decrease from the 1.026 btu conversion factor currently in effect through the end of April 2006.

Attached please find daily sendout data for the period May 1, 2005 through October 31, 2005, supporting the 1.023 btu conversion calculation. Volumetric and thermal equivalent sendout data is presented for each gate station and production facility on a daily basis for the six months ended October 31, 2005. As shown on page 12, for the six months ended October 31, 2005, the Company sent out 10,010,798 MMBtus and 9,783,728 Mcfs, resulting in the semi-annual weighted average btu conversion factor of 1.023.

Please call Peter Czekanski if you have any questions or would like to discuss the btu conversion calculation further. Peter can be reached at 574-2309.

Sincerely,



Kevin Renders
Manager Regulatory Relations

cc: Mr. Thomas Massaro
Mr. Steve Scialabba
Mr. Bruce Oliver

100 Weybosset Street
Providence, RI 02903

www.negasco.com

F:\pricshar\Therm Billing\BTU factor 032206.doc

Rhode Island Weighted Average BTU Content
 May through October 2005

New England Gas Company

TENN GATE STATIONS

DATE	BTU VALUE	YANKEE GAS		MCF		BTU VALUE	MMBTU TENN METERED	MCF TENN METERED	TOTAL		BTU VALUE	MMBTU AGT LNG VAPOR METERED	MCF AGT LNG B.O. METERED	BTU VALUE	MMBTU		MCF B.O. METERED	TOTAL		
		YANKEE GAS METERED	MCF METERED	MCF TENN METERED	MCF TENN METERED				BTU VALUE	AGT LNG VAPOR METERED					MMBTU AGT LNG VAPOR METERED	MCF AGT LNG B.O. METERED		BTU VALUE	MCF AGT LNG B.O. METERED	MMBTU AGT LNG VAPOR METERED
01-May-05	1,000	0	0	0	0	0	26658	26658	26186	1,000	0	0	0	0	0	0	0	0	0	0
02-May-05	1,000	0	0	0	0	0	34136	34136	33133	1,000	0	0	0	0	0	0	0	0	0	0
03-May-05	1,000	0	0	0	0	0	24942	24942	24942	1,000	0	0	0	0	0	0	0	0	0	0
04-May-05	1,000	0	0	0	0	0	35684	35684	34357	1,000	0	0	0	0	0	0	0	0	0	0
05-May-05	1,000	0	0	0	0	0	34892	34892	34892	1,000	0	0	0	0	0	0	0	0	0	0
06-May-05	1,000	0	0	0	0	0	35488	35488	34782	1,000	0	0	0	0	0	0	0	0	0	0
07-May-05	1,000	0	0	0	0	0	42353	42353	41428	1,000	0	0	0	0	0	0	0	0	0	0
08-May-05	1,000	0	0	0	0	0	36922	36922	36076	1,000	0	0	0	0	0	0	0	0	0	0
09-May-05	1,000	0	0	0	0	0	33454	33454	32864	1,000	0	0	0	0	0	0	0	0	0	0
10-May-05	1,000	0	0	0	0	0	35378	35378	33469	1,000	0	0	0	0	0	0	0	0	0	0
11-May-05	1,000	0	0	0	0	0	28192	28192	27798	1,000	0	0	0	0	0	0	0	0	0	0
12-May-05	1,000	0	0	0	0	0	31034	31034	30594	1,000	0	0	0	0	0	0	0	0	0	0
13-May-05	1,000	0	0	0	0	0	28692	28692	28226	1,000	0	0	0	0	0	0	0	0	0	0
14-May-05	1,000	0	0	0	0	0	30416	30416	30104	1,000	0	0	0	0	0	0	0	0	0	0
15-May-05	1,000	0	0	0	0	0	30667	30667	29148	1,000	0	0	0	0	0	0	0	0	0	0
16-May-05	1,000	0	0	0	0	0	28666	28666	28445	1,000	0	0	0	0	0	0	0	0	0	0
17-May-05	1,000	0	0	0	0	0	29132	29132	28845	1,000	0	0	0	0	0	0	0	0	0	0
18-May-05	1,000	0	0	0	0	0	28111	28111	28111	1,000	0	0	0	0	0	0	0	0	0	0
19-May-05	1,000	0	0	0	0	0	25110	25110	24830	1,000	0	0	0	0	0	0	0	0	0	0
20-May-05	1,000	0	0	0	0	0	26073	26073	25815	1,000	0	0	0	0	0	0	0	0	0	0
21-May-05	1,000	0	0	0	0	0	31431	31431	31159	1,000	0	0	0	0	0	0	0	0	0	0
22-May-05	1,000	0	0	0	0	0	31512	31512	31125	1,000	0	0	0	0	0	0	0	0	0	0
23-May-05	1,000	0	0	0	0	0	49967	49967	49282	1,000	0	0	0	0	0	0	0	0	0	0
24-May-05	1,000	0	0	0	0	0	21452	21452	21168	1,000	0	0	0	0	0	0	0	0	0	0
25-May-05	1,000	0	0	0	0	0	16957	16957	16857	1,000	0	0	0	0	0	0	0	0	0	0
26-May-05	1,000	0	0	0	0	0	22916	22916	22893	1,000	0	0	0	0	0	0	0	0	0	0
27-May-05	1,000	0	0	0	0	0	41866	41866	41455	1,000	0	0	0	0	0	0	0	0	0	0
28-May-05	1,000	0	0	0	0	0	15494	15494	15228	1,000	0	0	0	0	0	0	0	0	0	0
29-May-05	1,000	0	0	0	0	0	15734	15734	15555	1,000	0	0	0	0	0	0	0	0	0	0
30-May-05	1,000	0	0	0	0	0	12670	12670	12419	1,000	0	0	0	0	0	0	0	0	0	0
31-May-05	1,000	0	0	0	0	0	12216	12216	11997	1,000	0	0	0	0	0	0	0	0	0	0
01-Jun-05	1,000	0	0	0	0	0	12394	12394	12154	1,000	0	0	0	0	0	0	0	0	0	0
02-Jun-05	1,000	0	0	0	0	0	18801	18801	18378	1,000	0	0	0	0	0	0	0	0	0	0
03-Jun-05	1,000	0	0	0	0	0	25712	25712	25427	1,000	0	0	0	0	0	0	0	0	0	0
04-Jun-05	1,000	0	0	0	0	0	26705	26705	26165	1,000	0	0	0	0	0	0	0	0	0	0
05-Jun-05	1,000	0	0	0	0	0	17165	17165	16797	1,000	0	0	0	0	0	0	0	0	0	0
06-Jun-05	1,000	0	0	0	0	0	18953	18953	18498	1,000	0	0	0	0	0	0	0	0	0	0
07-Jun-05	1,000	0	0	0	0	0	20728	20728	20386	1,000	0	0	0	0	0	0	0	0	0	0
08-Jun-05	1,000	0	0	0	0	0	20765	20765	20355	1,000	0	0	0	0	0	0	0	0	0	0
09-Jun-05	1,000	0	0	0	0	0	17655	17655	17601	1,000	0	0	0	0	0	0	0	0	0	0
10-Jun-05	1,000	0	0	0	0	0	14570	14570	14379	1,000	0	0	0	0	0	0	0	0	0	0
11-Jun-05	1,000	0	0	0	0	0	14100	14100	13900	1,000	0	0	0	0	0	0	0	0	0	0
12-Jun-05	1,000	0	0	0	0	0	16553	16553	16462	1,000	0	0	0	0	0	0	0	0	0	0
13-Jun-05	1,000	0	0	0	0	0	18147	18147	17924	1,000	0	0	0	0	0	0	0	0	0	0
14-Jun-05	1,000	0	0	0	0	0	22086	22086	21744	1,000	0	0	0	0	0	0	0	0	0	0
15-Jun-05	1,000	0	0	0	0	0	16040	16040	15766	1,000	0	0	0	0	0	0	0	0	0	0
16-Jun-05	1,000	0	0	0	0	0	21870	21870	21335	1,000	0	0	0	0	0	0	0	0	0	0
17-Jun-05	1,000	0	0	0	0	0	17409	17409	16952	1,000	0	0	0	0	0	0	0	0	0	0

Rhodes Island Weighted Average BTU Content:
May through October 2005

DATE	BTU VALUE	MCF EXELNG B.O.	MCF EXELNG B.O. METERED	MMBTU EXELNG B.O.	MCF PORTLING VAPOR		MMBTU PORTLING VAPOR		BTU VALUE	MCF WESTLING VAPOR		MMBTU WESTLING VAPOR		BTU VALUE	MCF WESTLING VAPOR		MMBTU WESTLING VAPOR		BTU VALUE	AIR STABILIZED DAILY WEIGHTED AVG. BTU	GAS LOG DAILY WEIGHTED AVG. BTU	AIR STABILIZED DAILY WEIGHTED AVG. BTU		AREA FOUR	MCF AREA FOUR		MMBTU AREA FOUR		MCF TOTAL AREA FOUR	MCF TOTAL AREA FOUR		MMBTU TOTAL AREA FOUR		MCF CUMB B.O.	MCF CUMB B.O. METERED		MMBTU CUMB B.O.		MCF CUMB B.O.			
					MCF VAPOR METERED	BTU VAPOR METERED	MCF VAPOR METERED	BTU VAPOR METERED		MCF VAPOR METERED	BTU VAPOR METERED	MCF VAPOR METERED	BTU VAPOR METERED		MCF VAPOR METERED	BTU VAPOR METERED	MCF VAPOR METERED	BTU VAPOR METERED				MCF VAPOR METERED	BTU VAPOR METERED		MCF VAPOR METERED	BTU VAPOR METERED	MCF VAPOR METERED	BTU VAPOR METERED		MCF VAPOR METERED	BTU VAPOR METERED	MCF VAPOR METERED	BTU VAPOR METERED		MCF VAPOR METERED	BTU VAPOR METERED	MCF VAPOR METERED	BTU VAPOR METERED		MCF VAPOR METERED	BTU VAPOR METERED	MCF VAPOR METERED
01-Jul-05	1,009	85	108	85	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	33	32	53	32
02-Jul-05	1,009	87	108	87	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	92	90	90	90
03-Jul-05	1,009	86	108	86	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	139	139	139	139
04-Jul-05	1,011	85	108	84	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	142	139	142	139
05-Jul-05	1,008	87	108	88	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	149	147	149	147
06-Jul-05	1,012	86	108	85	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	149	149	149	149
07-Jul-05	1,012	103	102	103	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
08-Jul-05	1,012	111	110	111	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
09-Jul-05	1,008	88	108	88	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
10-Jul-05	1,006	86	108	85	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
11-Jul-05	1,005	108	107	108	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
12-Jul-05	1,004	89	108	88	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
13-Jul-05	1,008	88	108	88	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
14-Jul-05	1,008	88	108	88	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
15-Jul-05	1,008	88	108	88	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
16-Jul-05	1,008	87	108	86	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
17-Jul-05	1,008	105	104	105	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
18-Jul-05	1,009	134	133	134	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
19-Jul-05	1,007	124	123	124	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
20-Jul-05	1,008	164	163	164	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
21-Jul-05	1,005	110	109	110	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
22-Jul-05	1,005	110	109	110	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
23-Jul-05	1,005	102	101	102	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
24-Jul-05	1,009	106	105	106	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
25-Jul-05	1,009	122	121	122	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
26-Jul-05	1,008	120	119	120	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
27-Jul-05	1,011	131	130	131	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
28-Jul-05	1,011	107	106	107	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
29-Jul-05	1,011	107	106	107	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
30-Jul-05	1,012	123	123	123	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
31-Jul-05	1,012	264	264	264	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
01-Aug-05	1,012	264	264	264	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
02-Aug-05	1,012	264	264	264	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
03-Aug-05	1,012	264	264	264	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
04-Aug-05	1,012	264	264	264	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
05-Aug-05	1,012	264	264	264	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
06-Aug-05	1,012	264	264	264	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892	914	0	0	892	914	0	0	0	1,023	144	144	144	144
07-Aug-05	1,012	111	111	111	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1,034	0	0	0	0	892	914	0	0	892</													

Rhode Island Weighted Average BTU Content
May through October 2005

DATE	CUMBERLAND		CUMBERLAND		CUMB	PGC		PGC		RI	RI	RI
	MMBTU	MCF	MMBTU	MCF		SYSTEM	MMBTU	MCF	MMBTU			
	TOTAL	TOTAL	TOTAL	TOTAL	FACTOR	RECEIVED	PRODUCED	RECEIVED	PRODUCED	AND	AND	AND
	AND	AND	AND	AND		AND	AND	AND	AND	AND	AND	AND
	PRODUCED	PRODUCED	PRODUCED	PRODUCED		PRODUCED	PRODUCED	PRODUCED	PRODUCED	PRODUCED	PRODUCED	PRODUCED
	947	914	1036	1034		32269	1034	32269	1034	41988	42004	1034
01-Jul-05	947	914	1036	1034		32269	1034	32269	1034	41988	42004	1034
02-Jul-05	863	858	1033	1033		36656	1033	36656	1033	39752	37511	1033
03-Jul-05	949	919	1033	1034		35286	1034	35286	1034	37423	38205	1034
04-Jul-05	911	880	1035	1034		37443	1034	37443	1034	38223	38323	1034
05-Jul-05	1063	1054	1026	1026		40961	1026	40961	1026	42644	40787	1031
06-Jul-05	985	954	1032	1032		41091	1032	41091	1032	43386	42055	1032
07-Jul-05	1043	1043	1031	1031		42982	1031	42982	1031	43987	42703	1030
08-Jul-05	1048	1048	1031	1031		43475	1031	43475	1031	44785	43434	1031
09-Jul-05	876	852	1028	1028		38892	1028	38892	1028	39758	38670	1028
10-Jul-05	968	935	1033	1033		39961	1033	39961	1033	40627	39235	1035
11-Jul-05	1176	1081	1033	1032		42839	1032	42839	1032	43655	42862	1026
12-Jul-05	1101	1070	1028	1028		43438	1028	43438	1028	44528	43420	1026
13-Jul-05	1133	1100	1030	1030		43965	1030	43965	1030	44998	43728	1029
14-Jul-05	1106	1075	1028	1028		43121	1028	43121	1028	44227	43050	1027
15-Jul-05	930	907	1025	1025		43963	1025	43963	1025	45541	44541	1023
16-Jul-05	823	800	1028	1028		37000	1028	37000	1028	37523	36878	1026
17-Jul-05	866	842	1028	1028		40856	1028	40856	1028	40922	39914	1025
18-Jul-05	1010	965	1025	1025		42702	1025	42702	1025	43712	42708	1024
19-Jul-05	1062	1037	1024	1024		47286	1024	47286	1024	48460	47455	1019
20-Jul-05	1009	989	1020	1020		46363	1020	46363	1020	47342	46433	1020
21-Jul-05	1041	1018	1023	1023		42891	1023	42891	1023	43902	42923	1023
22-Jul-05	872	849	1027	1027		40224	1027	40224	1027	41095	40060	1026
23-Jul-05	791	769	1027	1027		38470	1027	38470	1027	37260	38308	1028
24-Jul-05	827	806	1028	1028		38026	1028	38026	1028	39763	38790	1026
25-Jul-05	1032	1007	1025	1025		47597	1025	47597	1025	48628	47587	1022
26-Jul-05	1041	1021	1020	1020		46482	1020	46482	1020	48223	46947	1020
27-Jul-05	976	950	1027	1027		43500	1027	43500	1027	44576	43489	1022
28-Jul-05	1040	1007	1033	1033		43436	1033	43436	1033	44476	43281	1028
29-Jul-05	859	827	1028	1028		36361	1028	36361	1028	37107	38186	1025
30-Jul-05	748	728	1028	1028		38561	1028	38561	1028	39415	39415	1025
31-Jul-05	871	871	1028	1028		35470	1028	35470	1028	37017	38186	1025
01-Aug-05	889	889	1028	1028		38099	1028	38099	1028	38984	38043	1025
02-Aug-05	1003	977	1027	1027		45002	1027	45002	1027	46183	41108	1021
03-Aug-05	1016	988	1018	1018		48739	1018	48739	1018	46005	45973	1018
04-Aug-05	934	914	1025	1025		48142	1025	48142	1025	49755	48140	1013
05-Aug-05	854	821	1016	1016		44330	1016	44330	1016	45604	44810	1016
06-Aug-05	744	727	1023	1023		34665	1023	34665	1023	35164	34512	1015
07-Aug-05	777	760	1022	1022		35319	1022	35319	1022	35408	34707	1018
08-Aug-05	916	894	1025	1025		41532	1025	41532	1025	42098	35415	1019
09-Aug-05	1132	1060	1020	1020		43306	1020	43306	1020	42448	41741	1017
10-Aug-05	1070	1051	1016	1016		42952	1016	42952	1016	48420	46623	1016
11-Aug-05	969	969	1021	1021		47486	1021	47486	1021	49332	48537	1016
12-Aug-05	973	956	1018	1018		45510	1018	45510	1018	47804	46476	1018
13-Aug-05	757	741	1022	1022		44339	1022	44339	1022	45956	45245	1015
14-Aug-05	630	614	1020	1020		33907	1020	33907	1020	34964	33722	1019
15-Aug-05	1014	965	1019	1019		36917	1019	36917	1019	37147	37157	1019
16-Aug-05	1046	1026	1026	1026		42779	1026	42779	1026	43799	43163	1015
17-Aug-05	1044	1018	1026	1026		41907	1026	41907	1026	42858	42228	1017
18-Aug-05	863	841	1023	1023		44873	1023	44873	1023	45417	44869	1016
19-Aug-05	958	939	1020	1020		39003	1020	39003	1020	39981	39308	1017
20-Aug-05	803	780	1029	1029		35996	1029	35996	1029	38701	35903	1022
21-Aug-05	887	846	1025	1025		43822	1025	43822	1025	44489	43751	1017
22-Aug-05	1011	989	1022	1022		46933	1022	46933	1022	47644	46670	1017
23-Aug-05	1043	1016	1025	1025		41912	1025	41912	1025	42555	42370	1014
24-Aug-05	1025	1002	1023	1023		43411	1023	43411	1023	44985	43900	1018
25-Aug-05	1152	1108	1022	1022		42302	1022	42302	1022	42773	43410	1020
26-Aug-05	988	970	1020	1020		38381	1020	38381	1020	41159	40306	1021
27-Aug-05	639	639	1031	1031		35451	1031	35451	1031	37295	36205	1027
28-Aug-05	837	807	1026	1026		38446	1026	38446	1026	39243	38332	1026
29-Aug-05	1029	1009	1026	1026		37465	1026	37465	1026	47800	46128	1019
30-Aug-05	1120	1092	1026	1026		40911	1026	40911	1026	42031	41234	1019
31-Aug-05	1088	1064	1023	1023		40965	1023	40965	1023	42052	41349	1017

DATE	CUMBERLAND MCF		CUMBERLAND MCF RECEIVED AND PRODUCED	CUMB SYSTEM FACTOR	PGC MCF		PGC MCF RECEIVED AND PRODUCED	PGC SYSTEM FACTOR	RI MMBTU		RI MMBTU RECEIVED AND PRODUCED	RI MCF RECEIVED AND PRODUCED	RI DAILY WEIGHTED AVERAGE
	TOTAL RECEIVED AND PRODUCED	TOTAL RECEIVED AND PRODUCED			TOTAL RECEIVED AND PRODUCED	TOTAL RECEIVED AND PRODUCED							
01-Sep-05	876	854	854	1.026	4230	41690	1.015	1.015	48196	43664	1.016	1.016	
02-Sep-05	893	864	864	1.034	3790	3790	1.020	1.020	38959	38765	1.021	1.021	
03-Sep-05	769	760	760	1.038	35106	35106	1.028	1.028	35928	35998	1.030	1.030	
04-Sep-05	744	711	711	1.046	35651	34439	1.036	1.036	35425	35150	1.036	1.036	
05-Sep-05	845	808	808	1.048	40543	39377	1.035	1.035	41788	40385	1.035	1.035	
06-Sep-05	957	920	920	1.040	44122	43046	1.025	1.025	45079	43969	1.025	1.025	
07-Sep-05	1008	977	977	1.030	54336	54572	1.016	1.016	50442	49550	1.016	1.016	
08-Sep-05	989	969	969	1.021	46995	46262	1.014	1.014	47886	47231	1.014	1.014	
09-Sep-05	952	935	935	1.016	42000	42000	1.013	1.013	43789	43235	1.013	1.013	
10-Sep-05	911	890	890	1.035	42047	41131	1.024	1.024	43047	42011	1.025	1.025	
11-Sep-05	816	802	802	1.039	41834	40751	1.029	1.029	42850	41833	1.029	1.029	
12-Sep-05	924	899	899	1.036	43576	42459	1.026	1.026	44504	43358	1.026	1.026	
13-Sep-05	847	820	820	1.029	44437	44431	1.022	1.022	44384	44331	1.022	1.022	
14-Sep-05	953	920	920	1.029	42343	42496	1.016	1.016	44199	43422	1.016	1.016	
15-Sep-05	936	911	911	1.027	42066	41299	1.016	1.016	42974	42210	1.016	1.016	
16-Sep-05	896	876	876	1.026	40197	39271	1.021	1.021	41006	40147	1.021	1.021	
17-Sep-05	861	831	831	1.036	37578	36562	1.026	1.026	38437	37393	1.026	1.026	
18-Sep-05	864	849	849	1.041	42071	42071	1.029	1.029	42089	40920	1.029	1.029	
19-Sep-05	937	911	911	1.041	42071	42112	1.016	1.016	43827	43043	1.016	1.016	
20-Sep-05	971	945	945	1.028	42482	42482	1.015	1.015	44455	43759	1.016	1.016	
21-Sep-05	972	950	950	1.023	43992	43387	1.014	1.014	44964	44337	1.014	1.014	
22-Sep-05	992	964	964	1.026	42381	42381	1.020	1.020	44723	43845	1.020	1.020	
23-Sep-05	941	909	909	1.035	41593	40577	1.025	1.025	42336	41486	1.025	1.025	
24-Sep-05	963	927	927	1.038	41128	39690	1.031	1.031	42052	40907	1.031	1.031	
25-Sep-05	963	931	931	1.040	41918	40522	1.034	1.034	42895	41463	1.035	1.035	
26-Sep-05	963	934	934	1.034	42450	42450	1.024	1.024	44426	43384	1.024	1.024	
27-Sep-05	933	903	903	1.035	40099	40099	1.026	1.026	42063	40581	1.026	1.026	
28-Sep-05	1059	1015	1015	1.043	44738	43392	1.031	1.031	45197	44397	1.031	1.031	
29-Sep-05	1101	1055	1055	1.044	46529	46941	1.034	1.034	49330	47996	1.034	1.034	
30-Sep-05	1109	1061	1061	1.045	51989	50180	1.036	1.036	53089	51241	1.036	1.036	
01-Oct-05	955	917	917	1.041	42559	41005	1.038	1.038	43514	41922	1.038	1.038	
02-Oct-05	904	862	862	1.049	43714	41941	1.042	1.042	44818	42803	1.042	1.042	
03-Oct-05	1050	1007	1007	1.043	45478	43719	1.040	1.040	46828	44726	1.040	1.040	
04-Oct-05	1051	1019	1019	1.041	45320	43612	1.034	1.034	46991	44831	1.035	1.035	
05-Oct-05	1043	1004	1004	1.039	44601	43165	1.034	1.034	45644	44159	1.034	1.034	
06-Oct-05	995	970	970	1.028	43929	42754	1.025	1.025	44824	43724	1.025	1.025	
07-Oct-05	907	898	898	1.010	39786	39072	1.018	1.018	40693	39970	1.018	1.018	
08-Oct-05	862	836	836	1.029	38832	37721	1.029	1.029	39694	38559	1.029	1.029	
09-Oct-05	1024	993	993	1.031	44875	44747	1.032	1.032	47198	45740	1.032	1.032	
10-Oct-05	1172	1137	1137	1.031	53269	51822	1.028	1.028	54441	52869	1.028	1.028	
12-Oct-05	1342	1290	1290	1.040	59856	58057	1.031	1.031	61189	59347	1.031	1.031	
13-Oct-05	1582	1520	1520	1.041	68696	66996	1.031	1.031	68278	66216	1.031	1.031	
14-Oct-05	1410	1364	1364	1.034	59846	58182	1.029	1.029	61256	59546	1.029	1.029	
15-Oct-05	1249	1204	1204	1.037	52046	50523	1.030	1.030	53285	51727	1.030	1.030	
16-Oct-05	1289	1249	1249	1.032	53208	53208	1.030	1.030	56497	54969	1.030	1.030	
18-Oct-05	1529	1469	1469	1.041	64418	62047	1.038	1.038	65947	63516	1.038	1.038	
17-Oct-05	1522	1471	1471	1.035	62739	62880	1.030	1.030	68761	66751	1.030	1.030	
18-Oct-05	1431	1398	1398	1.024	62359	61376	1.016	1.016	63780	62774	1.016	1.016	
19-Oct-05	1467	1431	1431	1.025	61555	60037	1.025	1.025	63022	61468	1.025	1.025	
20-Oct-05	1737	1684	1684	1.031	76098	74420	1.022	1.022	77835	76113	1.023	1.023	
21-Oct-05	2103	2053	2053	1.024	86259	84959	1.015	1.015	89362	87012	1.015	1.015	
22-Oct-05	2281	2216	2216	1.029	87895	86458	1.016	1.016	90146	88674	1.017	1.017	
23-Oct-05	2356	2250	2250	1.047	94565	91606	1.033	1.033	96921	93756	1.034	1.034	
24-Oct-05	2651	2531	2531	1.047	97777	94809	1.031	1.031	100428	97340	1.032	1.032	
25-Oct-05	3017	2911	2911	1.036	114811	111347	1.029	1.029	117628	114258	1.029	1.029	
26-Oct-05	2920	2841	2841	1.028	118410	116100	1.020	1.020	121330	118941	1.020	1.020	
27-Oct-05	2923	2806	2806	1.042	116372	113986	1.024	1.024	119295	116492	1.024	1.024	
28-Oct-05	3211	3096	3096	1.037	124336	121459	1.024	1.024	127547	124555	1.024	1.024	
29-Oct-05	3362	3231	3231	1.041	132656	122508	1.029	1.029	139418	128740	1.029	1.029	
30-Oct-05	1842	1766	1766	1.031	79172	77512	1.021	1.021	81074	79288	1.022	1.022	
31-Oct-05	1695	1623	1623	1.044	70089	68557	1.022	1.022	71784	70160	1.023	1.023	
	234934	228408	228408	1.029	9775664	9555322	1.023	1.023	10010789	9783728	1.023	1.023	