

August 28, 2018

BY HAND DELIVERY AND ELECTRONIC MAIL

Luly E. Massaro, Commission Clerk
Rhode Island Public Utilities Commission
89 Jefferson Boulevard
Warwick, RI 02888

RE: Docket 4237 - National Grid 2018 Contact Voltage Annual Report

Dear Ms. Massaro:

Pursuant to R.I. Gen. Laws § 39-2-25 and the Rhode Island Public Utilities Commission's (PUC) Order No. 20950 in Docket 4237, I have enclosed The Narragansett Electric Company's¹ 2018 Contact Voltage Annual Report.

The Annual Report includes the following nine sections:

- Section 1: Background and summary;
- Section 2: Summary of the Company's surveying and testing results of the fourteen designated contact voltage risk areas (DCVRAs) for the period of April 1, 2017 to March 31, 2018.
- Section 3: Contact Voltage Program costs;
- Section 4: Details regarding calls to the Company's Shock Line;
- Section 5: Copy of the Company's current emergency operating procedure (EOP)-G016;
- Section 6: Additional information on the Company's total harmonic distortion (THD) pilot program results;
- Section 7: The Company's recommendation for the percentage of DCVRAs to be completed in the sixth year of the program;
- Section 8: Summary of the Company's latest understanding of the current state of electrical standards and mobile equipment technology; and
- Section 9: Summary of the Company's Recommendations for the FY 2018 Contact Voltage Program.

¹ The Narragansett Electric Company d/b/a National Grid (the Company).

Luly E. Massaro, Commission Clerk
Docket 4237 - 2018 Contact Voltage Annual Report
August 28, 2018
Page 2 of 2

In October 2015, the Company awarded a new four-year contract to Willbros, now TRC, for FY 2016, FY 2017, FY 2018, and FY 2019 mobile surveys. The next request for proposals for the contract will be for the FY 2020 mobile survey.

Thank you for your attention to this filing. If you have any questions, please contact me at 781-907-2121.

Very truly yours,



Raquel J. Webster

Enclosure

cc: Docket 4237 Service List
John Bell, Division
Leo Wold, Esq.

Certificate of Service

I hereby certify that a copy of the cover letter and any materials accompanying this certificate was electronically transmitted to the individuals listed below.

The paper copies of this filing are being hand delivered to the Rhode Island Public Utilities Commission and to the Rhode Island Division of Public Utilities and Carriers.



Joanne M. Scanlon

August 28, 2018

Date

**Docket No. 4237 – Commission’s Proceeding Relating to Stray
and Contact Voltage Pursuant to Enacted Legislation
Service List updated 7/27/17**

Name	E-mail Distribution List	Phone
Raquel Webster, Esq. National Grid 280 Melrose Street Providence, RI 02907-1438	Raquel.webster@nationalgrid.com ;	401-784-7667
	Celia.obrien@nationalgrid.com ;	
	Joanne.scanlon@nationalgrid.com ;	
Leo Wold, Esq. Dept. of Attorney General 150 South Main St. Providence, RI 02903	lwold@riag.ri.gov ;	401-274-4400
	Steve.scialabba@dpuc.ri.gov ;	
	Al.contente@dpuc.ri.gov ;	
	Thomas.kogut@dpuc.ri.gov ;	
	joseph.shilling@dpuc.ri.gov ;	
	jmunoz@riag.ri.gov ;	
Greg Booth Michael White Power Services, Inc.	gbooth@powerservices.com ;	919-256-5900
	mwhite@powerservices.com ;	
Original & 9 copies file w/: Luly E. Massaro, Commission Clerk Public Utilities Commission 89 Jefferson Boulevard Warwick, RI 02888	Luly.massaro@puc.ri.gov ;	401-780-2107
	Cynthia.WilsonFrias@puc.ri.gov ;	
	Alan.nault@puc.ri.gov ;	
Joseph A. Keough, Jr. Esq.	jkeoughjr@keoughsweeney.com ;	401-724-3600
Roz Rustigian Contact Voltage Information Ctr. (CVIC)	rozrustigian@rustigianrugs.com ;	401-489-8667

The Narragansett Electric Company
d/b/a National Grid

Rhode Island 2018 Contact Voltage Annual Report

Submitted to:
Rhode Island Public Utilities Commission
RIPUC Docket No. 4237

Submitted by:
The logo for National Grid, featuring the word "national" in a blue sans-serif font and "grid" in a bold blue sans-serif font, with a small blue diamond shape above the letter "i" in "grid".

Table of Contents

Glossary of Terms.....1

Section 1 - Background and Summary3

Section 2 - Survey and Testing Results9

Section 3 - Contact Voltage Program Costs16

Section 4 - Shock Line Calls.....18

Section 5 - Company EOP-G016.....20

Section 6 - THD Pilot Program.....21

Section 7 - DCVRA Recommendation25

Section 8 - Standards and Equipment Update.....27

Section 9 - Company Recommendations.....29

Glossary of Terms

Term	Definition
Contact Voltage	A voltage resulting from abnormal power system conditions that may be present between two (2) conductive surfaces that can be simultaneously contacted by members of the general public and/or their animals.
Designated Contact Voltage Risk Areas (DCVRA)	Boundaries of areas approved by the Rhode Island Public Utilities Commission in Docket No. 4237 and subsequent proceedings that are based upon the presence of underground electric distribution and situated in pedestrian-dense areas such as neighborhoods, commercial areas, central business districts, tourist-heavy locations, and other places where pedestrians could be exposed to contact voltage.
Guarded – Made Safe	Guarded – Made Safe is defined as an asset being guarded by a person or a protective barrier that prevents public contact if the elevated voltage found is greater than 4.5 volts. If the voltage measures greater than 4.5 volts and less than 8 volts, it is either guarded in person or by installation of a protective barrier that prevents public contact. If the voltage measurement is greater than 8 volts, it is guarded by an equipment elevated voltage inspector or a Company employee that has been trained to stand by on energized facilities; in this instance, an immediate maintenance and repair response is required.

Investigatory Mobile Survey Stop	A stop during a survey where the mobile detection device indicated evidence of elevated voltage (greater than zero (0) volts) and a stop was made to survey for elevated voltage with manual instruments (pen detector). All metallic devices within 30 feet are tested manually for elevated voltage at each stop. The Investigatory Mobile Survey Stop may or may not discover an asset with elevated voltage.
Mobile Event	An Investigatory Mobile Survey Stop where elevated voltage (greater than zero 0 volts) was discovered on an asset (either company or customer-owned). These Mobile Events are divided into three categories: (1) those with readings below 1 volt, (2) those having elevated voltage between 1 volt and 4.5 volts, and (3) those having elevated voltage readings 4.5 volts or greater. The readings above reflect the actual voltage determined by manual shunt meter testing of the asset.
Post-Mitigation Manual Testing	Manual elevated voltage testing performed on assets which had a voltage of greater than 1 volt in the prior year's mobile testing and were subsequently mitigated.
Quality Assurance Manual Testing	Manual elevated voltage testing performed on a random sample of assets in the Designated Contact Voltage Risk Areas after the mobile survey is performed.
Total Harmonic Distortion (THD) Contact Voltage Testing	THD is determined by the use of a Fluke power quality clamp meter or a Fluke scope meter during an investigatory Mobile Survey Stop. THD contact voltage testing applies to any voltage measures greater than 1 volt and less than 4.5 volts that had a total harmonic distortion of less than 10%. A THD of less than 10% will be considered as contact voltage for Mobile testing.

Section 1

Background and Summary

Section 1 - Background and Summary

On June 6, 2012, the Rhode Island Contact Voltage statute, R.I. Gen. Laws § 39-2-25, was signed into law. That statute directed the Rhode Island Public Utilities Commission (PUC) to establish a contact voltage detection, repair, and reporting program, which would be applicable to National Grid.¹ On November 9, 2012, the PUC issued an order (Program Order)² approving the Company's amended contact voltage program (Contact Voltage Program). The Program Order established thirteen (13) Designated Contact Voltage Risk Areas (DCVRA)³ for the State of Rhode Island, and directed the Company to conduct testing and surveys for contact voltage on all conductive surfaces in public right-of-ways identified within these DCVRAs.

On February 1, 2013, the PUC issued a subsequent order (Compliance Order)⁴ that directed the Company to complete its initial testing and surveying of all thirteen (13) DCVRAs in the first year. The Compliance Order further required the Company to file the findings and results of this testing in an annual report (Contact Voltage Annual Report) by no later than September 1, 2013. The Contact Voltage Annual Report must identify the specific elevated voltage events found during surveying and testing and explain the appropriate remedial action taken by the Company to ensure public safety. The Compliance Order also required the Company, after the findings and results of its survey and testing were reviewed, to provide the PUC with a recommendation of the specific DCVRAs to be surveyed and tested in the next year

¹ The Narragansett Electric Company d/b/a National Grid (National Grid or Company).

² Written Order No. 20871 (issued on November 9, 2012 in Docket No. 4237).

³ The initial thirteen DCVRAs include Newport, Pawtucket, Woonsocket, and ten designated sections in the City of Providence (College Hill, Downtown, Elmwood, Federal Hill, Lower South Providence, Olneyville, Smith Hill, Upper South Providence, Washington Park, and West End). As noted below, a section of Westerly has been added as a fourteenth DCVRA.

⁴ Written Order No. 20950 (issued on February 1, 2013 in Docket No. 4237).

of the program. Finally, the Compliance Order further directed the Company to keep the PUC apprised of any advances in elevated voltage mobile technology as part of its Contact Voltage Annual Report.

The PUC directed that the Contact Voltage Annual Report must be provided in Excel or searchable PDF format and must include the information below by DCVRA.⁵ Exhibit 1 provides a searchable Excel file that includes the information for each mobile event recorded during testing (#1-14 below):

1. A record number for each contact voltage event (*Exhibit 1, Column (a)*)
2. The date and time of the testing (*Exhibit 1, Columns (b),(c)*)
3. The specific location of the testing (*Exhibit 1, Columns (d),(f),(g),(h),(i),(j)*)
4. An identification of whether it was a Company or customer asset (*Exhibit 1, Column (p)*)
5. The type of the equipment that failed (*Exhibit 1, Columns (n),(o)*)
6. The voltage recorded (*Exhibit 1, Columns (k),(l),(m)*)
7. Whether there was any personal injury to public, pet or property damage (*Section 4*)⁶
8. An identification of any other equipment involved (*Exhibit 1, Columns (n),(z)*)
9. Whether there were any prior incidents for the last five years at that location (*Exhibit 1, Column (u)*)
10. The corrective actions taken at the location (*Exhibit 1, Column (e),(z)*)
11. The number of customers if service is interrupted (*Exhibit 1, Column (s)*)
12. The duration of the interruption (*Exhibit 1, Column (t)*)
13. A summary of the investigation into the cause of the incident (*Exhibit 1, Column (z)*)
14. The date when corrective action was taken and the date on which repairs were made (i.e. temporary and final) (*Exhibit 1, Columns (y),(aa),(ab),(ac),(ad)*)

In addition, the PUC further directed that the Contact Voltage Annual Report also include information concerning:⁷

⁵ Program Order at 28-29.

⁶ Reports of any injury to the public, pets or property are reported in Section 4 below.

⁷ Program Order at 28-29, Compliance Order at 8-9.

15. The aggregated costs of repair for each contact voltage event by DCVRA (*Section 3*)
16. The number of calls to the Shock Line (*Section 4*)
17. Any additional back-up information currently included in Section 7.3⁸ of the Company's current EOP-G016 (*Section 5 and Exhibit 1*)
18. A recommendation on whether any DCVRA should be added or modified with a specific rationale supporting the recommendation (*Section 7*)
19. A recommendation of which DCVRAs should comprise the 20 percent to be tested in the next year (*Section 7*); and
20. Any updates the Company discovered concerning the standards (IEEE) and advances in equipment technology (*Section 8*)

On March 31, 2014, the PUC approved the Company's FY 2013 Contact Voltage Annual Report in Docket No. 4237-A and subsequently issued an order (First Annual Report Order)⁹ that amended the Company's Annual Contact Voltage Report to include:¹⁰

21. The addition of a section of Westerly as a fourteenth DCVRA (*Section 2*)
22. The estimated number of mobile survey stops (*Section 2*)
23. A glossary and listing of terminology in the report (*Glossary of Terms*)
24. A summary of mobile survey events and readings (*Section 2, Table 1 and Table 2*)
25. The inclusion of before and after readings for the Company's Total Harmonic Distortion (THD) pilot program (*Exhibit 1, Column (ac) and Section 6, Table 7 and Table 8*)

On December 16, 2014, the PUC approved the Company's FY 2014 Contact Voltage Annual Report in Docket No. 4237, and subsequently issued an order (Second Annual Report Order)¹¹ that directed the Company's Contact Voltage Annual Report to address the following:¹²

⁸ The Program Order directed the Company to include additional back-up information included in Section 7.2 of the Company's EOP-G016, Version 1. This EOP has since been revised (Version 3, attached as Exhibit 3) to include section 7.3, which includes the back-up information applicable for mobile elevated voltage testing to be included in the Annual Report.

⁹ Written Order No. 21414 (issued on March 31, 2013 in Docket No. 4237-A).

¹⁰ First Annual Report Order at 8-9.

¹¹ Written Order No. 21780 (issued on December 16, 2014 in Docket No. 4237).

¹² Second Annual Report Order at 6.

26. Implement follow-up scans in DCVRAs where remediation work was completed before the next annual mobile survey to verify that the objects found and repaired were fully addressed. (*Section 2 - Post-Mitigation Manual Testing, Exhibit 2*)
27. Implement a process where random objects are selected in each DCVRA and manually tested for contact voltage following the mobile testing. (*Section 2 - Quality Assurance Manual Testing*)¹³

Similar to last year's Contact Voltage Annual Report, the Company has incorporated these modifications into the charts and exhibits within this filing.

Additionally, on March 14, 2016, the PUC approved the Company's FY 2015 Contact Voltage Annual Report in Docket No. 4237, and subsequently issued an order (Third Annual Report Order)¹⁴ that approved a modified mobile testing schedule proposed by the Company, where mobile surveying and testing will now occur in the April-June timeframe.

Section 2 of the Contact Voltage Annual Report provides a summary of the Company's surveying and testing results of the fourteen (14) DCVRAs for the period of April 1, 2017 to March 31, 2018. Section 3 provides a preliminary summary of the aggregate costs of the Contact Voltage Program (#15 above). Section 4 provides a fiscal year list of calls to the Company's Shock Line and reports of any injury to the public, pets or property (#7 and #16 above). Section 5 includes a copy of the Company's current EOP-G016 (#17 above and Exhibit 3).¹⁵ Section 6 provides additional information on the results of the Company's total harmonic distortion (THD) pilot program, which the PUC approved in the First Annual Report Order. Section 7 includes the percentage of DCVRAs to be completed in the fifth year of the program (#18 and #19 above).

¹³ As noted in the Company's 2017 Contact Voltage Annual Report, which the Company filed with the PUC on July 28, 2017, the Company will no longer perform post-mobile survey audit testing to spot verify the accuracy of the mobile technology.

¹⁴ Written Order No. 22357 (issued on March 14, 2016 in Docket No. 4237).

¹⁵ In Section 5 of Exhibit 3, item 5.4.1 has changed from Narda 8950/10 Stray Voltage system to Electric Field Solutions Voltage Detection System.

Section 8 provides the current state of electrical standards and elevated voltage mobile equipment technology (#20 above). Finally, Section 9 provides the Company's recommendations for the FY 2019 Contact Voltage Program.

Section 2

Mobile Survey and Testing Results

Section 2 - Mobile Survey and Testing Results

In compliance with the First Annual Report Order, TRC (Formerly Willbros Engineers (U.S.), LLC. (Willbros), which previously performed mobile contact voltage testing under its subsidiary, Premier Utility Services, LLC (Premier), conducted the surveying and testing of 20% of previous established DCVRAs over the period of January 22, 2018 to January 25, 2018. TRC conducted all surveying and testing at nighttime to include the testing of street lights. In total, the surveying and testing covered approximately 21.4 miles.¹⁶ Contractor(s) hired by Municipalities to perform repair/mitigation work shadowed the Company/TRC performing the survey and testing and were available to immediately mitigate any elevated voltage findings discovered during the surveying and testing. If the site was customer-owned, the owner was notified by the Company, and appropriate action was taken to ensure public safety at that location.

In addition, the testing in each DCVRA included the THD pilot during which any voltage measure greater than 1 volt and less than 4.5 volts that had a total harmonic distortion of less than 10 percent was considered contact voltage. The Municipal hired contractor remediated four (4) locations where the THD was less than 10 percent. As such, these locations were safeguarded from the public and appropriate permanent repairs were made. THD was determined by the use of a Fluke power quality clamp meter or a Fluke scope meter

Four (4) mobile events were recorded during the mobile scanning survey having 1 volt or greater. These findings were down from the eight (8) mobile events recorded during the FY2017

¹⁶ The 21.4 miles includes all mileage driven to survey. This includes both sides of a street, not simply linear mileage.

mobile survey, the twenty-six (26) mobile events recorded during the FY 2016 mobile survey, and the nineteen (19) mobile events recorded during the FY 2015 mobile survey.

Table 1 below provides the dates of testing, number of estimated investigatory mobile survey stops, and number of mobile events by shunt voltage readings, summarizing the FY 2018 mobile survey. Of the four (4) mobile events that were recorded during the mobile survey having 1 volt or greater, two (2) were found and documented as having elevated voltage at or above 4.5 volts, and two (2) were found and documented as having elevated voltage below 4.5 volts. In each of these events, the Municipal hired contractor took immediate remedial action by disconnecting the asset, placing protective barriers, and/or repairing the asset. All of the assets that registered greater than 1 volt were permanently repaired between January 23 2018 and January 26, 2018.

Table 1
Mobile Events by DCVRA

DCVRA	Dates Tested	Estimated Investigatory Mobile Survey Stops	Mobile Events	Readings < 1 Volt	Readings > 1 Volt but < 4.5 Volts		Readings >= 4.5 Volts	
				Customer and Company Asset	Customer Asset	Company Asset	Customer Asset	Company Asset
PROVIDENCE								
College Hill	01/23/18 – 01/26/18	7	7	4	1		2	
Downtown	01/23/18 – 01/26/18	6	6	5	1			
Elmwood	01/23/18 – 01/26/18							
Federal Hill	01/23/18 – 01/26/18							
Lower So. Prov.	01/23/18 – 01/26/18							
Olneyville	01/23/18 – 01/26/18							
Smith Hill	01/23/18 – 01/26/18							
Upper So. Prov.	01/23/18 – 01/26/18							
Washington Park	01/23/18 – 01/26/18							
West End	01/23/18 – 01/26/18							
NEWPORT	01/23/18 – 01/26/18							
PAWTUCKET	01/23/18 – 01/26/18							
WESTERLY	01/23/18 – 01/26/18							
WOONSOCKET	01/23/18 – 01/26/18							
Total		13	13	9	2		2	

As shown in Table 1, during the mobile survey, thirteen (13) stops were made to investigate elevated voltage readings where the mobile detection system indicated increased electric field strength in the area surveyed. All available conductive objects and surfaces in the location were tested with a vast majority of these mobile events resulting in a finding of no

actionable voltage on a conductive object or surface. Overall, many additional manual checks were made on objects and assets over the 3-day scanning period.

Table 2 provides the same detail on mobile events as in Table 1, but by Asset Type. As shown in Table 2, streetlights are responsible for the majority of elevated voltage readings. This is consistent with the results from the FY 2013, FY 2014, FY 2015, FY 2016, and FY2017 mobile surveys.

Table 2
Mobile Events by Asset Type

Asset Type	Mobile Events	Readings less than 1 Volt	Readings Greater than 1 Volt but less than 4.5 Volts		Readings Greater than 4.5 Volts	
		Customer and Company Asset	Customer Asset	Company Asset	Customer Asset	Company Asset
Streetlight	9	6	2		1	
Traffic Control Box						
Private Lighting						
Traffic Standard	1	1				
No Parking Sign	1				1	
Store Fronts						
Other	2	2				
Total	13	9	2		2	

Table 3 provides a comparison of the number of mobile events by voltage level, found in the FY 2017 and FY 2018 mobile surveys.

Table 3
Comparison of Number of Mobile Events FY 2017 to FY 2018

Number of Mobile Events	FY 2017	FY 2018
Readings less than 1 Volt	24	9
Readings Greater than 1 Volt but less than 4.5 Volts	7	2
Readings Greater than 4.5 Volts	1	2
Total	32	13

Manual Surveying and Testing Results

As previously noted, in the Second Annual Report Order, the PUC directed the Company to conduct additional testing as part of the Contact Voltage Program and to provide the results in the Contact Voltage Annual Report. This included (1) manually testing the areas where previous remediation work was completed before this year's mobile survey to ensure the repairs were addressed, or post-mitigation manual testing; and (2) manually testing a number of random assets and objects in each DCVRA to spot verify areas not indicated by mobile technology after this year's mobile survey, or quality assurance manual testing.

On December 6, 2016, the Company conducted its post-mitigation manual testing of eight (8) company and customer mobile events from the FY 2017 mobile survey where repairs

were completed. Five (5) of the mitigated repair shunt voltage readings¹⁷ for this post-mitigation manual testing were less than 1 volt, and no further remediation was required. Additional details of the Company's post-mitigation manual testing are provided in Exhibit 2. In Exhibit 2, columns (a) through (ac) were taken from Exhibit 1 in this FY 2017 Annual Contact Voltage Report.

¹⁷ Exhibit 2, column (ah).

Section 3

Contact Voltage Program Costs

Section 3 - Contact Voltage Program Costs

The cost to perform the mobile survey, post-mitigation manual testing, and quality assurance manual testing in 20% of previous established DCVRAs was \$80,000. There were no repairs required during the FY 2018 contact voltage surveying and testing, therefore cost was \$0. These are shown by DCVRA in Table 4. The total cost for the FY 2018 contact voltage testing and repair was \$80,000. The Company will reconcile this cost as part of its FY 2018 Electric Infrastructure, Safety, and Reliability Plan Reconciliation Filing, which the Company will submit to the PUC on or before August 1, 2018.

Table 4
Aggregate Contact Voltage Testing and Repair Costs

DCVRA	Repair Costs (Company Locations)	Mobile Survey, Post-Mitigation Manual Testing
Newport	0	
Pawtucket	0	
College Hill	0	
Downtown	0	
Federal Hill	0	
Lower South Providence	0	
Smith Hill	0	
Woonsocket	0	
Total	\$0	\$80,000
Grand Total		

Section 4

Shock Line Calls

Section 4 - Shock Line Calls

As previously noted, the Compliance Order directed the Company to report annual calls to its Shock Line. Shock Line calls to the Company record an event of elevated voltage reported by either the public or other entities such as another utility. For the period April 1, 2017 to March 31, 2018, the Company received two calls of elevated voltage to its Shock Line. The Company responded to these calls by testing for elevated voltage, mitigating conditions where necessary, and repairing facilities as needed. In addition, if the asset was customer-owned, the Company notified the customer and informed them of any actions the Company planned to take to remedy the issues. There were no reported personal injuries or damages to property from any of these incidents.

**Table 5
Shock Line Calls**

Date	Town	Street	Asset	Voltage Found	Owner	Injury
2/23/2018	Westerly	Evergreen Ln		3.5 Volts	Customer	No
11/21/2017	Cumberland	Highland Corp Dr	Street Light	<0.1Volts	Customer	No

Trouble worker recorded elevated voltage of 3.5 Volts at 75 Evergreen Ct, Wakefield R.I. National Grid has been in constant communication with the customer and is making every effort to address this concern as effectively as possible.

At 1600 Highland Corp Dr., the customer reported picking up voltage on parking lot light poles. A National Grid crew tested the parking lot light poles and found no issues.

Section 5

Company EOP-G016

Section 5 - Company EOP-G016

There have been no additional updates or modifications to EOP-G016 since the FY 2017 Contact Voltage Annual Report that was filed with the PUC on July 28, 2017. Exhibit 3 of this filing includes the 3.0 version of EOP-G016, which was last updated and published on April 19, 2018.

Section 6

THD Pilot Program

Section 6 - THD Pilot Program

In the First Contact Voltage Annual Report Order, the PUC approved the continuation of the Total Harmonic Distortion (THD) pilot program, noting that THD testing will provide the Company and the PUC with additional information and testing results upon which to make a recommendation for continued THD use and possible modifications or changes to the Contact Voltage Program in future years. The THD pilot testing was performed as part of the sixth year of testing from January 22, 2018 to January 25, 2018. Under the THD pilot testing, during contact voltage testing, any voltage measures greater than 1 volt and less than 4.5 volts that had a THD of less than 10% would be considered contact voltage and treated accordingly. Specifically, these areas would be safeguarded from the public and permanent repairs would be made as needed. However, if the THD was greater than 10% and no visual defects were found, then no further action would be required. THD was determined by the use of a Fluke power quality clamp meter or a Fluke scope meter, both of which have the ability to measure THD. A summary of the results of the THD pilot program are set forth in the table below:

**Table 6
THD Readings**

Total Readings Greater than 1 Volt but less than 4.5 Volts	Number of Readings with THD < 10%	Number of Readings with THD > 10%
2	1	0

As shown above, the results of the THD pilot program indicate a total of two (2) readings between 1 volt and 4.5 volts (Exhibit 1, Column 1). Of that total, one (1) reading was below the

10% distortion level and, therefore, considered as contact voltage. Table 7 provides the THD readings with distortion levels below 10% by Event ID (*Exhibit 1, Columns (a)*), DCVRA (*Exhibit 1, Columns (d)*), street/cross street location (*Exhibit 1, Columns (g),(h)*), the associated shunt voltage reading (*Exhibit 1, Columns (l)*), initial THD reading (*Exhibit 1, Columns (m)*), and subsequent THD reading after the Company’s repairs (*Exhibit 1, Columns (ac)*).

Table 7*
THD Readings Below 10%

Event ID	DCVRA	Street	Shunt Voltage	THD Before	THD After
2	Providence-Zone2-Downtown	South Main St & College St	10.9	10.9	N/A
9	Providence-Zone2-Downtown	Citizen Bank & Westminster St	3.1	3.1	N/A
13	Providence-Zone2-Downtown	Waterman St & Governor St	13	13.5	N/A

* Repairs for these events are described in Section 2.

Table 8 is the same as Table 7, but provides the THD readings with distortion levels greater than 10%.

Table 8*
THD Readings Above 10%

Event ID	DCVRA	Street	Shunt Voltage	THD Before	THD After

* Repairs for these events are described in Section 2. All other voltage findings with VAC Ground to shunt were 1 volt or below, therefore no THD readings were taken.

After reviewing the THD pilot program information and the overall mobile survey testing results for the past six years, the Company plans to continue using THD testing during the FY 2019 mobile survey cycle. As evidenced by the low number of elevated voltage readings

greater than 1 volt and less than 4.5 volts for the past four years (nine (9) in 2014, twelve (12) in 2015, fourteen (14) in 2016), seven (7) in 2017, and two (2) in 2018, the Company believes that the costs of THD testing are minimal and that THD testing will continue to provide the Company and the PUC with additional information to be considered for any possible modifications or changes to the Contact Voltage Program in future periods.

Section 7

DCVRA Recommendation

Section 7 - DCVRA Recommendation

In the Compliance Order, the PUC directed the Company to include in its Contact Voltage Annual Report a recommendation as to which DCVRAs would be included in the 20 percent to be surveyed and tested in the next year of the Contact Voltage Program.¹⁸ In preparing its recommendation, as discussed below, the Company relied on the results of its first four years of surveying and testing. In addition, the Company has also examined additional areas of the state that may qualify as a new DCVRA. At this time, the Company does not recommend any changes to the current list of fourteen (14) DCVRAs.

Regarding surveying and testing for the sixth year, the Company proposes that it survey and test 20 percent of the DCVRAs in FY 2018 and 20 percent thereafter for CY 2019, FY 2020, FY 2021 and FY 2022 to complete 100% of the testing in a five-year period. If approved by the PUC, the Company will negotiate with the vendor as allowed for in the contract.

¹⁸ Compliance Order at 9.

Section 8

Standards and Equipment Update

Section 8 - Standards and Equipment Update

In its Compliance Order, the PUC directed the Company to continue monitoring advances in elevated voltage mobile technology and keep the PUC apprised of these efforts.¹⁹ On January 29, 2016, the Institute of Electrical and Electronics Engineers (IEEE) Standards Boards approved standard P1695, *Guide to Understanding, Diagnosing and Mitigating Stray and Contact Voltage*. A copy of this guide is currently with the Standards Publications Department pending editorial revisions and approval. As such, the IEEE has not officially published any final documentation or final recommendations on elevated voltage. In addition, the Company is not aware of any additional changes to mobile testing technology. In FY 2019, the Company plans to continue using its existing manual technology and chosen vendor mobile technology for the seventh year of the Contact Voltage Program.

In January of 2013, the Company awarded its first three-year contract to Premier for the FY 2013, FY 2014, and FY 2015 mobile surveys. In October of 2015, the Company awarded a new four-year contract to Willbros, now TRC, for the FY 2016, FY 2017, FY 2018, and FY 2019 mobile surveys. The next request for proposals for the contract will be for the FY 2020 mobile survey.

¹⁹ Compliance Order at 8.

Section 9

Company Recommendations

Section 9 - Company Recommendations

The Company makes the following recommendations for the FY 2019 Contact Voltage Program:

- There has been a recent and ongoing shift in street light ownership from the Company to the Municipalities in the DCVRAs, which was not considered when the original Contact Voltage Order was written. Currently, the Company's costs associated with executing the annual Contact Voltage program fall under the Electric ISR Plan, which is how the Company recovers the costs for this program. Due to shift in asset ownership, the Company would like to continue with the current established program working with the Municipalities during the Mobile Elevated Voltage Testing.
- As noted in Section 7, the Company is recommending that 20 percent of the DCVRAs be surveyed and tested for the FY 2019 mobile survey.

As noted in Section 6, the Company plans to continue using THD testing during the FY 2019 mobile survey.

- The Company/TRC would continue to perform the Contact Voltage Survey and Testing annually in the same 14 designated contact voltage risk areas (DCVRAs). To achieve 100% compliance, the Company/TRC will perform Contact Voltage Survey and Testing on 20% of assets annually in the DCVRAs over a five-year period. This is a change from 100% performed annually. This would result in the reduction of the time commitment to perform the work from two weeks annually to three days annually over a five-year period.

- The Company and Municipalities will work together to determine mutually agreed upon Contact Voltage Survey and Testing dates. The Company/TRC will perform the contact voltage survey and testing. Contractor(s) hired by Municipalities to perform repair/mitigation work will shadow the Company/TRC performing the survey and testing so they are available to immediately mitigate any elevated voltage findings discovered during the surveying and testing. Municipality-hired Contractor(s) can direct invoice Municipalities for any and all costs associated with mitigation efforts.
- The Company will perform post-mitigation manual testing, manually testing the areas where previous remediation work was completed on the prior year's mobile survey to ensure the repairs were addressed, on assets that are company owned. Currently, the Company is performing post-mitigation manual testing on both company and customer owned assets.
- The Company will no longer perform post-mobile survey audit testing to spot verify the accuracy of the mobile technology. Historical quality assurance audits for this program have found no instances of elevated voltage.

Exhibit 1

Designated Contact Voltage Risk Areas (DCVRA)

Please see Excel version of Exhibit 1

Exhibit 2

Post-Mitigation Manual Testing

Please see Excel version of Exhibit 2

Exhibit 3

NG-EOP G016

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 1 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

INTRODUCTION

The purpose of this procedure is to outline the requirements for the equipment elevated voltage testing on National Grid Facilities in New York, Massachusetts and Rhode Island as required by:

1. New York Public Service Commission’s “Electric Safety Standards” issued on January 5, 2005, the New York Public Service Commission’s “Order Adopting Changes to Electric Safety Standards issued and effective on December 15, 2008.
2. New York Public Service Commission’s “Order Requiring Additional Mobile Stray Voltage Testing” issued and effective on July 21, 2010 and the New York’s Public Service Commission “Order Granting Petition In Part and Modifying Electric Safety Standards” issued and effective on March 22, 2013.
3. Rhode Island Public Utilities Commission in Docket 4237 “Order to Establish a Contact Voltage Detection, Repair and Reporting Program” issued on November 9, 2012, and the subsequent order issued on February 1, 2013.
4. Massachusetts Department of Telecommunications and Energy provided a series of recommendations on December 9, 2005, that have been included in this procedure.

While there are variances in requirements between New York, Massachusetts, and Rhode Island driven by particular regulatory requirements in each State, the minimum requirements are based on sound utility practice.

PURPOSE

This procedure applies to all personnel involved (employees or contractors) with or responsible for the testing, mitigation/repair and reporting of facilities designated by this EOP for equipment elevated voltage testing. It should be noted that the term “Contact Voltage” has been adopted and is used in the EOP (refer to EOP-DEF).

ACCOUNTABILITY

1. T&D Work Methods, Electrical Material & Design Standards
 - a. Update Procedure as Necessary
 - b. Provide personnel guidance and assistance as requested.
2. Operations – Inspection & Maintenance
 - a. Ensure the program as outlined in this EOP is implemented properly and timely.
 - b. Ensure that the program as outlined in the EOP is completed each year.
 - c. Provide qualified personnel to complete equipment elevated voltage testing.
 - d. Ensure all qualified personal have been trained on performing equipment elevated voltage testing.

<p>Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum</p>		
FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 2 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

3. Quality Assurance Quality Control
 - a. Ensure a QAQC program has been implemented as part of the mandatory requirements for New York and Massachusetts Regulators.
 - b. QAQC Inspector shall randomly audit elevated voltage testing performed to ensure testing completeness and accuracy.
4. Equipment Elevated Voltage Inspector
 - a. Demonstrate the ability to perform equipment elevated voltage testing per this procedure
 - b. Demonstrate the ability to become proficient in the use of the appropriate database.
 - c. Perform walking patrols, collect information, edit data, and guard unsafe facilities.
 - d. Attend the equipment elevated voltage training program and demonstrate competency with the equipment.
5. Learning & Development
 - a. Provide training upon request
6. Distribution Asset Management
 - a. Provide input into program revisions.
 - b. Ensure the equipment elevated voltage program as outlined in this EOP is implemented, budgeted, and sanctioned properly and timely.

REFERENCES

NYPSC Order 04-M-0159
NYPSC Order Adopting Changes to Electric Safety Standards
NYPSC Order Requiring Additional Mobile Stray Voltage Testing
RIPUC Docket 4237 Order 20871 (November 9, 2012) and Order 20950 (February 1, 2013)
Proposed Rhode Island Electric Contact Voltage Program, Revised October 2, 2012 (Docket 4237)
NYPSC Order Granting Petition in Part and Modifying Electric Safety Standards
Applicable National Grid Safety Rules & Procedures
Testing Equipment Operation Instructions
NG EOP-DEF – EOP Definitions

. Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum		
FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 3 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

DOCUMENT CONTENTS

Table of Contents

1.0	SAFETY REQUIREMENTS.....	4
2.0	FACILITIES WHERE EQUIPMENT ELEVATED VOLTAGE TESTING/DOCUMENTATION IS REQUIRED – NEW YORK.....	4
3.0	FACILITIES WHERE EQUIPMENT ELEVATED VOLTAGE TESTING/DOCUMENTATION IS REQUIRED – RHODE ISLAND.....	7
4.0	FACILITIES WHERE EQUIPMENT ELEVATED VOLTAGE TESTING/DOCUMENTATION IS REQUIRED – MASSACHUSETTS.....	8
5.0	TEST EQUIPMENT.....	9
6.0	TEST PROCEDURE.....	10
7.0	CORRECTIVE ACTION REQUIREMENTS FOR EQUIPMENT ELEVATED VOLTAGE FINDINGS.....	12
8.0	EQUIPMENT ELEVATED VOLTAGE DATABASE.....	15
9.0	NEW YORK ANNUAL REPORTING AND CERTIFICATION REQUIREMENTS.....	16
10.0	MASSACHUSETTS REPORTING REQUIREMENTS.....	18
11.0	RHODE ISLAND REPORTING REQUIREMENTS.....	19
12.0	TYPE OF EQUIPMENT - APPENDIX A.....	20
13.0	EXCEPTION APPROVALS.....	21
14.0	REVISION HISTORY.....	22

. Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum

FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR
---	---	------------------------------

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 4 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

1.0 SAFETY REQUIREMENTS

- 1.1 All work shall be performed in accordance with:
 - 1.1.1 National Grid Employee Safety Handbook
 - 1.1.2 Applicable National Grid EOP's
- 1.2 All applicable and appropriate Personal Protective Equipment (PPE) shall be worn.
- 1.3 The employee in charge of the work shall conduct a written pre-job brief with the employees involved prior to the start of each job. Using the Job Brief Form as an aide, discussions for performing the work should include:
- 1.4 Minimum Approach Distances (MAD) to energized lines or exposed live parts shall be maintained.
- 1.5 Identify if a Process Hazard Assessment (PHA) is required. Refer to NG-EOP G037 "Process Hazard Analysis".
- 1.6 Identify if an ARC flash assessment is required. Refer to NG-EOP G035 "ARC Flash Awareness and Mitigation" and Work Methods Infonet site for Arc Flash Table to determine working distance and energy levels – see link below:
http://us3infonet/sites/eng_delivery_svcs/Pages/ArcFlashMitigation.aspx

2.0 FACILITIES WHERE EQUIPMENT ELEVATED VOLTAGE TESTING/DOCUMENTATION IS REQUIRED – NEW YORK

- 2.1 Street Lights and Municipally Owned Facilities
 - 2.1.1 Company owned metallic street lighting standards shall be one hundred percent (100%) tested for equipment elevated voltage annually.
 - a. This test is to be performed while the light is operating.
 - 2.1.2 Municipally owned street light systems that National Grid directly provides energy to shall be one hundred percent (100%) tested for equipment elevated voltage annually.
 - a. National Grid is responsible to complete this testing unless assurances of the completion of required testing and transfer of such test data are made by the appropriate municipality.
 - b. This test is to be performed while the light is operating.
 - 2.1.3 Municipally owned metallic traffic signal standards and accessible devices shall be one hundred percent (100%) tested annually for equipment elevated voltage.

. Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum		
FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 5 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

- 2.1.4 All street lights identified on public thoroughfares regardless of ownership shall be one hundred percent (100%) tested annually for equipment elevated voltage.
- 2.1.5 All street lights under a maintenance contract shall be one hundred percent (100%) tested annually for equipment elevated voltage.

a. Exceptions not requiring equipment elevated voltage testing:

- i. Private lighting, park associations, parking lots, fiberglass (or other non-conductive) street light standards.
- ii. Locations where street light standards are not publicly accessible, such as facilities located in the center of highways that cannot be accessed without stopping traffic or creating potentially hazardous situations for the worker and/or public.

2.2 National Grid Electric Substation Fences

- 2.2.1 Metallic fencing surrounding substations with National Grid Facilities shall be tested for equipment elevated voltage annually. This fencing can be customer owned for customer stations, if a National Grid facility is part of the station.

2.3 Overhead Distribution Facilities

- 2.3.1 Towers and/or metallic poles with distribution facilities shall be tested for equipment elevated voltage at an annual rate of twenty percent (20%) in conjunction with field inspections on a five-year cycle.
- 2.3.2 The following equipment on wood distribution poles requires equipment elevated voltage testing at an annual rate of twenty percent (20%) in conjunction with field inspections on a five-year cycle:
 - a. Metallic riser guard or conduit (company or non-company).
 - b. Uncovered or uninsulated down ground (company or non-company).
 - c. Down guy wire (company or non-company).
 - d. Any other publicly accessible conductive piece of equipment (company or non-company) on the pole within reach from the ground.

- 2.3.3 Exceptions: Customer meters and customer meter poles are excluded.

2.4 Overhead Transmission Facilities

- 2.4.1 Towers and/or metallic poles with transmission facilities shall be tested for equipment elevated voltage at an annual rate of twenty-percent (20%) in conjunction with field inspections on a five-year cycle.
- 2.4.2 The following equipment on wood transmission poles or structures require equipment elevated voltage testing at an annual rate of twenty-percent (20%) in conjunction with field inspections on a five-year cycle:
 - a. Metallic riser guard or conduit (company or non-company).

. Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum

FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR
---	---	------------------------------

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 6 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

- b. Uncovered or uninsulated down ground (company or non-company).
- c. Down guy wire (company or non-company).
- d. Any other publicly accessible conductive piece of equipment (company or non-company) on the pole or structure within reach from the ground.

2.5 Underground Facilities

2.5.1 Equipment elevated voltage testing is required on all of the following equipment where accessible to the public.

- a. All metallic manhole covers, vault covers and grates, junction box covers, and handhole covers at an annual rate of one hundred percent (100%).

2.5.2 Pad-mounted transformers and switchgear are tested at an annual rate of twenty percent (20%) in conjunction with field inspections on a five-year cycle.

2.5.3 Starting in 2010 and continuing thereafter, unless changed by subsequent order of the NY Public Service Commission:

- a. Two (2) mobile stray voltage surveys shall be conducted at an annual rate of one hundred percent (100%) in Buffalo
- b. One (1) mobile stray voltage survey is required to be conducted at an annual rate of one hundred percent (100%) in Albany and Niagara Falls.

2.5.4 Exceptions: Non-metallic concrete or fiberglass pads, handholes or pull/splice boxes are not required to be tested.

2.6 Daily Job Site Test Requirements

2.6.1 Each job site where National Grid personnel or its contractors complete a work assignment, they shall perform the following:

- a. Perform an equipment elevated voltage test at the start and at the end of the work day or at the start and at the completion of the assignment. This testing requirement is considered good utility practice and does not require specific documentation.

2.6.2 Exceptions:

- a. Electric substation fencing will not require equipment elevated voltage testing unless scheduled as part of the inspection program or if work was done on the fencing.
- b. In a storm situation, where mutual aid is required, testing by other than National Grid personnel will not be required.

2.7 Exemptions

2.7.1 No testing is required inside a completely fenced in area where access is denied to the general public and where access is only achieved by climbing a fence. Good judgment is required by the tester in these scenarios.

Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum		
FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 7 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

3.0 FACILITIES WHERE EQUIPMENT ELEVATED VOLTAGE TESTING/DOCUMENTATION IS REQUIRED – RHODE ISLAND

3.1 Company Owned Street Lights

- 3.1.1 Company owned metallic street lighting standards are required to be tested for equipment elevated voltage on a three-year cycle.
- 3.1.2 Exceptions: Testing shall not be completed at locations where street light standards are not publicly accessible, such as facilities located in the center of highways that cannot be accessed without stopping traffic or creating potentially hazardous situations for the worker and/or the public.

3.2 Overhead Distribution Facilities

- 3.2.1 Towers and/or metallic poles with distribution facilities shall be tested for equipment elevated voltage at an annual rate of twenty-percent (20%) in conjunction with field inspections on a five-year cycle.
- 3.2.2 The following equipment on wood distribution poles or structures require equipment elevated voltage testing at an annual rate of twenty-percent (20%) in conjunction with field inspections on a five-year cycle:
 - a. Metallic riser guard or conduit (company or non-company).
 - b. Uncovered or uninsulated down ground (company or non-company).
 - c. Down guy wire (company or non-company).
 - d. Any other publicly accessible conductive piece of equipment (company or non-company) on the pole or structure within reach from the ground.

3.3 Underground Facilities

- 3.3.1 Equipment elevated voltage testing at an annual rate of twenty-percent (20%), to be completed on a five-year cycle:
 - a. Metallic manhole covers, vault covers and grates, junction box covers, handhole covers
 - b. Pad-mounted transformers, secondary pedestals, and pad-mounted switchgears.
- 3.3.2 Starting in Fiscal Year 2013 and continuing thereafter, unless changed by subsequent order of the Rhode Island Public Utilities Commission, mobile contact voltage surveys will be performed in designated Contact Voltage Areas (CVA).
- 3.3.3 The mobile surveys will be performed at an annual rate of twenty-percent (20%), to be completed on a five-year cycle

Exceptions: Non-metallic concrete or fiberglass pads, handholes or pull/splice boxes are not required to be tested.

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 8 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

3.4 Daily Job Site Test Requirements

3.4.1 Each job site where National Grid personnel or its contractors complete a work assignment:

- a. An equipment elevated voltage test shall be taken at the start and at the end of the work day or at start and at the completion of the assignment. This testing requirement is considered good utility practice and does not require specific documentation.

3.4.2 Exceptions

- a. Electric substation fencing will not require equipment elevated voltage testing unless scheduled as part of the inspection program or if work was done on the fencing.
- b. In a storm situation, where mutual aid is required, testing by other than National Grid personnel will not be required.

3.5 Exemptions

3.5.1 See Section 2.7.1

4.0 FACILITIES WHERE EQUIPMENT ELEVATED VOLTAGE TESTING/DOCUMENTATION IS REQUIRED – MASSACHUSETTS

4.1 Company Owned Street Lights

4.1.1 Company owned metallic street lighting standards are required to be tested for equipment elevated voltage at an annual rate of twenty-percent (20%) on a five year cycle.

4.1.2 Exceptions: Testing shall not be completed at locations where street light standards are not publicly accessible, such as facilities located in the center of highways that cannot be accessed without stopping traffic or creating potentially hazardous situations for the worker and/or public.

4.2 Overhead Distribution Facilities

4.2.1 Towers and/or metallic poles with distribution facilities shall be tested for equipment elevated voltage at an annual rate of twenty-percent (20%) in conjunction with field inspections on a five-year cycle.

4.2.2 The following equipment on wood distribution poles or structures require equipment elevated voltage testing at an annual rate of twenty-percent (20%) in conjunction with field inspections on a five-year cycle:

- a. Metallic riser guard or conduit (company or non-company).

<p>Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum</p>		
FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 9 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

- b. Uncovered or uninsulated down ground (company or non-company).
- c. Down guy wire (company or non-company).
- d. Any other publicly accessible conductive piece of equipment (company or non-company) on the pole within reach from the ground.

4.3 Underground Facilities

4.3.1 Equipment elevated voltage testing at an annual rate of twenty-percent (20%), to be completed on a five-year cycle:

- a. All metallic manhole covers, vault covers and grates, junction box covers, handhole covers
- b. Pad-mounted transformers, secondary pedestals, and pad-mounted switchgears.

4.3.2 Exceptions: Non-metallic concrete or fiberglass pads or handholes or pull/splice boxes are not required to be tested.

4.4 Daily Job Site Test Requirements

4.4.1 Each job site where National Grid personnel or its contractors complete a work assignment:

- a. An equipment elevated voltage test shall be taken at the start and at the end of the work day or at the start and at the completion of the assignment. This testing requirement is considered good utility practice and does not require specific documentation.
- b. In a storm situation, where mutual aid is required, testing by other than National Grid personnel will not be required.

4.4.2 Exceptions

- a. Substation fencing will not require equipment elevated voltage testing unless scheduled as part of the inspection program or if work was done on the fencing.
- b. In a storm situation, where mutual aid is required, testing by other than National Grid personnel will not be required.

4.5 Exemptions

4.5.1 See Section 2.7.1

5.0 TEST EQUIPMENT

5.1 A hand held device (proximity detection unit) that is capable of detecting voltage from 5 to 600 VAC.

5.2 A portable AC digital high impedance volt meter must have the ability to take readings with and without an input load impedance of 500 ohms.

Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum		
FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 10 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

- 5.3 The handheld devices utilized shall be certified by an independent test laboratory as being able to reliably detect voltages from 5-600 VAC. The following units have been certified:
- 5.3.1 HD Electric Stray Voltage Detector model LV-5
 - 5.3.2 Fluke 85
 - 5.3.3 Fluke 87
 - 5.3.4 Fluke 170 series or equivalent
 - 5.3.5 Fluke 175
 - 5.3.6 Fluke 177
 - 5.3.7 Fluke 179
 - 5.3.8 Fluke 187
 - 5.3.9 Fluke 189
- 5.4 Mobile Contact Voltage Detection Equipment:
- 5.4.1 Narda 8950/10 Stray Voltage System
 - 5.4.2 SVD2000 Stray Voltage Mobile Detector

6.0 TEST PROCEDURE

- 6.1 Job Safety Requirements
- 6.1.1 At minimum, the following information shall be communicated to all personnel at the beginning of each shift for equipment elevated voltage testing:
 - a. Structures are never to be touched with a bare hand while performing the tests, only the proximity detector or meter probe is to be used to make contact with the facilities.
 - b. Appropriate PPE shall be worn.
 - c. Each individual needs to be aware of his/her surroundings at all times.
 - d. Make sure to observe all traffic before entering a street.
 - e. Traffic safety vest (DOT Compliant Class III) shall be worn at all times when exposed to traffic. Be aware that when bending down, the visibility benefits of the traffic safety vest are diminished.
 - f. Obey all traffic control devices.
 - g. When working in the street, face oncoming traffic whenever possible.
- 6.2 Measurements for detecting elevated voltages will be performed in accordance with the following:
- 6.2.1 Initial measurements for the presence of voltage shall be made using a certified proximity detection unit, refer to Section 5.3

Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum		
FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 11 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

- a. To verify the proper operation of the proximity detector, follow operating instructions for the particular unit being utilized, this is to be done daily.
 - b. After verification that the detection unit is working, approach the area/equipment to be tested. The proximity detector will illuminate prior to touching the area/equipment being tested if voltage is present. If the proximity detector does not illuminate in close proximity to the area/equipment touch the area/equipment to be tested with the probe of the unit.
- 6.2.2 If voltage is detected, re-test using a portable AC voltmeter (The 500 ohm resistor is NOT used in this initial test):
- a. Measurements with a portable AC voltmeter shall be taken on clean bare metallic surface (structure, ground wire, etc.)
 - b. When using a portable AC voltmeter, connection shall be made to suitable neutral or ground source with the common (black) lead.
 - 1. In locations where the neutral or ground point is at a distance in excess of the voltmeter lead length
 - i. The connection to the neutral/ground shall be made with up to 25' of # 16 stranded copper lead wire (covered).
 - ii. The other end of which shall be securely connected to the common (black) probe of the meter.
 - iii. When using such "extension leads" appropriate care shall be taken in the placement of such leads so as to not create a physical hazard to workers, pedestrian or vehicular traffic.
 - 2. In locations where a system ground is not available, or the existing ground registered voltage upon the proximity test
 - i. A metal rod shall be firmly embedded into the earth to a minimum depth of 6" to create a ground reference point for the measurement to be taken.
 - ii. An alternate method is available for obtaining a ground reference point utilizing an aluminum plate in lieu of driving a ground rod. The reference point should be as close as practicable to the facility being tested to simulate an equipment elevated voltage touch potential situation (3' to 4'.) On occasion longer leads may be necessary to find undisturbed earth (up to 25'.)
 - c. The "live" meter (red) probe lead shall then be placed into contact with the structure under inspection to determine the voltage.

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 12 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

1. Voltage readings greater than 30 volts AC shall be recorded in the database for the site.
 2. For voltage readings less than 30 volts, install a 500 ohm input load impedance resistor on the volt meter. Take another voltage measurement and record this voltage in the database for the site.
- 6.2.3 Measurements for elevated voltages/contact voltage using mobile technology will be performed in accordance with the following:
- a. Mobile testing is performed by contract crews driving pre-determined routes in Contact Voltage Areas searching for elevated voltage levels.
 - b. The equipment used is mounted to vehicles and detects contact voltage levels greater than 1 volt while driving at speeds of up to 25 mph near underground facilities.
 - c. Once elevated voltages are detected the crew stops and performs a thorough check with certified manual testing equipment to determine if there is contact voltage present.
- 6.2.4 Any positive indications by either mobile testing or hand held tools shall be followed up with voltage measurements on the target structures.
- a. Voltage measurements shall be taken in accordance with Section 6.2.2 above.
 - b. The investigators shall verify that a suitable ground (i.e. a ground that is not energized) is used as a reference. Ground source location shall be marked with tape, paint or flag for future testing of repair work.
- 6.2.5 A Total Harmonic Distortion (THD) test method will be implemented as a pilot for Rhode Island mobile elevated voltage testing. THD will be determined by the use of a Fluke Power Quality clamp meter or a Fluke scope meter both of which have the ability to measure THD.

7.0 CORRECTIVE ACTION REQUIREMENTS FOR EQUIPMENT ELEVATED VOLTAGE FINDINGS

7.1 Manual Testing

7.1.1 New York

If equipment elevated voltage condition is found and verified by the Test Procedure in Section 6.0, the site is to be guarded by a person or a protective barrier until made safe by Company personnel or if municipally owned, made safe by the owner or company.

. Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum		
FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 13 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

- a. If the voltage measures less than 1 volt and is found to be consistent with system operation design (no visual evidence of a problem upon review) **No further action is required.**
- b. If the voltage measures greater than or equal to 1 volts and less than 4.5 volts:
 - i. The asset can either be guarded in person or by a protective barrier that prevents public contact.
 - ii. Contact your supervisor for required action. Sound judgment shall be utilized in this application.
- c. If the voltage measures greater than or equal to 4.5 volts:
 - i. It shall be guarded by an equipment elevated voltage inspector or a Company employee that has been trained to stand by on energized facilities.
 - ii. Immediate response is required using the notification in Section 7.3.

7.1.2 Massachusetts and Rhode Island

If equipment elevated voltage condition is found and verified by the Test Procedure in Section 6.0, the site is to be guarded by a person or a protective barrier until made safe by Company personnel or if municipally owned, made safe by the owner or company.

- a. If the voltage measures less than 4.5 volts and is found to be consistent with system operation design (no visual evidence of a problem upon review) **No further action is required.**
- b. If the voltage measures greater than 4.5 volts and less than 8 volts:
 - i. The asset shall be guarded in person or by a protective barrier that prevents public contact.
 - ii. Contact your supervisor for required action. Sound judgment shall be utilized in this application.
- c. If the voltage measurement is greater than 8 volts:
 - i. It shall be guarded by an equipment elevated voltage inspector or a Company employee who has been trained to stand by on energized facilities.
 - ii. Immediate response is required using the notification in Section 7.3.

FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR
---	---	------------------------------

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 14 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

7.2 Mobile Testing

7.2.1 Rhode Island Total Harmonic Distortion Pilot

Under the Total Harmonic Distortion (THD) pilot in Section 6.2.5, if during mobile testing of the Contact Voltage Area the voltage measures greater than 1 volt and less than 4.5 volts and has a total harmonic distortion of less than 10% the voltage will be considered contact voltage.

- a. These areas will be safeguarded from the public and permanent repairs will be made.
- b. If the total harmonic distortion is greater than 10% (no visual evidence of a problem upon review) **No further action is required.**

7.2.2 New York and Rhode Island

In the event of an elevated/contact voltage finding on an electric facility or a street light, all publicly accessible structures and sidewalks within a minimum 30 foot radius of the electric facility or street light must be tested for stray voltage.

7.3 The following notification process for personnel to respond shall be utilized.

7.3.1 Notification by location:

- a. New York Regional Control Center 1-877-716-4996
- b. New England Regional Control Center, North
 - 1. Western, Central, North & Granite 1-508-421-7879
- c. New England Regional Control Center, South
 - 1. Southeast, South Shore & Ocean State (RI) 1-508-421-7885

7.3.2 Inform the System operator that this is an equipment elevated voltage call, and provide the following information:

- a. Inspector name, Company (if not National Grid)
- b. Address where the problem is identified; include facility number, circuit number, ownership, type of equipment and unique ID.
- c. Voltage found and whether they are physically guarding or leaving the site after flagging and installing a protective barrier. National Grid personnel or designee will be assigned to respond.

7.4 Temporary repairs may be used to mitigate the equipment elevated voltage thereby removing the need to guard the site.

7.5 Permanent repairs to the equipment shall be made within 45 days of the occurrence, except as noted in Section 7.6

<p>Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum</p>		
FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 15 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

- 7.6 If permanent repairs cannot be made within 45 days due to extraordinary circumstances, the company shall periodically perform site visits to monitor the condition of the temporary repair. For New York, all exceptions shall be identified and justified in the annual reporting of the program to the NYPSC.
- 7.7 The contractor and/or equipment elevated voltage Inspector may detect a minimal voltage level that is attributable to the design of the facility and not the result of an improper condition, no corrective action is required in this instance.
- 7.8 Angel Guards
 - 7.8.1 Individuals conducting the equipment elevated voltage tests on street light standards shall have a supply of “Angel guards” available for installation if the cover is missing or wires are found to be exposed to the public at the time of testing.
 - 7.8.2 Angel guards shall only be installed after the testing of the street light standard is complete and there is no indication of equipment elevated voltage above 1 volt (NY) and 4.5 volts (RI and MA)
 - 7.8.3 Repairs have been completed to correct the equipment elevated voltage.
- 7.9 The equipment elevated voltage inspector shall report any potentially hazardous conditions found on National Grid facilities seen visually during the survey process.
- 7.10 Customer Owned Equipment
 - 7.10.1 Where the Company finds equipment elevated voltage above the allowable thresholds and identifies its source as customer-owned equipment:
 - a. The Company shall guard the site and notify the customer or a responsible person, as appropriate, that a potentially hazardous situation exists.
 - b. The Company shall advise the customer or responsible person that the cause of the equipment elevated voltage shall be immediately remedied.
 - 7.10.2 Company personnel are encouraged to work with the customer to determine and rectify the problem. If the customer agrees to accept the Company’s assistance, the Company may charge a reasonable cost for this effort.
 - a. The Company may temporarily remove a customer’s meter or take such other actions as are appropriate and necessary to protect the public.

8.0 EQUIPMENT ELEVATED VOLTAGE DATABASE

- 8.1 The equipment elevated voltage database will be populated with information that is collected by the inspector using a hand-held device. The database shall be easily searchable for information and reporting.

Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum		
FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 16 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

8.2 The equipment elevated voltage inspector shall populate the following Information fields for manual testing:

Survey Date	Inspectors Name
Region	GPS Taken
District	Pre-load Match
Contractor	Equipment EV Test Required
GIS ID/Asset # (Unique ID)	Voltage Found Y/N
Facility Type	Voltage Measurement
Owner	Type of Equipment (Appendix A)
Feeder/Circuit	Immediate Action Taken
Line #	Person Notified
Tax District	Permanent Repair Date
Pole/Structure/Equipment ID	Type of Repair
Street Name	Person Responsible for repair (Employee ID)

8.3 Information fields required to be completed for facilities for mobile testing

Survey Date	Street Name
Region	GPS taken
District	Voltage Found Y/N
Contractor	Voltage Measurements
Facility Type	Type of Equipment (see Appendix A)
Owner	Immediate Action Taken
Pole/Structure/Equipment ID	Person Notified
Permanent Repair Date	Type of Repair

9.0 NEW YORK ANNUAL REPORTING AND CERTIFICATION REQUIREMENTS

- 9.1 Each Regional program supervisor shall provide certification to the program manager that the Region they supervise has complied with the equipment elevated voltage testing and inspection program as ordered by the PSC.
- 9.2 The program manager shall provide certification to the Vice President Distribution Network Strategy and the Senior Vice President of Customer Operations & Maintenance that the organization has complied with the equipment elevated voltage testing and inspection program as ordered by the PSC.
- 9.3 Written certification of the completion and results of every equipment elevated voltage test and inspection shall be completed, as well as a certification that all unsafe conditions identified have been remediated by appropriate company personnel.
- 9.4 The President or officer with direct responsibility for overseeing the equipment elevated voltage testing and inspection shall provide an annual certification to the NYPSC that the Company has tested all of its publicly accessible conductive surface electric facilities and all street lights, as well as completed all required inspections.

Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum		
FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 17 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

- 9.5 The President or officer with direct responsibility for overseeing facility inspections shall provide an annual certification to the Commission that the utility is in compliance with its inspection program and has inspected the requisite number of electric facilities. Additionally, at the end of the five-year inspection cycle, the officer shall certify that all of the utility’s electric facilities have been inspected at least once.
- 9.6 The annual reporting and certification is required by February 15 of each year. In addition to certifications, it shall address the following:
- 9.6.1 Details the results of equipment elevated voltage test results and inspections conducted over the 12-month period ending December 31 of the prior calendar year.
 - 9.6.2 Addresses the performance mechanism contained in Section 10 of the PSC Order Adopting Changes to Electric Safety Standard effective December 15, 2008 (December 15, 2008 Order).
 - 9.6.3 Contain certification described in 9.3, 9.4 and 9.5 of this section.
 - 9.6.4 Contain a breakdown of the voltage findings in a tabular format as detailed in Attachment 1 of the December 15, 2008 Order; for all findings that result in a reading of 1 V or more after completion of mitigation efforts, a detail report of company efforts shall be provided.
 - 9.6.5 Contain a breakdown of the shock reports received from the public as detailed in Attachment 2 of the December 15, 2008 Order.
 - 9.6.6 Discussion of the analysis undertaken on the causes of the stray voltage within the Company’s electric system, the conclusions drawn there from, the preventative and remedial measures identified, and the Company’s plan to implement those measures.
 - 9.6.7 Description of the priority levels used to gauge the severity of a deficiency, including repair timeframes, and details the requirements for training personnel to properly identify and categorize the deficiencies.
 - 9.6.8 Contain a breakdown of facilities to be inspected, unique inspection conducted per year, and the cumulative number of unique inspections conducted to meet the five year requirement.
 - 9.6.9 Contain a breakdown of the deficiencies found, permanent repair actions taken by year, whether a repair was completed within the required timeframe, and the number of deficiencies awaiting repair. This information should be provided on a yearly basis by priority level and by equipment groupings as detailed in Attachment 3 of the December 15, 2008 Order.
 - 9.6.10 Contain a review and analysis of the inspection results. The review should identify areas of concern along with remedial actions or future plans to alleviate inadequacies in current program assets.

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 18 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

- 9.6.11 Description of the quality assurance program along with the results from quality assurance activities conducted during the year.
- 9.6.12 Any additional information that is pertinent to the issues addressed by the safety standards should also be included.
- 9.7 The Company shall file reports on their mobile stray voltage testing with the Secretary of the New York PSC within 45 days after completion of the mobile testing or February 15, of each year. The filing shall include the historic results and costs associated with the manual test program in each area listed in Section 2.5 of this procedure.
- 9.8 The Company is required by the December 15, 2008 Order to have independence in the quality assurance program required by the order. The management and personnel performing the quality assurance activities shall be separate from those performing the required stray voltage testing and inspection activities.
- 9.9 The Company shall maintain its written certification and other documentary proof of its testing at its' Albany, Buffalo, and Syracuse office facilities. These documents shall be made available to the public for review upon request.

10.0 MASSACHUSETTS REPORTING REQUIREMENTS

- 10.1 National Grid shall submit an annual report that includes the following:
 - 10.1.1 Annual reports that list inspection and testing data, including number of inspections conducted by equipment type.
 - 10.1.2 Number of equipment elevated voltage events detected by inspection personnel versus call-ins or notification by third parties.
 - 10.1.3 Variance reports on current year inspection targets.
 - 10.1.4 Equipment elevated voltage events detected on equipment that is not included in equipment elevated voltage equipment inspection schedules (which will enable the Massachusetts DPU to determine if the company is inspecting and testing the correct equipment).
 - 10.1.5 Number of exceptional or non-routine events that required reporting to OSHA or other government organizations due to injuries or other substantive impacts
 - 10.1.6 Description of the quality assurance program along with the results from quality assurance activities conducted during the year.

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 19 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

11.0 Rhode Island Reporting Requirements

- 11.1 National Grid shall submit an annual Contact Voltage Compliance report that includes the following in a searchable form:
 - 11.1.1 Event record number
 - 11.1.2 Location of testing
 - 11.1.3 Date and time of testing
 - 11.1.4 Company or customer asset
 - 11.1.5 Failed equipment type
 - 11.1.6 Voltage recorded
 - 11.1.7 Personal injuries to members of the public, pets or property damage
 - 11.1.8 Any other equipment involved and age
 - 11.1.9 Prior incidents at this location in the past five years
 - 11.1.10 Corrective actions taken at the location and date taken
 - 11.1.11 Number of customers if service is interrupted while making repairs
 - 11.1.12 Duration of interruption
 - 11.1.13 Summary of investigation into cause of the incident
 - 11.1.14 Number of calls to the company “shock” line
 - 11.1.15 Total repair costs by Contact Voltage Area
 - 11.1.16 All information as provided for in Section 8.3

The Company will provide a summary of the above information as part of the report. In addition, the Company will include a recommendation for which specific CVAs will be tested the following year, whether there are any recommended changes to the CVAs and whether there are any advances in technology for detection of elevated voltages.

. Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum		
FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 20 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

12.0 TYPE OF EQUIPMENT - APPENDIX A

TYPE	CODE	EQUIPMENT DESCRIPTION
Distribution	910	Pole
	911	Regulator
	912	Sectionalizer
	913	Recloser
	914	Ground
	915	Guy
	916	Riser
	917	Switch Handle Mechanical Operated
	929	Distribution – Other (use comments)
Transmission	930	Pole
	931	Tower
	932	Guy
	933	Ground
	934	Riser
	935	Switch Hand Mechanical Operator
	949	Transmission – Other (use comments)
Underground	950	Handhole
	951	Manhole
	952	Switchgear
	953	Transformer
	954	Vault – Cover/Door
	969	Underground – Other (use comments)
Street Light	970	Handhole
	971	Standard
	979	Street light – Other (use comments)
Customer Street Light/Other	980	Handhole
	981	Standard
	989	Customer SL/Other – Other (use comments)
Traffic Control	990	Handhole
	991	Standard
	992	Control Box
	993	Pedestrian Crossing Pole
	999	Traffic control – Other (use comments)

. Copyright 2018 National Grid. Printed copies of this document are not document controlled. Refer to the National Grid INFONET, Distribution Engineering Services website, for the latest version. Controlled copies are maintained in Documentum

FILE: NG-EOP G016 EQUIPMENT ELEVATED VOLTAGE TESTING JAT	ORIGINATING DEPARTMENT: T&D O&M SERVICES	SPONSOR: JONATHAN GONYNOR
---	---	------------------------------

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 21 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

13.0 EXCEPTION APPROVAL

- 13.1 It is recognized that situations may arise that are not covered by this procedure
- 13.2 When this occurs, an exception may be approved
- 13.3 The person in charge of the work shall
 - 13.3.1 Develop a work plan detailing
 - a. The need for an exception to the EOP
 - b. Additional safeguards to be employed
 - 13.3.2 Provide the work plan to and obtain approval from all of:
 - a. The manager in charge of the work
 - b. The manager of T&D Work Methods
 - c. A manager from Safety
 - 13.3.3 Alternatively approval may be obtained from a designee of any of the above
- 13.4 If agreement cannot be obtained at the manager level
 - 13.4.1 The request shall be forwarded to the Director levels
 - a. Director's may assign a designee
- 13.5 After approval is obtained.
 - 13.5.1 The work plan shall be reviewed with all workers who will participate in the job
 - a. All workers need to agree on the work plan
 - b. Document the exception on the job brief
- 13.6 T&D Work Methods shall publish a Memorandum documenting the approval
 - 13.6.1 A copy of the work plan shall be included
 - 13.6.2 Such memorandum shall be sent to all stakeholders and approvers
 - 13.6.3 The memo shall be stored for the record

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 22 of 22
	Equipment Elevated Voltage Testing	Version 3.0 – 04/19/18

14.0 REVISION HISTORY

<u>Version</u>	<u>Date</u>	<u>Description of Revision</u>
1.0	04/01/11	This document supersedes document dated 08/17/09.
2.0	09/30/13	This document supersedes document date 04/01/11.
3.0	04/19/18	Revised the following: Formatting changes, broke paragraphs into subsections Accountability Section, Added “Quality Assurance Quality Control” group and removed “Network Strategy” and replaced with “Asset Management” Removed the Definitions Section Section 1 Added new “Safety Requirements” section 2.0 Renumbered section to revised listing 2.1.1 – 2.14 Revised language to include the percent rate of 100% 3.3.1 Added percent rate of 20% for underground testing in Rhode Island 4.11 Added percent rate of 20% for street light testing in Massachusetts 4.3.1 Added percent rate of 20% for underground testing in Massachusetts 7.3.1b.c Revised phone numbers for Northborough control center 7.8 Added “Angel Guard” Title and revised subsections 8.0 Database requirements, added language and formatted facilities list 13.0 7. Added new Exception Approval Section