

Jennifer Brooks Hutchinson Senior Counsel

February 1, 2012

## VIA HAND DELIVERY & ELECTRONIC MAIL

Luly E. Massaro, Commission Clerk Rhode Island Public Utilities Commission 89 Jefferson Boulevard Warwick, RI 02888

#### RE: Docket 4296 – The Narragansett Electric Company, d/b/a National Grid 2012 System Reliability Procurement Plan <u>Responses to EERMC Data Requests – Set 1</u>

Dear Ms. Massaro:

Enclosed are ten (10) copies of National Grid's<sup>1</sup> responses to the Energy Efficiency and Resource Management Council's ("EERMC") First Set of Data Requests issued in the above-captioned proceeding.

Thank you for your attention to this filing. If you have any questions, please feel free to contact me at (401) 784-7288.

Very truly yours,

Junfor Burg Hills

Jennifer Brooks Hutchinson

cc: Docket 4296 Service List Jon Hagopian, Esq. Steve Scialabba, Division

<sup>&</sup>lt;sup>1</sup> The Narragansett Electric Company d/b/a National Grid.

## <u>EERMC 1-1</u>

## Request:

How much local peak load reduction does NGrid estimate it will achieve each year in the Tiverton region with just the system-wide efficiency programs (i.e. without any additional geo-targeting efforts)?

## Response:

The load forecast assumes that National Grid's system-wide efficiency programs will reduce Rhode Island peak load growth by approximately 0.6% per year during the forecast period. These savings amounts are allocated proportionately to the power supply areas and local areas within Rhode Island. Please see the Company's response to EERMC 1-2 for these details.

Prepared by or under the supervision of: Alfred P. Morrissey, Jr.

## <u>EERMC 1-2</u>

## Request:

The projection that, absent other interventions, the Tiverton substation would need to be upgraded by 2014 is based on forecasted growth in the non-coincident peak for the Western NECO (p. 5). On a weather adjusted basis, this is estimated to be an annual increase of 2.6% from 2010 through 2020. Is that 2.6% net of the effects of NGrid's system-wide efficiency programs which are forecast, for example, to achieve incremental annual energy savings in 2012 of 1.7% (suggesting that growth absent those programs would be 4.3% annually if the programs achieved the same percentage peak reduction as energy reduction)? If so, please provide copies of the analysis that shows how those system-wide program savings were assumed to affect the Western NECO load forecast.

## Response:

The 2010 through 2020 annual peak demand forecast of 2.6% per year includes the savings on peak from National Grid's system-wide efficiency programs in Rhode Island. These energy efficiency (EE) savings are shown on the excel spreadsheet in Attachment EERMC 1-2.

National Grid has been implementing EE programs in Rhode Island for over 20 years. The spreadsheet shows that, as a result of these efforts, The Narragansett Electric Company reduced its summer peak by 154 MW or 9.2% in 2009. Total Rhode Island service area EE savings on peak increased from 5.0% of total peak in 1999 to 9.2% in 2009, a 7.5% average annual increase, or 8 MW per year. This reduced historical peak load growth by about 0.5% per year from 1999-2009. The peak demand forecast assumes incremental EE savings on peak will continue to reduce load growth by 0.5% per year plus an additional 0.1% per year for a total of 0.6% per year.

The EE savings estimates on the attached spreadsheet were developed in March 2010. They are the total savings from (1) all of the Company's EE programs offered through 2009, which are still producing savings in 2010 and beyond; and (2) the incremental savings from new programs the Company offered or planned to offer in 2010-2013. These annual incremental savings are a fraction of the total annual savings goals filed for any particular year. The incremental savings are always a fraction of the annual goal since customers participate in the Company's efficiency programs over the entire program year and are not all "on-line" as of January 1 of the program year.

## EERMC 1-2 (continued, p2)

Actual EE savings and trends achieved through 2009 are embedded in the historical load data used to develop the peak load forecasting models. These savings and trends carry forward into the forecast at approximately the historic rate. Incremental DSM savings beyond the amounts achieved through 2009 were subtracted from the PSA forecast results. These incremental DSM adjustments were calculated as the difference between total DSM savings in the forecast year minus total DSM savings in 2009. Total Rhode Island service area incremental EE savings were allocated to the Western NECo PSA based on its share in total Rhode Island load and are shown in Appendix 3, in the column labeled "Incremental DSM." These incremental EE savings reduced the Western NECo 2010 through 2020 weather-normalized peak demand forecast from 2.7% per year to 2.6% per year.

Note that these are cumulative EE savings due to National Grid's passive EE programs only. Savings resulting from the Company's SRP Plan proposal are not included.

National Grid must continually add new programs to maintain the historic savings increases shown on Attachment EERMC 1-2. Total EE savings fall quickly without new programs because these savings are the sum total of savings from all of National Grid's existing EE programs, some of which are new and some of which were installed several years ago. As program and product lifetimes expire, cumulative EE savings fall unless new programs are introduced to replace them. Attachment EERMC 1-2 shows that, beginning in 2014, total EE savings fall in the absence of new programs to replace them. However, the peak demand forecast assumes no drop off in cumulative EE savings after 2013. This assumes that National Grid will continue to implement more programs, beyond those that were planned for 2010 through 2012, so that total EE savings do not fall from the 2013 highs shown in the spreadsheet.

Note that EE savings from expired National Grid programs may still persist in the market. For example, after a light program expires, customers may continue to use the measures, such as fluorescent bulbs, rather going back to the technology they used before participating in the program. However, these savings are not included in the EE savings shown on Attachment EERMC 1-2.

Prepared by or under the supervision of: Alfred P. Morrissey, Jr.

Attachment EERMC 1-2 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 1 of 1

## Narragansett Electric Company Actual and Forecast Electric Efficiency Savings

	Total EE		Total EE	
	on Energy	Percent of	on Peak	Percent of
Year	<u>(MWh)</u>	<b>Energy</b>	<u>(MW)</u>	<u>Peak</u>
1999	322,567	4.6%	75	5.0%
2000	341,993	4.8%	76	5.1%
2001	392,584	5.3%	83	5.0%
2002	442,557	5.9%	91	5.4%
2003	480,714	6.2%	97	6.0%
2004	519,871	6.6%	105	6.5%
2005	568,507	7.1%	113	6.3%
2006	623,330	8.1%	121	6.3%
2007	674,152	8.6%	129	7.3%
2008	715,895	9.3%	136	7.6%
2009	798,504	10.7%	154	9.2%
Forecast				
2010	778,831	10.4%	152	8.5%
2011	815,992	10.6%	159	8.8%
2012	862,693	10.9%	164	8.9%
2013	857,013	10.6%	164	8.6%
2014	810,893	9.8%	156	8.1%
2015	776,296	9.3%	149	7.6%
2016	735,462	8.7%	142	7.1%
2017	680,762	8.0%	132	6.6%
2018	615,817	7.1%	120	5.9%
2019	520,331	6.0%	102	5.0%

<b>Notes</b> o Total EE consists of savings from existing electric efficiency programs and savings from programs planned for 2010 to 2013.
o In the absence of new EE programs, total savings decrease after 2013 as existing program lifetimes expire.
o PSA forecasts assume no reduction in total peak savings after 2013.
o EE adjustment to the peak demand forecast is equal to peak savings in forecast year minus peak savings in 2009 ("Incremental EE").
o Total Rhode Island EE savings are allocated to Western NECo and the other PSAs based on load.
o Peak savings are from passive programs only
Source: Energy Efficiency Dept.

## EERMC 1-3

## Request:

Appendix 3 to the plan suggests that the weather-normalized peak load growth in the Western NECO was -0.8% per year from 2004 through 2009 and only 1.2% in 2010. Given that past experience, what leads NGrid to believe that load growth will be substantially higher in the future? What factors are driving that project that are different from recent conditions?

## Response:

Weather-normalized peak load in Western NECo fell 0.8% per year from 2004 to 2009 due to the regional economic slowdown and the severe 2008/09 recession. Future load growth is expected to be higher because the Rhode Island economy is expected to recover.

Projections of Rhode Island economic growth were provided by Moody's Analytics, a leading economic consulting firm. These projections are summarized on the excel spreadsheet in Attachment EERMC 1-3. The peak demand forecast is driven by Moody's forecasts of Rhode Island employment and number of households; and by trends in the sensitivity of peak load to weather.

Rhode Island employment is forecast to rebound fairly sharply from 2011-2014, according to Moody's. For example, after falling 1.1% per year during the regional economic slowdown and recession from, 2004-2009, Rhode Island employment is expected to grow 1.1% in 2011, 2.9% in 2012, 3.2% in 2013 and 1.7% in 2014. Likewise, the number of households is projected to rise beginning in 2011 after falling from 2004 through 2009. Moody's expects all Rhode Island jobs lost during the recession to be regained by 2014. After that, Rhode Island employment and household growth are both expected to fall off as shown on Attachment EERMC 1-3. Appendix 3 shows that Western NECo peak load growth falls off after 2014 as well.

Actual Western Neco peak load for 2011 was 924.507 MW which was 0.9% higher the extreme weather forecast for 2011, 916.508 MW; and 9.5% higher the normal weather projection for 2011, 844.579 MW. Actual peak day weather conditions were slightly hotter than the extreme weather conditions assumed for the forecast.

Prepared by or under the supervision of: Alfred P. Morrissey, Jr

#### Attachment EERMC 1-3 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 1 of 1

## PSA Forecast 2010 Moody's Analytics Economic Outlook Rhode Island

			Real						_
			Disposable				Number		
	Total	Growth	Income	Growth		Growth	of	Growth	
Year	Employment	Rate	(\$mill 2000)	Rate	Population	Rate	Households	Rate	
====	========	=====	=======	=====	=======	=====	=======	=====	
1999	465,383		\$29,833		1,040,907		404,228		
2000	476,759	2.4%	\$30,981	3.8%	1,050,894	1.0%	409,371	1.3%	
2001	478,434	0.4%	\$32,074	3.5%	1,058,465	0.7%	412,388	0.7%	
2002	479,403	0.2%	\$32,816	2.3%	1,066,111	0.7%	415,353	0.7%	
2003	484,184	1.0%	\$33,555	2.3%	1,071,202	0.5%	417,340	0.5%	
2004	488,451	0.9%	\$34,259	2.1%	1,070,601	-0.1%	417,105	-0.1%	
2005	490,975	0.5%	\$34,005	-0.7%	1,064,372	-0.6%	414,678	-0.6%	
2006	493,274	0.5%	\$34,729	2.1%	1,058,628	-0.5%	412,440	-0.5%	
2007	492,697	-0.1%	\$35,175	1.3%	1,053,120	-0.5%	410,295	-0.5%	
2008	481,781	-2.2%	\$34,779	-1.1%	1,050,782	-0.2%	409,242	-0.3%	
2009	461,851	-4.1%	\$34,706	-0.2%	1,050,045	-0.1%	408,673	-0.1%	
Forecast									
2010	455,651	-1.3%	\$34,721	0.0%	1,050,022	0.0%	408,654	0.0%	
2011	460,471	1.1%	\$34,947	0.7%	1,052,902	0.3%	409,973	0.3%	
2012	473,783	2.9%	\$35,495	1.6%	1,057,327	0.4%	411,793	0.4%	
2013	488,895	3.2%	\$36,548	3.0%	1,061,787	0.4%	413,540	0.4%	
2014	497,036	1.7%	\$37,334	2.1%	1,066,282	0.4%	415,719	0.5%	
2015	501,397	0.9%	\$37,947	1.6%	1,070,840	0.4%	417,967	0.5%	
2016	504,632	0.6%	\$38,559	1.6%	1,075,492	0.4%	420,055	0.5%	
2017	507,105	0.5%	\$39,186	1.6%	1,080,251	0.4%	422,057	0.5%	
2018	508,938	0.4%	\$39,800	1.6%	1,085,099	0.4%	423,761	0.4%	
2019	510,241	0.3%	\$40,401	1.5%	1,090,026	0.5%	425,327	0.4%	
2020	511,510	0.2%	\$41,023	1.5%	1,095,011	0.5%	426,972	0.4%	
2021	512,864	0.3%	\$41,671	1.6%	1,100,023	0.5%	428,499	0.4%	
2022	514,200	0.3%	\$42,326	1.6%	1,105,051	0.5%	430,039	0.4%	
2023	515,485	0.2%	\$42,993	1.6%	1,110,065	0.5%	431,458	0.3%	
2024	516,785	0.3%	\$43,668	1.6%	1,115,039	0.4%	432,918	0.3%	
Compound Ann	ual Growth:								
Ten-Year	1999-2009	-0.1%		1.5%		0.1%		0.1%	
Five-Year	2004-2009	-1.1%		0.3%		-0.4%		-0.4%	
Five-Year	2009-2014	1.5%		1.5%		0.3%		0.3%	
Ten-Year	2009-2019	1.0%		1.5%		0.4%		0.4%	
Fifteen-Year	2009-2024	0.8%		1.5%		0.4%		0.4%	
Source:	Moody's Econom	iy.com, Janu	ary 2010 release	e.					

## <u>EERMC 1-4</u>

## Request:

The plan makes reference to several strategies that will be pursued to defer the Tiverton substation upgrades. Those strategies include geographically targeted energy efficiency, demand response and direct load control. What portions (in both MW and percent) of the forecasted the local peak demand reduction from the pilot project are expected from each of those strategies?

## Response:

The table in Attachment EERMC 1-4 illustrates what portions (in MW and percent) of the forecasted peak will be affected by the various strategies proposed for the Pilot.

Prepared by or under the supervision of: Christina Skursky

Attachment EERMC 1-4 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 1 of 1

		Targeted					
	Targeted	Energy		Demand			
	Energy	Efficiency	Demand	Response		DLC	
	Efficiency	Percentage of	Response	Percentage of	<b>DLC Total</b>	Percentage of	
	Total MW	Peak	Total MW	Peak	MW	Peak	PSA Peak
Year	Reduced	Reduction	Reduced	Reduction	Reduced	Reduction	Forecast (MW)
2012	0.025625	0.003%	0.18255	0.019%	0	0.000%	952.74
2013	0.050275	0.005%	0.3651	0.037%	0	0.000%	992.1
2014	0.074925	0.007%	0.54765	0.053%	0.008	0.001%	1031.66
2015	0.099575	0.009%	0.7302	0.069%	0.016	0.002%	1064.046
2016	0.124225	0.011%	0.91275	0.084%	0.024	0.002%	1091.13
2017	0.153125	0.014%	1.12655	0.101%	0.0296	0.003%	1114.7

## <u>EERMC 1-5</u>

## Request:

With respect to the geographically targeted energy efficiency component of the plan:

- a. How much local peak savings over and above those projected from the systemwide programs – will the geographically targeted efficiency efforts generate?
- b. What is the breakdown by sector, program and measure of what will comprise those additional geographically targeted efficiency savings?
- c. Are any new efficiency measures and/or programs planned? (beyond those included in the statewide initiative (and beyond the demand response commercial lighting ballasts described on p. 10) If so, which ones?
- d. Were any new measures or programs considered for Tiverton pilot and ultimately rejected? If so, which ones and why were they rejected? Was an analysis done to suggest they were not cost-effective? Please provide the analysis.
- e. To the extent that the Company is simply forecasting higher participation rates for measures it is already including in its system-wide programs, how will those higher participation rates be achieved?
  - i. Is it just through additional marketing?
  - ii. Will higher incentives be offered for any measures or programs? If not, why not?

## Response:

- a. This Pilot will focus approximately 105 summer peak kW of statewide levels of EE to the Tiverton/Little Compton area in 2012. It will achieve approximately 3 summer peak kW in the Tiverton/Little Compton area as a result of measures installed by the Pilot that would not have otherwise been installed by statewide levels of energy efficiency. Please refer to Table S-4 of Appendix 12 in the 2012 SRP Plan Report Supplement to view these figures as well as those for other years in the Pilot's lifetime.
- b. Please refer to Table S-4 in Appendix 12 in the 2012 SRP Plan Report Supplement to view the breakdown of kW savings in each year by program and type. The savings in the "SRP" rows come from the PCTs being installed in C&I facilities. These would not have been installed as part of the statewide programs. The savings in the EnergyWise program come from the evaluated savings of the

## EERMC 1-5 (continued, p2)

average measure mix expected to be installed through this program as well as the PCTs being installed in residential homes. The savings in the Small Business Direct Install program come from the evaluated savings of the average measure mix expected to be installed through the program including the lighting projects with the upgraded DR ballasts.

- c. There is only one measure providing savings to this Pilot that would not have been offered as part of the statewide levels of EE and that is the wi-fi programmable controllable thermostat (PCT) in the Small Business Direct Install program. Although this measure is offered in the residential sector, it has not been offered in the C&I sector in any capacity. The benefits and savings for this measure can be found on the "SRP" lines in Tables S-4 and S-5 of Appendix 12 in the 2012 SRP Plan Report Supplement. As new technology is piloted and deemed cost effective, the Company will consider integrating it into the non-wires solution proposed for Tiverton in future filings. However for the 2012 SRP Plan, nothing outside of what is described in the filing and supplement is planned.
- d. No new measures or programs were considered for the Tiverton pilot because the Company wanted to first leverage offerings from the current Energy Efficiency Plan. The measures considered for the Tiverton pilot were those that were proven to be cost effective and provided the most load relief capabilities. The Company wanted to make the pilot as cost effective as possible and in order to do so, is proposing to use cost effective measures as a baseline to achieve load curtailment. If the Company cannot achieve the required load relief by using cost effective measures, it may propose additional measures in subsequent annual SRP Plans.
- e. Obtaining higher participation rates in pre-existing programs will be accomplished by using a combination of targeted marketing efforts and offering increased incentives for measures/programs in the Tiverton/Little Compton areas. The methodology used will be similar to what was done during the Aquidneck Island pilot.

### EERMC 1-5 (continued, p3)

- No, it will be a combination of additional geographically targeted marketing and increased incentives for installation of PCTs through Energy Wise and installation of light dimming ballasts and PCTs through the Small Business/Direct Install program.
- ii. Yes. Typically customers would receive a \$100 rebate for purchasing a PCT in the residential sector; this pilot is proposing to cover the entire cost of the PCT plus installation costs, approximately a \$500 value. For the Small Business/Direct Install program, lighting projects typically have a 70/30% cost share, in Tiverton/Little Compton there will be a 80/20% cost share as an incentive for installing this measure.

Prepared by or under the supervision of: Timothy Roughan, Jeremy Newberger, Christina Skursky and Lindsay Perry

## EERMC 1-6

## Request:

With respect to the cost-effectiveness analysis summarized in Table S-2:

- a. Please provide a copy of the analysis including the populated analysis tool from which these values were derived.
- b. What is meant by "targeted base efficiency"? The term "targeted" implies these are additional savings above those that would otherwise be experienced in the Tiverton region through the system-wide programs. The term "base" potentially suggests a different interpretation.
- c. Are these just the benefits from those costs incurred and those savings realized over the life of the measures installed in 2012? If not, what do they represent? If so, what is the cost-effectiveness for the entire six year project?

## Response:

- a. The EERMC has agreed to withdraw this question.
- b. Targeted Base Energy Efficiency" refers to existing levels of energy efficiency (EE) that are focused in a certain area. To further clarify this, the Company has revised the language in the 2012 SRP Plan Report Supplement version of Table S-2 to read "Focused Energy Efficiency" benefits. Please refer to Pages 18-19 of the 2012 SRP Plan Report Supplement for an explanation of these benefits.
- c. Please see the Company's response to Division 1-2.

Prepared by or under the supervision of: Lindsay Perry and Jeremy Newberger

## <u>EERMC 1-7</u>

## Request:

The cost of the Tiverton upgrades that would otherwise be required in 2014 is estimated at \$2.69 million. Is that in 2014 dollars or current (i.e. 2011) dollars?

### Response:

Please see the Company's response to Division 1-1.

Prepared by or under the supervision of: Timothy Roughan

## <u>EERMC 1-8</u>

## Request:

The Company has estimated an energy efficiency savings of 0.17 kW per programmable controlled thermostat, based on evaluation results summarized in Appendix 8. However, the memo in Appendix 8 appears to describe only an analysis of gas heating savings from thermostats. There is a table at the end of the memo which shows central A/C savings. It appears as if the 7% savings found for gas heating was simply assumed to apply to both central air conditioning energy use and peak demand. Is that the case? If so, what is the basis for assuming so?

## Response:

The Company was advised by Cadmus that the 7% gas savings could be a reasonable assumption for the amount of cooling load savings; this is what the central A/C savings calculations illustrate in Appendix 8 of the Plan (assuming a 2.5 ton A/C unit).

In addition, Bonneville Power Association (BPA) has data that supports 7% as a minimum, conservative savings quantity. The BPA data is found in a report, *Measure Summary Report: Web-Enabled Programmable Thermostats*, prepared by EES Consulting and based on a wi-fi PCT from Honeywell. In Attachment EERMC 1-8, Figure 2 on page 14 illustrates that during the summer cooling months, Rhode Island can experience between 12-18% energy savings using a web enabled programmable thermostat.

The Company believes 7% savings is a conservative figure as to what can be expected from PCTs during cooling months. The Company will report on savings in future SRP Annual Reports.

Prepared by or under the supervision of: Christina Skursky

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 1 of 33

## **Bonneville Power Administration**

## Measure Summary Report: Web-Enabled Programmable Thermostats

February 2011

Prepared by:



570 Kirkland Way, Suite 200 Kirkland, Washington 98033

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 2 of 33

# Contents

С	CONTENTSI
L	IST OF FIGURESIII
L	IST OF TABLESIV
E	XECUTIVE SUMMARY
1	INTRODUCTION
	OBJECTIVE
	BACKGROUND
2	WEPT TECHNOLOGY
	TECHNOLOGY DESCRIPTION
	How IT SAVES ENERGY
	COMPETING OR OVERLAPPING TECHNOLOGIES
	COMMERCIAL AVAILABILITY
	Dreamwatts 5
	Honeywell T7350
	Proliphix
3	MEASURE DATA
	MEASURE SAVINGS
	MEASURE LIFE
	MEASURE COSTS
	Proliphix
	Honeywell

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 3 of 33

	OTHER COST-EFFECTIVENESS PARAMETERS	1
	Cost Effectiveness	2
4	MARKET14	4
	APPLICATIONS	4
	MARKET BARRIERS AND OPPORTUNITIES	4
5	ENERGY EFFICIENCY POTENTIAL1	5
	CODES AND STANDARDS	5
	APPLICABILITY	5
	RECENT EXPERIENCE	6
	MARKET SATURATION	8
	ACHIEVABLE POTENTIAL ESTIMATES	8
6.	SUMMARY	6
	RESEARCH NEEDS	6
7	REFERENCES	7

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 4 of 33

# **List of Figures**

FIGURE 1 – WEPT CONFIGURATION (SOURCE: POWERMAND)	4
FIGURE 2 – HEATING AND COOLING SAVINGS FROM WEPT	9
FIGURE 3 – ENERGY CONSUMPTION PER HDD REGRESSION FOR EVERGREEN SCHOOLS	17
FIGURE 4 – ANNUAL BPA WEPT SAVINGS, RETROFIT	25
FIGURE 5 – ANNUAL BPA WEPT SAVINGS, NEW CONSTRUCTION	25

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 5 of 33

# **List of Tables**

TABLE 1 - WEPT SAVINGS ESTIMATE BY MANUFACTURER	
TABLE 2 - WEPT COST ESTIMATE BY MANUFACTURER	10
TABLE 3 – COST EFFECTIVENESS FOR WEPT IN PORTABLE CLASSROOMS	12
TABLE 4 – SAVINGS BY BUILDING TYPE, RETROFIT	19
TABLE 5 – SAVINGS BY BUILDING TYPE, NEW CONSTRUCTION	20
TABLE 6 – APPLICABILITY FACTORS BY BUILDING TYPE	21
TABLE 7 – WEPT MATRIX, RETROFIT	22
TABLE 8 – WEPT MATRIX, NEW CONSTRUCTION	23
TABLE 9 – TOTAL BPA SAVINGS POTENTIAL BY COMMERCIAL BUILDING TYPE	24

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 6 of 33

## **Executive Summary**

Web-enabled programmable thermostats (WEPT) allow users to modify temperature set points and HVAC controls remotely using the Internet. Building owners can use WEPT to help optimize heating energy use without having to make physical site visits to manually re-program thermostats. WEPT applies to medium and small commercial buildings without direct digital control (DDC) systems.

A variety of case studies utilizing WEPT have recently been performed in the Northwest. These case studies show that WEPT can save significant amounts of electricity (32-47%) in small commercial building applications. Table ES 1 shows the percent savings for each case study.

ES 1 - WEPT Savings Estimate by Manufacturer						
Manufacturer	Percent Savings	Heat Type	Source	Info		
Honeywell	30%	Various	Specification Sheet	http://customer.honeywell.com/techlit/p df/63-0000s/63-9093.pdf		
DreamWatts	10-15%	Rooftop units	Portland State Business Accelerator Building	http://PowerMand.com/case-studies		
DreamWatts	33%	Rooftop units	MacDonald-Miller Lower Building, Seattle	David Nieman, MMFS		
Proliphix	20%	Various	AAA Case Study	http://www.proliphix.com/Collateral/Do cuments/English- US/case_studies/CSC(AAA)Case%20St udy_Rev1.pdf		
Proliphix	40-60%	Electric	Evergreen School District	David Cone, Evergreen School District		

The Evergreen School District in Vancouver, WA pilot study included web-enabled thermostats installed in 30 electrically heated portable classrooms buildings (60 classrooms). The savings in these school portables were between 40 and 60% of total electricity consumption. This represents about 1900 kWh of savings per portable unit, or about 1.7 kWh per square foot of portable floor space.

In general, installed cost of a WEPT system ranges between \$500 and \$1000 per thermostat, plus an annual monitoring/maintenance fee of \$200-\$300 per year. The results show that with these measure assumptions, a measure life of close to 5 years is needed for cost effectiveness. The measure data including benefit cost ratios are shown in Table ES 2.

ES 2 – Cost Effectiveness for WEPT in Portable Classrooms (Units are Per Square Foot of Floor Area)							
		~			Annual		
		Site	Site	Capital	O&M		TRC Net Levelized
	Measure	Savings	Savings	Cost	Cost	TRC B/C	Cost (Net of All
Measure	Life	(kWh)	(therms)	(\$/unit)	(\$/unit)	Ratio	Benefits) in mills/kWh
WEPT	1.0	1.7	0.0	0.64	-0.011	0.2	362.2
WEPT	3.0	1.7	0.0	0.64	-0.011	0.7	83.8
WEPT	5.0	1.7	0.0	0.64	-0.011	1.2	28.2
WEPT	7.0	1.7	0.0	0.64	-0.011	1.6	4.5
WEPT	9.0	1.7	0.0	0.64	-0.011	1.9	-8.6
WEPT	11.0	1.7	0.0	0.64	-0.011	2.3	-16.9

The savings values can be used to estimate regional potential, by applying them to square footage of applicable building floor space. The per-unit savings values range from 0.32 kWh/sf (small office with heat pump) to the 1.7 kWh/sf in school portables. WEPT is applicable to a narrow range of commercial buildings, including school portables, small offices, small retail, lodging, and other health facilities. Methodologies and selected applicability assumptions from the Sixth Power Plan were used to roll up the unit savings into BPA's share of regional potential, shown in Table ES 3.

ES 3	– Total BPA Savings	Potential	by Comme	ercial Building	Туре	
	<u>5 Year I</u>	Potential aN	<u>AW</u>	<u>20 Year I</u>	Potential aN	<u>AW</u>
	Retrofit	New	Total	Retrofit	New	Total
TOTAL	0.65	0.09	0.73	4.17	0.55	4.73

This report summarizes available information regarding WEPT and provides some initial potential and cost-effectiveness estimates. The results of early pilot studies and field test indicate promising energy savings (32-47% in small commercial building applications). However, continued research and evaluation are needed to better understand the savings, applications, and costs for WEPT. As with any controls or commissioning type measure, it is often difficult to ensure reliable savings. WEPT has an advantage of being targeted for small, well defined applications (e.g., single meter) which enable quality M&V.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 8 of 33

# **1** Introduction

## Objective

The objective of this report is to provide a summary of available energy efficiency related information regarding the web-enabled programmable thermostat (WEPT). In addition, the total regional energy efficiency potential (and BPA share) is estimated based on available data. These estimates are provided as a proxy to indicate the relative magnitude of the measure's potential.

## Background

The WEPT technology makes it possible to adjust HVAC setpoints and schedules from a remote location. This feature can save energy in all geographical locations in small commercial buildings with single zone packaged or split systems. It is a bridge between stand-alone thermostats and a direct digital (DDC) system.

WEPT is a good fit for small commercial buildings with single zone systems where the building owner or maintenance team resides at a remote location. The WEPT technology enables building owners to much more effectively monitor and control temperature setpoints. Benefits of WEPT include cost savings from reduced energy consumption as well as possible maintenance labor savings.

One of the primary applications for the WEPT technology is school classroom portables. These units are often individually metered (or several classrooms on one meter), and they are notorious for having thermostats incorrectly programmed, reset, or set to run full time. Therefore, BPA is conducting research to verify savings for these applications. Other potentially good applications are places of assembly such as movie theaters and small retail spaces remotely by a property management company.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 9 of 33

# 2 WEPT Technology

## **Technology Description**

Web-enabled programmable thermostats (WEPT) are devices that allow users to modify temperature set points and HVAC controls remotely. WEPT applies to medium and small commercial buildings); this type of facility usually doesn't have a digital (DDC) system. Typically, they are buildings less than 100,000 square feet, but vendors and installers generally target buildings less than 40,000 square feet (Neiman, 2011). Note that WEPT are information and control devices that require human input to achieve savings. A diagram of one WEPT configuration is shown in Figure 1.



Figure 1 – WEPT Configuration (Source: PowerMand)

## How It Saves Energy

Thermostats in general can help reduce energy consumption in a building by controlling HVAC systems to run less during unoccupied times. However, because energy savings depend on setting the unoccupied times and occupants are rarely responsible for reducing energy use, these settings are seldom a priority. The WEPT enables much easier access to the thermostat settings and can result in more optimized settings and higher energy savings. However, the persistence of the savings relies on someone monitoring the settings, either through a service contract or an energy manager.

For measurement and verification purposes, it is best if the WEPT measure is utilized with single-zoned systems without sensors or variable air volume systems.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 10 of 33

## **Competing or Overlapping Technologies**

The Pacific Northwest has a variety of efforts underway to improve the energy performance of rooftop HVAC systems. Better thermostat control, including the WEPT technology, can be an important aspect of optimizing rooftop system energy use. Measures such as Demand Controlled Ventilation, Energy Star rating, or other efforts that impact the HVAC energy consumption could impact the total savings available to WEPT. Regional savings potential for rooftop units are outlined in the Northwest Power and Conservation Council's 6<sup>th</sup> Power Plan (Sixth Plan) as 51 average megawatts<sup>1</sup>.

Additionally, a well-monitored standalone programmable thermostat has the potential to compete with WEPT. For both, energy savings are a result of temperature setbacks. However, the webenabled component of WEPT allows a resource manager to correct programming in real time and as needed from a remote location, which could result in deeper and more persistent savings.

Based on U.S. Department of Energy estimates, programmable thermostats save one percent of energy consumption per degree set-back per eight hours. Therefore, a thermostat set back by  $10^{\circ}$  each night, or up by  $10^{\circ}$  for eight hours each day during the cooling season, can be expected to produce a 10 percent annual energy savings (Karr, 2010). Higher savings will occur in more extreme climates.

The WEPT thermostats covered in this report do not include wireless pneumatic thermostats (WPT). WPT is a viable option for HVAC setback savings in larger commercial buildings with pneumatic control systems.

## **Commercial Availability**

There are a variety of components associated with WEPT, from the thermostat alone to a full package that includes the thermostat as well as all communicating equipment, data storage, and monitoring services. Two key cost drivers are the number of gateways that are installed and data hosting fee; this system design not only affects the cost, but it can also affect how easy it is to program the thermostats remotely. A few of these options are summarized below:

- DreamWatts
- Honeywell T7300
- Proliphix Uniphy Professional Series

#### Dreamwatts

PowerMand, Inc. offers a packaged called DreamWatts that includes software, hardware, and service for automating small commercial building HVAC. DreamWatts is able to support any communicating thermostat (WEPT), but primarily supports the Robertshaw 982512 and the Temco Controls Tstat5 thermostats. The DreamWatts Solution provides the following:

<sup>&</sup>lt;sup>1</sup> This value comes from the "Summary Tables" Sixth Plan commercial supply curve file.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 11 of 33

- ZigBee(R) radio-enabled thermostats
- Internet gateway (called DreamWay)
- Commercially hosted data center
- Any client device with web access (PC / MAC, laptop, smart-phone etc) can be used to access a DreamWatts account, modify settings, create and maintain custom energy management profiles, examine monitored data and manage alerts.
- All communication is bi-directional

#### Supported Thermostats

RobertShaw 9825I2 Deluxe Programmable Thermostat



Temco Controls Tstat5 Communicating Thermostat



#### Honeywell T7350

The Honeywell T7350 thermostat is very common and is installed in many Northwest commercial buildings. The newest version of the T7350H includes remote communication features. This is the premium model of the 7350D, which does not include internet cabailities. Honeywell plans to offer web communication on more inexpensive models in the future. Communicating Thermostat can be accessed on a network through your PC, via modem. The LonStat® software allows remote adjustment to schedules, set points and overrides through the WebStat controller.

The T7350H is well suited to retrofit applications. It can function as a standalone programmable thermostat initially, or can be upgraded to web control in the future if WebStat gateways are installed. Some building, specifically Beaverton Public Schools, are approaching WEPT in this manner to minimize the initial cost.

#### Proliphix

Proliphix offers their Energy Control Solution (ECS) which is comprised of three components:

Energy Manager Software

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 12 of 33

- Internet-Managed Thermostats
- Monitoring Services

#### <u>IMT550c/w</u>

The IMT 550 is the newest version of the Proliphix Network Thermostat. The IMT550w connects to a data network through 802.11b/g WiFi. The IMT550c can also connect via wired Ethernet for traditional installation or in areas where WiFi signal strength may be degraded by environmental influences. The IMT550 Network Thermostats provide remote monitoring and control of temperature and humidity. The IMT550 thermostats can handle up to 3 stages of heat and 2 stages of A/C.

The IMT550 supports three external wired sensors which can be used to sense temperature or dry contact closures from external equipment. Each of these sensors can provide independent alarms via email or text message notification when pre-set threshold conditions are exceeded. Two auxiliary relays are also supported to enable customers to control additional equipment.



Uniphy Professional Series

Un*ip*hy Professional Series, models NT120, NT130, NT150, and NT160, are the original Proliphix web-enabled thermostats for commercial applications. Facility managers can remotely manage network thermostats over the Internet using a Web browser. The thermostats support dual-stage, fossil fuel or heat pump (with auxiliary heat) HVAC systems and derive power via Ethernet ("e" designation) or via HVAC system ("h" designation). The thermostat can support two external wired sensors.

These thermostats feature internet browser-based configuration and control over a secure Ethernet connection (no wi-fi). In addition to remote configuring and monitoring, the thermostats have the ability to deliver e-mail status alerts.

There are numerous other brands and manufacturers of WEPT devices and supporting systems, including Ecobee, Bay Controlls, LLC, and X300 (ControByWeb.com). Most of these are being marketed to the residential market but could also be used or adapted for small commercial applications.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 13 of 33

# 3 Measure Data

## **Measure Savings**

Savings estimates are provided in Table 1. The range of savings is 10-60% of space conditioning energy consumption, which is both a large magnitude and range of potential savings. While these savings are not based on rigorous whole building modeling studies, they have been validated by individual pilot programs.

Table 1 - WEPT Savings Estimate by Manufacturer							
Manufacturer	Percent Savings	Heat Type	Source	Info			
Honeywell	30%	Various	Specification Sheet	http://customer.honeywell.com/techlit/p df/63-0000s/63-9093.pdf			
DreamWatts	10-15%	Rooftop units	Portland State Business Accelerator Building	http://PowerMand.com/case-studies			
DreamWatts	33%	Rooftop units	MacDonald-Miller Lower Building, Seattle	David Nieman, MMFS			
Proliphix	20%	Various	AAA Case Study	http://www.proliphix.com/Collateral/Do cuments/English- US/case_studies/CSC(AAA)Case%20St udy_Rev1.pdf			
Proliphix	40-60%	Electric	Evergreen School District	David Cone, Evergreen School District			

One of the best pilot studies for WEPT in the Northwest was the Evergreen School District in Vancouver, Washington. The school district installed web-enabled thermostats on 30 electrically heated portable classrooms buildings (60 classrooms). Based on a Measurement and Verification calculator, savings in these school portables were between 40 and 60% of total electricity consumption. This represents about 1900 kWh per portable unit, or about 1.7 kWh per square foot of portable floor space.

A more detailed description of the program and its results is included in a subsequent section.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 14 of 33

Figure 2 shows estimated energy savings for WEPT installation in different climate regions on a nationwide basis (source: Honeywell). These graphs show that WEPT can save up to 13% of heating energy and up to 18% of cooling energy in the Northwest.



Figure 2 – Heating and Cooling Savings from WEPT (Source: Honeywell)

## **Measure Life**

The thermostat will last about 15 years. However, since this measure includes a heavy behavioral and monitoring component, the measure life will depend more on utility program design or the long term monitoring contract, rather than the equipment life. An estimated minimum 4-5 year measure life may be required for cost effectiveness.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 15 of 33

## **Measure Costs**

Potential costs for WEPT installation vary not only by vendor and model, but also by building type, dealer markup, contractor and volume pricing. Below are equipment cost estimates from three primary vendors, Proliphix, PowerMand and Honeywell. Based on the data from these three manufacturers, the installed cost of a WEPT system ranges between \$500 and \$1000 per thermostat, plus an annual monitoring/maintenance fee of \$200-\$300 per year. Table 2 summarizes the price points for major manufactures included in this report. Note that most web-enabled system requires a centralized gateway, with the exception of the Proliphix system.

Table 2 - WEPT Cost Estimate by Manufacturer							
Manufacturer	Thermostat Model	Thermostat Cost	Gateway Cost	Thermostats per Gateway	Per Unit Installed Cast	Annual Subscription (Per Installation)	
Powermand/ DreamWatts	RobertShaw 9825i2	\$200	\$300	10	\$500-\$765	\$200-\$300	
Proliphix	IMT550c, IMT550w	\$545-\$595	N/A	N/A	\$500-\$1000	\$200-\$300	
Honeywell	7350H	\$500	\$1,000	20	\$500-\$1000	\$0	

Below is a more detailed description of specifics and installed cost for each manufacturer.

#### **PowerMand/DreamWatts**

PowerMand's DreamWatt system consists of three main components: a thermostat, an Internet Gateway (DreamWay) that collects thermostat data using the ZigBee platform and PowerMand's commercially hosted data center services. Each component of the WEPT system has an associated base cost:

- PowerMand predominantly uses a RobertShaw 9825i2 communicating thermostat at a cost of \$200.
- The Internet Gateway costs \$300 and can operate up to 10 thermostats.
- The annual subscription fee for the total installation costs an average of \$200-\$300 per year.

Installation costs are highly variable and must consider factors specific to each building. However, PowerMand provided the following cost information for two recent installations:

1) 14 thermostats and two DreamWay gateways were installed for a total cost of roughly \$7000, for an installed cost of \$500 per unit.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 16 of 33

2) 23 thermostats and two DreamWay gateways were installed for a total cost of roughly \$17,541, for an installed cost of \$765 per unit.

### Proliphix

Proliphix thermostats have an internal gateway and can be wired directly to an Ethernet connection. Proliphix thermostats were used in the Evergreen Public Schools, where estimated installed costs were \$625 per unit. However, final installed cost was roughly \$1,150 per thermostat. Thermostat-only prices are shown below:

- IMT550c \$545
- IMT550w \$595

Based on the data from these two manufacturers, the installed cost of a WEPT system ranges between \$500 and \$1000 per thermostat, plus an annual monitoring/maintenance fee of \$200-\$300 per year.

#### Honeywell

Honeywell manufactures the 7350H that is capable of web communication. This is the webenabled version of the 7350D model. The estimated cost for the equipment is \$500 per thermostat, which is a \$100 cost premium over the 7350D. A WebStat gateway is required (\$1000) and can be connected to 20 thermostats. Honeywell differs from other vendors in that there is no annual service fee and the software for building management is included (Nieman, 2011).

## Other Cost-Effectiveness Parameters

Measure cost-effectiveness depends primarily on incremental capital cost, savings, and life. Below are brief descriptions of the other cost-effectiveness parameters used in the Council's ProCost model to determine regional (Total Resource Cost) cost effectiveness.

#### Load Shapes

The following load shapes were used in PROCOST for retrofit and new measures:

- EXCOMM Existing Shell and HVAC Measures
- NEWCOMM New Shell and HVAC Measures

#### **Operation and Maintenance Cost or Savings**

As indicated in Table 2, WEPT requires (in some cases) an annual subscription fee. For this analysis we used the average of the range, or \$250 per year.

There is also a maintenance cost savings for using WEPT by avoiding trips by an off-site maintenance person to visit the site and re-set the thermostats. For this analysis it is assumed

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 17 of 33

that two trips can be saved at a cost of 200 per trip (total = 400 per year). This results in a net O&M savings of 150 per year.

#### **Non-Energy Benefits**

There were no non-energy benefits quantified for this analysis.

#### **Periodic Replacement Costs**

There were no periodic replacement costs quantified for this analysis.

#### **Gas Savings**

The initial and best applications for WEPT are electrically heated, single-zone small commercial buildings. Therefore, gas savings are not quantified in this analysis. It is possible that future applications could include facilities with high cooling loads and gas heat, which would result in a need to quantify the gas savings.

#### **Avoided Cost**

The avoided cost used is the "Sixth Plan Mid-C Final" price forecast used in the Sixth Plan and approved by the RTF. In addition, the Risk Mitigation Credit of \$43/MWh was used. This credit is added to the avoided cost and is representative of retrofit measures.

## **Cost Effectiveness**

The Council's ProCost model was used to gain some initial insight into possible cost effectiveness ranges for WEPT. Table 3 summarizes cost-effectiveness for the WEPT measure in portable classrooms. In this example, the site savings are 1.7 kWh/sf per year, the cost is 0.64 \$/sf, and the annual O&M savings is 0.011 \$/sf per year. In this example, a range of measure life years was selected. The results show that with these measure assumptions, a measure life of close to 5 years is needed for cost effectiveness.

Table 3 – Cost Effectiveness for WEPT in Portable Classrooms(Units are Per Square Foot of Floor Area)							
		Site	Site	Canital	Annual O&M		TRC Net Levelized
	Measure	Savings	Savings	Cost	Cost	TRC B/C	Cost (Net of All
Measure	Life	(kWh)	(therms)	(\$/unit)	(\$/unit)	Ratio	Benefits) in mills/kWh
WEPT	1.0	1.7	0.0	0.64	-0.011	0.2	362.2
WEPT	3.0	1.7	0.0	0.64	-0.011	0.7	83.8
WEPT	5.0	1.7	0.0	0.64	-0.011	1.2	28.2
WEPT	7.0	1.7	0.0	0.64	-0.011	1.6	4.5
WEPT	9.0	1.7	0.0	0.64	-0.011	1.9	-8.6
WEPT	11.0	1.7	0.0	0.64	-0.011	2.3	-16.9

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 18 of 33

This example was selected since the school portables case study carries the highest degree of confidence. In other applications, the preliminary estimates of savings are significantly lower, and would require a longer measure life for cost-effectiveness. Also consider that the cost estimate of \$1150 per thermostat was used, which reflects the actual installed costs for the pilot study (Evergreen). However the projected costs are likely to be slightly lower, which will improve the cost-effectiveness. Other factors including increased value of avoided O&M would also increase the value of this measure.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 19 of 33

# 4 Market

## Applications

WEPT applies specifically to small to medium (less than 100,000 square feet) commercial facilities without direct digital (DDC) systems or variable air volume (VAV). Additionally, WEPT devices can only be installed in single zone applications with an existing wall thermostat Larger buildings with many zones could also be applicable, but must have individual zones with their own thermostat (Nieman, 2011, Needman, 2010). Electric savings are greatest in buildings with electric heat.

School portables and small-medium office buildings are the most logical applications for WEPT devices. Most case studies in the region are in these two building types. However, there are other buildings that meet the criteria outlined above from the Sixth Plan.

- Small retail
  - Strip malls
  - Small stores within larger enclosed mall environments
  - Space managed by an off-site property manager
  - Bank branch locations
- Assembly
  - Assembly common spaces
- Assembly
  - Common areas of nursing homes, doctor's offices

Specific applicability assumptions for the potential calculation are outlined in the Energy Efficiency Potential Section.

## **Market Barriers and Opportunities**

WEPT devices are commercially available. The market channel is from the manufacturer to controls companies, to contractors, to the building owner. There are few barriers for obtaining the product. For example, Powermand is the vendor for the DreamWatts control system. They have distribution contracts with several contractors to design and install the system in buildings.

However, there is a barrier in terms of consumer acceptance and persistent savings. Many building owners do not see the inherent value in the web-enabled component of a thermostat. It is unclear if this is because building managers are uninterested in managing the setpoints, or simply unaware of the difference between a web-enabled thermostat and a programmable thermostat. Also, regular monitoring of settings is required for optimal savings. MacDonald Miller Facility Solutions is pioneering the business model of an HVAC service contractor actively marketing WEPT for persistent energy savings, improved comfort and remote trouble-shooting of rooftop units.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 20 of 33

# **5 Energy Efficiency Potential**

## **Codes and Standards**

Programmable thermostats capable of nighttime setbacks are required by code for new construction or major retrofits in the Northwest. Similarly, in larger commercial spaces, DDC systems are required.

Codes are consistent between states in the Northwest. Below is an excerpt from the State of Washington non-residential building code, applicable in 2010:

1412.4 Setback and Shutoff: HVAC systems shall be equipped with automatic controls capable of accomplishing a reduction of energy use through control setback or equipment shutdown during periods of nonuse or alternate use of the spaces served by the system. The automatic controls shall:

a. Have a minimum seven-day clock and be capable of being set for seven different day types per week,

b. Be capable of retaining programming and time setting during loss of power for a period of at least ten hours, and

*c.* Include an accessible manual override, or equivalent function (e.g., telephone interface), that allows temporary operation of the system for up to two hours.

Codes do not require permanent setback operation or web-enabled capability. Therefore, all savings from WEPT are above current codes, or will result in capturing a higher degree of the savings intended by the code.

## Applicability

WEPT is potentially applicable to a wide range of small commercial spaces. There are four main criteria for determining the best spaces for maximum electricity savings:

- Less <100,000 square feet (although most vendors believe <40,000 square feet is ideal)</li>
- Single zone
- Existing wall thermostat
- Electric or heat pump heating

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 21 of 33

Additionally, measure savings come from effective management and are most effective when staff regularly monitors settings for optimal savings. Examples include, school portable classrooms, small retail spaces that are managed by a property company and theater chains with a resource manager. Specific applicability factors are addressed in the potential section.

## **Recent Experience**

#### **Evergreen Public Schools – Vancouver, WA**

Evergreen Public School district installed WEPT devices in 60 portable classrooms in 2009. The district was initially leaning towards Honeywell as their vendor, but chose Proliphix. The primary benefit was a global controller and access to data from each device. Savings were estimated at 45-65% based on a linear regression forecast tool. There is no record of the model or settings of the thermostats previously in the building. In this example, the savings were 91,917 kWh per year (47% of consumption) in 30 portables with a total of 60 classrooms. Figure 3 shows the plot of baseline data (average kWh per day, vs. HDD per day) compared with the post data.

While the District considers the program a great success, there were several key lessons learned. First, there were installation problems coordinating between the internal IT department and HVAC technicians doing the installation. Also, costs were higher than initially budgeted. The initial cost was estimated at \$625 per unit, but the actual cost was about \$1,150. There were large energy savings, but a spike in morning in demand resulted from all units being programmed with the same start time. After this was discovered, staggering the start times solved this problem.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 22 of 33



Figure 3 – Energy Consumption per HDD Regression for Evergreen Schools (Koran, 2010)

#### Portland State Business Accelerator – Portland, OR

A recent Portland State University WEPT application includes 47,000 square feet of office space for 30 tenants. At the time of the pilot program, there were 30 individual rooftop units and 65 programmable thermostats.

Robertshaw 9825i2 web-enabled thermostats and two DreamWay gateways were installed on 14 common area thermostats, which represented 22% of the total building square footage. Two HVAC technicians installed the units in half a day and the total installed cost was roughly \$7000.

Areas were defined with different temperature setpoints depending on usage. Two different general modes were created, one for occupied and unoccupied areas. Occupied areas were also sub-divided, with differing setpoints given to hallways, conference rooms and other common areas. Work holidays were scheduled and updated using unoccupied modes. Real-time temperature monitoring allowed management to adjust setpoints and schedules based on verified system run-times. Manually overrides in shared conference rooms were possible to adjust for thermal comfort, but only for two hours at a time.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 23 of 33

According to PowerMand, the energy related costs were reduced 13% in the first 6 months using DreamWatts, or \$.02 a square foot per month. It was also estimated that the building management saved an additional day of staff time in not having to reprogram thermostats.

#### MacDonald-Miller – Seattle, WA

MacDonald-Miller Facility Solutions installed the DreamWatts system in the Lower Building in Seattle, WA. 14 thermostats controlled single zone rooftop units and produced a 33% annual electric savings.

## **Market Saturation**

Market saturation of WEPT is low in the Northwest, primarily due to low consumer acceptance and cost barrier for DDC retrofits in larger commercial buildings. While there are likely some WEPT devices installed in the region, for estimates of potential, saturations in applicable buildings are assumed to be zero.

## Achievable Potential Estimates

While manufacturers claim large savings and wide applicability, savings from WEPT installations are difficult to verify and deem indefinitely. A responsible energy manager or service contract is necessary, so savings potential estimates for the region rely on the limited program experience in the Northwest. The calculated regional savings assumes that there is regular monitoring of settings for persistent savings over the measure life.

The best program example is Evergreen Public school district. In conjunction with Clark Public Utilities, Evergreen installed WEPT in 30 portable buildings (two classrooms per building, 60 classrooms). Based on a weather-adjusted linear regression model, there was a 47% savings among all sites  $(91,917 \text{ kWh})^2$ . Note that these savings are for electric heating units, which are common in portable classrooms (Cone, 2010). The average size of the portable classrooms in this pilot study is 900 sf per classroom<sup>3</sup>. Therefore, the total conditioned space is 54,000 square feet, which makes the total savings 1.7 kWh/sq ft for electrically heated portable classrooms.

The savings estimates generated from Evergreen Public Schools test can be used to help estimate the regional potential, by applying it to square footage of portable buildings in the region. The potential savings are large on a square footage basis, but only applicable to a very narrow range of commercial buildings, and require a dedicated resource manager that can control the WEPT devices and monitor their status. Therefore, for this analysis, it is assumed that savings seen in the Evergreen Public Schools are applicable to school portables only.

In other building types, a percentage savings from baseline was used to calculate potential savings. Electric and heat pump systems maximize electric WEPT savings. Energy Use Intensity

<sup>&</sup>lt;sup>2</sup> Source: "Evergreen School District Portable Classroom Thermostats Analysis-10-5-10.xlsx"

<sup>&</sup>lt;sup>3</sup> On average, a portable classroom is 900 square feet (Holden, 2005, Tanner, 2000).

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 24 of 33

(EUI) is shown in Table 4 for each commercial building category in the Sixth  $Plan^4$ . Retrofit savings in school portables are custom based on the Evergreen Public Schools data, while other building types use a 32% savings from the Dreamwatts installation in the MacDonald-Miller Building in Seattle<sup>5</sup>.

Table 4 – Savings by Building Type, Retrofit						
	Baseline Consumpt	tion (kWh/sq.ft.)	Percentage	Savings (kWh/sq. ft.)		
	Electric Heat	Heat Pump	Assumption	Electric Heat	Heat Pump	
Large Office	2	1		0	0	
Medium Office	2	1		0	0	
Small Office	2	1	32%	0.64	0.32	
Big Box	2	1		0	0	
Small Box	2.2	1.1	32%	0.704	0.352	
High End	3	1.5	32%	0.96	0.48	
Anchor	3	1.5		0	0	
K-12	3	1.5	CUSTOM	1.7	0.71	
University	4	2		0	0	
Warehouse	2	1		0	0	
Supermarket	5	2.5		0	0	
Mini Mart	4	2		0	0	
Restaurant	4	2		0	0	
Lodging	4	2	32%	1.28	0.64	
Hospital	6	3		0	0	
Other Health	5	2.5	32%	1.6	0.8	
Assembly	4	2		0	0	
Other	4	2		0	0	

<sup>&</sup>lt;sup>4</sup> These values come from the "Commercial Master" supply curve file.

<sup>&</sup>lt;sup>5</sup> Source: "Lower Building Report 2010.xls"

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 25 of 33

Table 5 shows WEPT savings for new construction, separated by commercial building type. A lower percentage savings is assumed for new buildings (15%) as compared to retrofit project. This is based on the Portland State Business Accelerator Building case study. Again, savings for school portables are custom.

Table 5 – Savings by Building Type, New Construction							
	Baseline Consumpt	ion (kWh/sq.ft.)	Percentage Savings	Savings (kWh/sq. ft.)			
	Electric Heat	Heat Pump	Assumption	Electric Heat	Heat Pump		
Large Office	2	1		0	0		
Medium Office	2	1		0	0		
Small Office	2	1	15%	0.3	0.15		
Big Box	2	1		0	0		
Small Box	2.2	1.1	15%	0.33	0.165		
High End	3	1.5	15%	0.45	0.225		
Anchor	3	1.5		0	0		
K-12	3	1.5	CUSTOM	1.7	0.71		
University	4	2		0	0		
Warehouse	2	1		0	0		
Supermarket	5	2.5		0	0		
Mini Mart	4	2		0	0		
Restaurant	4	2		0	0		
Lodging	4	2	15%	0.6	0.3		
Hospital	6	3		0	0		
Other Health	5	2.5	15%	0.75	0.375		
Assembly	4	2		0	0		
Other	4	2		0	0		

Table 6 shows percentages in each of the Sixth Plan commercial building categories that are applicable to WEPT savings. There are separate applicabilities for electric and heat pump heat baseline consumption. Applicability refers to the percentage of square footage in that building category that is applicable to the shown savings. For example, 5.3% of Small Box Retail square footage in the region can technically achieve savings from WEPT using heat pumps as a baseline (0.352 kWh/sq.ft.).

These percentages are calculated using heat type percentage from the Sixth Plan<sup>6</sup> and single zone and thermostat percentages from NEEA's 2006 *Baseline Characteristics of the 2002-2004* 

<sup>&</sup>lt;sup>6</sup> These values come from the Characteristics tab in the "Commercial Master" commercial supply curve file.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 26 of 33

*Nonresidential Sector: Idaho, Montana, Oregon, and Washington.* The percent thermostats refers to the percentage of floor space that is not controlled by DDC systems (NEEA, 2006). As stated previously, commercial spaces must be electrically heated, single zoned, and controlled by a thermostat to be applicable to WEPT savings. Therefore, the applicability factor is calculated by:

Heat Type % **x** Thermostat % **x** Single Zone % = Applicability Factor

K-12 applicability factors differ slightly from this formula. The applicability factors represent the percentage of school square footage that is in portable classrooms only. It was calculated that 8.3% of school square footage in the region is in school portable. This assumption reflexes the high applicability for WEPT in schools and is confirmed by discussions with school facility managers in the Northwest (Cone, 2010; Miller, 2010; Tyler, 2010).

Table 6 – Applicability Factors by Building Type							
		Percer	nt of Buildings		тот	TOTAL	
	Electric Heat	Heat Pump	Thermostat Control	Single Zone	Electric Heat	Heat Pump	
Large Office	52.1%	9.5%	45.0%	48.3%			
Medium Office	26.3%	23.0%	45.0%	48.3%			
Small Office	21.3%	21.6%	45.0%	48.3%	5%	5%	
Big Box	2.3%	18.3%	45.0%	84.7%			
Small Box	18.9%	13.9%	45.0%	84.7%	7%	5%	
High End	16.8%	9.4%	45.0%	84.7%	6%	4%	
Anchor	18.8%	28.8%	45.0%	84.7%			
K-12	CUST	ТОМ	CUSTON	M	8.3%		
University	9.3%	9.3%	45.0%	27.7%			
Warehouse	9.5%	8.1%	45.0%	46.2%			
Supermarket	14.0%	17.6%	45.0%	88.2%			
Mini Mart	12.4%	5.6%	45.0%	88.2%			
Restaurant	8.6%	10.5%	45.0%	100.0%			
Lodging	38.6%	24.3%	45.0%	63.2%	11%	7%	
Hospital	3.0%	1.0%	45.0%	5.0%			
Other Health	32.8%	7.6%	45.0%	28.7%	4%	1%	
Assembly	12.8%	13.1%	45.0%	74.0%			
Other	12.7%	13.0%	45.0%	85.8%			

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 27 of 33

Table 7 shows a matrix of savings, life and applicability factors for WEPT in retrofit projects under different heat types. Table 8 is a similar matrix for new construction. As programs improve, data from other sectors can be added.

Table 7 – WEPT Matrix, Retrofit								
Electric Heat Heat Pump								
		Life	Savings (kWh/sq. ft.)	% Applicability	Life	Savings (kWh/sq. ft.)	% Applicability	
Large Office	Retrofit	15	0	0.0%	15	0	0.0%	
Medium Office	Retrofit	15	0	0.0%	15	0	0.0%	
Small Office	Retrofit	15	0.64	4.6%	15	0.32	4.7%	
Big Box	Retrofit	15	0	0.0%	15	0	0.0%	
Small Box	Retrofit	15	0.704	7.2%	15	0.352	5.3%	
High End	Retrofit	15	0.96	6.4%	15	0.48	3.6%	
Anchor	Retrofit	15	0	0.0%	15	0	0.0%	
K-12	Retrofit	15	1.7	4.2%	15	0.71	4.2%	
University	Retrofit	15	0	0.0%	15	0	0.0%	
Warehouse	Retrofit	15	0	0.0%	15	0	0.0%	
Supermarket	Retrofit	15	0	0.0%	15	0	0.0%	
Mini Mart	Retrofit	15	0	0.0%	15	0	0.0%	
Restaurant	Retrofit	15	0	0.0%	15	0	0.0%	
Lodging	Retrofit	15	1.28	11.0%	15	0.64	6.9%	
Hospital	Retrofit	15	0	0.0%	15	0	0.0%	
Other Health	Retrofit	15	1.6	4.2%	15	0.8	1.0%	
Assembly	Retrofit	15	0	0.0%	15	0	0.0%	
Other	Retrofit	15	0	0.0%	15	0	0.0%	

Table 8 – WEPT Matrix, New Construction									
Electric Heat Heat Pump									
		Life	Savings (kWh/sq. ft.)	% Applicability	Savings cability Life (kWh/sq. ft.) % Ar				
Large Office	New	15	0	0.0%	15	0	0.0%		
Medium Office	New	15	0	0.0%	15	0	0.0%		
Small Office	New	15	0.3	4.6%	15	0.15	4.7%		
Big Box	New	15	0	0.0%	15	0	0.0%		
Small Box	New	15	0.33	7.2%	15	0.165	5.3%		
High End	New	15	0.45	6.4%	15	0.225	3.6%		
Anchor	New	15	0	0.0%	15	0	0.0%		
K-12	New	15	1.7	4.2%	15	0.71	4.2%		
University	New	15	0	0.0%	15	0	0.0%		
Warehouse	New	15	0	0.0%	15	0	0.0%		
Supermarket	New	15	0	0.0%	15	0	0.0%		
Mini Mart	New	15	0	0.0%	15	0	0.0%		
Restaurant	New	15	0	0.0%	15	0	0.0%		
Lodging	New	15	0.6	11.0%	15	0.3	6.9%		
Hospital	New	15	0	0.0%	15	0	0.0%		
Other Health	New	15	0.75	4.2%	15	0.375	1.0%		
Assembly	New	15	0	0.0%	15	0	0.0%		
Other	New	15	0	0.0%	15	0	0.0%		

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 29 of 33

Sixth Plan estimates of total square footage were applied to the measure matrix in Tables 7 and 8. Table 9 shows the 20 year savings potential by building type. Note that these are estimates of Technical Potential. The potential is also the BPA share of regional potential, which is assumed to be 42% for commercial measures. The Council often uses an 85% achievability factor, which is not included in this estimate. Figures 4 and 5 show annual technical potential using a ramp rate similar to the Sixth Plan Emerging Technologies ramp rate. In this case the ramp rate is applied as a percent of the total potential acquired each year.

Luste > Louis Dilli Suttings Lotentain of Commercial Sunaing Life						
	<u>5 Year Po</u>	tential aM	W	<u>20 Year Po</u>	tential aM	W
	Retrofit	New	Total	Retrofit	New	Total
Large Office	0.00	0.00	0.00	0.00	0.00	0.00
Medium Office	0.00	0.00	0.00	0.00	0.00	0.00
Small Office	0.04	0.01	0.05	0.29	0.05	0.33
Big Box	0.00	0.00	0.00	0.00	0.00	0.00
Small Box	0.11	0.01	0.12	0.72	0.06	0.78
High End	0.03	0.00	0.03	0.20	0.02	0.22
Anchor	0.00	0.00	0.00	0.00	0.00	0.00
K-12	0.17	0.04	0.21	1.10	0.25	1.34
University	0.00	0.00	0.00	0.00	0.00	0.00
Warehouse	0.00	0.00	0.00	0.00	0.00	0.00
Supermarket	0.00	0.00	0.00	0.00	0.00	0.00
Mini Mart	0.00	0.00	0.00	0.00	0.00	0.00
Restaurant	0.00	0.00	0.00	0.00	0.00	0.00
Lodging	0.21	0.01	0.22	1.36	0.08	1.44
Hospital	0.00	0.00	0.00	0.00	0.00	0.00
Other Health	0.08	0.02	0.09	0.51	0.10	0.61
Assembly	0.00	0.00	0.00	0.00	0.00	0.00
Other	0.00	0.00	0.00	0.00	0.00	0.00
TOTAL	0.65	0.09	0.73	4.17	0.55	4.73

#### Table 9 – Total BPA Savings Potential by Commercial Building Type

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 30 of 33







Figure 5 – Annual BPA WEPT Savings, New Construction

The total 20 year regional potential for HVAC measures in the Sixth Plan is 304 aMW. Assuming BPA share of 42% (128 aMW), WEPT savings represents 3.7% of HVAC potential in the region.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 31 of 33

# 6. Summary

The use of Web Enabled Programmable Thermostats can save significant amounts of electricity (32-47%) in small commercial building applications, based on recent case studies. As with any controls or commissioning type measure, it is often difficult to ensure reliable savings. WEPT has an advantage of being targeted for small, well defined applications (e.g., single meter) which enable quality M&V.

## **Research Needs**

This report summarizes available information regarding WEPT and provides some initial potential and cost-effectiveness estimates. The results of early pilot studies and field test indicate promising energy savings. However, continued research and evaluation are needed to better understand the savings, applications, and costs for WEPT. These research areas may include:

- Total BPA share of regional potential for WEPT is estimated to be 5.6 aMW. This is small relative compared to total HVAC potential in the Sixth Plan. However, niche applications such as school portable are viable and cost effective.
- Calculators WEPT is not likely to become a "deemed" measure. The best approach is to continue to develop and support calculators that utilize pre and post data.
- Persistence of Savings and Measure Life The definition of this measure will also depend on the program specifications and requirements, specifically that the consumption be continuously monitored over its life. This could possibly require a maintenance contract.
- Baseline Data Baseline data for other portable classrooms could be obtained to improve the confidence in evaluating pre and post energy consumption.
- Additional Markets A limited set of market applications were evaluated in this review. It is possible that addition building sectors, or portions of these sectors are good applications and will need evaluation.
- Additional Climates The savings values in this review are based on cased studies in heating zone 1. However, it is likely that savings values would be higher in the other heating zones.

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 32 of 33

## 7 References

Bonneville Power Administration, Koran, W.E. (2010): Energy Savings for Thermostats in School Portables Workbook.

Cone, David. Resource Conservation Manager, Evergreen School District. Personal Conversation. Nov 21, 2010.

Holden, R (2005): Needs Assessment. http://www.shelbycountytn.gov/FirstPortal/dotShowDoc/Government/CountyServices/Adminan dFinance/nac\_050121.pdf

Honeywell. (2010).T7300 Communicating Commercial Programmable Thermostat. Online at: http://customer.honeywell.com/techlit/pdf/63-0000s/63-9093.pdf

Karr, Marcia (2010): HVAC: Wireless Technology Solution to Pneumatic Controls. WSU Extension Energy Program. Nov 21, 2010.

Koran, William. Senior Engineer, Quantum Energy Services and Technologies. Personal Conversation. Nov 21, 2010.

Miller, Lindy. Private/Nonpublic School Data Specialist, State of Montana Office of Measurement and Accountability. Personal Conversation. Nov 17, 2010.

Montgomery County Public Schools (2004): Remote Control for Portable Classroom HVAC http://www.montgomeryschoolsmd.org/departments/maintenance/shadygrove/ems/pdf/Remote% 20Control%20for%20Portable%20Classroom%20HVAC.pdf

Needham, Paul (2010). Director, Product Marketing PowerMand, Inc. Personal Conversation. Dec 28, 2010.

Neiman, David. Senior Building Performance Engineer, MacDonald-Miller Facility Solutions, Inc. Personal Conversation. Jan 5, 2010.

Northwest Power and Conservation Council. 6th Power Plan Supply Curve Files. December 10, 2009. Available online:

http://www.nwcouncil.org/energy/powerplan/6/supplycurves/default.htm

Northwest Power and Conservation Council. Sixth Northwest Conservation and Electric Power Plan. Feb 2010. Online at: http://www.nwcouncil.org/energy/powerplan/6/default.htm

Attachment EERMC 1-8 Docket No. 4296 In re: 2012 System Reliability Plan Responses to EERMC's Data Requests – Set 1 Page 33 of 33

PowerMand, Inc. (2010): Case Study: Small Investment Big Savings. Online at: http://PowerMand.com/uploads/123/Case%20Study%20PSBA.pdf

Prolipohix: (2010). Commercial Product Catalog. Available online at: http://www.proliphix.com/buy-product-catalog.htm

State of Montana (2008): K-12 Public Schools Facility Condition Assessment, Final Report. A/E Project #26-30-03.

Tanner, C. (2000a): Minimum classroom size and number of students per classroom. Retrieved November 10, 2002, www.coe.uga.edu/sdpl/research/terrioriality.html

Tanner, C. K., & Lackney, J. (2006): Educational Facilities Planning: Leadership, Architecture, and Management. Boston, MA: Pearson, Allyn and Bacon.

Tyler, Mark. Facilities Coordinator, Oregon Department of Education. Personal Conversation. Nov 17, 2010.

Washington State Legislature (2009): Washington state energy code 2009 edition. Chapter 51-11. Available online: http://apps.leg.wa.gov/WAC/default.aspx?cite=51-11

## Certificate of Service

I hereby certify that a copy of the cover letter and / or any materials accompanying this certificate has been electronically transmitted, sent via U.S. mail or hand-delivered to the individuals listed below.

<u>February 1, 2012</u> Date

Joanne M. Scanlon

Docket No. 4296 - National Grid's 2012 System Reliability Plan Report Service List – Updated 12/19/11

Name/Address	E-mail Distribution List	Phone/FAX
Jennifer Brooks Hutchinson, Esq.	Jennifer.hutchinson@us.ngrid.com	401-784-7288
National Grid	Thomas.teehan@us.ngrid.com	
280 Melrose St.	Joanne.scanlon@us.ngrid.com	
Providence, RI 02907	Jeremy.newberger@us.ngrid.com	-
R. Daniel Prentiss, P.C. (for EERMC)	dan@prentisslaw.com	401-824-5150
Prentiss Law Firm		
One Turks Head Place, Suite 380		
Providence, RI 02903		
S. Paul Ryan (for EERMC)	spryan@eplaw.necoxmail.com	
Scudder Parker	sparker@veic.org	
VEIC		
Jon Hagopian, Esq. (Division/AG)	Jhagopian@riag.ri.gov	401-222-2424
Dept. of Attorney General	Dstearns@ripuc.state.ri.us	
150 South Main St.	Sscialabba@ripuc.state.ri.us	
Providence, RI 02903	Acontente@ripuc.state.ri.us	
	mcorey@riag.ri.gov	
	dmacrae@riag.ri.gov	
Jeremy McDiarmid, Esq. (ENE)	jmcdiarmid@env-ne.org	617-742-0054
Environment Northeast		
101 Tremont St., Suite 401	aanthony@env-ne.org	
Boston, MA 02108		
Seth H. Handy, Esq. (ENE)	seth@handylawllc.com	401 626.4839
HANDY LAW, LLC		
42 Weybosset Street		
Providence, RI 02903		

Tim Woolf	twoolf@synapse-energy.com	617-661-3248
Synapse Energy Economics		
22 Pearl Street		
Cambridge, MA 02139		
Bob Fagan	rfagan@synapse-energy.com	
Synapse Energy Economics		
Tim Woof	twoolf@synapse-energy.com	
Synapse Energy Economics		
22 Pearl Street		
Cambridge, MA 02139		
Jerry Elmer, Esq.	JElmer@clf.org	401-351-1102
Conservation Law Foundation		
55 Dorrance Street		
Providence, RI 02903		
Original & 11 copies to be filed w/:	Lmassaro@puc.state.ri.us	401-780-2107
Luly E. Massaro, Commission Clerk	Adalessandro@puc.state.ri.us	401-941-1691
Public Utilities Commission	Anault@puc.state.ri.us	
89 Jefferson Blvd.	Dshah@puc.state.ri.us	
Warwick, RI 02888	Nucci@puc.state.ri.us	