Providence Water Docket 4406

Data Requests of the Division of Public Utilities and Carriers Set 1

- DIV 1-31. Please provide a copy of Providence Water's 2010 IFR Plan and any subsequent updates.
- Response: Attached is a copy of PW's approved 2010 IFR Plan. Hard copies of this plan will be provided to the Commission Clerk and to interveners requesting hard copies. Others will receive a pdf copy of the plan. Also attached is a copy of the plan update that was submitted to the Rhode Island Department of Health on March 1, 2013.



552 Academy Avenue Providence, RI 02908

March 1, 2013

401-521-6300 www.provwater.com

June Swallow Chief, Drinking Water Quality R.I. Department of Health Cannon Building, Room 209 Three Capitol Hill Providence, RI 02908-5097

The Hon, Angel Taveras Mayor

> Boyce Spinelli General Manager

BOARD OF DIRECTORS

Brett P. Smiley Chairman

Joseph D. Cataldi Vice Chairman

Michael L. Pearis Ex-Officio

Michael A. Solomon City Council President

Michael J. Correia City Councilman

Andy M. Andujar Member

Joan S. Badway Member

Carissa R. Richard Secretary

William E. O'Gara, Esq. Legal Advisor

Member

Rhode Island Water Works Assn. New England Water Works Assn. American Water Works Assn. Water Research Foundation

An EPA WaterSense Partner

Only Tap Water Delivers

RE: Updated Infrastructure Replacement Plan

Dear Ms. Swallow,

As requested in RIDOH's December 6, 2012 letter, Providence Water is submitting the attached updated Exhibits 1, 2, 10, 11 and 13 from the 20-year Infrastructure Replacement Plan (Plan) dated December 2010.

The primary difference between the attached and the December 2010 Plan is the addition of \$6 million per year for main replacement/rehabilitation. Providence Water is currently preparing a full rate filing with the Public Utilities Commission (PUC) to be submitted in April 2013 and is requesting a \$6 million dollar increase in IFR funding. It is the intention that the entire \$6 million increase in funding will be completely allocated to main replacement/rehabilitation.

In Providence Water's opinion, the additional \$6 million in additional IFR money is appropriate for the following reasons.

- Providence Water is currently returning the distribution pH to pre-2005 levels in accordance with the pH Transition Implementation Plan. At this time, it is unclear what effect this change will have on our Lead and Copper, and what eventually will be our long term corrosion control strategy.
- Providence Water is still awaiting the complete results from the sequential sampling and the subsequent recommendations from the Expert Panel.
- The additional \$6 million will translate to approximately \$15-\$20 million of main replacement/rehabilitation work per year. This is the maximum amount of work that Providence Water can reasonably manage in one year. Providence Water is concerned that construction work on the distribution in excess of the above stated quantities may substantially increase the probability of water quality issues.
- As the Unidirectional Flushing (UDF), corrosion control, and main replacement/rehabilitation programs progress, Providence Water will continually reevaluate to determine the necessary quantities and locations of mains that require replacement or rehabilitation to best meet the criteria to minimize water quality issues.

Providence Water would like to meet with you to discuss the attached, please call (401-521-6300 x 7291) or e-mail (ggiasson@provwater.com) at your earliest convenience to schedule a time and date to meet.

Attachment: Revised Exhibits 1, 2, 10, 11, and 13

Sincerely,

Gregg Giasson, PE Senior Director of Operations Providence Water Supply Board

cc: Boyce Spinelli Ricky Caruolo Stephen Soito, PE Peter LePage Rich Razza Joe Spremulli Steven Santaniello Paul Gadoury, PE John Phillips, PE

Exhibit 1 Providence Water 20 Year IFR Expenditure Plan Fiscal Years 2011 through 2030

	Total	Budget	Budget	Budget	Budget
	Amount	2011-2015	2016-2020	2021-2025	2026-2030
Raw Water Supply	6,840,000	1,300,000	4,090,000	800,000	650,000
Treatment Plant	87,330,000	45,975,000	38,335,000	1,985,000	1,035,000
Pumping and Storage	11,565,000	1,640,000	3,625,000	2,150,000	4,150,000
Transmission System	20,925,000	5,825,000	4,150,000	8,300,000	2,650,000
Distribution System	352,950,000	63,750,000	89,350,000	96,850,000	103,000,000
Support Systems Facilities	6,055,000	605,000	1,950,000	1,750,000	1,750,000

Total

.

485,665,000

119,095,000 141,500,000

111,835,000

113,235,000

Exhibit 2 Providence Water 20 Year IFR Expenditures

Fiscal Years 2011 through 2030



20 Year Investiment - \$486 Million

Exhibit 10 **Providence Water** IFR Expenditure Plan Fiscal Years 2011 through 2015

Total	Budget	Budget	Budget	Budget	Budget
Amount	2011	2012	2013	2014	2015

RAW WATER SUPPLY

Reservoirs, Dams, and Watershed

	Internet and the second s	the second s				
Regulating Reservoir dam rehabilitation	65,000	15,000		50,000		
Raw Water Booster PS - replace generator	300,000		300,000			···
Large dam Improvements	80,000		50,000	10,000	10,000	10,000
Watershed fencing, fire lanes, property rehabilitation	55,000	15,000	10,000	10,000	10,000	10,000
Raw Water Structures and Conduits				l		
Meter & junction chambers rehabilitation	700,000	300,000	400,000			
60" influent conduits - inspection	50,000		50,000			
90" Influent conduit rehabilitation	50,000		50,000			
Raw Water Supply Total	1,300,000	330,000	860,000	70,000	20,000	20,000

TREATMENT PLANT

Plant Influent and Aerator

			and the second design of the s	and the second se	the state of the second s	The second state in the second state of the se
Influent structure rehabilitation	410,000	80,000		75,000	130,000	125,000
Aerator / Influent actuators and valves replacement	710,000			240,000	330,000	140,000
Influent structure - replace drain and bypass valves	1,090,000			380,000	520,000	190,000
Influent / Effluent aerator conduits Inspect / Rehabilitate	160,000			50,000	50,000	60,000
Aeration basin concrete rehabilitation	800,000		50,000	300,000	300,000	150,000
Aeration basin - replace piping, nozzles, and drain valves	1,200,000			450,000	550,000	200,000
Aerated, Settled, and Filter Influent Conduits	less a second		h		l_	
Settled water conduit - installation of access hatch	100,000		100,000			
Concrete conduits Inspect / rehabilitate	1,100,000			400,000	550,000	150,000
Influent venturis Inspection	500,000			200,000	200,000	100,000
Emergency bypass - clean tunnel and install sluice gate	75,000			75,000		
Chemical Storage, Transfer, and Feed Systems		·			l	1
Ferric system upgrades	250,000			250,000		
Lime system upgrades	900,000			25,000	875,000	
Filters	1	······				
Filter replacement (including valves & piping)	31,200,000	6,600,000	5,000,000	6,500,000	6,600,000	6,500,000
Treatment process studies	960,000	70,000	150,000	545,000	195,000	
Water Quality Study	1,000,000			650,000	350,000	
Inspect wash water system	5,000			5,000		
Building, Support, and Operational Systems				I		
Treatment plant building rehabilitation	250,000	50,000	50,000	50,000	50,000	50,000
PW lab / equipment Improvements	100,000	5,000	20,000	25,000	25,000	25,000
SCADA / Control system upgrades	-160,000	60,000	25,000	25,000	25,000	25,000

25,000

Exhibit 10 **Providence Water** IFR Expenditure Plan Fiscal Years 2011 through 2015

	Total Amount	Budget 2011	Budget 2012	Budget 2013	Budget 2014	Budget 2015
Inspect service water system	5,000			5,000		
Sludge removal and disposal	5,000,000	1,000,000	1,000,000	1,000,000	1,000,000	1,000,000
Treatment Plant Total	45,975,000	7,865,000	6,395,000	11,250,000	11,750,000	8,715,000

PUMPING AND STORAGE

•

Neutaconkanut reservoir rehabilitation	110,000	110,000				
Dean Estates pump station upgrades	1,200,000	450,000	750,000			
Aqueduct reservor - replace 60" valve	150,000			150,000		
Various pump station improvements	80,000		20,000	20,000	20,000	20,000
Storage tanks inspections / improvements	100,000			50,000	50,000	
Pumping and Storage Total	1,640,000	560,000	770,000	220,000	70,000	20,000

TRANSMISSION SYSTEM

102" aqueduct inspection	3,900,000	1,500,000	1,900,000	500,000		
78" aqueduct inspection	900,000		-	900,000		
66", 60", 48" transmission mains inspections	50,000			50,000		
16" and larger valves replacements	975,000	125,000	150,000	200,000	200,000	300,000
Transmission System Total	5,825,000	1,625,000	2,050,000	1,650,000	200,000	300,000

DISTRIBUTION SYSTEM

Replace / Upgrade water mains	50,900,000	8,700,000	5,700,000	9,000,000	12,000,000	15,500,000
Replace Distribution Valves	760,000	60,000	100,000	200,000	200,000	200,000
Replace lead services	8,950,000	6,700,000	750,000	500,000	500,000	500,000
Replace fire hydrants	1,630,000	430,000	300,000	300,000	300,000	300,000
Valve data collection program	1,500,000	500,000	500,000	500,000		
Leak detection	10,000	10,000				
Distribution System Total	63,750,000	16,400,000	7,350,000	10,500,000	13,000,000	16,500,000

SUPPORT SYSTEM FACILITIES

Building and facilities rehabilitation	430,000	30,000	100,000	100,000	100,000	100,000
Facilities fencing and roads rehabilitation	175,000	50,000	50,000	25,000	25,000	25,000
Support System Facilities Total	605,000	80,000	150,000	125,000	125,000	125,000

TOTAL

\$119,095,000 \$26,860,000 \$17,575,000 \$23,815,000 \$25,165,000 \$25,680,000



2



5 Year Investiment - \$119 Million

Exhibit 13 **Providence Water** 15 Year IFR Expenditure Plan Fiscal Years 2016 through 2030

	Total Amount	Budget 2016-2020	Budget 2021-2025	Budget
Raw Water Supply			2021 2020	2020-2030
Large Dam Improvements	2,200,000	1,700,000	250,000	250,000
Secondary Dam Improvements	1,240,000	940,000	150,000	150.000
Raw Water Booster Pump Station Improvements	200,000	200,000	0	0
Gainer Dam Gatehouse Improvements	1,000,000	1,000,000	o	0
Raw Water Conduit Improvements	150,000	0	150.000	0
Watershed Fence and Road Rehabilitation	750,000	250,000	250.000	250.000
Raw Water Supply Total	5,540,000	4,090,000	800,000	650,000
Treatment Plant				
Central Control System (SCADA) Upgrades	600,000	200.000	200,000	200.000
Condults and Structures Inspect/Rehabilitate	280,000	10.000	260.000	10,000
Sedimentation Basins Rehabilitation	30,000,000	30,000,000	0	
Chemical Storage/Transfer/Feed Systems Improvements	3.200.000	2,400,000	650 000	150.000

Treatment Plant Laboratory Improvements	
Treatment Plant Process Meters Replacements	
Lagoon System Improvements	
Treatment Plant Building Improvements	
Treatment Plant Total	

10,000	260,000	10,000	280,000	4
0	0	30,000,000	30,000,000	
150,000	650,000	2,400,000	3,200,000	
0	200,000	2,000,000	2,200,000	
250,000	250,000	250,000	750,000	
75,000	75,000	75,000	225,000	
100,000	100,000	1,000,000	1,200,000	┛║
250,000	250,000	2,400,000	2,900,000	
1.035.000	1,985,000	38,335,000	41,355,000	

Pumping and Storage

Filters - Improvements

Pump Station Improvements	425,000	125,000	150,000	150.000
Bath Street Pump Station Improvements	2,000,000	0	o	2,000,000
Neutaconkanut Pump Station Improvements	2,000,000	0	D	2,000,000
Greenville Ave Pump Station Improvements	1,000,000	1,000,000	0	0
Cranston Commons Pump Station Improvements	1,500,000	1,500,000	0	0
Fruit Hill Pump Station Improvements	1,000,000	1,000,000	0	0
Storage Tank inspections / Improvements	2,000,000	0	2,000,000	0
Pumping and Storage Total	9,925,000	3,625,000	2,150,000	4,150,000

Transmission

78" and 102" Aqueducts Inspection	5,400,000	1,600,000	1.800.000	2.000.000
90" Aqueduct Inspection	6,500,000	500,000	6,000,000	0
66", 60", 48" Transmission Main Inspections	100,000	50,000	0	50,000
16" and Larger Valve Replacements	3,100,000	2,000,000	500,000	600,000
Transmission System Total	15,100.000	4,150,000	8,300,000	2,650.000

Exhibit 13 **Providence Water** 15 Year IFR Expenditure Plan Fiscal Years 2016 through 2030

	Total Amount	Budget 2016-2020	Budget 2021-2025	Budget 2026-2030
Distribution				
Distribution Main Upgrades	274,850,000	84,850,000	92,000,000	98,000,000
Distribution Valve Replacements	3,000,000	1,000,000	1,000,000	1,000,000
Lead Service Replacements	7,500,000	2,500,000	2,500,000	2,500,000
Hydrant Replacements	3,750,000	1,000,000	1,250,000	1,500,000
Leak Detection	100,000	o	100,000	0
Distribution System Total	289,200,000	89,350,000	96,850,000	103,000,000
Support Systems				

Building and Facilities Rehabilitation	3,000,000	1,000,000	1,000,000	1,000,000
Records Management (GIS) Upgrades	1,500,000	500,000	500,000	500,000
Facility Fence and Road Rehabilitation	750,000	250,000	250,000	250,000
Underground Fuel Storage Tank Replacements	200,000	200,000	0	0
Support SystemsTotal	5,450,000	1,950,000	1,750,000	1,750,000

Total

. .

ĩ.

366,570,000 141,500,000 111,835,000 113,235,000



20-YEAR INFRASTRUCTURE REPLACEMENT PLAN 2011-2030



December 2010

Cover: Rendering of Treatment Plant following completion of the Filter Rehabilitation and Influent Structure and Aerator upgrade projects.



PROVIDENCE WATER SUPPLY BOARD

INFRASTRUCTURE REPLACEMENT PLAN For Fiscal Years 2011 Through 2030

Prepared In-House by the Development Team of

Steven D. Santaniello, Manager Capital Improvements Christopher R. Labossiere, Engineer/Project Manager Paul J. Gadoury, P.E., Director of Engineering Leo E. Fontaine, Engineer/Project Manager

Norman C. Ripstein, Engineer/Project Manager Richard A. Razza, Engineer/Project Manager Gary Marino, Engineer/Project Manager

Engineering Department Support

Stephen Soito, P.E., Engineer/Project Manager

Jeanne Bondarevskis-Brasil, Director of Finance

Finance Department Support

Chief Engineer and General Manager

Pamela M. Marchand, P.E.

₽rovidence SWater

DECEMBER 2010

Infrastructure Replacement Plan

Title Page

TABLE OF CONTENTS

Page

EXECUTIVE SUMMARY

0 Year IFR Funding Projections - FY 2011 - 2030 Bar Graph (Exhibit 4)	0 Year Sources and Uses of Funds - FY 2011 - 2030 (Exhibit 3)	0 Year IFR Expenditure Plan – FY 2011 – 2030 Pie Chart (Exhibit 2)	0 Year IFR Expenditure Plan – FY 2011 – 2030 (Exhibit 1)	etter from Chief Engineer	
ES - 6	ES - 5	ES - 4	ES - 3	ES - 2	

INFRASTRUCTURE REPLACEMENT PLAN

IV.	Ħ.	II.	I.
Revenue Requirements Overview of Revenue Requirements 20-Year Sources and Uses of Funds, Five Year Phases FY 2011 - 2030 (Exhibit 3) 20-Year IFR Funding Projections - FY 2011 – 2030 Bar Graph (Exhibit 4)	IFR Expenditure Plan Background IFR Needs and Expenditure Plan 20-Year IFR Expenditure Plan - FY 2011 - 2030 (Exhibit 1) 20-Year IFR Expenditure Plan - FY 2011 - 2013 (Exhibit 10) 5-Year IFR Expenditure Plan - FY 2011 - 2015 (Exhibit 10) 5-Year IFR Expenditure Plan - FY 2011 - 2015 Pie Chart (Exhibit 11) 5-Year IFR Expenditure Plan - Project Overview - FY 2011 - 2015 (Exhibit 12) 15-Year IFR Expenditure Plan - FY 2016 - 2030 (Exhibit 13) 15-Year IFR Expenditure Plan - Project Overview - FY 2016 - 2030 (Exhibit 14)	IFR Program Accomplishments Summary of IFR Program Accomplishments (Fiscal Years 1996 through 2010) IFR Expenditures for FY1996 through 2010 by Facility Type Pie Chart (Exhibit 8) IFR Expenditures for FY1996 through 2010 by Year Bar Graph (Exhibit 9)	Facilities Description System Description Statistical Information (Exhibit 5) Process Diagram (Exhibit 6) Summary of the System's Principal Components by Facility Category (Exhibit 7)
IV - 2 IV - 3 IV - 4	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	III - 2 III - 5 III - 6	I-2 I-14 I-16 I-17

A. Appendix

The Comprehensive Clean Water Infrastructure Act of 1993 Chapter 46-15.6 of the General Laws of Rhode Island

Infrastructure / Capital Program Report FY 1996-2010 (September 2010) Rules and Regulations for Clean Water Infrastructure Plans

Executive Summary

Letter from Chief Engineer

Exhibit 1 – 20 Year IFR Expenditure Plan – Fiscal Years 2011 through 2030

Exhibit 2 – 20 Year IFR Expenditure Plan – Fiscal Years 2011 through 2030 Pie Chart

Exhibit 3 – 20 Year Sources and Uses of Funds – Fiscal Years 2011 through 2030

Exhibit 4 – IFR Funding Projections – Fiscal Years 2011 through 2030 Bar Graph





Exhibit 1 Providence Water 20 Year IFR Expenditure Plan

Fiscal Years 2011 through 2030

	Total Amount	Budget 2011-2015	Budget 2016-2020	Budget 2021-2025	Budget 2026-2030
RAW WATER SUPPLY	6,950,000	3,650,000	1,850,000	800,000	650,000
TREATMENT PLANT	81,935,000	45,080,000	34,085,000	1,735,000	1,035,000
PUMPING AND STORAGE	11,425,000	1,500,000	3,625,000	6,150,000	150,000
TRANSMISSION SYSTEM	18,100,000	4,500,000	2,650,000	8,300,000	2,650,000
DISTRIBUTION SYSTEM	260,235,000	53,610,000	67,400,000	61,975,000	77,250,000
SUPPORT SYSTEMS AND FACILITIES	6,700,000	1,250,000	1,950,000	1,750,000	1,750,000

TOTAL

109,590,000 111,560,000 80,710,000 83,485,000

385,345,000





20 Year Investment - \$385 million



Exhibit 2 - 20-Year IFR Expenditure Plan - FY 2011 through FY 2030 Pie Chart

Providence Water

Exhibit 2

Exhibit 3 Providence Water Sources and Uses of Funds IFR Funding & Expenditure Projections (\$000's) Fiscal Years 2011 through 2030

	2011-2015	2016-2020	2021-2025	2026-2030	2011-2030
	Phase 1	Phase 2	Phase 3	Phase 4	Total
Sources of Funding:					
Current Authorized Funding Current Bond Proceeds	\$80,000 8,300	\$80,000 0	\$80,000 \$0	\$80,000 \$0	\$320,000 8,300
Funds Available from Prior Years	15,123	0	\$0	\$0	15,123
Additional Rate Revenue Additional Bond Proceeds Total Sources of Funds	11,500 <u>15,500</u> 130,423	34,000 <u>30,000</u> 144,000	\$35,000 <u>\$0</u> 115,000	\$35,000 <u>\$0</u> 115,000	115,500 <u>45,500</u> 504,423
Uses of Funding:					
Cash Funded Construction Projects Existing Debt Service Additional Debt Service Total Uses of Funds	\$109,590 18,742 <u>1,775</u> 130,107	\$111,560 14,689 <u>13,948</u> 140,197	\$80,710 14,689 <u>17,390</u> 112,789	\$83,485 14,689 <u>17,390</u> 115,564	\$385,345 62,809 <u>50,502</u> 498,656
IFR Program Surplus/(Deficit)	\$317	\$3,804	\$2,211	-\$564	\$5,767



Infrastructure Replacement Plan FY 2011 through FY 2030

The contents of the plan and the sections are as follows:

source of supply to the service system, and a summary of the principal components of the system. statistical information for key components of the system, a flow diagram originating from the Section I - Facilities Description - A description of the water system. Included in the section are

costs from fiscal years 1996 through 2010. Section II - IFR Program Accomplishments - A summary of IFR program accomplishments with

2030). (fiscal years 2011 through 2015), and the 15 Year Expenditure Plan (fiscal years 2016 through Section III - IFR Expenditure Plan - The section contains the projects and descriptions for the 20 Year IFR Expenditure Plan (fiscal years 2011 through 2030), the 5 Year IFR Expenditure Plan

Section IV - Revenue Requirements - The sources and uses of funds for the 20 Year IFR Plan (fiscal years 2011 through 2030) and the IFR funding projections for the same period.

Report 1996 - 2010 (September 2010). Regulations for the Clean Water Infrastructure Plans, and the Infrastructure / Capital Program Appendix - The Comprehensive Clean Water Infrastructure Act of 1993, the Rules and



Section I

Facilities Description



Infrastructure Replacement Plan

Section I – Facilities Description

transmission and distribution systems, and the wholesale interconnections. components and processes, the pump stations and storage facilities, an overview of the System Description – Included in the description are the sources of supply, the treatment facility

and information for the system. Exhibit 5 - Statistical Information - Exhibit 5 contains a summary of the major statistical data

shows in schematic form the sequence and inter-relation of various water treatment and delivery processes Exhibit 6 – Process Diagram – Exhibit 6 is a process diagram of the Providence Water system. It

narrative description of the general condition of the facility, its approximate average age, and an estimate of its approximate remaining life. listing of the various major components of the Providence Water system. Provided is a brief Exhibit 7 – Summary of Principal Components by Facility Category – Exhibit 7 is a tabular

SYSTEM DESCRIPTION

WATER SUPPLY SOURCES

reservoirs which are tributary to the main reservoir. Reservoir complex consists of six reservoirs: the main (Scituate) reservoir and five smaller Providence Water's sole source of supply is the Scituate Reservoir Complex. The Scituate

Scituate Reservoir

water surface area of 5.30 square miles, and a watershed area of 92.8 square miles 400 million gallons (MG), resulting in a net storage volume of 36.611 BG. The reservoir has a The total storage capacity of the Scituate Reservoir is 37.011 billion gallons (BG). Dead storage is

High Water Datum (MHW). structure at the southeast end of the Reservoir which is traversed along its 3,200 foot length by Rhode Island Route 12 (Scituate Avenue). Elevation of the crest of the dam is 299.0 feet Mean Water in the Scituate Reservoir is impounded behind the Gainer Dam, a large zoned earth

rock channel to the Pawtuxet River below the dam. Crest elevation of the spillway is 284.00 feet (MHW). The flow discharges through a natural

Water needed for water supply flows from the reservoir to the treatment plant

Regulating Reservoir

miles. drainage area of this reservoir is 22.3 square miles, while the water surface area is 0.38 square Regulating Reservoir has a total storage capacity of 428 MG, of which 7 MG is dead storage. The

earth embankment structure which includes a 260 foot long concrete overfall spillway The dam impounding the waters in the Regulating Reservoir is an approximately 600 foot long Elevation of the crest of the overfall is 285.50 feet (MHW)

Barden Reservoir

square miles. no dead storage. The total storage in Barden Reservoir is 853 MG. Due to the arrangement of the outlets there The water surface area is 0.38 square miles, and the watershed area is 33.0 lS

352.2 feet (MHW). Elevation of the crest of the spillway is 345.1 feet (MHW). length, including the spillway, is approximately 612 feet. The crest of the dam is at elevation The Barden Reservoir Dam is an earth embankment structure with a concrete corewall. The

Moswansicut Reservoir

area of this reservoir is about 3.9 square miles capacity of 1.781 BG and dead storage of 1.066 BG, for a net storage of 715 MG. The drainage Moswansicut Reservoir covers a surface area of about 0.44 square miles. It has a total storage

spillway crest is 301.90 feet (MHW); elevation of the emergency spillway crest is 303.4 feet are two spillways, an overflow spillway and an emergency spillway. Elevation of the overflow The dam forming Moswansicut Reservoir is a 450 feet long earth embankment structure. (MHW) There

Ponaganset Reservoir

storage capacity is 693 MG. square miles. Total storage in the reservoir is 742 MG of which 49 MG is dead storage. Net Ponaganset Reservoir has a watershed area of 2.1 square miles, and a water surface area of 0.36

elevation is 633.05 feet (MHW). embankment structure. Crest of the dam is elevation 641.4 feet (MHW). Spillway crest The dam impounding the Ponaganset Reservoir is an approximately 635 foot long earth

Westconnaug Reservoir

area covers about 0.27 square miles. It has a drainage area of 4 square miles Westconnaug Reservoir has a total storage capacity of 453 MG with no dead storage. Its surface

conduit discharge into Westconnaug Brook. The crest elevation of the spillway is 454.17 feet (MHW). Both the spillway and the outlet length of the dam is approximately 320 feet long, with a crest elevation of 457.2 feet (MHW). The dam is an earth embankment structure with a steel sheeting and concrete corewall. The

TREATMENT FACILITIES

low pH, low alkaline, low turbidity water with seasonal overturn events Reservoir are typical of well protected surface water supplies in the New England region. It is flows from the Scituate Reservoir to the plant. Providence Water operates one conventional water treatment plant to purify source water which The raw water characteristics from the Scituate a

control and pH adjustment, sedimentation, disinfection, filtration, and fluoridation treatment process consists of aeration, coagulation-flocculation, lime addition for corrosion available for pumping water to the plant under extremely low reservoir conditions. normally operated under gravity flow conditions. The Raw Water Booster Pump Station is The plant utilizes a conventional treatment process. The hydraulics of the plant allow it to The be

Influent Control Chamber

and drain valves that regulate the flow of water entering the plant. The influent control chamber is a concrete structure consisting of internal chambers and control

Aeration Basin

volatile organics and gases. The aerated water travels by gravity to the sedimentation basins. gravity pressure and sprays water into the air in a fountain style. This treatment step removes Water flows from the influent chamber to the aeration basin. The aeration system works under

Basin Influent Conduit

conduit. Water then travels on to the basins through an 8.5-foot wide, 10-foot high rectangular concrete through two 72-inch by 36-inch diameter venturi meter tubes which measure the influent flow. The aerated water travels to the sedimentation basins through a 108-inch conduit and then

Coagulation/Flocculation

draining and flushing the basins bottom of the basins. The resulting ferric sludge must be removed manually by periodically basin (111 million gallon capacity). Here, the flocculated material is allowed to settle on the has two large sedimentation basins; the north basin (43 million gallon capacity) and the south the removal of the flocculated colloidal material through sedimentation. The treatment plant cylindrical motion to the water. This step is commonly known as flocculation. The next step is bottom of the mixing chamber. The mixer works under gravity feed and imparts a slow tangential mixer. The water enters the mixer through a 4-foot wide, 3-foot high opening at the result of the lime addition at this point. Further mixing and flocculation takes place in a through the basin influent conduit. The pH of the water is increased to approximately 7.0 as a conduit utilizing the pumped flash mix system. Quicklime is added to the water as it passes Ferric sulfate is added as a coagulant to the aerated water as it passes through the 108-inch

Filtration

lagoons supplied by gravity via a 400,000 gallon wash water tank which is then discharged to the sludge head loss through the filter reaches approximately 6.5 feet of water. The filter backwash water is The average filter run is approximately 72 hours and, generally, a backwash is initiated when two 16-inch effluent lines with 12-inch butterfly valves that control discharge into the clearwell. The number of filters on-line concurrently is dependent upon water demand. Each filter has air scour backwash. Each filter is operated over a flow range of 5 to 8 million gallons per day. filters, one (1) is a dual media filter with air scour backwash, and one (1) is a tri-media filter with following the coagulation, flocculation, and sedimentation stages. Sixteen (16) are rapid sand dioxide will be injected in this conduit to raise dissolved inorganic carbon (DIC) and alkalinity second lime injection point is located in this conduit to raise the pH from 7.0 to 10.2. Carbon conduit to the plant's filters. Chlorine is added in this conduit for disinfection purposes. A Settled water travels from the basins through a 10-foot wide, 11-foot high rectangular concrete There are eighteen (18) filters which remove non-settleable floc and impurities remaining

Emergency Provisions

that could allow chlorinated unfiltered water to flow to the system. Emergency provisions at the plant include stand-by power and an emergency by-pass process

available through a 2000 KW diesel generator located at the Raw Water Booster Pump Station. life safety requirements during power outages. Redundant backup power for the system is also generator. This generator is capable of providing adequate power for treatment operations and treatment plant. The emergency electrical power at the plant is provided by a 600 KW diesel Electrical service is provided by a 23 kilo-volt (KV) transmission line to a 2.3 KV service to the

Chemical Feed Systems

Ferric Sulfate

treatment process after aeration occurs then used to provide a measured feed rate to the raw water. Ferric sulfate is added to the is stored and then transferred by pumps, as needed, into two (2) day tanks. Metering pumps are The plant uses ferric sulfate as a coagulant. Ferric sulfate arrives at the plant in liquid form and

Quicklime

locations, both prior to, and after sedimentation. utilized to add lime to the unfinished water. Lime is added to the treatment process in two secondary feeder hoppers from which gravimetric feeders, slakers, float tanks, and pumps are pneumatic blower-style transfer system is utilized to convey lime from bulk storage to Quicklime is added to aerated water for pH adjustment and corrosion control purposes. \triangleright

Carbon Dioxide

storage tanks distribution system. Carbon dioxide will be delivered in liquid form and will be stored in two carbon (DIC) and alkalinity of the finished water in order to stabilize the pH throughout the Carbon dioxide will be added to the settled water to increase the levels of dissolved inorganic A Carbon dioxide feed system is currently under construction under the Capital Program.

Chlorine

chlorine leak is detected. ventilation system that would turn on and exhaust air to the outdoors in the event that a ton containers which are transported to a storage room. Chlorine is added to the settled water for disinfection. Chlorine is delivered to the plant in one The storage room is equipped with a

Hydrofluorosilicic Acid (Liquid Fluoride)

injection point from a day tank at a rate paced to the metered effluent flow of the plant. delivered in liquid form and is stored in four storage tanks. Fluoride is then pumped to the Hydrofluorosilicic acid is added to filtered water just downstream of the clearwell. Fluoride SI

Solids Handling and Disposal

lagoons water and directed through drains in the basins where it then flows to off-site sludge settling by draining the basin. The exposed sludge is manually pushed and scoured using high pressure basins and must be periodically removed. The cleaning of the sedimentation basins is initiated sedimentation processes which settles and accumulates at the bottom of the sedimentation The treatment process produces ferric hydroxide sludge from the coagulation and

Lagoon Description

presently set by our RIPDES permit issued by the Rhode Island Department of Environmental removal of sediments. Discharge limits including flow, pH and total suspended solids are treatment sludge received by the lagoons. Lagoon 2 is used as a 'polishing' lagoon for further dewatering and cleaning operations. Lagoons 1a and 1b are used to store the majority of water control structures that allow the lagoons to be independently removed from service for of three settling lagoons, three overflow structures and outfalls, and a series of swales and Ferric sludge from the plant is collected in a settling lagoon system. The lagoon system consists Management.

STORAGE FACILITIES

for emergency and fire fighting purposes. distribution system. These facilities are used to meet peak demand flows and to provide storage Water is also collected in a 260,000 gallon clearwell at the plant before being delivered to the Providence Water operates five water storage facilities throughout the distribution system.

Aqueduct Reservoir

reservoir through aqueducts and transmission mains from the treatment plant. operational storage for the Low Service area of the distribution system. Water is supplied to the elevation of 231 feet mean high water (MHW). underground concrete structure with a water depth of approximately 25 feet and an overflow The Aqueduct Reservoir has a storage capacity of 43.4 MG and is 390 x 590 foot enclosed The facility is gravity fed and provides

Neutaconkanut Reservoir

the High Service area of the distribution system. operational storage for the gravity fed Low Service area and a portion of the pumped supply to approximately 25 feet and an overflow elevation of 227 feet MHW. The facility provides and is a 397 x 597 foot enclosed underground concrete structure with an average water depth of Neutaconkanut Reservoir. The Neutaconkanut Reservoir has a storage capacity of 42.09 MG Water continues to flow through the Neutaconkanut Conduit to the further downstream

Longview Reservoir

emergency, and fire storage to the High Service area of the distribution system doubled the size of the reservoir to its current capacity. The facility provides operational constructed immediately adjacent to the existing reservoir and was put on line in 1990. This feet MHW. A 200 foot x 323 foot x 29 foot deep cast in place concrete underground addition was The Longview Reservoir has a storage capacity of 24.8 MG and has an overflow elevation of 306

Ridge Road Reservoir

water depth of 40 feet and an overflow elevation of 398 feet MHW. reservoir by the Fruit Hill Pump Station. The structure is a prestressed concrete tank with a fire storage for the Extra-High Service area of the distribution system. Water is pumped to the The Ridge Road Reservoir has a capacity of 3.5 MG and provides operational, emergency, and

Lawton Hill Reservoir

Western Cranston area of the distribution system. Water is pumped to the reservoir by the elevation of 485 feet mean high water (MHW). The facility provides operational storage for the enclosed underground concrete structure with a water depth of 20 feet and an overflow The Lawton Hill Reservoir has a storage capacity of 5.0 MG and is a 187-foot by 187-foot Aqueduct Pump Station adjacent to the Aqueduct Reservoir.

PUMP STATIONS

pump station. A description of the pump stations follows: Water owns and operates ten water pump stations in the distribution system and one raw water In order to maintain an adequate supply of potable water at a sufficient pressure, Providence

Raw Water Pumping Station

2000 KW diesel generator. reservoir water level conditions. The RWBPS is equipped with emergency power supplied by a supplement the head to provide adequate delivery capacity the water treatment plant under low capacity of 50 MGD and two with a pumping capacity of 30 MGD. The station is used to The Raw Water Booster Pumping Station (RWBPS) contains four pumps, two with a pumping

Dean Estates Pump Station

subdivisions Estates Pump Station serves the higher elevations in the Dean Estates and the Garden Hills 1,200 GPM pumps. Emergency power is supplied by a 125 KW natural gas generator. The Dean The Dean Estates Pump Station contains one 200 GPM pump, two 475 GPM pumps and two

Greenville Avenue Pump Station

generator pumps, and one 750 GPM fire pump. The Greenville Avenue Pump Station contains one 50 GPM jockey pump, three 320 GPM Emergency power is supplied by a 180 KW diesel

Fruit Hill Pump Station

High Service area. Emergency power is provided by a 125 KW natural gas generator The Fruit Hill Pump Station contains two 1,500 GPM pumps and provides water to the Extra

Bath Street Pump Station

as the high pressure fire zone in downtown Providence station pumps water to Longview Reservoir and supplies water to the High Service area as well 6,700 GPM each. A 1000 KW diesel generator supplies emergency power for the station. The The Bath Street Pump Station contains three pumps with a pumping capacity of approximately

Neutaconkanut Pump Station

Longview Reservoir and the High Service area. station. The station pumps water from the Neutaconkanut Reservoir and supplies water to approximately 6,700 GPM each. A 1000 KW diesel generator supplies emergency power for the The Neutaconkanut Pump Station contains four pumps with a pumping capacity of

Aqueduct Pump Station

area. station. approximately 2,000 GPM each. A 600 KW diesel generator supplies emergency power for the The Aqueduct Pump Station contains four vertical turbine pumps with a pumping capacity of The station pumps water to Lawton Hill Reservoir and the Western Cranston Service

Alpine Estates Pump Station

Station to provide water to the Alpine Estates subdivision in Western Cranston. station is currently out of service and serves as a back-up to the Cranston Commons Pump domestic pumps. The Alpine Estates Pump Station contains one 100 GPM jockey pump and three 370 GPM A 75 KW diesel generator supplies emergency power for the station. This

Ashby Street Pump Station

residential services in the Neutaconkanut Hill area in Johnston. station from the Neutaconkanut Pump Station. The station provides water to approximately 100 pumps and one 750 GPM fire pump. The Ashby Street Pump Station contains one 50 GPM jockey pump, two 100 GPM domestic Electrical power and emergency power is supplied to the

Cranston Commons Pump Station

station provides water to Cranston Commons and Alpine Estates subdivision in Western power supply for a booster pump station for the sewer system in the City of Cranston. The privately managed water/sewer utility company who also uses the generator as an emergency Emergency power is supplied by a diesel generator, which is owned and maintained by a domestic pumps. The station utilizes an underground 530 gallon hydro-pneumatic storage tank. The Cranston Commons Pump Station contains two 130 GPM jockey pumps and three 800 GPM Cranston

TRANSMISSION AND DISTRIBUTION SYSTEM

treatment plant. Large diameter pipe conduits transfer raw water by gravity from the dam intakes to the

and the 78-inch and 102-inch diameter Supplemental Tunnel and Aqueduct (STA) two major transmission conduits, the 90-inch diameter Scituate Tunnel and Aqueduct (ScTA) Finished water is transmitted from the clearwell at the plant to the distribution system through

distribution piping (6" to 12"). concrete aqueduct, 114 miles of various sizes of transmission piping (16" to 66") and 885 miles of Providence Water currently operates approximately 4 miles of concrete lined tunnel, 10 miles of

Service Area

potable water through both its retail and wholesale customers. Providence Water supplies approximately 600,000 people in the State of Rhode Island with

The Retail Area

industrial, commercial, and fire service supplies a significant portion of Johnston. The 74,000 retail service connections include residential, The retail service area consists essentially of all of Providence, Cranston, North Providence, and

Service, Extra High Service, and the Western Cranston water district. The retail service area is divided into four major separate pressure zones: the Low Service, High

are maintained at approximate elevations 225 and 230 feet MHW respectively. Service area is maintained by the levels at the Neutaconkanut and Aqueduct Reservoirs which within elevations 0 to 140 feet above Mean High Water (MHW). The pressure in the Low Cranston, Johnston and Providence. The Low Service area is generally defined as the area The Low Service area comprises approximately 75% of the retail area and serves portions of

Service system by the Neutaconkanut and Bath Street Pumping Stations 305 feet MHW. Water for the High Service area is supplied by water pumped from the Low operating level at the Longview Reservoir, which is maintained at the approximate elevation of 140 to 220 feet above MHW. The pressure in the High Service area is maintained by the the Town of Johnston. The High Service area is generally defined as the area within elevations The High Service area serves the higher elevation sections of North Providence, Providence and

Service system and pumped from the Fruit Hill Pump Station to the Ridge Road Reservoir from 220 feet to 315 feet above MHW. The water for this service area is drawn from the High North Providence. The Extra High Service area is generally defined as the area with elevations The Extra High Service area serves a small portion of the retail area in the Fruit Hill section of where the water level is maintained at the approximate elevation of 397 feet MHW

Low Service system by the Aqueduct Pump Station. elevation of 484 feet MHW. Water for this service area is supplied by water pumped from the service area is maintained by the operating level at Lawton Hill Reservoir at the approximate The Western Cranston water district encompasses 3.5% of the retail area. The pressure in this

Service area mains range in size from 6 inches to 66 inches in diameter and are constructed of a services are metered. Service connections are generally constructed of lead, copper, cast iron, or ductile iron. Service connections range from 5/8-inch to 12-inches in size, based upon customers' demands. variety of materials including cast iron, ductile iron, concrete, steel, and asbestos cement. All

The Wholesale Area

Sewer and Water Department (six interconnections), and the East Smithfield Water District (three interconnections), Lincoln Water Commission (two interconnections), Smithfield Water interconnection), Greenville Water District (one interconnection), Kent County Water Authority the Bristol County Water Authority (one interconnection), East Providence Water Division (one Providence Water wholesales water to nine water utilities in the Providence area. These include (three interconnections) Department (one interconnection), Warwick Water Department (two interconnections), Johnston

System Metering

connections. Raw water flowing into the plant is measured by two 72" x 36" diameter venturi Providence Water meters water produced at the treatment plant and meters 100% of its service to the sedimentation basins meters. These venturi meters measure the flow of raw water from the influent control chamber

effluent lines from the plant's filters. Plant effluent flows are also measured by two 72" X 42" plant's 36 master effluent meters. These meters are 12-inch venturi tube meters located on the The flow of effluent discharged from the plant to the distribution system is measured by the finished water effluent venturi meters

industrial and manufacturing accounts, commercial accounts, and residential users connections. The retail service area contains a variety of water consumers including large meters at interconnections to wholesale customers as well as normal metering of all retail service Providence Water meters all customers in its entire service area. Service area metering includes

PROVIDENCE WATER STATISTICAL INFORMATION Exhibit 5

WATER SUPPLY SOURCES

	Watershed	Surface	Storage	Dam	Spillway
	Area (Sq Miles)	Area (Sq Miles)	Capacity (MG)	Length (feet) Ele	vation (MHW)
Scituate Reservoir	92.8	5.30	37011	3200	284.00
Regulating Reservoir	22.3	0.38	428	340	285.50
Barden Reservoir	33.0	0.38	853	530	345.10
Moswansicut Reservoir	3.9	0.44	1781	450	301.90
Ponaganset Reservoir	2.1	0.36	742	635	633.05
Westconnaug Reservoir	4.0	0.27	453	320	454.17

TREATMENT FACILITIES

of aeration, coagulation-flocculation, corrosion control, sedimentation, filtration, disinfection, and fluoridation. 4,400 feet from the Gainer Dam in Scituate and operates as a coventional treatment process. The treatment process consists Providence Water operates one treatment plant to purify the Scituate Reservoir water. The plant is located appoximately

STORAGE FACILITIES

	Storage	Overflow
	Capacity (MG)	Elevation (MHW)
Aqueduct Reservoir	43.4	231
Neutaconkanut Reservoir	42.1	227
Longview Reservoir	24.8	306
Ridge Road Reservoir	3.5	398
Lawton Hill Reservoir	5.0	485

6

Providence Vater
STATISTICAL INFORMATION

Exhibit 5

PROVIDENCE WATER

Infrastructure Replacement Plan Facilities Description



20	Total
ω	East Smithfield Water District
5	Johnston Sewer and Water Department
2	Warwick Water Department
-	Smithfield Water Department
2	Lincoln Water Commission
ω	Kent County Water Authority
-	Greenville Water District
L	East Providence Water Division
-	Bristol County Water Authority

SU

II.	
tercol	
nne	

74,000 service connections

6,067 hydrants

13,500 distribution valves

885 miles of distribution piping (6" to 12")

814 transmission valves

114 miles of transmission piping (16" to 66")

9.5 miles - 78" / 102" Supplemental Tunnel and Aqueduct

4.5 miles - 90" Scituate Tunnel and Aqueduct

Alpine Estates

Ashby St.

Aqueduct

Cranston Commons

2 - 130 GPM jockey pumps; 3 - 800 GPM pumps; emergency power provided by PS&G

1 - 50 GPM jockey pump; 2 - 100 GPM pumps; 1 - 750 GPM pump; emergency power provided by Neut. P.S. and generator.

1 - 100 GPM jockey pump; 3 - 370 GPM pumps; 75 KW diesel generator

4 - 2,000 GPM pumps; 600 KW diesel generator 4 - 6,700 GPM pumps; 1000 KW diesel generator

Neutaconkanut Bath Street Fruit Hill

3 - 6,700 GPM pumps; 1000 KW diesel generator

2 - 1,500 GPM pumps; 125 KW natural gas generator

1 - 50 GPM jockey pump; 3 - 320 GPM pumps; 1 - 750 GPM pump; 180 KW diesel generator 1 - 200 GPM pump; 2 - 475 GPM pumps; 2 - 1,200 GPM pumps; 125 KW natural gas generator

Dean Estates Raw Water

2 - 30 MGD pumps; 2 - 50 MGD pumps; 2000 KW diesel generator

PUMP STATIONS

Greenville Ave

WHOLESALERS

TRANSMISSION AND DISTRIBUTION SYSTEM

I - 15

EXHIBIT 6



			Approx. Practical	
PRINCIPAL COMPONENTS BY CATEGORY	Installation Date(s)	Age of Component	Remaining Life (years)	Assessment
RAW WATER SUPPLY				
Principal Reservoirs and Dams	1917 to 1927	various	100	Generally all the dams are in good to excellent condition. Gainer Dam has been rehabilitated but requires further concrete rehabilitative work on the upstream face of the spillway. The stonewall bordering each side of Gainer dam on Route 12 has been reconstructed. Ponaganset Reservoir Dam has been rehabilitated and is in good condition. Barden, Westconnaug, and Moswansicut Reservoir Dams have been rehabilitated and are in excellent condition. Improvements to Regulating Reservoir Dam is in design and rehabilitation is needed to both the upstream and downstream slopes of the dam and at the outlet structure and spillway.
Reservoir Watershed Area	various	various	various	Generally in good condition. Various rehabilitative work is needed to secondary dams, fencing, gates, access and fire roads.
Gainer Dam Gate House	1927	84	45	The gatehouse dates back to its original construction in the 1920s and is generally in good condition. All sluice gates, stop shutters, and drain valves have been replaced. Electrical actuators were installed to operate the sluice gates. Instrumentation and telemetry have been replaced. The gatehouse is in need of architectural rehabilitation along with a replacement of the two existing cranes.



			Approx. Practical	
PRINCIPAL COMPONENTS BY CATEGORY	Installation Date(s)	Age of Component	Remaining Life (years)	Assessment
RAW WATER SUPPLY				
60 inch Raw Water Influent Conduits	1926	85	50	The twin 60" mains appear to be in good condition. The exposed section of the twin 60 inch mains inside the meter and junction chambers was inspected and some of the exterior coating will need to be recoated. The cathodic protection system installed for the underground portion is in good working condition.
90 inch Steel Raw Water Influent Conduit	1926	85	50	Dates back to original plant construction. The 90" raw water conduit is in good condition. Minor internal surface imperfections were identified during a structural inspection and will be rehabilitated under the Influent Structure Rehabilitation project.
Raw Water Booster Pump Station	1966	45	50	The station is in relatively good condition. A 2000 kW generator was installed in 1996, replacing the old diesel generator. The electrical feeder lines to the 60" control valves from the station have been replaced and the valves are in good working condition. The suction and discharge valves, as well as the valve actuators for each of the booster pumps have been replaced. The motor control center has been replaced and the pumps rehabilitated. SCADA has also been added to this station. The station is in need of architectural rehabilitation.

	Installation	Age of	Approx. Practical Remaining				
PRINCIPAL COMPONENTS BY CATEGORY	Date(s)	Component	Life (years)	Assessment			
TREATMENT PLANT FACILITIES							
Treatment Plant Structure / Infrastructure	1926	84	50	The plant is generally in good condition with improvements made to the roof, lab, HVAC system, and electrical system. The public address system throughout the plant and forestry building is in the process of being replaced. The plant is in need of various architectural improvements.			
Electrical Supply System - Treatment Plant	various	various	various	The overall system is in excellent condition. The feeder lines from the Hope substation to the treatment plant have been replaced. A 480-volt transformer and feed line has been installed at the treatment plant replacing the old 550V system. The old 175 kW generator was replaced with a 600 kW diesel generator.			
Aeration	1926	85	5	The influent structure and aeration basin date back to the 1920s. Improvements to the aeration basin and influent structure are in design and rehabilitation will take place in the near future, consisting of the relocation and reconstruction of the basin, rehabilitation of concrete surfaces of the structures and conduits, replacement of the influent control valves, and reconstruction work on the influent control chamber. Plant influent hydraulics will be improved by raising the overflow and aerator weirs.			
Sedimentation Basins	1939	72	10	The concrete sedimentation basins at the plant consist of two large open water surface basins dating back to 1939. The concrete walls and slabs making up the basin have deteriorated over time. In light of the outmoded nature of this sedimentation process by today's standards, Providence Water is considering a new modern-design settling system to be installed in their place.			
Filters and Appurtenances	1927/1943/1968	varies	5	Construction is in progress for the rehabilitation of all 18 filters at the treatment plant. Rehabilitation work consists of completely replacing the existing filters' valves, underdrains, washwater troughs, and media, and erecting a new superstructure to house the filters. In addition to the filter rehabilitation, all associated washwater and effluent piping and appurtenances are being replaced, including the replacement and relocation of the 48-inch washwater pipe.			
Clearwell	1927/1943/1968	71	50	The exterior yard and the interior of the clearwell have been fully rehabilitated. The two venturi meters at the outlet have been rehabilitated.			



			Approx. Practical	
	Installation	Age of	Remaining	
PRINCIPAL COMPONENTS BY CATEGORY	Date(s)	Component	Life (years)	Assessment

TREATMENT PLANT FACILITIES

Wash Water System	1926 Tank 2004 Pumps	84 (Tank) 6 (Pumps)	50 (Tank) 30 (Pumps)	The pumps are in good condition. Concrete rehabilitative work was performed on the washwater tank. The washwater tank is in good condition.
Service Water System	1960 Tank 2004 Pumps	50 (Tank) 6 (Pumps)	50 (Tank) 30 (Pumps)	The pumps are in good condition. Magnesium anodes were installed in the tank for corrosion protection. The service water tank appears to be in good condition.
Ferric Storage/Transfer/Feed System	1997	13	10	The protective coating and insulation on the bulk storage tanks have shown wear and will need rehabilitative work.
Lime Storage/Transfer/Feed System Storage system Transfer system	n 2006 n 2004	4 6	20 20	Due to the abrasive nature of lime, the pipe bends for the transfer system will need to be replaced eventually. The feed system is in need of replacement.
Chlorine Storage/Transfer/Feed System	1998 1997	12	<5	Due to continually increasing safety concerns associated with bulk gaseous chlorine storage, the existing gaseous chlorine storage and feed systems will be replaced to a sodium hypochlorite system.
Fluoride Storage/Transfer/Feed System	2005	5	20	The system is in excellent operational condition. Only minor repairs are anticipated during the next 10 years.
Sludge Handling / Disposal System	2004	6	50	The system is in excellent operational condition. Sludge has been removed from lagoons #1A and #1B and a residuals management system is in operation which provides flexibility for alternating between each side of lagoon #1 to provide for alternate drying and removal of residual deposits. Sludge has been removed from all of Lagoon #2 to restore the lagoon to its original intended function of acting as a buffering pond to maintain an acceptable standard of water quality for discharge to the Pawtuxet River.
Process Control / Data Acquisition System	2010	0	10	The SCADA system is new and in excellent condition.
Carbon Dioxide Storage/Feed System	2010	0	20	The Carbon Dioxide system is new and in excellent condition.

Providence Vater

PRINCIPAL COMPONENTS BY CATEGORY	Installation	Age of	Approx. Practical Remaining Life (years)	Assessment
TRANSMISSION SYSTEM	Datt(s)	Component	Life (years)	Assessment
90-inch Scituate Tunnel and Aqueduct	1925	85	75	The entire 4.5 mile 90" conduit is in good condition. The conduit was inspected and various concrete rehabilitative work was conducted including crack injections, spalled concrete repairs, and the investigation and repair of hollow sounding areas. Further rehabilitative work will be required in the tunnel section consisting of contact grouting to fill various voids between the concrete tunnel and the bedrock.
Supplemental Tunnel and Aqueduct (102" & 78")	1970	40	50	The 78" and 102" transmission lines, approximately 9.6 miles in length, were constructed in the 1960's and consist of prestressed concrete cylinder pipe (PCCP) and two sections of concrete lined tunnel. Because of prior deficiencies encountered on these pipelines, a program has been adopted in which the pipelines are inspected and repairs are conducted on a five year interval basis. In addition to the inspections, a fiber optic acoustic monitoring system has been installed in the 102" pipeline that continually monitors the pipeline for wire breaks.
Transmission Mains (16" to 66")	1871-2006	76	various	Some of the mains are older than 100 years and will eventually need to be replaced. No mains have been identified needing replacement in the short term.
Transmission Valves (16" to 60")	1871-2006	38	various	Many of the valves are old and need to be replaced. Plans are to replace 16" and larger valves in the system that are older than 75 years with new butterfly valves.



			Approx. Practical	
	Installation	Age of	Remaining	
PRINCIPAL COMPONENTS BY CATEGORY	Date(s)	Component	Life (years)	Assessment
DISTRIBUTION SYSTEM				
Distribution Mains (6" to 12")	1871-2010	73	various	Approximately 27% of mains consist of unlined cast iron pipe installed prior to 1900. Main replacements are necessary.
Distribution Valves (6" to 12")	1871-2010	65	various	Of the approximately 13,500 valves in the system, 1,900 have been identified as 6", 8" and 12" diameter valves installed prior to 1900. Plans are to replace these valves in conjunction with the main replacement program. Older distribution valves that are found to be defective and valves in areas of local and state road resurfacing projects will also be replaced.
Services	1871-2010	55 (all) 100 (lead)	various	Of the approximate 74,000 services in the system, over 23 percent are lead. Plans are to continue replacing these services under the Lead Service Replacement Program. Other lead services will be replaced on main replacement projects.
Hydrants	1941-2010	33	various	Plans are to replace all hydrants greater than 75 years old with new breakaway style hydrants.



			Approx.	
			Practical	
	Installation	Age of	Remaining	
PRINCIPAL COMPONENTS BY CATEGORY	Date(s)	Component	Life (years)	Assessment
PUMPING AND STORAGE				
				The reservoir and gatehouse are in good condition. The reservoir has been fully
Aqueduct Reservoir and Gatehouse	1962	48	50	rehabilitated; exterior waterproofing was applied. Cracks and construction joints on
				the interior of the structure were sealed.
				Dates back to the 1920s. The reservoir and gatehouse has been rehabilitated under a
Neutaconkanut Reservoir and Gatehouse	1928	82	50	recent contract. Cracks and construction joints on the interior of the structure were
				sealed.
				The reservoir and gatehouse are in good condition. The reservoir has been fully
Longview Reservoir and Gatehouse	1928, 1990	82	50	rehabilitated; exterior waterproofing was applied. Cracks and construction joints on
				the interior of the structure were sealed.
Didge Dead Decement	1020	21	50	The storage tank is in good condition. The tank has some exterior cracking which
Riuge Road Reservon	1909	21	50	needs to be rehabilitated.
				A brief diving inspection was completed in 2004 and found the tank in relatively
Lawton Hills Reservoir	1972	38	50	good condition. Some concrete rehabilitative work will be needed inside the
				reservoir.
				Construction has begun to rehabilitate the pump station and to combine the Garden
				Hills and Dean Estates pressure zones into a single pressure zone. Work includes
Dean Estates Pump Station	1982	28	1	installation of new VFD turbine pumps, elimination of the hydropneumatic tanks,
				instrumentation and electrical system upgrades, installation of an emergency
				generator, and architectural improvements.
				The station is in good condition. It is anticipated that the pumps will need to be
	1000	21	10	replaced along with upgrades to the various mechanical and electrical systems,
Fruit Hill Pump Station	1989	21	10	including architectural improvements.

			Approx. Practical	
PRINCIPAL COMPONENTS BY CATEGORY	Installation Date(s)	Age of Component	Remaining Life (years)	Assessment
PUMPING AND STORAGE				
Bath Street Pump Station				The pump station is in good condition. Rehabilitation of the pump station was completed in 1999 which included replacement of the pumps, suction and discharge piping, instrumentation and electrical system upgrades, architectural/structural improvements, and installation of an emergency power generator.
Building	1928 1999	82 11	40	
Neutaconkanut Pump Station				The pump station is in good condition. Rehabilitation of the pump station was completed in 1999 which included replacement of the pumps, suction and discharge piping, instrumentation and electrical system upgrades, architectural/structural improvements, and installation of an emergency power generator.
Building Pumps	1935 1999	75 11	40 19	
Greenville Ave Pump Station Building Pumps	1994 1994	17 17	10	The pump station is in good condition. It is anticipated that various mechanical, electrical, and architectural improvements will be needed.
Aqueduct Pump Station Building Pumps	1972 2006	38	40 26	The pump station is new and is in excellent condition.
Alpine Estates Pump Station	1988	23	7	The station needs upgrading of the electrical supply, new valves and piping, a new pneumatic pressure tank, and various new system controls. The station is presently inactive and upgrades are on hold pending future plans for the station.
Ashby Street Pump Station	1999	12	18	This pump station is in excellent condition. It is anticipated that various mechanical, electrical, and architectural improvements will be needed.
Cranston Commons Pump Station	1996	15	15	The pump station is in good condition. Long-term plans are to replace the below grade pump station with an above ground pre-engineered packaged-unit with its own emergency back-up generator.



			Approx. Practical	
	Installation	Age of	Remaining	
PRINCIPAL COMPONENTS BY CATEGORY	Date(s)	Component	Life (years)	Assessment

SUPPORT SYSTEMS & FACILITIES

Forestry Garage	1962	49	15	Various rehabilitative work has been conducted on the facility. The building is 49 years old and will require architectural and mechanical rehabilitation.
Academy Ave Administration Building	1954	57	5	Various rehabilitative work has been conducted on the facility. The building is 57 years old and will require architectural and mechanical rehabilitation. A new administration building is needed.
Aqueduct Reservoir Administration Building	1997	14	5	The building is a one level office building constructed in 1998. The facility is functional and will require minor architectural and mechanical rehabilitation.
Watershed Storage Facility	2009	2	40	Th e building is pre-engieered metal frame storage building constructed in 2009. The facility is in excellent condition.



IFR Program Accomplishments Section II



Infrastructure Replacement Plan IFR Program Accomplishments

Section II – IFR Program Accomplishments

Summary of IFR Program Accomplishments (Fiscal Years 1996 through 2010)

Exhibit 8 – IFR Expenditures for Fiscal Years 1996 through 2010 by Facility Type Pie Graph

Exhibit 9 – IFR Expenditures for Fiscal Years 1996 through 2010 by Year Bar Graph

SUMMARY OF IFR PROGRAM ACCOMPLISHMENTS - 1996 - 2010

hydrants, service connections, and meters with a multitude of appurtenances complex system of transmission mains, distribution reservoirs, and pumping stations into the and projected drinking water regulations as administered by the Rhode Island Department of source water comes from the Scituate Reservoir complex and is treated to meet and exceed current nine (9) wholesale customer water systems representing 60 percent of the State's population. retail customer communities of Providence, Cranston, North Providence, and Johnston and Providence Water is a full service utility supplying drinking water and fire protection to four (4) various communities. Health consistent with national drinking water laws. The water supply is distributed through The utility and its workforce operate and maintain a vast system of mains, The ھ

long-term planned infrastructure replacement programs adopted the Comprehensive Clean Water Infrastructure Act in accordance with Chapter 46-15.6 of intention of staving off deterioration and obsolescence of the State's water infrastructure systems, the General Laws of the State of Rhode Island. In 1993, the State legislature, recognizing the need for establishing a funding mechanism with the In 1990, Providence Water initiated an Infrastructure Replacement Program with limited funds The law set aside portions of water revenues for

is required to develop and maintain an infrastructure replacement plan to be submitted to the 2006, with this being our fourth plan submission. with the legislation, Providence Water prepared and submitted its first 20-year Infrastructure Rhode Island Department of Health once every five years for review and approval. In accordance In accordance with the requirements of the legislation, a water supplier subject to Chapter 46-15.6 Replacement Plan in 1996. Subsequent 5-year plan updates were submitted thereafter in 2001 and

inception of our infrastructure replacement effort which began in 1990, approximately \$200 million into raw water supply facility structures, and \$6.3 million into support facilities. Since the million into the transmission system, \$11.8 million into pumping and storage facilities, \$9.9 in improvements in the distribution system, \$56.6 million into our water treatment facilities, \$27.6 infrastructure, having reinvested approximately \$191 million into the system, with \$64.5 million Since submission of our first plan in 1996, we have made substantial improvements to our million has been invested into system improvements

Water **W**ater

scale providing automatic reading capabilities. problems have been identified along with older and / or defective hydrants and valves in the replacing or cleaning and lining water mains where water quality complaints and low-pressure system. In August 2007, we began the replacement of lead services in the distribution system on a largebasis to comply with the requirements of the Lead and Copper Rule. All water meters have been replaced with new radio-frequency transmission meters We have been

system, and has been replaced again in 2010 to keep up with the changing hardware and software been made to the plant's HVAC system. A new SCADA (Supervisory Control and Data electrical room dedicated solely to electrical panelboards and switchgear, and the old 175 kW new 480-volt transformer installed. The antiquated and obsolete 550-volt service has been substation, the underground electrical feeders to the treatment plant have been replaced, and a substation dating back to the 1920's that fed the plant has been replaced with a new modern completely new and reliable electrical feed service system to the plant. The old electrical of the clearwell, the effluent clearwell yard, the emergency bypass, and the wash water tank. The system to optimize coagulation. Concrete rehabilitative work has been performed on the interior been made to the ferric sulfate feed system with the incorporation of a pumped flash mixer ferric sulfate, and fluoride have been rehabilitated or replaced. Additional improvements have transmission, and lower operating and maintenance costs technology. All of the instrumentation and remote telemetry units (RTU's) have been replaced emergency power generator has been replaced with a new 600 kW generator. Improvements have replaced with a standard 480-volt service, the scope of work including construction of a new HVAC, and electrical upgrades. Electrical upgrades have been done, essentially providing a testing laboratory has been fully renovated to include a new floor, lighting, laboratory benches, with programmable logic controllers (PLC's) for increased security, more efficient data Acquisition) system was completed in 2000 replacing the old analog Central Control Board At our treatment plant, the chemical bulk storage / transfer / feed systems for chlorine, lime,

since its catastrophic failure in November 1996. Substantial rehabilitation work has been inspections. A third inspection which commenced in 2010 is underway. The 90" aqueduct has performed on the line as the result of significant deterioration uncovered in each of the In our transmission system, our problematic 102" aqueduct has been inspected at 5-year intervals

rovidence ter

been replaced with new butterfly valves rehabilitated. Valves 16" and larger, older than 75 years, and valves found to be defective have been inspected with various concrete rehabilitative work performed. the 78" aqueduct has been conducted and pipe sections found to be severely deteriorated were The first ever inspection of

completely rehabilitated and the Aqueduct pump station replaced. The storage reservoirs at In our pumping and storage system the Neutaconkanut and Bath Street pump stations have been Longview, Aqueduct, and Neutaconkanut have all been fully rehabilitated

Scituate Reservoir, and the dams at Ponaganset Reservoir, Barden Reservoir, Westconnaug the old obsolete 1750 kW generator replaced with a new 2000 kW unit. Gainer Dam at the been replaced. The Raw Water Booster pump station motor control center has been replaced and Reservoir, and Moswansicut Reservoir have all undergone rehabilitative work At our raw water facilities, all sluice gates and stop shutters at the Gainer Dam gatehouse have

storage tanks at various facilities have been replaced with new above-ground tanks, all 27 has been replaced. Fencing has been replaced and access roads improved at a number of the Providence Water facility structures were brought into compliance with the amended Rhode various support facilities Island Fire Safety Code, and the watershed storage facility used to house equipment and supplies At our support facilities, offices have been renovated at Academy Avenue, underground fuel

submission, will safeguard the integrity of our water supply for generations to come These improvements, along with the ongoing planned improvements outlined in this 2010 plan

September 2010, detailing our IFR and CIP accomplishments from 1996 through June 2010 is included for reference in the Appendix of this report. program to the Rhode Island Public Utilities Commission. The latest report, submitted in Every six months, Providence Water submits a project status report of its ongoing IFR/CIP

Exhibit 8 Providence Water

IFR Expenditures





*Through June 30, 2010

Total Investment Into System \$190.5 MIL





Exhibit 9

Providence Water Summary of IFR Expenditures Fiscal Years 1996 to 2010



Total to Dat	2010	2009	2008	2007	2006	2005	2004	2003	2002	2001	2000	1999	1998	1997	1996	FISCAL Year
e \$190,534,208	\$26,790,595	\$20,622,218	\$16,854,654	\$9,746,919	\$13,996,118	\$9,856,233	\$7,864,982	\$10,054,569	\$10,915,284	\$11,551,726	\$10,175,318	\$14,864,327	\$10,248,978	\$12,612,265	\$4,380,022	

II - 6



Infrastructure Replacement Plan IFR Program Accomplishments

Section III IFR Expenditure Plan



Infrastructure Replacement Plan IFR Expenditure Plan

Section III – IFR Expenditure Plan

Background - IFR Needs and Expenditure Plan

staff at Providence Water assessed the facilities consistent with the definitions within the next twenty years, from fiscal year 2011 (ending June 30, 2010) through FY 2030 (ending June 30, infrastructure replacement expenditure plan is a summary of forecasted expenditure needs for the regulations and developed a twenty-year project plan. Project needs were determined based on 2030) aggregated by major categories into four separate five year plan increments. Management factors such as age, condition, level of priority, and use of engineering and practical judgment. Exhibit 1 – 20-Year IFR Expenditure Plan - Fiscal Years 2011 through 2030 - The twenty year

consistent with drinking water standards and regulations as they presently exist. necessary to continue to deliver a reliable and healthy water supply to all our customers obsolescence, as we know conditions to be now. The plan's focus is on replacement of facilities ongoing basis. system's needs have been and will continue to be reevaluated by Providence Water staff on an required to match changing State and Federal regulations and changing field conditions. may necessitate. and will be adjusted and / or modified as changing needs, priorities, or regulatory requirements Project needs are based on the best available information and assessments available at this time Our schedule of proposed facility replacements is consistent with deterioration or We consider this plan to be a living document subject to amendments as may be The

representation of 20 Year IFR Expenditure Plan Exhibit 2 – 20-Year IFR Expenditure Plan – Fiscal Years 2011 through 2030 Pie chart – Graphical

period from FY 2011 through FY 2015. The plan is detailed on a project-by-project basis with adjusted and / or modified as changing needs and priorities may require the best available information and assessments available at this point in time. projects grouped according to functional categories within the system. Project needs are based on Expenditure Plan is a detail of the planned infrastructure replacement program over the five year Exhibit 10 – 5-Year IFR Expenditure Plan Fiscal Years 2011 through 2015 - The Five Year The plan will be

SWater ₽

Graphical Representation of 5 Year IFR Expenditure Plan Exhibit 11 – 5-Year Planned IFR Expenditures for Fiscal Years 2011 through 2015 Pie Chart Т

overview of the scope of each project for the 5 Year IFR Expenditure Plan. Exhibit 12 - 5-Year IFR Project Overview Fiscal Years 2011 through 2015 - A brief narrative

summarized according to major system components and aggregated into three five-year time time frame are less detailed than those of the initial five-year plan. They are generally fifteen year period from Fy 2016 through Fy 2030. Projects and estimated expenditures over this point in time and will be adjusted and / or modified as changing needs and priorities may dictate. increments. Project needs are based on the best information and assessments available at this Expenditure Plan is a summary of the planned infrastructure replacement program over the Exhibit 13 - 15 Year IFR Expenditure Plan – Fiscal Years 2016 through 2030 - The Fifteen Year

of the system for the 15 Year IFR Expenditure Plan. explanation of the scope of anticipated replacement work associated with each major component Exhibit 14 - 15 Year IFR Project Overview Fiscal Years 2016 through 2030 - A brief narrative

Background - IFR Needs and Expenditure Plan

a composite of system needs and expenditure projected over the next twenty years (fiscal years increments over the 15-year period from FY 2016 through FY 2030. The 20-year plan summary is according to major system components and aggregated into three individual 5-year time projects, with projects grouped according to functional categories over the 5-year period from FY infrastructure replacement needs and expenditures. The five-year plan is organized by specific 2011 through 2030), aggregated by major system category into four separate five-year plan 2011 through FY 2015. The subsequent 15-year period of the fifteen plan is generally summarized The plans contained herein encompass the five (5), and twenty (20) year projections of our increments

infrastructure replacement programs which would ensure the continued integrity of their systems and provide for funding of this program from water rates In January 1993, the Rhode Island State Legislature enacted the Comprehensive Clean Water Infrastructure Act. The intent of the legislation was for water suppliers to develop long-term

replacements for water suppliers. The Rules and Regulations for Clean Water Infrastructure Plans were enacted in January 1995 Pursuant to the enactment of the legislation, the Rhode Island Department of Health, Division of Drinking Water Quality, promulgated Rules and Regulations governing infrastructure

million in water treatment facilities, \$27.6 million in the transmission system, \$11.8 million in million into the system, with \$64.5 million in improvements in the distribution system, \$56.6 changing needs and priorities. Since FY 1996 through to June 30, 2010, we have reinvested \$190.5 regulations, each plan identified needed system improvements over each ensuing 20-year period. submitted its first 20-Year Infrastructure Replacement (IFR) plan to RIDOH. Our second IFR plan pumping and storage facilities, \$9.9 million in reservoirs and dams, \$13.8 million in meter was submitted March 30, 2001, and our third on March 23, 2006. In accordance with the This is the fourth plan being submitted to the Rhode Island Department of Health (RIDOH) by The plans were amended from time to time since 1996 to meet new challenges and to address Providence Water since enactment of the regulations. On February 29, 1996, Providence Water

infrastructure replacements in 1990, nearly \$200 million has been spent in improving the system. replacements, and \$6.3 million into support facilities. Since the inception of our program of

major focuses of our Infrastructure Replacement Program as we move forward. upgrading and replacement of distribution mains and their appurtenances is to become one of the installed in the 1800's. our distribution system date back 140 years, with approximately 27 percent of our water mains emphasize a major shift in concentration of work into the distribution area. The oldest portions of and within the distribution system alone. As with our previous plan, the latter years of this plan period, with \$110 million of that scheduled over the first five-year period at the treatment plant Our plan addresses \$426 million in needed improvements to the system over the next twenty-year To ensure the integrity and reliability of the system into the future, the

20 Year IFR Expenditure Plan Fiscal Years 2011 through 2030 Exhibit 1 Providence Water

RAW WATER SUPPLY	Total Amount 6,950,000	Budget 2011-2015 3,650,000	Budget 2016-2020 1,850,000	Budget 2021-2025 800,000	Budget 2026-2030 650,00
TREATMENT PLANT	81,935,000	45,080,000	34,085,000	1,735,000	1,035,00
PUMPING AND STORAGE	11,425,000	1,500,000	3,625,000	6,150,000	150,00
TRANSMISSION SYSTEM	18,100,000	4,500,000	2,650,000	8,300,000	2,650,00
DISTRIBUTION SYSTEM	260,235,000	53,610,000	67,400,000	61,975,000	77,250,00
SUPPORT SYSTEMS AND FACILITIES	6,700,000	1,250,000	1,950,000	1,750,000	1,750,00
2	2				

TOTAL

109,590,000 111,560,000 80,710,000 83,485,000

385,345,000



Exhibit 2 Providence Water 20 Year IFR Expenditures Fiscal Years 2011 through 2030



20 Year Investment - \$385 million







5 Year IFR Expenditure Plan Fiscal Years 2011 through 2015 Exhibit 10 Providence Water

Amount	Total
2011	Budget
2012	Budget
2013	Budget
2014	Budget
2015	Budge

RAW WATER SUPPLY

Reservoirs, Dams, and Watershed

Regulating Reservoir dam rehabilitation	1,200,000		300,000	000,000		
Gainer Dam Spillway Rehabilitation	300,000		300,000			
Large dam improvements	250,000	50,000	50,000	50,000	50,000	50,000
Secondary dam improvements	850,000		100,000	300,000	450,000	
Watershed fencing, fire lanes, property rehabilitation	250,000	50,000	50,000	50,000	50,000	50,000
Raw Water Structures and Conduits						
Meter & iunction chambers rehabilitation	700.000	700.000				

Raw Water Supply Total	90" influent conduit rehabilitation	60" influent conduits - inspection	Meter & junction chambers rehabilitation
3,650,000	50,000	50,000	700,000
800,000			700,000
900,000	50,000	50,000	
1,300,000			
550,000			
100,000			

TREATMENT PLANT

Plant Influent and Aerator						
Influent structure rehabilitation	330,000	75,000	130,000	75,000	50,000	
Aerator / Influent actuators and valves replacement	710,000	000,00	330,000	240,000	50,000	
Influent structure - replace drain and bypass valves	1,090,000	140,000	520,000	380,000	50,000	
Influent / Effluent aerator conduits Inspect / Rehabilitate	165,000	35,000	50,000	55,000	25,000	
Aeration basin concrete rehabilitation	800,000	100,000	350,000	300,000	50,000	
Aeration basin - replace piping, nozzles, and drain valves	1,200,000	150,000	550,000	450,000	50,000	
Aerated, Settled, and Filter Influent Conduits						
Settled water conduit - installation of access hatch	100,000	50,000	50,000			
Concrete conduits inspect / rehabilitate	1,100,000	100,000	550,000	400,000	50,000	
Influent venturis inspection	500,000	50,000	200,000	200,000	50,000	
Emergency bypass - clean tunnel and install sluice gate	75,000		75,000			
Chemical Storage, Transfer, and Feed Systems						
Chlorine system upgrades	2,500,000			250,000	1,000,000	1,250,000
Ferric system upgrades	250,000		250,000			

Concrete conduits inspect / rehabilitate	1,100,000	100,000	550,000	400,000	50,000	
Influent venturis inspection	500,000	50,000	200,000	200,000	50,000	
Emergency bypass - clean tunnel and install sluice gate	75,000		75,000			
Chemical Storage, Transfer, and Feed Systems						
Chlorine system upgrades	2,500,000			250,000	1,000,000	1,250,000
Ferric system upgrades	250,000		250,000			
Lime system upgrades	900,000	100,000	400,000	400,000		
Filters						
Filter replacement (including valves & piping)	29,000,000	000,000,0	7,000,000	5,000,000	4,000,000	4,000,000
Treatment process pilot model	150,000	100,000	50,000			



Infrastructure Replacement Plan IFR Expenditure Plan

Inspect wash water system

5,000

5,000

Infrastructure Replacement Plan IFR Expenditure Plan



TOTAL

\$109,590,000 \$26,320,000 \$19,650,000 \$23,755,000 \$20,420,000 \$19,445,000

Support System Facilities Total 1,26	acilities fencing and roads rehabilitation 25	uilding and facilities rehabilitation 1,00
50,000	50,000	00,000
250,000	50,000	200,000
250,000	50,000	200,000
250,000	50,000	200,000
250,000	50,000	200,000
250,000	50,000	200,000

SUPPORT SYSTEM FACILITIES

12,200,000	12,100,000	12,000,000	6,550,000	10,760,000	53,610,000	Distribution System Total
				10,000	10,000	Leak detection
			750,000	750,000	1,500,000	Valve data collection program
200,000	200,000	200,000	200,000	200,000	1,000,000	Replace fire hydrants
7,900,000	7,800,000	7,700,000		4,200,000	27,600,000	Replace lead services
100,000	100,000	100,000	100,000	100,000	500,000	Replace Distribution Valves
4,000,000	4,000,000	4,000,000	5,500,000	5,500,000	23,000,000	Replace / Upgrade water mains

DISTRIBUTION SYSTEM

Transmission Sy 16" and larger valves r 66", 60", 48" transmis 90" aqueduct inspecti

lion	1,500,000	000,000,1				
n	700,000			700,000		
on	500,000				500,000	
sion mains inspections	50,000			50,000		
eplacements	1,750,000		250,000	500,000	500,000	500,000
stem Total	4,500,000	1,500,000	250,000	1,250,000	1,000,000	500,000

Neutaconkanut reservoir rehabilitation	100,000	100,000	7	-		
Dean Estates pump station upgrades	1,200,000	1,200,000	2		8	
Various pump station improvements	100,000	20,000	20,000	20,000	20,000	20,000
Storage tanks inspections / improvements	100,000		50,000	50,000		
Pumping and Storage Total	1,500,000	1,320,000	70,000	70,000	20,000	20,000

102

78" aqueduct inspecti

ayu

" annoticet inconcetion	RANSMISSION	
	SYSTEM	

20,00	20,000	70,000	70,000	1,320,000	1,500,000	nd Storage Total
		50,000	50,000		100,000	inspections / improvements
20,00	20,000	20,000	20,000	20,000	100,000	station improvements
				1,200,000	1,200,000	pump station upgrades
				000,001	100,000	t reservoir rehabilitation

100,000	100,000	1,200,000	100,000
	20,000	1,200,000	100,000
50,000	20,000		
50,000	20,000		

PUMPING AND STORAGE

Sludge removal and disposal

pect service water system

SCADA / Control system upgrades PW lab / equipment Improvements Treatment plant building rehabilitation

Treatment Plant Total

45 (J)

6,375,000	6,500,000	8,885,000	11,630,000	11,690,000	080,000
1,000,000	1,000,000	1,000,000	1,000,000	1,000,000	000,000
		5,000			5,000
25,000	25,000	25,000	25,000	600,000	700,000
50,000	50,000	50,000	50,000	50,000	250,000
50,000	50,000	50,000	50,000	50,000	250,000

Building, Support, and Operational Systems

Total	Fiscal Years
Budget	2011 throu
Budget	igh 2015
Budget 2013	
Budget	
Budget 2015	

б

Year IFR Expenditure Plan

Providence Water Exhibit 10

2011 2012 2013 2014	Budget Budget Budget Budge
2014	Budget
2015	Budge

Total Amount

III - 8

Exhibit 11 Providence Water 5 Year IFR Expenditures Fiscal Years 2011 through 2015



5 Year Investment - \$109.6 million





EXHIBIT 12 - 5-Year IFR Project Overview - FY 2011 through 2015

RAW WATER SUPPLY

Reservoirs, Dams, and Watershed

Regulating Reservoir Dam Rehabilitation

drainage system along the length of the dam. concrete spillway, rehabilitating the concrete outlet structure, and rehabilitating the current stone walls along both the upstream and downstream slopes, inspecting and rehabilitating the protection along both the upstream and downstream slopes, repairing/replacing the existing inspection. Design is in progress for improvements to include regrading and providing armor The dam was inspected in 2004 and needed rehabilitative work was identified from the

Gainer Dam Spillway Rehabilitation

surface of the old unsound concrete along the upstream face of the spillway with a new concrete The upstream face of the spillway is exhibiting signs of wear. Plans are to completely replace all

Large Dam Improvements

deficiencies as identified through continuing inspections that are conducted on a quarterly basis. rehabilitative work to correct deficiencies. Work under this project is to address minor dams, with the exception of the Regulating Reservoir Dam, have recently undergone major Pond Dam, Ponaganset Reservoir Dam, and Regulating Reservoir (Horseshoe) Dam. tributary reservoirs dams, Barden Reservoir Dam, Westconnaug Reservoir Dam, Moswansicut Six dams are part of the Scituate Reservoir water complex: Gainer Memorial Dam and its five All the

Secondary Dams Improvements

to address needed improvements to extend their useful lives. watershed. This will establish a scope of work in the subsequent years of the twenty-year plan inspections. of the Scituate Reservoir. Plans are to rehabilitate several of the secondary dams based on prior were constructed primarily for mill purposes in the mid to late 1800's prior to the development Several small secondary dams are located throughout the watershed. These secondary dams In addition, plans are to inspect the remaining smaller secondary dams along the

Watershed Fencing, Fire Lanes, Property Rehabilitation

determined by condition assessments construction in the 1920's. The fencing and road improvements are selected by priority as The fences and access roads, much of which are in poor condition, date back to their original

Raw Water Structures and Conduits

Meter and Junction Chambers Rehabilitation

reinforced concrete columns partially submerged concrete filled cast iron pipe support columns will be replaced with chamber. 480V/120V-230V transformer, and installing additional lighting along the entire length of the feeders into the new breaker, changing out the existing 600V/120-230V transformer with a new new breaker in the 480V panelboard in the Gainer Dam Gatehouse for connecting the existing construction joints to stop leakage of groundwater into the tunnel. Plans are for also installing a membrane, removing and replacing the damaged sections of fence along the roof and injecting the Scituate Reservoir Dam which includes replacing the existing exterior rubber roof A construction contract has been awarded for rehabilitation of the Meter Chamber structure at The exterior coating of the 60" conduits will be rehabilitated as necessary, and the

inside and outside the structure, and rehabilitation of the exterior coating of the 60" the air release/vacuum valve assemblies, installing new lighting to improve lighting conditions the lower portion of the structure, cleaning and painting the outside steel access doors, replacing improvements, installing a new aluminum staircase to allow access from the entry platform to At the junction chamber, a construction contract has been awarded for exterior rip-rap conduits.



60" Influent Conduits - Inspection

inspection only. cannot be anticipated in advance, the budgeted amount shown for this project is for the evaluation and testing of the existing cathodic protection system. As the need for remedial work evaluation of soils along the pipeline, soil resistivity testing, an internal pipeline inspection, and assessment. Inspection of the underground pipeline consists of an over-the-line survey, an exposed piping consists of evaluating the condition of the exterior coating and an internal pipe Plans are to inspect the interior and exterior of the conduits every ten years. Inspection of the

90" Influent Conduit - Rehabilitation

concrete lining as identified during the inspection / assessment phase. approximately 85 years old. The pipeline was recently inspected. Plans are to rehabilitate the The 90" influent conduit that transports raw water from Gainer Dam to the treatment plant is



TREATMENT PLANT

Plant Influent and Aerator

Design is substantially in progress. The project is comprised of the following six sub-projects

Influent Structure Rehabilitation

equipment from the elements. top of the existing footprint of the structure to protect the new actuators and electrical capacity for water influent through the structure. appurtenances. requires replacement. Plans are for the rehabilitation of the concrete structure and weather and concrete deterioration is evident. Steel grating on the structure is corroding and approximately 85 years. The exterior above-grade portion of the structure is exposed to the The influent structure is a reinforced concrete structure which has been in service The overflow weir in the influent structure will be raised to increase hydraulic A masonry structure will be constructed on for

Aerator / Influent Actuators and Valves Replacement

existing SCADA system. conduits, power wiring and disconnects, and incorporating the new valve operators into the age and condition. This project also consists of replacing the electric actuators, electrical The 4 electrically operated 36-inch butterfly valves for the aerators will be replaced due to their

Influent Structure - Replace Drain and Bypass Valves

guides. valves, the 3 drain sluice gates, the north influent venturi sluice gate, and all valve stems and inoperable, and require replacement. The project consists of the replacement of the 4 bypass gate evidence of corrosion. The stems for the valves are worn, in some cases distorted and accuracy. The valves, valve stems and operators are all approximately 85 years old and show purpose of diverting influent water through the south venturi meter to maintain flow meter inch influent venturi sluice gate was used during periods of extremely low influent flow for the influent control structure, influent tunnel, settled water conduit, and the mixer. A 72-inch by 72-Three 36-inch by 36-inch drain sluice gates are used to drain the aerator effluent conduit, Four 36-inch bypass gate valves allow diversion of influent water to bypass the aeration basin. A new 72-inch by 72-inch sluice gate will be installed at the south venturi meter



system. actuators conduits. entrance to provide the ability to isolate the influent control chamber from the downstream with position and control signals that will be incorporated into the existing SCADA The existing manually operated valve actuators will be replaced with electric

Influent / Effluent Aerator Conduits Inspect / Rehabilitate

concrete conduits revealed areas that require rehabilitation addressed under this project external inspection of the steel conduits, as well as structural evaluations of the steel and An internal inspection of the steel and concrete influent and effluent aerator conduits, and an

Aeration Basin Concrete Rehabilitation

the hydraulic capacity for gravity water flow through the plant location. This project also includes raising the elevation of the basin's circular weir to increase replacement and relocation of the aeration basin in a westerly direction away from its current term exposure to weather and treatment chemicals. This project includes the complete an uneven surfaces and exposed joints. The concrete is also severely deteriorated due to long process takes place. The concrete panels forming the basin have settled and shifted, resulting in The aeration basin is a reinforced concrete lined basin within which the influent water aeration

Aeration Basin - Replace Piping, Nozzles, and Drain Valves

piping, fittings, nozzles, and the aeration basin drain valve the air which spray influent water into the air. This project includes complete replacement of all Aeration takes place through a series of aerator nozzles and jets, which spray influent water into

Aerated, Settled, and Filter Influent Conduits

Design is substantially in progress. The project is comprised of the following four sub-projects.

Settled Water Conduit - Installation of Access Hatch

access hatch in conjunction with the filter rehabilitation project. access rectangular underground reinforced concrete conduits constructed in 1925. Aerated and settled water is conveyed to the various treatment processes through circular and to the upper settled water conduit as it is currently configured. Plans are to install an The hatch will facilitate entry There is limited

Vater **V**ater

into the settled water conduit by providing a safer and more convenient access point for inspection and rehabilitation operations

Concrete Conduits Inspect / Rehabilitate

revealed deteriorated areas that require concrete rehabilitation addressed under this project. the sludge lagoons. An internal inspection and structural evaluation of the concrete structures from backwashing operations of the filters to the main washwater drain that eventually leads to the filter influent conduit is a rectangular washwater drain conduit that conveys water released to the filter influent conduit which conveys the water to the 18 filters. Located directly below wide rectangular reinforced concrete conduit that conveys settled water from the settling basins upper settled water conduit. The upper settled water conduit is an 11.5 foot high by 10 foot aerated water to the tangential mixer. A bypass chamber connects the lower conduit to the The 12 foot high by 8.5 foot wide rectangular reinforced concrete lower conduit conveys the

Influent Venturis Inspection

measure the flow rate of water entering the plant lead to two 72 inch by 36 inch cast-in-place venturi concrete flow meters. These venturis Aerated water enters two 72 inch diameter reinforced concrete conduits, 45 feet in length, which

original specifications considerations concluded that it is not cost effective to rehabilitate the existing venturi meters to An internal inspection, structural evaluation, performance evaluation, and plant operational

junction chamber. The flow signals will be incorporated into the existing SCADA system installing new vortex meters within the twin existing 60" plant influent conduits upstream of the This project consists of encapsulating and abandoning the existing venturi meters in place and

Emergency Bypass - Clean Tunnel and Install Sluice Gate

it becomes necessary to bypass the plant's treatment process in the event of an emergency. with emergency disinfection treatment only, to flow directly to the effluent conduit in the event to the emergency bypass chamber. The purpose of the bypass tunnel is to allow aerated water, A 6 foot wide by 7.5 foot high bypass tunnel connects the lower influent (aerated water) conduit \triangleright

bypass tunnel to prevent future buildup of the lime sludge. addressing required concrete rehabilitative work and installing a flap gate at the entrance of the event that the bypass would need to be utilized. Plans are for cleaning the lime sludge buildup, the lime solution injection point in the lower conduit which would be an impediment in the buildup of lime sludge currently occurs in the bypass tunnel due to its location downstream of

Chemical Storage, Transfer, and Feed System

Chlorine System Upgrades

generation of the solution. new system should consist of the bulk storage of delivered sodium hypochlorite or on-site hypochlorite system. As part of the project, a study will be conducted to determine whether the transport and storage, the entire gaseous chlorine system will be replaced with a new sodium However, in light of increasing safety and security concerns associated with bulk gaseous Original plans called for the replacement of the existing gaseous chlorine feed equipment.

Ferric System Upgrades

will be further inspected and rehabilitative work performed as needed and surface recoating of the tank containment area. Additionally, the transfer and feed system tanks' exterior urethane foam insulation, replacement of exterior pipe and strainer insulation and associated piping are in need of some rehabilitative work. Work will include repairs to the The liquid ferric storage system was installed in 1997. The three 12,000 gallon bulk storage tanks

Lime System Upgrades

nature of the chemical. existing pipe bends for the lime transfer system will need to be replaced due to the abrasive investigate the benefits and cost of switching from quicklime to hydrated lime. still providing sufficient redundancy. As part of the project, a study will be performed to as the current lime feed system does not have the capacity to handle the expected increase while chemical feed system presently being installed, the existing feed system will need to be replaced Due to the expected increase in lime dosage required as a result of the new carbon dioxide In addition, the

Filters

Filter Replacement

proprietary system replacement of the existing old control board SCADA system with a new state of the art nonconditions and facilitate construction activity of the project. The scope of work also includes the will also consist of new lighting, HVAC, and a new outside access point that will improve safety gallery to an enclosed area to be constructed outside the building. Pipe gallery improvements and the relocation and replacement of the 48" washwater pipe from inside the congested pipe replacement of all filter piping, control valves and meters, installation of filter-to-waste piping, visibility and access to the entire surface areas of the filters. The project also includes construction of above-ground protective building structures in their place which will furnish full removing the existing underground concrete roof slab structures covering the filters with depth providing the option for future use of granular activated carbon (GAC), completely reconstructing all 18 filters, raising the filter backwash troughs to provide greater filter media date back to the plant's original construction in the 1920's. The scope of work includes The filter media in the plant filters dates back to the 1960's and parts of the underdrain system

and erection of the new filter superstructure above the rebuilt filters installation of new backwash troughs, incorporation of an air scour system, new filter media, including construction of new concrete gullet walls, installation of new filter underdrains gallery. The second phase will include the complete reconstruction of all eighteen filter boxes The project is currently in the first phase of construction, focused primarily within the pipe

Treatment Process Pilot Model

manganese in the event that GAC media is utilized impact of prechlorination on its life and whether a pre-oxidant will be required to control carbon (GAC) as the filter media at the treatment plant. Piloting work includes determining the compliance with current regulations. treatment train and is being used to evaluate various treatment alternatives to ensure continued A bench-scale pilot is operational at the treatment plant. This bench-scale pilot models the Being studied is the potential use of granular activated
Inspect Washwater System

any deficiencies that are identified. evaluate the condition of the pumps, perform a structural evaluation of the tank, and address centrifugal pumps are used to fill the washwater tank between filter backwashes. filters, is a circular reinforced concrete underground tank. The 400,000 gallon washwater tank, which provides backwashing water to the treatment plant's Two 5,600 GPM horizontal Plans are to

Building, Support, and Operational Systems

Treatment Plant Building Rehabilitation

public address system, and site improvements as needed plumbing, and mechanical systems, security and fire system upgrades, replacement of the reconditioning, architectural and structural improvements, rehabilitation of the electrical, The plant will be in need of ongoing improvements. Funds are budgeted for office

PW Lab / Equipment Improvements

as it becomes necessary. The budget amounts shown in the plan are for anticipated needs depending on the type of equipment and frequency of use. Plans are to replace this equipment testing and monitoring equipment utilized has a normal life ranging from 4 to 15 years Extensive testing of the raw and treated water is required on a regularly scheduled basis. The

SCADA / Control System Upgrades

console and WonderWare control system software upgrade (PLCs), I/O modules, racks and terminations, data communication network, a new operator Improvements include new workstations, monitors servers, Programmable Logic Controllers upgrades to the existing SCADA system presently underway at the treatment plant The budget amount in the first year of the plan represents the completion of construction for the

future hardware replacements and software upgrades on an as-needed basis. been budgeted for the upgrade of the remote PLC system and additional software programming Because computer technology is ever-changing and upgrades are routinely needed, funds have Annual funds are budgeted to anticipate ongoing needs which include



Inspect Service Water System

system will be evaluated and replaced if needed needed to the interior and exterior surfaces of the tank, and the current cathodic protection address any deficiencies identified. As part of the scope, a coating application will be applied as service and process water system. Plans are to perform a structural evaluation of the tank, and height. Two 1750 GPM horizontal centrifugal pumps pump water to the tank to feed the plant's tank, approximately 90 feet high and 20 feet in diameter with a 36-inch diameter riser 63 feet in The 40,000 gallon welded steel service water tank, constructed in 1961, is a double ellipsoidal

Sludge Removal and Disposal

this work to continue over the subsequent years disposal of the previously stockpiled sludge that was dredged from Lagoon 2, with payment for discharged to the Pawtuxet River. Remaining work for sludge removal consists of transport and storage and serving as a buffer that will maintain an acceptable standard of water quality from all three lagoons restoring them to their original design intent of providing adequate allowed to accumulate since the plant was originally placed in operation has now been removed sedimentation operations at the plant. All sludge accumulation that had been previously treatment plant to receive periodic sludge discharges resulting from filter backwash and The three lagoons (1A, 1B, & 2) were constructed in 1924 during the construction of the

PUMPING AND STORAGE

Neutaconkanut Reservoir Rehabilitation

with a new 48" butterfly valve the reservoir, is difficult to operate and is in need of replacement. Plans are to replace this valve Neutaconkanut Pump Station. The main isolation gate valve, located in a valve vault outside of constructed in 1928. Neutaconkanut Reservoir has a storage capacity of 42.1 MG. The facility feeds the gravity fed Low Service system and the This underground tank was

Dean Estates Pump Station Upgrades

improvements to the pump station building. and electrical system upgrades, installation of an emergency generator, and architectural drive vertical turbine pumps, elimination of the aged hydropneumatic tanks, instrumentation rehabilitation of the Dean Estates Pump Station includes installation of new variable frequency Station which will allow for the abandonment of the Garden Hills Pump Station. The Glen Hills Drive Bridge crossing RI 37. Plans are to rehabilitate only the Dean Estates Pump zone served by one pump station. To accomplish this, a new water main will be installed at the includes combining the Garden Hills and Dean Estates pressure zones into a single pressure Construction has begun to rehabilitate the Dean Estates Pump Station. The scope of work

Various Pump Stations Improvements

remedy deficiencies as identified components of each pump station. Funds have been budgeted for anticipated improvements to Plans are to periodically inspect all mechanical, electrical, architectural, and structural

Storage Tanks Inspections / Improvements

for inspection only. and FY2013. Since remedial work cannot be identified at this time, the budget amount shown is ten years to assess their condition. All five tanks are scheduled for inspection during FY2012 reservoirs and one aboveground tank. Plans are for interior inspections of the structures every Providence Water's distribution storage system consists of 4 underground concrete storage

TRANSMISSION SYSTEM

102" Aqueduct Inspection

rehabilitation work only. be quantified at this time, the budget amount shown is for inspection and some minor perform interior and exterior inspections of the aqueduct in 2011. Since remedial work cannot found needed in both cases. In accordance with the inspection schedule, plans are to again schedule. The aqueduct has been twice inspected since the with major rehabilitative work being inspecting and rehabilitating (as necessary) this critical transmission line on a regular 5-year where the side wall of the pipeline failed. Following the break, a program was developed for this pipeline where it crosses Oaklawn Avenue in Cranston experienced a catastrophic break 1960's and consists of prestressed concrete cylinder pipe (PCCP). In November 1996, a section of The 102" aqueduct transmission line, approximately 5.2 miles in length, was constructed in the

78" Aqueduct Inspection

quantified at this time, the budget amount shown is for inspection only. inspection of the line is scheduled in the five-year plan. Since remedial work cannot be and rehabilitating (as necessary) this transmission line on a regular 5-year schedule. The next significant rehabilitative work became necessary. lined tunnel. 1960's and consists of prestressed concrete cylinder pipe (PCCP) and two sections of concrete The 78" aqueduct transmission line, approximately 4.4 miles in length, was constructed in the The 78" pipeline was first inspected in 2008. Major deficiencies were found and A program has implemented for inspecting

90" Effluent Aqueduct Inspection

only remedial work cannot be quantified at this time, the budget amount shown is for inspection thereafter. Plans are to perform interior and exterior inspections of the aqueduct. Since concrete lined tunnel section between the west and east portals, and reinforced concrete pipe The 4.5 mile long aqueduct transmission line was constructed in the 1920's. It is comprised of a

66", 60", 48" Transmission Mains Inspections

inspection only. Since remedial work cannot be quantified at this time, the budget amount shown is for pipelines, rehabilitate the pipe as needed, and provide corrosion protection where applicable. feeding Neutakoncanut Reservoir. Plans are to perform interior and exterior inspections of the 1926. The reinforced concrete steel cylinder pipeline transitions to a 2100 feet long 48" pipeline 1500 feet to Reservoir Avenue. The 22,140 feet long 60" Neutaconkanut Conduit was installed in riveted steel 48" main at Budlong Road in Cranston which then continues easterly an additional The 66" main, installed in 1926, is an 8500 feet long riveted steel pipeline which transitions to a

16" and Larger Valves Replacements

given to replacing valves that are found to be defective butterfly valves with the emphasis placed on the most critical valves. Emphasis will also be are to replace the 16" and larger valves in the system that are older than 75 years with new to successfully operate these valves when needed is critical in an emergency shutdown. Plans There are approximately 814 transmission valves in the system. Because of their size, the ability

DISTRIBUTION SYSTEM

Replace / Upgrade Water Mains

area of increasing concentration as our IFR program proceeds savings can be realized. The upgrading or replacement of distribution mains will become an also be given to replacements in areas of local and state road resurfacing projects where cost quality complaints, past leak history, and main sampling will all be considered. mains will need to receive first priority. Factors such as flow testing, hydraulic modeling, water quality complaints or flow problems have been documented. Generally, older unlined cast iron for upgrading or replacement. ranging in size from 6" The Providence Water system consists of approximately 885 miles of smaller distribution pipes to 12". Of these, approximately 27% are pre 1900 and will be candidates The first order of priority will be to replace mains where water Emphasis will

Replace Distribution Valves

realized. Emphasis will also be given on replacing valves found to be defective to replacements in areas of local and state road resurfacing projects where cost savings can be criteria for mains. In accordance with current practice, emphasis will also continue to be given replacement program. This will generally prioritize the replacement of valves, using the same diameter valves pre 1900. Plans are to replace these valves in conjunction with the main Of the approximately 13,500 valves in the system, 1,900 have been identified as 6", 8" and 12"

Replace Lead Services

reassessed Water falls below the action level, our plan for the replacement of lead services we will the annual replacement of 7% of its 25,000 lead services. If at some future date Providence taps sampled, and was required in September 2006, in accordance with the regulations, to begin Rule, Providence Water exceeded the lead action level of 15 ppb in more than 10% of customer As a result of lead testing within the system under the requirements of the Lead and Copper

also be replaced on an ongoing basis under special conditions and where customers are services will be replaced in conjunction with the water main replacement program. Services will In addition to the scheduled replacement of lead services under our formal program effort, lead



are found to be leaking. replace lead services in areas of local and state road resurfacing projects and where lead services voluntary replacing their private side lead service. Providence Water will also continue ð

Replace Fire Hydrants

replacing hydrants that are found defective. become 75 years old with new breakaway style hydrants. Emphasis will also be given on There are 6,067 hydrants in the system. Plans are generally to replace all hydrants as they

Valve Data Collection Program

and asset management system. mapping with GPS to integrate water system utility information into Providence Water's GIS all valve assets, testing and operating each valve, documenting the valve data and condition, The project consists of performing an initial field assessment of the condition and operability of

Leak Detection

leak detection survey at approximately 10-year intervals. 6,067 hydrants. A system-wide leak detection was completed in 2010. The plan is to perform a transmission mains, 814 transmission valves, 13,500 distribution valves, 74,000 services, and The system is comprised of approximately 885 miles of distribution mains, 114 miles of

SUPPORT SYSTEM FACILITIES

Building and Facilities Rehabilitation

upgrades, and site improvements. rehabilitation of the electrical, plumbing, and mechanical systems, security and fire system budgeted for reconditioning the offices, architectural and structural improvements The Forestry Maintenance Garage, the Academy Avenue Administration Building, and the Aqueduct Reservoir Office Buildings are in need of ongoing improvements. Funds are

Facilities Fencing and Roads Rehabilitation

selected by priority as determined by condition assessment. distribution reservoirs, pump stations, and facilities. The fencing and road improvements are Plans are to replace damaged fencing and rehabilitate deteriorated roads at some of the various

identified and reported prior to fiscal year 2011. reflect the entire cost of the project. The balance that makes up the full project cost was costs for the remainder of the project. Therefore, in these instances the budget amount does not Note: Some of these projects are in progress and the cost shown for the project may be a partial

⊖rovidence SWater

15 Year IFR Expenditure Plan **Providence Water** Exhibit 13

Fiscal Years 2016 through 2030

	DAWI WATED CIIDDI V		

Amount Total

2016-2020 Budget

2021-2025 Budget

2026-2030 Budget

Gainer Dam Gatehouse Improvements	Raw Water Booster Pump Station Improvements	Secondary Dam Improvements	Large Dam Improvements

Raw Water Conduit Improvements

1,000,000

1,000,000

150,000 250,000

200,000 450,000 750,000

200,000

250,000

250,000

250,000

150,000

150,000

150,000

Watershed Fence and Road Rehabilitation

Raw Water Supply Total

3,300,000

1,850,000

800,000

650,000

250,000

750,000 150,000

250,000

TREATMENT PLANT

Process Meter Renlacements
Treatment Plant Laboratory Improvements
Filter Improvements
Chemical Storage/Transfer/Feed Systems Improvements
Sedimentation Basins Rehabilitation
Conduits and Structures Inspection/Rehabilitation
Central Control System (SCADA) Upgrades

Treatment Plant Total

Treatment Plant Building Improvements

Lagoon System Improvements

P
C
\leq
P
₹
G
Þ
z
S
-
0
70
Þ
G
m

Pump Station Improvements
Bath Street Pump Station Improvements
Neutaconkanut Pump Station Improvements

425,000

125,000

150,000

150,000

2,000,000

2,000,000

Greenville Ave Pump Station Improvements
Cranston Commons Pump Station Improvements
Fruit Hill Pump Station Improvements
Storage Tank Inspections / Improvements

_						
9,925,000	2,000,000	1,000,000	1,500,000	1,000,000	2,000,000	2,000,000

1,500,000

1,000,000

1,000,000

1,035,000	1,735,000	34,085,000	000
250,000	250,000	2,400,000	0,000
100,000	100,000	1,000,000	0,000
75,000	75,000	75,000	5,000
250,000	250,000	250,000	0,000
	200,000		0,000
150,000	400,000	150,000	0,000
		30,000,000	0,000
10,000	260,000	10,000	0,000
200,000	200,000	200,000	0,000
			511

36 855 (2,900,	1,200,	225,	750,	200,	700,	30,000,	280,	600,
000	,000	,000	5,000	,000	,000	,000	,000	,000	,000

200,000 10,000 30,000,000 150,000 250,000 75,000
200,000 200 10,000 260 30,000,000 400 150,000 400 250,000 250 75,000 75
200,000 200 10,000 260 30,000,000 400 150,000 400 250,000 250
200,000 200 10,000 260 30,000,000 400 150,000 400
200,000 200 10,000 260 30,000,000 150,000 400
200,000 200 10,000 260 30,000,000
200,000 200 10,000 260
200,000 200

	200
1,000,000	0,000
75,000	25,000
250,000	50,000
	0,000
150,000	0,000
30,000,000	0,000
10,000	30,000
200,000	0,000

-	
50	
8	
ō	

2,000,000

3,625,000

6,150,000

26

Ξ



Infrastructure Replacement Plan IFR Expenditure Plan

Pumping and Storage Total

15 Year IFR Expenditure Plan Fiscal Years 2016 through 2030 **Providence Water** Exhibit 13

5,400,000	Total Amount
1,600,000	Budget 2016-2020
1,800,000	Budget 2021-2025
2,000,000	Budget 2026-2030

600,00	500,000	1,000,000
50,0		50,000
	6,000,000	
2,000,00	1,800,000	1,600,000

6,000,000

2,	8,300,000	2,650,000
	500,000	1,000,000
		50,000
	6,000,000	
2	1,800,000	1,600,000

66", 60", 48" Transmission Main Inspections

90" Aqueduct Inspection / Rehabilitation

78" and 102" Aqueducts Inspection / Rehabilitation

TRANSMISSION SYSTEM

2,650,000 8,3	1,000,000	50,000		1,600,000 1
300,000	500,000		000,000	000,008,1
2,650,000	600,000	50,000		2,000,000

13,600,000	2,100,000	100,000
2,650,000	1,000,000	50,000
~		

8,300,000	2,650,000
500,000	1,000,000
	50,000
6,000,000	

2,6	8,300,000	2,650,000
	500,000	1,000,000
		50,000
	6,000,000	

206.625	100	3,750	40,900	1,875	160,000	
000	0,000	0,000	0,000	5,000	0,000	

206,625,000	100,000	3,750,000	40,900,000	1,875,000	160,000,000
00	8	8	8	8	8

206,625,000	100,000	3,750,000	40,900,000	1,875,000	160,000,000

N	L .
0	L .
0	L .
-	L .
0	1
N	1
G	
0	
õ	1
č	
0	

77,250	61,975,000	67,400,000
	100,000	
1,50	1,250,000	1,000,000
		40,900,000
75	625,000	500,000
75,00	60,000,000	25,000,000

77,250,000	61,975,000	67,400,000
	100,000	
1,500,000	1,250,000	1,000,000
		40,900,000
750,000	625,000	500,000
75,000,000	60,000,000	25,000,000

206,625,000	100,000	3,750,000	40,900,000	1,875,000
ä				

N	
00	
6	
N	
0,0	,
ŏ	8
0	

Distribution System Total

Hydrant Replacements

Leak Detection

Distribution Main Upgrades

Distribution Valve Replacements

Lead Service Replacements

DISTRIBUTION SYSTEM

Transmission System Total

16" and Larger Valve Replacements

	1		
3,000,000	206,625,000	100,000	

SUPPORT SYSTEMS AND FACILITIES	
Building and Facilities Rehabilitation	
Records Management (GIS) Upgrades	
acility Fence and Road Rehabilitation	

1,000,000

1,000,000

1,000,000

5,450,000	200,000	750,000	1,500,000

Sul
opol
tsy
stems
and
Facilities
Total

Underground Fuel Storage Tank Replacements

-	
0	
7	
~	

275,755,000 111,560,000

80,710,000

83,485,000

1,750,000	1,750,000	1,950,000
		200,000
250,000	250,000	250,000
500,000	500,000	500,000



EXHIBIT 14 – 15-Year IFR Project Overview – FY 2016 through 2030

RAW WATER SUPPLY

Large Dam Improvements

extend their useful lives. Amounts are budgeted for ongoing needed improvements Plans are to inspect all 6 dams and structures and to conduct remedial work as required to

Secondary Dam Improvements

improvements for the continual upkeep of all 6 dams and appurtenant structures remedial work as required to extend their useful lives. Amounts are budgeted for needed of the Scituate Reservoir. Plans are to inspect all secondary dams and structures and to conduct were constructed primarily for mill purposes in the mid to late 1800's prior to the development Several small secondary dams are located throughout the watershed. These secondary dams

Raw Water Booster Pump Station Improvements

restoration includes replacement of the garage doors, windows and roof replacement, and brick and tile Various architectural improvements are needed at the Raw Water Booster Pump Station. Work

Gainer Dam Gatehouse Improvements

rehabilitation along with replacement of the two existing cranes The gatehouse dates back to its original construction in the 1920's and is in need of architectural

Raw Water Conduit Improvements

advance, the budget amount shown for this project is for inspection only inspection will be addressed. Since the quantity of remedial work cannot be anticipated in inch influent conduit every 10 years. Any remedial work that may be required as a result of the Plans are to inspect the interior and exterior of the two 60-inch raw water conduits and the 90-

Watershed Fence and Road Rehabilitation

budgeted to perform ongoing rehabilitative work as needed. are in poor condition, date back to their original construction in the 1920's. Amounts are on the watershed and Providence owned property. The fences and access roads, some of which There are approximately 40 miles of fencing and 66 miles of access roads and fire lanes that exist



TREATMENT PLANT

Central Control System (SCADA) Upgrades

SCADA system. hardware replacements, software upgrades, and new hardware and software additions to the plan to address continued upgrade needs for the SCADA system. Needs will consist of Given that the nature of computer technology is ever changing, funds have been budgeted in the

Conduits and Structures Inspection / Rehabilitation

and to address minor rehabilitative work only. water tank every five years. A budget amount has been included to perform these inspections years. water conduit (upper conduit), filter influent conduit, clearwell, and washwater tank every ten aerator conduits, aerated water conduit (lower conduit), emergency by-pass tunnel, settled This project consists of internal inspections of the influent control structure, influent/effluent The project also consists of an internal inspection and structural analysis of the service

Sedimentation Basins Rehabilitation

place. project is at this point conceptual in nature only continuous basis, eliminating sludge buildup and cleaning and handling requirements. Providence Water is considering a new modern-design settling system to be installed in their of this sedimentation process by today's standards, we have reconsidered this approach rehabilitate and renew them back to nearly original condition. In light of the outmoded nature and slabs making up the basin have deteriorated over time and initially our IFR plans were to part of the plant's original construction back in the 1920s. The massive area of concrete walls The sedimentation basins at the plant consist of two large open water surface basins that were Such an installation would consist of automatic mechanized removal of sludge on a This

Chemical Storage/Transfer/Feed Systems Improvements

period. Amounts are budgeted for needed improvements to the feed systems during the 15-year plan Five chemicals are added in the treatment process at different locations at the treatment plant.

storage, transfer, and feed systems will need to be rehabilitated during the 15-year period. Due to the corrosive nature of the ferric sulfate, it is anticipated that various components of the

regular intervals nature of the dry chemical, sections or all of the transfer piping will need to be replaced at The lime feeders will be replaced during the first five years of the plan. Due to the abrasive

work will be performed as needed of the plan. The new system will be inspected during the 15-year plan period and remedial The chlorine gas system will be replaced with a liquid chlorine system during the first five years

rehabilitated during the 15-year period anticipated that various components of the storage, transfer and feed systems will need to be fluoride system was installed back in 2005. Due to the corrosive nature of the chemical, it is Fluoride is added as a liquid in the clearwell just prior to water leaving the treatment plant. The

performed as needed new system will be inspected during the 15-year plan period and remedial work will be \geq carbon dioxide feed system is currently under construction under the Capital Program. The

Filter Improvements

upkeep of the entire filtration system during the 15-year period first five years of the plan. Amounts are budgeted for needed improvements for the continual All eighteen filters, including all valves and piping, are scheduled to be rehabilitated during the

Treatment Plant Laboratory Improvements

necessary. The budget amounts shown in the plan are for anticipated needs. The plan is to replace laboratory equipment and provide architectural upgrades as they become

Process Meter Replacements

meters, pH meters, turbidimeters, and a total organic carbon meter. scheduled replacements, PW is planning to replace fluoride residual meters, chlorine residual regular interval is required to ensure the accuracy and reliability of the data. collected and logged for record and reporting purposes. Replacement of this equipment on a and in the distribution system for monitoring and maintaining water quality. The data is Several types of process metering and monitoring equipment are used at the treatment plant Based on

Lagoon System Improvements

in accordance with contractual requirements was dredged from Lagoon 2. Payment for this work will end in the first year of the 15-year plan sludge removal consists of the transport and disposal of the previously stockpiled sludge that acceptable standard of water quality discharged into the Pawtuxet River. Remaining work for original design intent of providing solids settling and an adequate buffer to maintain an All sludge accumulation has now been removed from the three lagoons to restore them to their

Treatment Plant Building Improvements

structural, architectural, and mechanical rehabilitation and upgrades Various rehabilitative work has been conducted at the facility. The building requires ongoing

PUMPING AND STORAGE

Pump Station Improvements

and to remedy deficiencies as they are identified through inspections components of each pump station. Funds have been budgeted for anticipated improvements, Plans are to periodically inspect all mechanical, electrical, architectural, and structural

Bath Street Pump Station Improvements

to the station will be required in the second five-year period of the fifteen-year plan. will be needed at this pump station as they are identified through inspections. It is anticipated that various mechanical, electrical, architectural, and structural improvements Major upgrades

Neutaconkanut Pump Station Improvements

to the station will be required in the second five-year period of the fifteen-year plan. will be needed at this pump station as they are identified through inspections. Major upgrades It is anticipated that various mechanical, electrical, architectural, and structural improvements

Greenville Avenue Pump Station Improvements

to the station will be required in the first five-year period of the fifteen-year plan will be needed at this pump station as they are identified through inspections. Major upgrades It is anticipated that various mechanical, electrical, architectural, and structural improvements

Cranston Commons Pump Station Improvements

generator station with an above ground pre-engineered packaged unit with its own emergency back-up Anticipated in the first 5 years of the 15-year plan is the replacement of the below grade pump

Fruit Hill Pump Station Improvements

and structural improvements along with upgrades to the various mechanical and electrical systems, as well as architectural It is anticipated that pumps will need to be replaced in the first five years of the 15 year plan



Storage Tanks Inspections / Improvements

structure. Since remedial work cannot be quantified at this time, the budget amounts shown in the plan are for inspection only. dewatering the structure. More extensive inspections will be conducted in a fully dewatered for the 5 tanks in the system. Visual inspections will be performed by divers without Plans are to alternately perform a visual inspection and an extensive inspection every ten years



TRANSMISSION SYSTEM

78" and 102" Aqueducts Inspection / Rehabilitation

78" and 102" lines will continue to be inspected and rehabilitated, as necessary, every five years. inspections. significant rehabilitation as extensive corrosive damage has been discovered in previous sections of concrete lined tunnel. The 78" and the 102" aqueducts have both undergone constructed in the 1960's and consist of prestressed concrete cylinder pipe (PCCP) and two The 78" and 102" aqueduct transmission lines, approximately 9.6 miles in length, were In accordance with the inspection and rehabilitation program developed, both the

90" Aqueduct Inspection / Rehabilitation

and for conducting contact grouting of the tunnel section. inspection. regular schedule and future rehabilitative work will be conducted based upon the results of the incorrectly. The 90" aqueduct, including the effluent venturi meters, will be inspected on a taken place during the original construction of the aqueduct was never performed, or performed inspection of the tunnel section, it was discovered that the contact grouting that was to have rehabilitated as corrosive damage was discovered during the inspection. During the last reinforced concrete pipe thereafter. This 90" aqueduct was previously inspected and miles. It is constructed of a concrete lined tunnel section between the west and east portals, and The 90" effluent finished water aqueduct, constructed in the 1920's, runs approximately 4.5 An amount has been budgeted for inspection of the entire length of the aqueduct

66", 60", 48" Transmission Mains Inspection

the budget amount is only for inspection corrosion protection where applicable. Since remedial work cannot be quantified at this time, Reservoir. Plans are to perform interior and exterior inspections of the pipelines and to provide reinforced concrete steel cylinder pipeline for an additional 2100 feet to the Neutakoncanut (Neutaconkanut Conduit), installed in 1926, extends for 22,140 feet and feeds into a 48' 1500 feet to Reservoir Avenue. The 60" reinforced concrete steel cylinder pipeline transitions into a riveted steel 48" main at Budlong Road and continues easterly for an additional The 66" main, installed in 1926, is a riveted steel pipeline and extends for 8500 feet and then

16" and Larger Valves Replacements

will also be given on replacing valves that are found defective. years with new butterfly valves with the emphasis placed on the more critical valves. Emphasis year period. Plans are to replace the 16" and larger valves in the system that are older than 75 All transmission valves installed through 1955 are being targeted for replacement over the 15-



DISTRIBUTION SYSTEM

Distribution Main Upgrades

water quality, flow capacity, and overall condition of the mains. mains, but determinations of mains to be replaced will also be based on other factors including concentrations in the future of the program. The initial general plan is to replace all pre 1900 priority. The upgrading or replacement of distribution mains will be one of the major upgrading or replacement. Generally, older unlined cast iron mains will need to receive first from 6" to 12". The system consists of approximately 885 miles of smaller size distribution pipes ranging in size Of these mains, approximately 27 percent are pre 1900 and will be candidates for

Distribution Valve Replacements

projects where cost savings can be realized emphasis will continue to be given to replacements in areas of local and state road resurfacing distribution valves that are found to be defective, and in accordance with current practice criteria for mains, by age and overall condition. Priority will be given to replace older replacement program. This will generally prioritize the replacement of valves using the same diameter valves that are pre 1900. Plans are to replace these valves in conjunction with the main Of the 13,500 valves in the system, approximately 1,900 have been identified as 6", 8", and 12"

Lead Service Replacements

level, we will reassess our plan for the replacement of lead services and Copper Rule. If at some future date Providence Water falls below the regulatory lead action The plan is to continue to replace lead services in accordance with the requirements of the Lead

lead services are found to be leaking continue to replace lead services in areas of local and state road resurfacing projects and where requested by the owner in accordance with internal policy, and at sites identified by the program. Services will also be replaced on an ongoing basis under special conditions when Department of Health as having lead contamination problems. Providence Water will also Additionally, lead services will be replaced in conjunction with the water main replacement



Hydrant Replacements

system no older than 75 years. Emphasis will also be given on replacing hydrants that are found to be defective. The objective of the hydrant replacement program will be to maintain ages of hydrants in the

Leak Detection

to perform a leak detection survey of the system every ten years. transmission valves, 13,500 distribution valves, 74,000 services, and 6,067 hydrants. The plan is The system is comprised of 885 miles of distribution mains, 114 miles of transmission mains, 814

SUPPORT SYSTEM FACILITIES

Building and Facilities Rehabilitation

fire system upgrades, and site improvements improvements, rehabilitation of the electrical, plumbing, and mechanical systems, security and Funds are annually budgeted for reconditioning the offices, architectural and structural The Forestry Maintenance Garage, Academy Avenue Administration Building, Aqueduct Reservoir Office, and the Watershed Storage Building will be in need of ongoing improvements.

Records Management (GIS) Upgrades

and software additions to the system. GIS. Upgrades will consist of hardware replacements, software upgrades, and new hardware for in the plan to address continued upgrade needs for both the asset management system and Given that the nature of computer technology is ever changing, a budget amount is accounted

Facility Fence and Roads Rehabilitation

It is anticipated in the 15-year plan that various facility access roads will need to be resurfaced. Fences will also be in need of replacement or rehabilitation.

Underground Fuel Storage Tank Replacements

underground storage tanks. life expectancy of the tanks and in consideration of EPA and RIDEM regulations for gasoline split tank located at Academy Ave. The replacement schedule is in accordance with the underground diesel tank at the transformer building in Scituate, and replacing the diesel, Planned work is scheduled for the first five years of the 15-year plan consisting of replacing the

Section IV Revenue Requirements



Infrastructure Replacement Plan Revenue Requirements

Section IV - Revenue Requirements

Overview of Revenue Requirements

Any additional funding or borrowing will be addressed as we move forward. and Uses of Funds in four five-year phases. The plan is subject to change as it is implemented. authorized funding, and minimal proposed new funding. The Exhibit lists the projected Sources developed a Sources and Uses of Funds Plan based on planned replacement needs, current Exhibit 3 - Sources and Uses of Funds - FY 2011 through 2030 - Providence Water has

of the twenty-year plan. Exhibit 4 – IFR Funding Projections – A graphical depiction of the sources of funds in each year

Overview of Revenue Requirements

the projected expenditures. amount is \$16 million per year. Additional funding and borrowing will be required to balance projected Sources and Uses of Funds in four five-year phases. The current authorized funding funds based on our anticipated replacement needs within our system. EXHIBIT-3 lists the Providence Water has developed a Sources and Uses of Funds Plan using current authorized

Sources of Funds

increases to the funding level consistent with our plan and accomplishments. Public Utilities Commission granted Providence Water a phased-in funding approach to begin its IFR program. Over the years, Providence Water has requested and the PUC has approved several Providence Water began funding a restricted Infrastructure Replacement fund in 1996. The RI

proceeds are \$8.3 million and available funds from prior years are \$15.1 million. Additional bond see EXHIBIT-4. Over the 20 year period, current funding is \$320 million, current available bond by projecting a number of additional increases in the funding level authorized by the PUC. Please Water does plan to issue bonds for some of our projects in our IFR plan. The plan is also balanced Providence Water access to funds in case of an emergency or cash flow fluctuations. proceeds of \$45.5 million and additional rate revenue of \$115.5 million will be needed to balance Providence Water has a short term revolving line of credit with Century Bank that provides the plan. Providence

Uses of funds

included as a use of funds in this plan. debt service totals \$50,502,000. be reimbursed to Providence Water's Operating Fund from the IFR Fund. Debt service is amount includes capitalized labor and benefits authorized by the Public Utilities Commission to Providence Water has cash funded projects totaling \$385,345,000 over the 20 year period. This Existing debt service totals \$62,809,000, and additional

funding of the plan, is based on the best information available at this time. and we will invariably have to make amendments to this plan to match changing State and small \$5.7 million projected surplus over the 20 year period. Our IFR plan is subject to change of funds of \$498.7 million. Total sources of funds are projected at \$504.4 million, resulting in a approximately \$62.8 million and additional debt service is projected at \$50.5 million for total uses To recap, total cash funded construction projects are \$385.3 million, current debt service Federal regulations and changing field conditions. Our replacement plan, and the projected

Exhibit 3 Providence Water Sources and Uses of Funds IFR Funding & Expenditure Projections (\$000's) Fiscal Years 2011 through 2030

	2011-2015	2016-2020	2021-2025	2026-2030	2011-2030
	Phase 1	Phase 2	Phase 3	Phase 4	Total
Sources of Funding:					
Current Authorized Funding Current Bond Proceeds	\$80,000 8,300	\$80,000 0	\$80,000 \$0	\$80,000 \$0	\$320,000 8,300
Funds Available from Prior Years	15,123	0	\$0	\$0	15,123
Additional Rate Revenue Additional Bond Proceeds Total Sources of Funds	11,500 <u>15,500</u> 130,423	34,000 <u>30,000</u> 144,000	\$35,000 <u>\$0</u> 115,000	\$35,000 <u>\$0</u> 115,000	115,500 <u>45,500</u> 504,423
Uses of Funding:					
Cash Funded Construction Projects Existing Debt Service Additional Debt Service Total Uses of Funds	\$109,590 18,742 <u>1,775</u> 130,107	\$111,560 14,689 <u>13,948</u> 140,197	\$80,710 14,689 <u>17,390</u> 112,789	\$83,485 14,689 <u>17,390</u> 115,564	\$385,345 62,809 <u>50,502</u> 498,656
IFR Program Surplus/(Deficit)	\$317	\$3,804	\$2,211	-\$564	\$5,767





Appendix

Appendix

The Comprehensive Clean Water Infrastructure Act of 1993 Chapter 46-15.6 of the General Laws of Rhode Island

Rules and Regulations for Clean Water Infrastructure Plans

Infrastructure / Capital Program Report 1996 - 2010 (September 2010)



Infrastructure Replacement Plan Appendix

TITLE 46 Waters and Navigation CHAPTER 46-15.6 - Clean Water Infrastructure

Index Of Sections

- § 46-15.6-1 Short title.
- § 46-15.6-2 Legislative findings, intent, and objectives.
- § 46-15.6-3 Infrastructure replacement program.
- § 46-15.6-4 Content of infrastructure replacement component.
- § 46-15.6-5 Completion, filing, approval and implementation of infrastructure component.
- § 46-15.6-6 Financing infrastructure replacement.
- § 46-15.6-7 Rules governing content of programs, components, review, evaluation, funding, and implementation.
- § 46-15.6-8 Severability.
- § 46-15.6-9 Excluding requirement of state mandated cost.

History of Section. **§ 46-15.6-1** Short title. - This chapter shall be referred to as the "Comprehensive Clean Water" Infrastructure Act of 1993"

(P.L. 1993, ch. 312, § 1; P.L. 1993, ch. 438, § 1.)

recognizes and declares that: **§ 46-15.6-2** Legislative findings, intent, and objectives. - (a) The general assembly hereby

enhance, and maintain the chemical, physical, and biological integrity of its waters to protect by any segment of the state's population or its economy. It is the policy of this state to restore, health (1) Water is vital to life and comprises an invaluable natural resource which is not to be abused

the availability of safe and potable drinking water for present and future needs. (2) The waters of this state are a critical renewable resource which must be protected to insure

supplies by protecting the infrastructure of potable water, including treatment plants, pipes, valves, pumping stations, storage facilities, interconnections, and water mains. (3) It is a paramount policy of the state to protect the purity of present and future drinking water

construction, repair, protection, and/or improvement of potable water infrastructure replacement. (4) It is imperative to provide a uniform and valid mechanism to base assistance for the

used to deliver water supplies in order to restore water system facilities. it is necessary to take immediate and continuing steps to repair and replace the infrastructure obsolescence can threaten the quality of supplies and, therefore, can endanger public health; thus (5) The decay of infrastructure and related construction due to deterioration or functional

will continue to degrade the quality of public drinking water. (6) Failure to replace the infrastructure used to deliver water supplies may cause and probably

delivery to the ultimate consumer. (7) Protection of water quality is necessary from the collection source through the point of

economic costs for the construction of the potable water infrastructure replacement. (8) The potable threat to public health caused by unsafe drinking water far outweighs the

(b) That the objectives of this chapter are:

other entity engaged in or authorized to engage in the supply, treatment, transmission, or carried out by each municipality and by each municipal department, agency, district, authority, or distribution of drinking water, and (1) To establish a funding mechanism to insure that infrastructure replacement programs are

such facilities is not eroded. History of Section. (2) That the plans and their execution achieve and insure that the investment of the public in

(P.L. 1993, ch. 312, § 1; P.L. 1993, ch. 438, § 1; P.L. 2007, ch. 340, § 53.)

History of Section. maintain, and carry out an infrastructure replacement program as described in this chapter. referred to as "water suppliers" for the purpose of this chapter. All water suppliers shall prepare, transport, purchase, or sell more than fifty million (50,000,000) gallons of water per year, shall be transmission, distribution of drinking water on a wholesale or retail basis, and which obtain, agencies, districts, authorities or other entities engaged in or authorized to engage in the supply, § 46-15.6-3 Infrastructure replacement program. - All municipalities, municipal departments and

(P.L. 1993, ch. 312, § 1; P.L. 1993, ch. 438, § 1.)

replacement component (hereinafter referred to as "component") shall include without limitation: **§ 46-15.6-4** Content of infrastructure replacement component. - (a) The infrastructure

complete or partial compliance with the provisions of this section. funding approved by their appropriate governing bodies may submit their existing programs for which have in effect infrastructure improvement or rehabilitation programs and mechanisms for twenty (20) years in accordance with rules and regulations promulgated herein. Water suppliers and replacements and amortize such improvement requirements on an annual basis over the next shall analyze the condition and life expectancy of the existing facilities, prioritize needed repairs facilities, pumping and well equipment, interconnections and water mains. Each financial forecast as reservoirs, dams, treatment plants, pipes, valves, fire hydrants, pumping stations, storage twenty (20) years including, but not limited to, the principal components of the water system such (1) A detailed financial forecast of facility replacement improvement requirements for the next

necessitated by this chapter in accordance with rules and regulations promulgated herein standards sufficient to ensure proper accounting for evaluation of facility requirements (2) A method that establishes and maintains fiscal controls and accounting depreciation

service areas are or are planned to be located (b) Components shall be consistent with applicable local comprehensive plans in which the

chapter up to fifty percent (50%) of the cost of the component. suppliers for preparation of their infrastructure replacement components as described in this History of Section. (c) Proceeds from the watershed protection fund shall be usable for reimbursement of water

(P.L. 1993, ch. 312, § 1; P.L. 1993, ch. 438, § 1.)

replacement component shall complete and adopt a component two (2) years subsequent to the § 46-15.6-5 Completion, filing, approval and implementation of infrastructure component. - (a) date each party's water supply management plan per § 46-15.3-7.5 is due Each water supplier required by this chapter to prepare and maintain an infrastructure



following: the division of drinking water quality of the department of health (hereinafter referred only to the extent the components differ from plans filed under § 46-15.3-5.1 thereto with the to as "the department"). (b) Water suppliers subject to the requirements of § 46-15.6-3 shall file a copy of all components,

(5) years and shall modify or replace their components as necessary. (c) A water supplier subject to § 46-15.6-3 shall review their components at least once every five

comments by all agencies designated herein the department shall determine whether the suppliers of its determination within the prescribed time limit shall constitute approval. included in this eight (8) month review period. Failure by the department to notify water within eight (8) months of the initial submission. A thirty (30) day public comment period shall be component complies with the requirements of this chapter. This determination shall be made the components and submit comments thereon to the department. Upon consideration of written water suppliers within their jurisdiction) shall have one hundred and twenty (120) days to review this chapter, water resources board, and the division of public utilities and carriers (for those suppliers subject to this chapter. Upon receipt of components prepared by water suppliers under (d) The department shall coordinate expeditious review of components prepared by water

chapter in accordance to rules and regulations promulgated per § 46-15.6-7. program and component, including its infrastructure replacement fund, as mandated by this History of Section. (e) Each water supplier shall implement the requirements of its infrastructure replacement

ch. 340, § 1; P.L. 2009, ch. 288, § 9; P.L. 2009, ch. 341, § 9.) (P.L. 1993, ch. 312, § 1; P.L. 1993, ch. 438, § 1; P.L. 1995, ch. 103, § 1; P.L. 1997, ch. 37, § 1; P.L. 1998,

programs and indemnification as required by this chapter shall be financed as follows § 46-15.6-6 Financing infrastructure replacement. - The cost of infrastructure replacement

earned on money in this infrastructure replacement fund shall be credited to this infrastructure the facility improvements necessitated over each successive twenty (20) year period. Interest required by this chapter. These charges shall be based upon the annual funding requirements of users. The charges shall be limited to those necessary and reasonable to undertake the actions replacement fund. (1) The cost of programs to implement infrastructure replacement shall be paid by the water

infrastructure as required by this chapter. administered by the water supplier solely to implement and carry out the replacement of the infrastructure replacement fund to be held as a restricted receipt account and to be (2) Each water supplier designated in § 46-15.6-3 shall establish a special account designated as

exclusively pledged to repayment of outstanding bonds or notes or loan repayments to needed to implement the annual infrastructure replacement program or in excess of that (3) Any money which may accumulate in the infrastructure replacement fund in excess of that

system on a biannual basis implement the infrastructure replacement program shall revert to the rate payers of that particular

funding requirements. program through bonding. The annual debt service of each bond or bonds shall be applied and credited towards the annual requirement of the infrastructure replacement program's annual direct funding of its infrastructure replacement program, finance its infrastructure replacement (4) Each water supplier designated in § 46-15.6-3 may, as a complete or partial alternative to

add this required funding to its rate base in accordance with this chapter. water suppliers' rate structure to comply with this chapter and shall allow the water supplier to shall permit an increase for just and reasonable infrastructure replacement in the portion of the (5) The Rhode Island public utilities commission, as to water suppliers within its jurisdiction,

(P.L. 1993, ch. 312, § 1; P.L. 1993, ch. 438, § 1; P.L. 2009, ch. 288, § 9; P.L. 2009, ch. 341, § 9.) History of Section.

implementation of approved components, programs and funding mechanisms. within its jurisdiction, shall promulgate the criteria or standards which it will use to evaluate the the water resource board, and the Rhode Island public utilities commission, as to water suppliers depreciation standards per § 46-15.6-4(a)(1) and (a)(2). The department with the concurrence of forecasts of facility replacement, improvement requirements and fiscal controls and accounting forthwith promulgate rules and regulations for the review of components as pertains to financial § 46-15.6-7 Rules governing content of programs, components, review, evaluation, funding, History of Section. Rhode Island public utilities commission, as to water suppliers within its jurisdiction, shall and implementation. - The department with the concurrence of the water resource board, and the

ch. 341, § 9.) (P.L. 1993, ch. 312, § 1; P.L. 1993, ch. 438, § 1; P.L. 1997, ch. 37, § 1; P.L. 2009, ch. 288, § 9; P.L. 2009,

determination made thereunder, or the application thereof to any person, agency or of this chapter shall not affect the validity of the remainder of this chapter. agencies, or circumstances shall not be affected thereby. The invalidity of any section or sections rule, regulation, or determination and the application of such provisions to other persons circumstances, is held invalid by a court of competent jurisdiction, the remainder of the chapter, **§ 46-15.6-8** Severability. - If any provision of this chapter or of any rule, regulation or History of Section.

(P.L. 1993, ch. 312, § 1; P.L. 1993, ch. 438, § 1.)

§ 46-15.6-9 Excluding requirement of state mandated cost. - The provisions of §§ 45-13-7 - 45-13-History of Section. 10 shall not apply to §§ 46-15.6-1 - 46-15.6-8

(P.L. 1993, ch. 312, § 1; P.L. 1993, ch. 438, § 1.)



CLEAN WATER INFRASTRUCTURE PLANS RULES AND REGULATIONS FOR

[R46-15.6-INFRA]

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATION

Department of Health

October 1994

AS AMENDED January 1995 January 2002 (re-filing in accordance with the provisions of section 42-35-4.1 of the Rhode Island General Laws, as amended)

INTRODUCTION

state to protect the purity of present and future drinking water supplies by protecting the infrastructure of funding mechanism, the prioritization of infrastructure replacement, and the prevention of the erosion of engaged in the supply, treatment, transmission, and/or distribution of drinking water. causing sudden increases in water rates can hopefully be avoided. The intent of this Infrastructure By planning and funding for future infrastructure replacement, unexpected large capital expenditures repair and replace the infrastructure used to treat and deliver drinking water from public water suppliers. and therefore can endanger public health. Therefore, it is necessary to take timely and continuing steps to infrastructure due to deterioration or functional obsolescence can threaten the quality of water supplies drinking water infrastructure. include the justification of a facility replacement program, the provision of a dedicated and sufficient replacement programs are carried out by each municipality, district, agency, authority, or other entity Replacement Plan is potable water, including sources, treatment plants and distribution systems. The decay of water supply availability of safe and potable drinking water for present and future needs. It is a paramount policy of the The waters of this state are a critical renewable resource which must be protected to insure the continued to provide a planning and funding mechanism to insure that infrastructure Goals of the plan

These rules and regulations are promulgated pursuant to the requirements and provisions of RIGL Chapter 46-15.6 Clean Water Infrastructure of the General Laws of Rhode Island, as amended.

of Health to effectuate the purposes of the state law, goals and policies consistent with the Clean Water Infrastructure Act, Chapter 46-15.6 of the General Laws of Rhode Island, as amended The terms and provisions of the rules and regulations shall be liberally construed to allow the Department
TABLE OF CONTENTS

APPENDIX 1 TY	SECTION 7 SE	SECTION 6 FIN	SECTION 5 RE	SECTION 4 CC	SECTION 3 CC	SECTION 2 AP	SECTION 1 DE
PICAL LIFE EXPECTANCY	VERABILITY	VANCING OF IMPROVEMENTS	VIEW OF PLANS	NTENTS OF PLANS	NFORMITY WITH OTHER LEGISLATION	PLICABILITYPREPARATION OF PLANS	FINITIONS
7	6	S	4	ω	2	2	PAGE 1

SECTION 1.0 DEFINITIONS

follows: Wherever used in these rules and regulations the following terms shall be construed as

- 1.1 investments, interest, expenditures, and operating costs Audit--the annual formal examination of the water supplier's financial statements including all
- 1.2 Commission--the Public Utilities Commission (PUC) of the State of Rhode Island
- 1.3 and facilities, open space and recreation, and circulation. program for land use, housing, economic development, natural and cultural resources, services document prepared by each local municipality which contains the planning and implementation RIGL Chapter 45-22.2, the RI Comprehensive Planning and Land Use Regulation Act. Comprehensive Plan-the Comprehensive Plan adopted and approved in accordance with \triangleright
- 1.4 Department--the Department of Health (DOH), Division of Drinking Water Quality
- 1.5 dispense, to render or to circulate potable water directly to the consumer. Distribution facilities--the pipes and appurtenant facilities employed specifically to deliver, to
- 1.6 Drinking Water--potable water served to the public.
- 1.7 is used to depreciate the capital expense of the component. Economic life--the expected financial lifespan of a component of a public water system which
- 1.8consulting fees, replacement construction, etc. the infrastructure replacement plan, only. This may include associated accounting fees, Eligible expenditures--those costs and expenses necessary to fund, manage, and implement
- 1.9not limited to, supplies, transmission, storage, distribution, pumping, and treatment facilities Infrastructure--the permanent underlying framework of the public water system, including but
- 1.10Life expectancy--the expected physical lifespan of a component of a public water system
- 1.11 cost to the utility as required in the Department of Environmental Management's Water eligible for funding from the Infrastructure Replacement Plan. Supply Management Planning Section 8.07(c). Routine maintenance expenditures are not allows the maximum continuous service of the equipment in the system at the lowest possible Maintenance--a planned program of inspection, adjustment, exercise, lubrication, etc. which
- 1.12 the cost of supplying potable drinking water. Rate fee--the charge per unit for public water based upon a ratio, scale, or standard relative to
- 1.13expenditure under the Infrastructure Replacement Plan. which extends the physical and economic life of the component. Rehabilitation--rehabilitation which restores existing facilities or components to a condition Rehabilitation is an eligible
- 1.14 not an eligible expenditure under the Infrastructure Replacement Plan. Repair--expenditures to return into service a component of the infrastructure that has failed is

- 1.15 Replacement--new construction to substitute for existing facilities or components which can Infrastructure Replacement Plan. not be rehabilitated or repaired cost effectively IS. an eligible expenditure under the
- 1.16 account dedicated solely for funding of eligible expenditures from the infrastructure a fiduciary relationship with the utility. This special account shall be a restricted receipt self-contained in that deposits and withdrawals are recorded by the financial institution through special account. designee. All receipts, income, and interest earned on these funds shall be accrued within this replacement program and be administered by the general manager of the water supplier or his "Infrastructure Replacement Fund" that is acceptable under this Act. This account shall be Special account--an account established by physically opening an account designated as the
- 1.17 Surcharge--a fee charged in addition to normal system rate fees which is used to fund extraordinary or special conditions of the water system.
- 1.18 general population. be served by a water supply system for the specific purpose of supplying water to support a to carry raw and/or potable water from a water source to or throughout an area served or to Transmission facilities--shall mean the pipes, pumping stations, and storage facilities required
- 1.19 of drinking water on a wholesale or retail sales basis. entity engaged in or authorized to engage in the supply, treatment, transmission, or distribution Water supplier--any municipality, municipal department, agency, district, authority, or other
- 1.20groundwater wells. water supply system and available for distribution. Water supply sources--are Department of Health approved sources of supply connected to a These sources may be surface waters or
- 1.21 and its people as defined in RIGL 46-15.4. protection of water supply resources consistent with the present and future needs of the State plans and implements effective and efficient conservation, development, utilization, Water supply management plan--a plan prepared by applicable public water suppliers which and

SECTION 2.0 APPLICABILITY - PREPARATION OF PLANS

2.1 All water suppliers which supply, obtain, transport, distribute, purchase, and/or sell on a described in these regulations. required to prepare, maintain, and carry out a clean water infrastructure replacement plan as wholesale or retail basis, more than fifty million (50,000,000) gallons of water per year shall be

SECTION 3.0 CONFORMITY WITH OTHER LEGISLATION

3.1 Water Supply. provisions of state and federal laws including the federal Safe Drinking Water Act (42 USC Section 300f et seq.); Chapter 46-13 of the General Laws of Rhode Island, Public Drinking The clean water infrastructure replacement plans shall be in conformity with all applicable Infrastructure replacement plans must be consistent with the Comprehensive

replacement plans shall also be consistent with the Water Supply Management plans required under Chapter 46-15.4. Plan for the community or communities associated with the water system. Infrastructure

SECTION 4.0 CONTENTS OF PLANS

- 4.1 completion of the evaluation of major components or items which require detailed supplier, the water source, the water system, and the transmission/distribution/storage system. time period for compliance. investigation. infrastructure replacement plan outlined below. The initial plan may include a schedule for the plan and utilize existing information to the extent that it is consistent with the intent of the address each of the topics listed in this section, to the extent that each is relevant to the water Clean water infrastructure replacement plans shall be prepared in the format, and shall Systems which currently have an infrastructure replacement plan may review the existing The schedule must demonstrate an expeditious, responsible, and reasonable
- 4.2 group. water mains, distribution piping, valves, hydrants, and interconnections may be evaluated as a be listed and evaluated. intakes, treatment plants, pump stations, storage facilities, pumping and well equipment, shall All principal components of the water system such as sources, reservoirs, dams, spillways, This evaluation shall consider the following: Relatively small and numerous components of the system such as
- a. A brief description of the system with a schematic of the process flow will be included in operation of the system as well as the age and known condition of the component. A the analysis of the component should reflect the priority of the component to the proper evaluated and prioritized over a minimum of five (5) year intervals. others may extend well beyond the twenty year time frame. Replacement should be shall be evaluated. the evaluation of individual components. Age and condition of the existing component and replacement construction is required to take place within any time interval if demonstrated detailed schedule for the initial five year interval must be included. No infrastructure the necessity for replacement of the component within a twenty (20) year time frame Management Plan where relevant and is not intended as a duplicate effort but to facilitate the plan. to not be necessary. This description of the system may be taken directly from the Water Supply Specific components may be in need of immediate replacement while The level of detail in
- ġ. thumb for component life expectancy and actual life expectancy within an individual component. The attached Guideline, Appendix 1, is intended to serve as a general rule of inspection and maintenance may be reviewed when determining the life expectancy of the system may be demonstrated to be significantly more or less than the Guideline value. or non-destructive integrity testing, or a combination of all of the above. manufacturer's documentation, engineering evaluation, physical inspection, invasive and/ determined Life expectancy of the component shall be determined. by design criteria, specific site conditions, maintenance Life expectancy shall be Records of records,
- <u></u> Consideration shall be given to the public water system's ability to meet current and future requirements of the Safe Drinking Water Act. rehabilitation will comply with mandated requirements consistent with the Safe Drinking analyzed to the extent possible to insure that infrastructure replacement and/or Treatment requirements should be

Water Act.

- ġ. the existing facilities, prioritized needed repairs and replacements and amortize proportionally such improvement requirements on an annual basis over the next twenty A financial forecast shall be based on the analysis of the condition and life expectancy of contingency costs, range of construction costs, and/or confidence limits of the financial years consistent with their respective life expectancy. forecast. The forecast shall include
- <u>о</u> Infrastructure replacement shall meet the needs of the water suppliers, however priority similarity of projects, and importance of the component to the system shall be considered of anticipated replacement and grouping of replacement projects by time of replacement, infrastructure items. known need for replacement and less detailed analysis given to relatively new when establishing the schedule. Priority should be given to components which have a
- 4.3 supplier's most recent Water Supply Management Plan. Funding for proposed expansion shall consistent with sound waterworks practic e. come from the capital improvement program utilizing new capital rather than from existing or proposed service area shall be defined consistent with that described in the meet the approved local comprehensive plans for existing or proposed service areas. initiated in the Water Supply Management Plan. The infrastructure replacement plan shall be Water Supply Management Plan and expand the concepts of capital improvement planning replacement funding. When planning infrastructure replacement, the water supplier shall consider sizing facilities to It is intended that the infrastructure replacement plan evolve from the The
- 4.4 accounting standards in accordance with Generally Accepted Government Accounting to those outlined in Section 6.0 of these regulations established where none currently exist. The financial requirements of the plan shall conform infrastructure replacement. Principles sufficient to ensure fiscal responsibility for the evaluation and implementation of the The infrastructure replacement plan must recognize and maintain existing fiscal controls and These fiscal controls and accounting standards must be
- 4.5 Disbursements from the fund shall be in accordance with Chapter 46-15.3-11 of the Public Drinking Water Resources Board Operating Fund. The remaining costs are eligible for Funds from the watershed protection fund may be used for the preparation of clean water infrastructure replacement plans up to fifty (50) percent of the cost of the plan. funding consistent with the funding requirements for scheduled infrastructure replacement. the proposed rate structure impacts, schedule of proposed rate changes, and schedule for full funding through the Safe Drinking Water Revolving Loan Fund. The plan shall incorporate plan.

SECTION 5.0 REVIEW OF PLANS

5.1 15.4-4. date the system's water supply management plan is due in accordance with RIGL Section 46-Health (the Department). Plans must be submitted no later than one year subsequent to the water infrastructure plan with the Division of Drinking Water Quality of the Department of Water suppliers subject to the requirements of this chapter shall file six copies of the clean

- 5.2 of Health. Upon consideration of the comments, the Department shall determine if the plan day (240) review period. initial submission. A thirty day public comment period is inclusive in this two hundred forty complies with the requirements of these regulations within two hundred forty days (240) of the Department shall have 120 days to review the plan and submit comments to the Department PUC shall only review Plans for those systems which are regulated by the PUC. Each Division of Planning, the Water Resources Board, and the Public Utilities Commission. Management's Division of Water Supply Management, the Department of Administration's The Department shall coordinate review of the plan with the Department of Environmental
- 5.3 replacement plan shall be submitted for review more frequently as necessary. frequency Water suppliers shall review and update their infrastructure replacement plans at a minimum of every five years. Major modifications or revisions to the infrastructure
- 5.4 plan. required to verify that construction expenditures are consistent with the plan. appropriate and/or applicable. Water suppliers shall implement the infrastructure replacement plan according to the approved On-site review of facility components may be conducted by the Department when The responsible official of the water supply system shall be

SECTION 6.0 FINANCING INFRASTRUCTURE IMPROVEMENTS

- 6.1 agency, municipality, or water supplier. dedicated account should be invested in accordance with the standards established for the the replacement or rehabilitation of infrastructure in accordance with the approved plan. receipt account and to be administered by the water supplier solely to implement and carry out special account designated as the Infrastructure Replacement Fund to be held as a restricted Each water supplier subject to the requirements of this chapter shall establish a separate The
- 6.2 shall be limited to those necessary and reasonable for implementation of the plan. the water system at a rate directly proportional to the users' consumption of water. necessitated over each successive twenty year period. charges shall be based upon the annual funding requirements of the facility improvements The costs of programs to implement infrastructure replacement shall be paid by the users of Charges These
- 6.3 sufficient capital to finance the estimated costs of major projects. It is understood that annual excess of that estimated to be necessary to implement the plan shall revert to the rate payers reduce the future charges for infrastructure replacement. that are in excess of that estimated to implement the plan will cause the water supplier to investments may be necessary over many years to fund major projects. Funds accumulated of the system on a biannual basis. Funds will be allowed to accumulate with the intent to build Interest earned on this account shall be credited to this account only. Accumulated funds in
- 6.4 service issuance costs for any and all funding shall be an eligible expense as part of the program's funding requirements. or complete external funding at the option of the water supply system. Debt service and debt Water suppliers may alternatively fund the infrastructure replacement program through partial
- 6.5 increase for just and reasonable infrastructure replacement in the portion of the water The Public Utilities Commission, as to water suppliers within its jurisdiction, shall permit an

rates by regulated water utilities to finance infrastructure improvements shall be filed and suppliers' rate structure to comply with this chapter and shall allow the water supplier to add reviewed in conformance with Chapter 39 of the RI General Laws. this required funding to its rate base in accordance with this chapter. Proposed increases in

6.6 audit. plan. within 180 days from the end of the water suppliers fiscal year. Extensions will be allowed for consistent with the plan and be eligible expenditures under the plan. Audits shall be submitted which outlines funds spent on the project, funds remaining, percentage of completion, and a reasonable cause. brief description of work completed and work remaining. Department to verify compliance with the funding intentions of the infrastructure replacement The applicable section of the water supplier's annual audit shall be submitted to the The dedicated fund for infrastructure replacement will be a separate line item in the Financial and summary status reports shall be submitted for each on-going project Project expenditures must be

SECTION 7.0 SEVERABILITY

7.1 If any provision of these rules and regulations or the application thereof to any person or circumstance is held invalid by a court of competent jurisdiction, the remainder of the rules of any section or sections shall not affect the validity of the remainder of these rules and and regulations shall not be affected thereby. The invalidity of any section or sections or parts regulations.

APPENDIX 1

TYPICALLIEE EXPECTANCY

EQUIPMENT	YEARS
Source of supply plant Structures and improvements	35-40
Collecting/impounding reservoirs	50-75 35-45
Wells and springs	25-35
Galleries and tunnels	25-50
Supply mains	50-75
Pumping plant Structures	35-40
Pumping equipment	10-15 20
Water treatment plant	
Structures	35-40
Transmission/Distribution	
Structures	35-40
Reservoirs and tanks	30-60
Mains	50-75
Services	30-50
Hydrants	13 40-60
General plant	
Structures	35-40
Furniture/equipment	15-20 7
Stores equipment	10
Tools, shop equipment	7-10
Laboratory equipment	10-15
Power operated equipment	10
Communication equipment	01