



552 Academy Avenue  
Providence, RI 02908

**401-521-6300**

[www.provwater.com](http://www.provwater.com)

June 7, 2013

The Hon. Angel Taveras  
*Mayor*

Boyce Spinelli  
*General Manager*

Mrs. Luly Massaro  
Commission Clerk  
RI Public Utilities Commission  
89 Jefferson Boulevard  
Warwick, RI 02888

RE: Dk 4406 Division of Public Utilities & Carriers; Set 2

BOARD OF DIRECTORS

Brett P. Smiley  
*Chairman*

Joseph D. Cataldi  
*Vice Chairman*

Michael L. Pearis  
*Ex-Officio*

Michael A. Solomon  
*City Council President*

Michael J. Correia  
*City Councilman*

Andy M. Andujar  
*Member*

Joan S. Badway  
*Member*

Carissa R. Richard  
*Secretary*

William E. O'Gara, Esq.  
*Legal Advisor*

Dear Mrs. Massaro:

Enclosed is an original and seven copies of Providence Water's revised response to data request number 2-2 from the Division of Public Utilities.

If you have any questions you can contact me at extension 7217.

Sincerely,

Mary L. Deignan-White  
Senior Manager of Regulatory

cc: service list

Member

Rhode Island Water Works Assn.  
New England Water Works Assn.  
American Water Works Assn.  
Water Research Foundation

An EPA WaterSense Partner

Only Tap Water Delivers

Providence Water Docket 4406

**Data Requests of the  
Division of Public Utilities and Carriers  
Set 2**

DIV 2-2. Please provide the average, maximum day and maximum hour system-wide demands in each of the last three years.

Answer: Please see the attached Revised response to Div 2-2. Our Engineering department noticed an error in the original response and have prepared this revised response, for the past 4 years.

**Engineering response to Division of PUC data request Set II:**

**Item DIV 2-2: (Revised 6-7-13)**

	<u>FY 2012</u>	<u>FY 2011</u>	<u>FY 2010</u>	<u>FY 2009</u>
Average Day Demand:	61.6 mgd	61.8 mgd	59.7 mgd	62.2 mgd
Maximum Day Demand:	110.82 mgd	107.76 mgd	90.65 mgd	116.37 mgd
Maximum Hour Demand:	114.08 mgd	146.39 mgd	111.40 mgd	139.86 mgd