

Record Request No. 17

Request:

Please run the interconnection metric and show the results as if the metric were in effect for CY 2016 and CY 2017.

Response:

Below is the Company’s performance for the three tracks proposed in the Settlement Agreement for CY 2016 and CY 2017.

As can be seen in the tables below, performance in two of the tracks (Simplified – No Networks, and Expedited – No Supplemental Review), and the weighting assigned to them under the metric, skewed the results to the extent that the Performance Incentive Mechanism as proposed is now not viable. In lieu of the original Performance Incentive Mechanism, the Company would propose that only the Standard track be measured for attainment of this Performance Incentive Mechanism, with the other two tracks measured as scorecard metrics for future review. The Company believes the 95 percent and 90 percent target levels proposed remain appropriate for the Standard track going forward, particularly given that the complexity of studying projects in this track has been increasing due to the increasing levels of saturation.

Timeline Calculation Calendar Year 2016					
	Time Allowed	Average Time	Percent	Weighting	Weighted Allowed Time
Simplified - No Networks	20	3	13%	20%	3%
Expedited - No Supplemental Review	45	7	15%	40%	6%
Standard	105	100	95%	40%	38%
Measurement				100%	47%

The Narragansett Electric Company
d/b/a National Grid
RIPUC Docket Nos. 4770/4780
Responses to Record Requests
Issued at the Commission's Evidentiary Hearing
On June 20, 2018

Timeline Calculation Calendar Year 2017					
	Time Allowed	Average Time	Percent	Weighting	Weighted Allowed Time
Simplified - No Networks	20	2	12%	20%	2%
Expedited - No Supplemental Review	45	7	15%	40%	6%
Standard	105	100	95%	40%	38%
Measurement				100%	46%