

Substation Name	Region	Total Connected DG MW (> 1MW)	Total Pending DG MW (> 1MW)	Total # of Pending Applications (> 1MW)	Total Connected + Pending DG MW (>1MW)	Ongoing ASO Study?	Potential Need for an ASO Study in next 6 months?	DG Penetration Level	Notes
ADMIRAL STREET SUBSTATION	Capital	0.1	0.0	0	0.1	No		<5MW	
ANTHONY SUBSTATION	Coastal	0.2	0.0	0	0.2	No		<5MW	
APPONAUG SUBSTATION	Coastal	0.8	0.6	1	1.4	No		<5MW	
BARRINGTON SUBSTATION	Coastal	0.0	0.0	0	0.0	No		<5MW	
BONNET SUBSTATION	Capital	0.2	0.0	0	0.2	No		<5MW	
BRISTOL SUBSTATION	Coastal	1.0	5.2	4	6.2	No	Yes	Between 5MW and 15MW	Future Applications will require study
CHASE HILL SUBSTATION	Capital	24.0	22.1	9	46.2	Yes		>15MW	Future Applications will require study
CHOPMIST SUBSTATION	Coastal	10.5	3.7	2	14.2	No	Yes	Between 5MW and 15MW	
CLARKE STREET SUBSTATION	Capital	0.1	0.0	0	0.1	No		<5MW	
CLARKSON STREET SUBSTATION	Capital	3.1	0.2	2	3.2	No	Yes	<5MW	
COTTAGE STREET SUBSTATION	Capital	0.0	0.0	0	0.0	No		<5MW	
COVENTRY SUBSTATION	Capital	4.7	0.0	0	4.7	No		<5MW	
DAVISVILLE SUBSTATION	Coastal	2.1	18.0	3	20.1	Yes		>15MW	Future Applications will require study
DEXTER SUBSTATION	Capital	10.4	7.8	4	18.2	No	Yes	>15MW	Future Applications will require study
DIVISION ST SUBSTATION	Coastal	0.5	0.8	3	1.3	No		<5MW	
DRUMROCK SUBSTATION	Capital	0.0	8.9	3	8.9	No	Yes	Between 5MW and 15MW	Future Applications will require study
DYER STREET SUBSTATION	Capital	0.2	0.8	1	1.0	No		<5MW	
ELDERED SUBSTATION	Coastal	0.1	0.0	0	0.1	No		<5MW	
ELMWOOD SUBSTATION	Capital	0.1	2.0	1	2.1	No		<5MW	
FARNUM SUBSTATION	Capital	0.0	0.0	0	0.0	No		<5MW	
FARNUM PIKE SUBSTATION	Capital	8.0	8.0	1	16.0	No		>15MW	Future Applications will require study
GATE TWO SUBSTATION	Coastal	0.8	0.0	0	0.8	No		<5MW	
HARRIS AVENUE SUBSTATION	Capital	0.1	0.2	1	0.3	No		<5MW	
HIGHLAND PARK SUBSTATION	Capital	0.0	0.0	0	0.0	No	Yes	<5MW	Future Applications will require study
HOPE VALLEY SUBSTATION	Coastal	0.0	0.0	0	0.0	No	Yes	<5MW	Future Applications will require study
HOPKINS HILL SUBSTATION	Coastal	12.0	5.1	3	17.1	No	Yes	>15MW	Future Applications will require study
JEPSON SUBSTATION	Coastal	3.8	33.4	9	37.1	No	Yes	>15MW	Future Applications will require study
JOHNSTON SUBSTATION	Capital	51.0	8.6	9	59.7	No	Yes	>15MW	Future Applications will require study
KENT COUNTY SUBSTATION	Coastal	28.0	89.3	17	117.3	Yes		>15MW	Future Applications will require study
KENYON SUBSTATION	Coastal	18.3	5.6	3	24.0	No	Yes	>15MW	Future Applications will require study
KILVERT ST. SUBSTATION	Coastal	5.9	0.7	3	6.6	No	Yes	Between 5MW and 15MW	Future Applications will require study
LAFAYETTE SUBSTATION	Coastal	2.0	14.0	4	16.1	No	Yes	>15MW	Future Applications will require study
LAKEWOOD SUBSTATION	Coastal	0.0	0.0	0	0.0	No		<5MW	
LANGWORTHY CORNER SUBSTATION	Coastal	0.3	0.2	1	0.5	No		<5MW	
LINCOLN AVENUE SUBSTATION	Coastal	0.5	0.0	0	0.5	No		<5MW	
LIPPITT HILL SUBSTATION	Capital	0.3	0.0	0	0.3	No		<5MW	
MANTON SUBSTATION	Capital	0.3	0.1	1	0.4	No		<5MW	
MERTON SUBSTATION	Coastal	0.0	0.0	0	0.0	No		<5MW	
MINK STREET SUBSTATION	MA	3.0	0.0	0	3.0	No	Yes	<5MW	Future Applications will require study
NASONVILLE SUBSTATION	Capital	10.2	13.5	6	23.7	No		>15MW	Future Applications will require study
NATICK SUBSTATION	Coastal	0.7	0.5	1	1.1	No		<5MW	
NEW LONDON AVE SUBSTATION	Coastal	1.6	22.1	7	23.8	No	Yes	>15MW	Future Applications will require study
NORTH AQUIDNECK SUBSTATION	Coastal	0.3	0.3	1	0.6	No		<5MW	
NORTON SUBSTATION	Coastal	0.0	0.0	0	0.0	No		<5MW	
OLD BAPTIST ROAD SUBSTATION	Coastal	7.6	13.4	6	21.0	No	Yes	>15MW	Future Applications will require study
OLNEYVILLE SUBSTATION	Capital	0.3	0.6	1	0.9	No		<5MW	
PARK ST SUBSTATION	Coastal	0.0	0.0	0	0.0	No	Yes	<5MW	
PAWTUCKET SUBSTATION	Capital	5.2	3.8	13	9.0	No	Yes	Between 5MW and 15MW	Future Applications will require study
PEACEDALE SUBSTATION	Coastal	1.2	0.1	2	1.3	No		<5MW	
PERRY STREET SUBSTATION	Coastal	0.0	0.0	0	0.0	No		<5MW	
PHILLIPSDALE SUBSTATION	Capital	0.2	0.0	0	0.2	No		<5MW	
POINT STREET SUBSTATION	Capital	11.8	0.3	2	12.1	No	Yes	Between 5MW and 15MW	Future Applications will require study
PONTIAC SUBSTATION	Capital	3.7	1.7	3	5.4	No	Yes	Between 5MW and 15MW	
PUTNAM PIKE SUBSTATION	Capital	2.7	46.4	12	49.1	Yes		>15MW	Future Applications will require study
QUONSET SUBSTATION	Coastal	13.7	2.4	2	16.1	No		>15MW	
RIVERSIDE SUBSTATION	Capital	4.7	1.0	5	5.8	No	Yes	Between 5MW and 15MW	Future Applications will require study
SOUTH AQUIDNECK SUBSTATION	Coastal	0.7	0.0	0	0.7	No		<5MW	
SOUTH STREET SUBSTATION	Capital	0.0	0.0	0	0.0	No		<5MW	
SOUTH WRENTHAM SUBSTATION	MA	0.0	0.0	1	0.0	No		<5MW	
SPRAGUE STREET SUBSTATION	Capital	0.0	0.0	0	0.0	No		<5MW	
STAPLES SUBSTATION	Capital	5.6	1.4	5	7.0	No	Yes	Between 5MW and 15MW	Future Applications will require study
TIOGUE AVE SUBSTATION	Capital	0.0	0.5	1	0.5	No	Yes	<5MW	
TIVERTON SUBSTATION	Coastal	6.5	17.1	9	23.5	No	Yes	>15MW	Future Applications will require study
TOWER HILL SUBSTATION	Coastal	0.9	15.9	6	16.8	Yes		>15MW	Future Applications will require study
VALLEY SUBSTATION	Coastal	0.7	6.2	5	6.9	No	Yes	Between 5MW and 15MW	Future Applications will require study
WAKEFIELD SUBSTATION	Capital	0.3	0.2	1	0.5	No		<5MW	
WAKEFIELD SUBSTATION	Coastal	0.0	0.0	0	0.0	No		<5MW	
WAMPANOAG SUBSTATION	Coastal	4.6	1.4	6	5.9	No	Yes	Between 5MW and 15MW	Future Applications will require study
WARREN SUBSTATION	Capital	3.4	8.5	3	11.9	No	Yes	Between 5MW and 15MW	Future Applications will require study
WARWICK MALL SUBSTATION	Capital	0.1	0.0	0	0.1	No		<5MW	
WARWICK SUBSTATION	Coastal	0.0	0.3	2	0.3	No		<5MW	
WASHINGTON SUBSTATION	Coastal	6.6	8.3	9	14.9	No	Yes	Between 5MW and 15MW	Future Applications will require study
WATERMAN AVE SUBSTATION	Capital	0.4	0.3	2	0.7	No	Yes	<5MW	
WEST CRANSTON SUBSTATION	Capital	10.6	8.7	4	19.3	No	Yes	>15MW	Future Applications will require study
WEST GREENVILLE SUBSTATION	Capital	0.1	30.5	4	30.6	No		>15MW	
WEST HOWARD SUBSTATION	Capital	0.0	0.1	2	0.1	No		<5MW	
WEST KINGSTON SUBSTATION	Coastal	0.0	0.0	0	0.0	No	Yes	<5MW	Future Applications will require study
WESTERLY SUBSTATION	Coastal	0.4	0.8	3	1.2	No	Yes	<5MW	Future Applications will require study
WICKFORD JUNCTION SUBSTATION	Coastal	0.0	50.0	5	50.0	No	Yes	>15MW	Future Applications will require study
WOLF HILL SUBSTATION	Capital	0.0	0.0	0	0.0	No		<5MW	
WOOD RIVER SUBSTATION	Coastal	33.9	93.2	19	127.0	Yes		>15MW	Future Applications will require study
WOONSOCKET SUBSTATION	Coastal	50.4	6.5	5	56.9	No	Yes	>15MW	Future Applications will require study