

Substation Name	Region	Total Connected DG MW (> 1MW)	Total Pending DG MW (> 1MW)	Total Connected + Pending DG MW (> 1MW)	Ongoing ASO Study?	Potential Need for an ASO Study in next 6 months?	DG Penetration Level	Notes
ADMIRAL STREET SUBSTATION	Capital	0.1	0.0	0.1	No		<5MW	
ANTHONY SUBSTATION	Coastal	0.2	0.0	0.2	No		<5MW	
APPONAUG SUBSTATION	Coastal	0.8	0.0	0.8	No		<5MW	
BARRINGTON SUBSTATION	Coastal	0.0	0.0	0.0	No		<5MW	
BONNET SUBSTATION	Capital	0.2	0.0	0.2	No		<5MW	
BRISTOL SUBSTATION	Coastal	0.7	6.0	6.7	No	Yes	Between 5MW and 15MW	Future Applications will require study
CHASE HILL SUBSTATION	Capital	19.2	28.8	48.1	Yes		>15MW	Future Applications will require study
CHOPMIST SUBSTATION	Coastal	9.7	2.2	11.9	No	Yes	Between 5MW and 15MW	
CLARKE STREET SUBSTATION	Capital	0.1	0.0	0.1	No		<5MW	
CLARKSON STREET SUBSTATION	Capital	2.6	0.4	3.1	No	Yes	<5MW	
COTTAGE STREET SUBSTATION	Capital	0.0	0.0	0.0	No		<5MW	
COVENTRY SUBSTATION	Capital	4.0	5.9	9.9	No	Yes	Between 5MW and 15MW	
DAVISVILLE SUBSTATION	Coastal	1.7	0.0	1.7	No	Yes	<5MW	Future Applications will require study
DEXTER SUBSTATION	Capital	10.6	7.9	18.4	No	Yes	>15MW	Future Applications will require study
DIVISION ST SUBSTATION	Coastal	0.5	0.5	1.0	No		<5MW	
DRUMROCK SUBSTATION	Capital	15.0	8.9	23.9	No	Yes	>15MW	Future Applications will require study
DYER STREET SUBSTATION	Capital	0.2	0.3	0.5	No		<5MW	
ELDERED SUBSTATION	Coastal	0.1	0.0	0.1	No		<5MW	
ELMWOOD SUBSTATION	Capital	0.9	0.6	1.5	No		<5MW	
FARNUM SUBSTATION	Capital	0.1	0.0	0.1	No		<5MW	
FARNUM PIKE SUBSTATION	Capital	5.8	8.0	13.8	No	Yes	Between 5MW and 15MW	Future Applications will require study
GATE TWO SUBSTATION	Coastal	0.8	0.0	0.8	No		<5MW	
HARRIS AVENUE SUBSTATION	Capital	0.1	0.3	0.3	No		<5MW	
HIGHLAND PARK SUBSTATION	Capital	6.1	1.1	7.2	No	Yes	Between 5MW and 15MW	Future Applications will require study
HOPE VALLEY SUBSTATION	Coastal	0.0	0.8	0.8	No	Yes	<5MW	Future Applications will require study
HOPKINS HILL SUBSTATION	Coastal	11.5	10.1	21.6	No	Yes	>15MW	Future Applications will require study
JEPSON SUBSTATION	Coastal	3.4	36.2	39.6	No	Yes	>15MW	Future Applications will require study
JOHNSTON SUBSTATION	Capital	54.1	16.2	70.3	No	Yes	>15MW	Future Applications will require study
KENT COUNTY SUBSTATION	Coastal	24.0	115.3	139.4	Yes	Yes	>15MW	Future Applications will require study
KENVON SUBSTATION	Coastal	11.7	11.7	23.4	No	Yes	>15MW	Future Applications will require study
KILVERT ST. SUBSTATION	Coastal	5.5	1.1	6.7	No	Yes	Between 5MW and 15MW	Future Applications will require study
LAFAVETTE SUBSTATION	Coastal	2.0	4.1	6.1	No	Yes	Between 5MW and 15MW	Future Applications will require study
LAKEWOOD SUBSTATION	Coastal	0.0	0.0	0.0	No		<5MW	
LANGWORTHY CORNER SUBSTATION	Coastal	0.3	0.2	0.5	No		<5MW	
LINCOLN AVENUE SUBSTATION	Coastal	0.5	0.4	0.9	No		<5MW	
LIPPITT HILL SUBSTATION	Capital	0.3	0.0	0.3	No		<5MW	
MANTON SUBSTATION	Capital	0.1	0.2	0.3	No		<5MW	
MERTON SUBSTATION	Coastal	0.0	0.0	0.0	No		<5MW	
MINK STREET SUBSTATION	MA	6.0	0.0	6.0	No	Yes	Between 5MW and 15MW	Future Applications will require study
NASONVILLE SUBSTATION	Capital	6.3	15.6	21.9	No	Yes	>15MW	
NATICK SUBSTATION	Coastal	0.0	1.1	1.1	No		<5MW	
NEW LONDON AVE SUBSTATION	Coastal	2.0	4.6	6.6	No	Yes	Between 5MW and 15MW	
NORTH AQUIDNECK SUBSTATION	Coastal	0.2	0.3	0.5	No		<5MW	
NORTON SUBSTATION	Coastal	0.0	3.6	3.6	No		<5MW	
OLD BAPTIST ROAD SUBSTATION	Coastal	4.7	14.2	18.9	No	Yes	>15MW	Future Applications will require study
OLNEYVILLE SUBSTATION	Capital	0.0	0.6	0.6	No		<5MW	
PARK ST SUBSTATION	Coastal	0.5	4.0	4.5	No	Yes	<5MW	
PAWTUCKET SUBSTATION	Capital	2.7	2.5	5.2	No	Yes	Between 5MW and 15MW	
PEACEDALE SUBSTATION	Coastal	1.1	2.3	3.4	No		<5MW	
PERRY STREET SUBSTATION	Coastal	0.0	0.2	0.2	No		<5MW	
PHILLIPSDALE SUBSTATION	Capital	0.9	0.0	0.9	No		<5MW	
POINT STREET SUBSTATION	Capital	7.3	4.7	12.0	No	Yes	Between 5MW and 15MW	Future Applications will require study
PONTIAC SUBSTATION	Capital	3.6	1.8	5.4	No	Yes	Between 5MW and 15MW	
PUTNAM PIKE SUBSTATION	Capital	1.7	55.9	57.6	Yes	Yes	>15MW	Future Applications will require study
QUONSET SUBSTATION	Coastal	13.2	0.6	13.8	No	Yes	Between 5MW and 15MW	
RIVERSIDE SUBSTATION	Capital	3.9	1.5	5.4	No	Yes	Between 5MW and 15MW	Future Applications will require study
SOUTH AQUIDNECK SUBSTATION	Coastal	0.6	0.1	0.7	No		<5MW	
SPRAGUE STREET SUBSTATION	Capital	0.0	0.0	0.0	No		<5MW	
STARPLES SUBSTATION	Capital	0.9	5.6	6.5	No	Yes	Between 5MW and 15MW	Future Applications will require study
TIOGUE AVE SUBSTATION	Capital	0.0	0.7	0.7	No	Yes	<5MW	
TIVERTON SUBSTATION	Coastal	6.5	14.1	20.6	No	Yes	>15MW	Future Applications will require study
TOWER HILL SUBSTATION	Coastal	0.9	14.0	14.9	No	Yes	Between 5MW and 15MW	Future Applications will require study
VALLEY SUBSTATION	Coastal	1.2	3.5	4.7	No	Yes	<5MW	
WAKEFIELD SUBSTATION	Capital	0.3	0.4	0.7	No		<5MW	
WAKEFIELD SUBSTATION	Coastal	0.0	0.0	0.0	No		<5MW	
WAMPANOAG SUBSTATION	Coastal	4.7	3.1	7.8	No	Yes	Between 5MW and 15MW	Future Applications will require study
WARREN SUBSTATION	Capital	3.9	9.4	13.4	No	Yes	Between 5MW and 15MW	Future Applications will require study
WARWICK MALL SUBSTATION	Capital	0.1	0.0	0.1	No		<5MW	
WARWICK SUBSTATION	Coastal	0.0	0.1	0.1	No		<5MW	
WASHINGTON SUBSTATION	Coastal	5.0	2.8	7.8	No	Yes	Between 5MW and 15MW	Future Applications will require study
WATERMAN AVE SUBSTATION	Capital	0.4	0.4	0.8	No	Yes	<5MW	
WEST CRANSTON SUBSTATION	Capital	14.7	7.8	22.5	No	Yes	>15MW	Future Applications will require study
WEST GREENVILLE SUBSTATION	Capital	0.1	0.0	0.1	No		<5MW	
WEST HOWARD SUBSTATION	Capital	0.0	0.0	0.0	No		<5MW	
WESTERLY SUBSTATION	Coastal	0.1	5.3	5.5	No	Yes	Between 5MW and 15MW	Future Applications will require study
WICKFORD JUNCTION SUBSTATION	Coastal	0.0	105.6	105.6	No	Yes	>15MW	Future Applications will require study
WOOD RIVER SUBSTATION	Coastal	19.8	90.6	110.4	No	Yes	>15MW	Future Applications will require study
WOONSOCKET SUBSTATION	Coastal	7.3	38.6	46.0	No	Yes	>15MW	Future Applications will require study
SOUTH STREET SUBSTATION	Capital	0.0	0.0	0.0	No		<5MW	
WEST KINGSTON SUBSTATION	Coastal	6.9	0.0	6.9	Yes		Between 5MW and 15MW	Future Applications will require study
WOLF HILL SUBSTATION	Capital	1.8	0.0	1.8	No		<5MW	
SOUTH WRENTHAM SUBSTATION	MA	0.0	0.0	0.0	No		<5MW	