

Substation Name	Region	Total Connected DG MW (> 1MW)	Total Pending DG MW (> 1MW)	Total # of Pending Applications (> 1MW)	Total Connected + Pending DG MW (> 1MW)	Ongoing ASO Study?	Potential Need for an ASO Study in next 6 months?	DG Penetration Level	Notes
ADMIRAL STREET SUBSTATION	Capital	0.1	0.0	0	0.1	No		<5MW	
ANTHONY SUBSTATION	Coastal	0.2	0.0	0	0.2	No		<5MW	
APPONAUG SUBSTATION	Coastal	0.8	0.0	0	0.8	No		<5MW	
BARRINGTON SUBSTATION	Coastal	0.0	0.0	0	0.0	No		<5MW	
BONNET SUBSTATION	Capital	0.2	0.0	0	0.2	No		<5MW	
BRISTOL SUBSTATION	Coastal	0.7	5.8	5	6.5	No	Yes	Between 5MW and 15MW	Future Applications will require study
CHASE HILL SUBSTATION	Capital	19.3	22.7	11	42.0	Yes		>15MW	Future Applications will require study
CHOPMIST SUBSTATION	Coastal	9.7	6.1	2	15.8	No	Yes	>15MW	
CLARKE STREET SUBSTATION	Capital	0.1	0.0	0	0.1	No		<5MW	
CLARKSON STREET SUBSTATION	Capital	3.1	0.2	2	3.2	No	Yes	<5MW	
COTTAGE STREET SUBSTATION	Capital	0.0	0.0	0	0.0	No		<5MW	
COVENTRY SUBSTATION	Capital	4.7	0.0	0	4.7	Yes		<5MW	
DAVSVILLE SUBSTATION	Coastal	1.7	0.0	0	1.7	Yes		<5MW	Future Applications will require study
DEXTER SUBSTATION	Capital	10.6	7.8	4	18.4	No	Yes	>15MW	Future Applications will require study
DIVISION ST SUBSTATION	Coastal	0.5	1.5	4	2.0	No		<5MW	
DRUMROCK SUBSTATION	Capital	15.0	8.9	3	23.9	No	Yes	>15MW	Future Applications will require study
DYER STREET SUBSTATION	Capital	0.2	0.8	1	1.1	No		<5MW	
ELDERED SUBSTATION	Coastal	0.1	0.0	0	0.1	No		<5MW	
ELMWOOD SUBSTATION	Capital	0.9	2.1	2	3.1	No		<5MW	
FARNUM SUBSTATION	Capital	0.1	0.0	0	0.1	No		<5MW	
FARNUM PIKE SUBSTATION	Capital	5.8	8.0	1	13.8	No		Between 5MW and 15MW	Future Applications will require study
GATE TWO SUBSTATION	Coastal	0.8	0.0	0	0.8	No		<5MW	
HARRIS AVENUE SUBSTATION	Capital	0.1	0.2	1	0.3	No		<5MW	
HIGHLAND PARK SUBSTATION	Capital	6.1	1.1	2	7.2	No	Yes	Between 5MW and 15MW	Future Applications will require study
HOPE VALLEY SUBSTATION	Coastal	0.0	0.8	1	0.8	No	Yes	<5MW	Future Applications will require study
HOPKINS HILL SUBSTATION	Coastal	11.5	5.7	4	17.2	No	Yes	>15MW	Future Applications will require study
JEPSON SUBSTATION	Coastal	3.4	36.4	11	39.8	No	Yes	>15MW	Future Applications will require study
JOHNSTON SUBSTATION	Capital	54.1	16.0	10	70.1	No	Yes	>15MW	Future Applications will require study
KENT COUNTY SUBSTATION	Coastal	28.0	123.6	22	151.6	Yes		>15MW	Future Applications will require study
KENYON SUBSTATION	Coastal	11.9	11.6	6	23.6	No	Yes	>15MW	Future Applications will require study
KILVERT ST. SUBSTATION	Coastal	5.7	1.2	5	6.9	No	Yes	Between 5MW and 15MW	Future Applications will require study
LAFAYETTE SUBSTATION	Coastal	2.0	44.9	9	46.9	No	Yes	>15MW	Future Applications will require study
LAKEWOOD SUBSTATION	Coastal	0.0	0.0	0	0.0	No		<5MW	
LANGWORTHY CORNER SUBSTATION	Coastal	0.3	0.2	1	0.5	No		<5MW	
LINCOLN AVENUE SUBSTATION	Coastal	0.5	0.4	1	0.9	No		<5MW	
LIPPITT HILL SUBSTATION	Capital	0.3	0.0	0	0.3	No		<5MW	
MANTON SUBSTATION	Capital	0.1	0.2	1	0.3	No		<5MW	
MERTON SUBSTATION	Coastal	0.0	0.0	0	0.0	No		<5MW	
MINK STREET SUBSTATION	MA	6.0	0.0	0	6.0	No	Yes	Between 5MW and 15MW	Future Applications will require study
NASONVILLE SUBSTATION	Capital	6.3	15.6	6	21.9	Yes		>15MW	Future Applications will require study
NATICK SUBSTATION	Coastal	0.7	0.5	1	1.1	No		<5MW	
NEW LONDON AVE SUBSTATION	Coastal	2.0	25.7	8	27.6	No	Yes	>15MW	Future Applications will require study
NORTH AQUIDNECK SUBSTATION	Coastal	0.2	0.3	2	0.5	No		<5MW	
NORTON SUBSTATION	Coastal	0.0	3.6	1	3.6	No		<5MW	
OLD BAPTIST ROAD SUBSTATION	Coastal	9.9	6.6	5	16.4	No	Yes	>15MW	Future Applications will require study
OLNEYVILLE SUBSTATION	Capital	0.3	0.6	1	0.9	No		<5MW	
PARK ST SUBSTATION	Coastal	0.5	4.0	4	4.5	No	Yes	<5MW	
PAWTUCKET SUBSTATION	Capital	3.4	5.0	16	8.4	No	Yes	Between 5MW and 15MW	Future Applications will require study
PEACEDALE SUBSTATION	Coastal	1.2	2.3	2	3.5	No		<5MW	
PERRY STREET SUBSTATION	Coastal	0.2	0.0	0	0.2	No		<5MW	
PHILLIPSDALE SUBSTATION	Capital	0.9	0.0	0	0.9	No		<5MW	
POINT STREET SUBSTATION	Capital	7.3	4.7	4	12.0	No	Yes	Between 5MW and 15MW	Future Applications will require study
PONTIAC SUBSTATION	Capital	3.7	1.7	3	5.4	No	Yes	Between 5MW and 15MW	
PUTNAM PIKE SUBSTATION	Capital	1.7	44.3	15	46.0	Yes		>15MW	Future Applications will require study
QUONSET SUBSTATION	Coastal	13.2	2.9	3	16.1	No		>15MW	
RIVERSIDE SUBSTATION	Capital	4.0	1.5	4	5.5	No	Yes	Between 5MW and 15MW	Future Applications will require study
SOUTH AQUIDNECK SUBSTATION	Coastal	0.6	0.1	1	0.7	No		<5MW	
SOUTH STREET SUBSTATION	Capital	0.0	0.0	0	0.0	No		<5MW	
SOUTH WRENTHAM SUBSTATION	MA	0.0	0.0	1	0.0	No		<5MW	
SPRAGUE STREET SUBSTATION	Capital	0.0	0.0	4	0.0	No		<5MW	
STAPLES SUBSTATION	Capital	5.6	0.9	4	6.5	No	Yes	Between 5MW and 15MW	Future Applications will require study
TIOGUE AVE SUBSTATION	Capital	0.0	0.5	1	0.5	No	Yes	<5MW	
TIVERTON SUBSTATION	Coastal	6.5	17.2	10	23.6	No	Yes	>15MW	Future Applications will require study
TOWER HILL SUBSTATION	Coastal	0.9	15.9	6	16.8	Yes		>15MW	Future Applications will require study
VALLEY SUBSTATION	Coastal	0.9	6.2	5	7.1	No	Yes	Between 5MW and 15MW	
WAKEFIELD SUBSTATION	Capital	0.3	0.4	2	0.7	No		<5MW	
WAKEFIELD SUBSTATION	Coastal	0.0	0.0	0	0.0	No		<5MW	
WAMPANOAG SUBSTATION	Coastal	4.6	3.3	9	7.9	No	Yes	Between 5MW and 15MW	Future Applications will require study
WARREN SUBSTATION	Capital	4.1	9.2	3	13.4	No	Yes	Between 5MW and 15MW	Future Applications will require study
WARWICK MALL SUBSTATION	Capital	0.1	0.0	0	0.1	No		<5MW	
WARWICK SUBSTATION	Coastal	0.0	0.1	1	0.1	No		<5MW	
WASHINGTON SUBSTATION	Coastal	6.0	6.4	10	12.4	No	Yes	Between 5MW and 15MW	Future Applications will require study
WATERMAN AVE SUBSTATION	Capital	0.4	0.3	2	0.7	No	Yes	<5MW	
WEST CRANSTON SUBSTATION	Capital	14.7	7.9	4	22.6	No	Yes	>15MW	Future Applications will require study
WEST GREENVILLE SUBSTATION	Capital	0.1	34.0	5	34.1	No		>15MW	
WEST HOWARD SUBSTATION	Capital	0.0	0.0	1	0.0	No		<5MW	
WEST KINGSTON SUBSTATION	Coastal	6.9	0.0	0	6.9	No	Yes	Between 5MW and 15MW	Future Applications will require study
WESTERLY SUBSTATION	Coastal	0.1	1.1	5	1.2	No	Yes	<5MW	Future Applications will require study
WICKFORD JUNCTION SUBSTATION	Coastal	0.0	105.6	14	105.6	No	Yes	>15MW	Future Applications will require study
WOLF HILL SUBSTATION	Capital	1.8	0.0	0	1.8	No		<5MW	
WOOD RIVER SUBSTATION	Coastal	19.8	80.5	17	100.3	Yes		>15MW	Future Applications will require study
WOONSOCKET SUBSTATION	Coastal	7.3	36.6	12	43.9	No	Yes	>15MW	Future Applications will require study