

## Distributed Generation Interconnection

### National Grid Reporting Requirements - Affected System Operator Studies

#### **Paragraph 4 Monthly Report**

February 16, 2020

The Narragansett Electric Company (NECo) is experiencing Distributed Generation (DG) saturation in certain regions and at certain substations that indicate the potential need for an Affected System Operator (ASO) study that would affect three or more DG applications or more than 15 MW of DG capacity in the following 6 months. Below is a list of the specific regions and substations where NECo is experiencing DG saturation. This Paragraph 4 Monthly Report (Paragraph 4 Report) provides an update since NECo's previous Paragraph 4 Report on the potential need for an ASO study in such regions and substations, as well as the actions NECo is taking to prevent, mitigate, and prepare for such an occurrence while working with its transmission provider, New England Power (NEP). The information in this Paragraph 4 Report is in addition to the other information and reporting NECo is providing under the Reporting Requirements with respect to potential and ongoing ASO studies.

#### **Paragraph 4 Attachment**

Paragraph 4 Attachment lists the substations with on-going ASO Studies currently being reported under the Reporting Requirements as well as substations for which any future applications over 1MW that propose to be connected to one of these substations will require an ASO study due to DG saturation over 5MW at an individual substation and/or over multiple substations fed from a common transmission injection point.

#### **Potential ASO Studies for Pending Applications**

The below table lists the substations that have the potential need for an ASO study that would affect three or more DG applications or more than 15 MW of DG capacity in the following 6 months. Please note that these stations are not part of any of the ongoing ASO Studies. NECo identified the potential need based on the fact that at least one of the Generator Notification Forms (GNFs) for each of these substations that was presented to ISO-NE was returned for further analysis.

---

<b>Substation Name</b>	<b>Region</b>	<b>DG Penetration Level</b>
BRISTOL SUBSTATION	Coastal	< 1 MW
CHASE HILL SUBSTATION	Capital	< 1 MW
CHOPMIST SUBSTATION	Coastal	< 1 MW
CLARKSON STREET SUBSTATION	Capital	< 1 MW
COVENTRY SUBSTATION	Capital	< 1 MW
DEXTER SUBSTATION	Capital	>15MW

## Distributed Generation Interconnection

### National Grid Reporting Requirements - Affected System Operator Studies

DRUMROCK SUBSTATION	Capital	>15MW
HOPKINS HILL SUBSTATION	Coastal	< 1 MW
JEPSON SUBSTATION	Coastal	>15MW
JOHNSTON SUBSTATION	Capital	>15MW
KENT COUNTY SUBSTATION	Coastal	< 1 MW
KENYON SUBSTATION	Coastal	< 1 MW
KILVERT ST. SUBSTATION	Coastal	< 1 MW
LAFAYETTE SUBSTATION	Coastal	< 1 MW
NASONVILLE SUBSTATION	Capital	< 1 MW
		Between 5MW and
NEW LONDON AVE SUBSTATION	Coastal	15MW
OLD BAPTIST ROAD SUBSTATION	Coastal	< 1 MW
PARK ST SUBSTATION	Coastal	<5MW
PAWTUCKET SUBSTATION	Capital	< 1 MW
PEACEDALE SUBSTATION	Coastal	< 1 MW
POINT STREET SUBSTATION	Capital	< 1 MW
PONTIAC SUBSTATION	Capital	< 1 MW
PUTNAM PIKE SUBSTATION	Capital	< 1 MW
RIVERSIDE SUBSTATION	Capital	< 1 MW
		Between 5MW and
STAPLES SUBSTATION	Capital	15MW
TIVERTON SUBSTATION	Coastal	>15MW
TOWER HILL SUBSTATION	Coastal	>15MW
VALLEY SUBSTATION	Coastal	< 1 MW
		Between 5MW and
WAMPANOAG SUBSTATION	Coastal	15MW
WARREN SUBSTATION	Capital	< 1 MW
		Between 5MW and
WASHINGTON SUBSTATION	Coastal	15MW
WEST CRANSTON SUBSTATION	Capital	>15MW
WESTERLY SUBSTATION	Coastal	< 1 MW
WICKFORD JUNCTION SUBSTATION	Coastal	>15MW
WOOD RIVER SUBSTATION	Coastal	< 1 MW
WOONSOCKET SUBSTATION	Coastal	< 1 MW

#### *Action Plan/Next Steps*

NECo is taking the following actions to prevent, mitigate, and prepare for such an occurrence for the above applications:

- NECo will continue to submit notification to NEP for all pre-ISA projects as soon as they reach the 20-business day mark during the distribution impact study stage.
- For the substations listed above, NECo will provide NEP the list of pending applications for NEP to consider as part of its initial assessment in coordination with ISO-NE as to what level of ASO study will be required.

## Distributed Generation Interconnection

### National Grid Reporting Requirements - Affected System Operator Studies

- NECo will provide notification to the PUC and send notifications to affected customers per Paragraph 1 or Paragraph 5 and Paragraph 6 of the Reporting Requirements.

#### Potential ASO Studies for Future Applications

The below table indicates the list of substations where an ASO study will be required for any future application connecting to that substation. Future applications to these substations for over 1 MW will require ASO studies due to DG saturation at these substations.

Substation Name	Region	DG Penetration Level
BRISTOL SUBSTATION	Coastal	< 1 MW
CHASE HILL SUBSTATION	Capital	< 1 MW
DAVISVILLE SUBSTATION	Coastal	<5MW
DEXTER SUBSTATION	Capital	>15MW
DRUMROCK SUBSTATION	Capital	>15MW
FARNUM PIKE SUBSTATION	Capital	Between 5MW and 15MW
HIGHLAND PARK SUBSTATION	Capital	< 1 MW
HOPE VALLEY SUBSTATION	Coastal	< 1 MW
HOPKINS HILL SUBSTATION	Coastal	< 1 MW
JEPSON SUBSTATION	Coastal	>15MW
JOHNSTON SUBSTATION	Capital	>15MW
KENT COUNTY SUBSTATION	Coastal	< 1 MW
KENYON SUBSTATION	Coastal	< 1 MW
KILVERT ST. SUBSTATION	Coastal	< 1 MW
LAFAYETTE SUBSTATION	Coastal	< 1 MW
MINK STREET SUBSTATION	MA	<5MW
OLD BAPTIST ROAD SUBSTATION	Coastal	< 1 MW
POINT STREET SUBSTATION	Capital	< 1 MW
PUTNAM PIKE SUBSTATION	Capital	< 1 MW
RIVERSIDE SUBSTATION	Capital	< 1 MW
STAPLES SUBSTATION	Capital	Between 5MW and 15MW
TIVERTON SUBSTATION	Coastal	>15MW
TOWER HILL SUBSTATION	Coastal	>15MW
WAMPANOAG SUBSTATION	Coastal	Between 5MW and 15MW
WARREN SUBSTATION	Capital	< 1 MW
WASHINGTON SUBSTATION	Coastal	Between 5MW and 15MW
WEST CRANSTON SUBSTATION	Capital	>15MW

## Distributed Generation Interconnection

### National Grid Reporting Requirements - Affected System Operator Studies

WEST KINGSTON SUBSTATION	Coastal	< 1 MW
WESTERLY SUBSTATION	Coastal	< 1 MW
WICKFORD JUNCTION SUBSTATION	Coastal	>15MW
WOOD RIVER SUBSTATION	Coastal	< 1 MW
WOONSOCKET SUBSTATION	Coastal	< 1 MW

---

#### *Action Plan/Next Step*

NECO is taking the following actions to prevent, mitigate, and prepare for such an occurrence for the above applications:

- NECo will publish on its website (<https://ngus.force.com/s/article/RI-DG-Group-Transmission-Study-Update>), the above list of substations that will require ASO study for future applications.
- In all future pre-application reports in these areas, NECo will notify the proposed project of the status of a likely ASO study in the future if the request may be served from one of the substations mentioned above.

#### *Force Majeure Event*

NECo is informing all new applicants that due to the developing COVID-19 crisis, NECO declared a Force Majeure Event (Event) pursuant to the Standards for Connecting Distributed Generation, RIPUC No. 2180 ("Tariff") Section 3.0., that the Company will notify customers whose DG project is directly impacted by this Event, and that all customers will be kept informed of the scope and duration (to extent known) of this Force Majeure Event and of the steps the Company is taking to mitigate the effects of the Event on its performance through periodic updates on the Company's distributed generation website: <https://ngus.force.com/s/article/RI-Force-Majeure-Declarations>